

DRAFT Reliability Standard Audit Worksheet¹

FAC-014-3 - Establish and Communicate System Operating Limits

This section to be completed by the Compliance Enforcement Authority.

Audit ID: Audit ID if available; or REG-NCRnnnnn-YYYYMMDD

Registered Entity: Registered name of entity being audited

NCR Number: NCRnnnnn

Compliance Enforcement Authority: Region or NERC performing audit
Compliance Assessment Date(s)²: Month DD, YYYY, to Month DD, YYYY

Compliance Monitoring Method: [On-site Audit | Off-site Audit | Spot Check]

Names of Auditors: Supplied by CEA

Applicability of Requirements

	ВА	DP	GO	GOP	PA/PC	RC	RP	RSG	то	TOP	TP	TSP
R1						Х						
R2										Х		
R3										Х		
R4						Х						
R5						Х						
R6					Х						Х	
R7					Х						Х	
R8					Х						Χ	

Legend:

Text with blue background:	Fixed text – do not edit
Text entry area with Green background:	Entity-supplied information
Text entry area with white background:	Auditor-supplied information

The RSAW may provide a non-exclusive list, for informational purposes only, of examples of the types of evidence a registered entity may produce or may be asked to produce to demonstrate compliance with the Reliability Standard. A registered entity's adherence to the examples contained within this RSAW does not necessarily constitute compliance with the applicable Reliability Standard, and NERC and the Regional Entity using this RSAW reserve the right to request additional evidence from the registered entity that is not included in this RSAW. This RSAW may include excerpts from FERC Orders and other regulatory references which are provided for ease of reference only, and this document does not necessarily include all applicable Order provisions. In the event of a discrepancy between FERC Orders, and the language included in this document, FERC Orders shall prevail.

¹ NERC developed this Reliability Standard Audit Worksheet (RSAW) language in order to facilitate NERC's and the Regional Entities' assessment of a registered entity's compliance with this Reliability Standard. The NERC RSAW language is written to specific versions of each NERC Reliability Standard. Entities using this RSAW should choose the version of the RSAW applicable to the Reliability Standard being assessed. While the information included in this RSAW provides some of the methodology that NERC has elected to use to assess compliance with the requirements of the Reliability Standard, this document should not be treated as a substitute for the Reliability Standard or viewed as additional Reliability Standard requirements. In all cases, the Regional Entity should rely on the language contained in the Reliability Standard itself, and not on the language contained in this RSAW, to determine compliance with the Reliability Standard. NERC's Reliability Standards can be found on NERC's website. Additionally, NERC Reliability Standards are updated frequently, and this RSAW may not necessarily be updated with the same frequency. Therefore, it is imperative that entities treat this RSAW as a reference document only, and not as a substitute or replacement for the Reliability Standard. It is the responsibility of the registered entity to verify its compliance with the latest approved version of the Reliability Standards, by the applicable governmental authority, relevant to its registration status.

² Compliance Assessment Date(s): The date(s) the actual compliance assessment (on-site audit, off-site spot check, etc.) occurs.

Findings

(This section to be completed by the Compliance Enforcement Authority)

Req.	Finding	Summary and Documentation	Functions Monitored
R1			
R2			
R3			
R4			
R5			
R6			
R7			
R8			

Req.	Areas of Concern								

Req.	Recommendations

Req.	Positive Observations

Subject Matter Experts

Identify the Subject Matter Expert(s) responsible for this Reliability Standard.

Registered Entity Response (Required; Insert additional rows if needed):

SME Name	Title	Organization	Requirement(s)	

R1 Supporting Evidence and Documentation

- **R1.** Each Reliability Coordinator shall establish Interconnection Reliability Operating Limits (IROLs) for its Reliability Coordinator Area in accordance with its System Operating Limit methodology (SOL methodology).
- **M1.** Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation to demonstrate that the Reliability Coordinator established IROLs in accordance with it SOL methodology.

Registered Entity Response (Required):

Compliance Narrative:

Provide a brief explanation, in your own words, of how you comply with this Requirement. References to supplied evidence, including links to the appropriate page, are recommended.

Evidence Requested ::

Provide the following evidence, or other evidence to demonstrate compliance.

Entity's System Operating Limit Methodology (SOL methodology).

Evidence IROLs for the entity's Reliability Coordinator Area have been established in accordance with entity's SOL methodology.

Registered Entity Evidence (Required):

The following information is requested for each document submitted as evidence. Also, evidence submitted should be highlighted and bookmarked, as appropriate, to identify the exact location where evidence of compliance may be found.

File Name	Document Title	Revision or Version	Document Date	Relevant Page(s) or Section(s)	Description of Applicability of Document

Audit Team Evidence Reviewed (This section to be completed by the Compliance Enforcement Authority):

Compliance Assessment Approach Specific to FAC-014-3, R1

This section to be completed by the Compliance Enforcement Authority

Verify the entity has established IROLs for its Reliability Coordinator Area in accordance with its SOL methodology.

Note to Auditor:

Auditor Notes:

DRAFT NERC Reliability Standard Audit Worksheet

Audit ID: Audit ID if available; or NCRnnnnn-YYYYMMDD

RSAW Version: RSAW FAC-014-3 2020 v1 Revision Date: July, 2020 RSAW Template: RSAW2014R1.2

DRAFT NERC Reliability Standard Audit Worksneet



R2 Supporting Evidence and Documentation

- **R2.** Each Transmission Operator shall establish System Operating Limits (SOLs) for its portion of the Reliability Coordinator Area in accordance with its Reliability Coordinator's SOL methodology.
- **M2.** Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation to demonstrate that the Transmission Operator established SOLs in accordance with its Reliability Coordinator's SOL methodology.

Registered Entity Response (Required):

Compliance Narrative:

Provide a brief explanation, in your own words, of how you comply with this Requirement. References to supplied evidence, including links to the appropriate page, are recommended.

Evidence Requested i:

Provide the following evidence, or other evidence to demonstrate compliance.

Entity's Reliability Coordinator's System Operating Limit methodology (SOL methodology).

Evidence the entity established SOLs in accordance with its Reliability Coordinator's SOL methodology.

Registered Entity Evidence (Required):

The following information is requested for each document submitted as evidence. Also, evidence submitted should be highlighted and bookmarked, as appropriate, to identify the exact location where evidence of compliance may be found.

File Name	Document Title	Revision or Version	Document Date	Relevant Page(s) or Section(s)	Description of Applicability of Document

Audit Team Evidence Reviewed (This section to be completed by the Compliance Enforcement Authority):				

Compliance Assessment Approach Specific to FAC-014-3, R2

This section to be completed by the Compliance Enforcement Authority

Verify the entity has established SOLs in accordance with its Reliability Coordinator's SOL methodology.

Note to Auditor:

Auc	litor	Ν	lotes

DRAFT NERC Reliability Standard Audit Worksheet	



R3 Supporting Evidence and Documentation

- **R3.** Each Transmission Operator shall provide its SOLs to its Reliability Coordinator.
- **M3.** Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation to demonstrate that the Transmission Operator provided its SOLs in accordance with its Reliability Coordinator's SOL methodology.

Registered Entity Response (Required):

Compliance Narrative:

Provide a brief explanation, in your own words, of how you comply with this Requirement. References to supplied evidence, including links to the appropriate page, are recommended.

Evidence Requested i:

Provide the following evidence, or other evidence to demonstrate compliance.

Entity's Reliability Coordinator's System Operating Limit methodology (SOL methodology).

Evidence SOLs were provided to the entity's Reliability Coordinator.

Registered Entity Evidence (Required):

The following information is requested for each document submitted as evidence. Also, evidence submitted should be highlighted and bookmarked, as appropriate, to identify the exact location where evidence of compliance may be found.

File Name	Document Title	Revision or Version	Document Date	Relevant Page(s) or Section(s)	Description of Applicability of Document

Audit Team Evidence Reviewed (This	section to be completed by the Compliance Enforcement Authority):

Compliance Assessment Approach Specific to FAC-014-3, R3

This section to be completed by the Compliance Enforcement Authority

Verify the entity provided its SOLs to its Reliability Coordinator.

Note to Auditor:

Δı	пd	ita	٦r	N	οt	65	

DRAFT NERC Reliability Standard Audit Worksheet	



R4 Supporting Evidence and Documentation

- **R4.** Each Reliability Coordinator shall establish stability limits when the limit impacts adjacent Reliability Coordinator Areas or more than one Transmission Operator in its Reliability Coordinator Area in accordance with its SOL methodology.
- **M4.** Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation to demonstrate that the Reliability Coordinator established stability limits in accordance with Requirement R4.

Registered Entity Response (Required):

Compliance Narrative:

Provide a brief explanation, in your own words, of how you comply with this Requirement. References to supplied evidence, including links to the appropriate page, are recommended.

Evidence Requested i:

Provide the following evidence, or other evidence to demonstrate compliance.

Entity's System Operating Limit methodology (SOL methodology).

Evidence entity established stability limits when the limit impacts adjacent Reliability Coordinator Areas or more than one Transmission Operator in its Reliability Coordinator Area in accordance with entity's SOL methodology.

Registered Entity Evidence (Required):

The following information is requested for each document submitted as evidence. Also, evidence submitted should be highlighted and bookmarked, as appropriate, to identify the exact location where evidence of compliance may be found.

		Revision or	Document	Relevant Page(s) or	Description of Applicability
File Name	Document Title	Version	Date	Section(s)	of Document
The Name	Document ritle	Version	Date	Section(s)	or bocament

Audit Team Evidence Reviewed (This section to be completed by the Compliance Enforcement Authority):					

Compliance Assessment Approach Specific to FAC-014-3, R4

This section to be completed by the Compliance Enforcement Authority

Verify the entity established stability limits when the limit impacts adjacent Reliability Coordinator Areas or more than one Transmission Operator in its Reliability Coordinator Area in accordance with entity's SOL methodology.

Note to Auditor:

Audit ID: Audit ID if available; or NCRnnnnn-YYYYMMDD

RSAW Version: RSAW FAC-014-3 2020 v1 Revision Date: July, 2020 RSAW Template: RSAW2014R1.2

Auditor Notes:			



R5 Supporting Evidence and Documentation

- **R5.** Each Reliability Coordinator shall provide:
 - **5.1.** Each Planning Coordinator and each Transmission Planner within its Reliability Coordinator Area, the SOLs for its Reliability Coordinator Area (including the subset of SOLs that are IROLs) at least once every twelve calendar months.
 - **5.2.** Each impacted Planning Coordinator and each impacted Transmission Planner within its Reliability Coordinator Area, the following information for each established stability limit and each established IROL at least once every twelve calendar months:
 - **5.2.1** The value of the stability limit or IROL;
 - **5.2.2.** Identification of the Facilities that are critical to the stability limit or IROL;
 - **5.2.3.** The associated IROL T_v for any IROL;
 - **5.2.4.** The associated Contingency(ies);
 - 5.2.5. A description of system conditions associated with the stability limit or IROL; and
 - **5.2.6.** The type of limitation represented by the stability limit or IROL (e.g., voltage collapse, angular stability).
 - **5.3.** Each impacted Transmission Operator within its Reliability Coordinator Area, the value of the stability limits established pursuant to Requirement R4 and each IROL established pursuant to Requirement R1, in an agreed upon time frame necessary for inclusion in the Transmission Operator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments.
 - **5.4.** Each impacted Transmission Operator within its Reliability Coordinator Area, the information identified in Requirement R5 Parts 5.2.2 5.2.6 for each established stability limit or each IROL, and any updates to that information within an agreed upon time frame necessary for inclusion in the Transmission Operator's Operational Planning Analyses.
 - **5.5.** Each requesting Transmission Operator within its Reliability Coordinator Area, requested SOL information for its Reliability Coordinator Area, on a mutually agreed upon schedule.
- **M5.** Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation, posting to a secure website, or other electronic means, that demonstrates the Reliability Coordinator provided the information in accordance with Requirement R5.

Registered Entity Response (Required):

Compliance Narrative:

Provide a brief explanation, in your own words, of how you comply with this Requirement. References to supplied evidence, including links to the appropriate page, are recommended.

Evidence Requested i:

Provide the following evidence, or other evidence to demonstrate compliance.

Evidence the entity provided SOLs for Reliability Coordinator Area (including the subset of SOLs that are IROLs) to each Planning Coordinator and each Transmission Planner within its Reliability Coordinator Area at least once

every twelve calendar months.

Evidence the entity provided the information specified in Parts 5.2.1 - 5.2.6 for each established stability limit and each established IROL to each impacted Planning Coordinator and each impacted Transmission Planner within its Reliability Coordinator Area at least once every twelve calendar months.

Evidence the entity provided the value of the stability limits established pursuant to Requirement R4 and each IROL established pursuant to Requirement R1, in an agreed upon time frame necessary for inclusion in the Transmission Operator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments, to each impacted Transmission Operator within its Reliability Coordinator Area.

Evidence the entity provided the information identified in Requirement R5 Parts 5.2.2 - 5.2.6 for each established stability limit or each IROL, and any updates to that information within an agreed upon time frame necessary for inclusion in the Transmission Operator's Operational Planning Analyses, to each impacted Transmission Operator within its Reliability Coordinator Area.

Evidence the entity provided requested SOL information for its Reliability Coordinator Area, on a mutually agreed upon schedule, to each requesting Transmission Operator within its Reliability Coordinator Area.

Registered Entity Evidence (Required):

The following information is requested for each document submitted as evidence. Also, evidence submitted should be highlighted and bookmarked, as appropriate, to identify the exact location where evidence of compliance may be found.

File Name	Document Title	Revision or Version	Document Date	Relevant Page(s) or Section(s)	Description of Applicability of Document

Audit Team E	vidence Reviewed	(This section	n to be com	pleted by the Compliance Enforcement Authority):

Compliance Assessment Approach Specific to FAC-014-3, R5

This section to be completed by the Compliance Enforcement Authority

(5.1) Verify the entity provided SOLs for its Reliability Coordinator Area (including the subset of SOLs that are IROLs) to each Planning Coordinator and each Transmission Planner within its Reliability Coordinator Area at least once every twelve calendar months.
(5.2) Verify the entity provided the following information for each established stability limit and each established IROL to each impacted Planning Coordinator and each impacted Transmission Planner within its Reliability Coordinator Area at least once every twelve calendar months:
(5.2.1) The value of the stability limit or IROL
(5.2.2) Identification of the Facilities that are critical to the derivation of the stability limit or IROL;
(5.2.3) The associated IROL T_v for any IROL;

DRAFT NERC Reliability Standard Audit Worksheet

Audit ID: Audit ID if available; or NCRnnnnn-YYYYMMDD

(5.2.4) The associated Contingency(ies);

	(5.2.5) A description of system conditions associated with the stability limit or IROL; and
	(5.2.6) The type of limitation represented by the stability limit or IROL (e.g., voltage collapse, angular
	stability).
	(5.3) Verify the entity provided the value of the stability limits established pursuant to Requirement R4
	and each IROL established pursuant to Requirement R1, in an agreed upon time frame necessary for
	inclusion in the Transmission Operator's Operational Planning Analyses, Real-time monitoring, and Real-
	time Assessments, to each impacted Transmission Operator within its Reliability Coordinator Area.
	(5.4) Verify the entity provided the information identified in Requirement R5 Parts 5.2.2 - 5.2.5 for each
	established stability limit or each IROL, and any updates to that information within an agreed upon time
	frame necessary for inclusion in the Transmission Operator's Operational Planning Analyses, to each
	impacted Transmission Operator within its Reliability Coordinator Area.
	(5.5) Verify the entity provided each requesting Transmission Operator within its Reliability Coordinator
	Area, requested SOL information for its Reliability Coordinator Area, on a mutually agreed upon
	schedule.
No	te to Auditor: Some stability limits may be determined at the time of the assessment while others may
be	determined by a series of offline studies. For either instance, a single representative value or table of
val	ues may be communicated at the required time frame.
Aud	itor Notes:



R6 Supporting Evidence and Documentation

- R6. Each Planning Coordinator and each Transmission Planner shall implement a documented process to use Facility Ratings, System steady-state voltage limits and stability criteria in its Planning Assessment of Near Term Transmission Planning Horizon that are equally limiting or more limiting than the criteria for Facility Ratings, System Voltage Limits and stability described in its respective Reliability Coordinator's SOL methodology.
 - The Planning Coordinator may use less limiting Facility Ratings, System steady-state voltage limits and stability criteria if it provides a technical rationale to each affected Transmission Planner, Transmission Operator and Reliability Coordinator.
 - The Transmission Planner may use less limiting Facility Ratings, System steady-state voltage limits and stability criteria if it provides a technical rationale to each affected Planning Coordinator, Transmission Operator and Reliability Coordinator.
- M6. Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation demonstrating the Planning Coordinator and Transmission Planner implemented its documented process in accordance with Requirement R6.

Registered	Entity Response	(Required)	١
NESISTELE	LIILILV IVESDOIISE	ıncuuncu	

Registered Entity Response (Required):
Question: Does the entity use Facility Ratings, System steady-state voltage limits and stability criteria in its
Planning Assessment of Near Term Transmission Planning Horizon that are less limiting than the criteria for
Facility Ratings, System Voltage Limits and stability described in its respective Reliability Coordinator's SOL methodology? \square Yes $\ \square$ No
If Yes, evidence the entity provided a technical rationale to each of the required Transmission Planners, Transmission Operators, and Reliability Coordinators.
[Note: A separate spreadsheet or other document may be used. If so, provide the document reference below.]
Registered Entity Response (Required):
Compliance Narrative:
Provide a brief explanation, in your own words, of how you comply with this Requirement. References to supplied evidence, including links to the appropriate page, are recommended.
Evidence Requested ^{i:}
Provide the following evidence, or other evidence to demonstrate compliance.

Registered Entity Evidence (Required):

The following information is requested for each document submitted as evidence. Also, evidence submitted should be highlighted and bookmarked, as appropriate, to identify the exact location where evidence of compliance may be found.

File	e Name	Document Title	Revision or Version	Document Date	Relevant Page(s) or Section(s)	Description of Applicability of Document		
Audit Tea	Audit Team Evidence Reviewed (This section to be completed by the Compliance Enforcement Authority):							
This section	Compliance Assessment Approach Specific to FAC-014-3, R6 This section to be completed by the Compliance Enforcement Authority							
	Verify the entity implemented a process to ensure that Facility Ratings, System steady-state voltage limits and stability criteria used in its Planning Assessment of the Near-Term Transmission Planning							
	•		•			ngs, System Voltage Limits		
			_		•			
If the criter	and stability described in its respective Reliability Coordinator's SOL methodology. If the entity uses less limiting System Facility Ratings, System steady-state voltage limits and stability criteria than the criteria for Facility Ratings, System Voltage Limits and stability described in its respective Reliability Coordinator's SOL methodology, verify the entity provided a technical justification to each of the required Transmission Planners, Planning Coordinators, and Reliability Coordinators.							
Note to Auditor: Technical justification can be specific justification for a specific facility or broad based justification (e.g. upgrading a facility).								
Auditor Notes:								

R7 Supporting Evidence and Documentation

- R7. Each Planning Coordinator and each Transmission Planner shall annually communicate the following information for Corrective Action Plans developed to address any instability identified in its Planning Assessment of the Near-Term Transmission Planning Horizon to each impacted Transmission Operator and Reliability Coordinator. This communication shall include:
 - **7.1** The Corrective Action Plan developed to mitigate the identified instability, including any automatic control or operator-assisted actions (such as Remedial Action Schemes, under voltage load shedding, or any Operating Procedures);
 - **7.2** The type of instability addressed by the Corrective Action Plan (e.g. steady-state and/or transient voltage instability, angular instability including generating unit loss of synchronism and/or unacceptable damping);
 - **7.3** The associated stability criteria violation requiring the Corrective Action Plan (e.g. violation of transient voltage response criteria or damping rate criteria);
 - **7.4** The planning event Contingency(ies) associated with the identified instability requiring the Corrective Action Plan;
 - **7.5** The System conditions and Facilities associated with the identified instability requiring the Corrective Action Plan.
- **M7.** Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation demonstrating the Planning Coordinator and Transmission Planner communicated the information in accordance with Requirement R7.

Registered Entity Response (Required):

Question: Does the entity have any Corrective Action Plans to address any instability identified in its Planning
Assessment of the Near-Term Transmission Planning Horizon that were required to be communicated as
required? 🗆 Yes 🗇 No
f Yes, provide a list of the Corrective Action Plans. If No, explain how the entity made this determination.
Note: A separate spreadsheet or other document may be used. If so, provide the document reference below.]

Registered Entity Response (Required):

Compliance Narrative:

Provide a brief explanation, in your own words, of how you comply with this Requirement. References to supplied evidence, including links to the appropriate page, are recommended.

Evidence Requested ii

Provide the following evidence, or other evidence to demonstrate compliance.

Corrective Action Plans to address any instability identified in its Planning Assessment of the Near-Term Transmission Planning Horizon

Evidence communication to each impacted Reliability Coordinator and Transmission Operator included Parts 7.1 through 7.5.

DRAFT NERC Reliability Standard Audit Worksheet

Audit ID: Audit ID if available; or NCRnnnnn-YYYYMMDD

RSAW Version: RSAW FAC-014-3 2020 v1 Revision Date: July, 2020 RSAW Template: RSAW2014R1.2

File Name	Document Title	Revision or Version	Document Date	Relevant Page(s) or Section(s)	Description of Applicabil of Document	
-	t Approach Specific to		-	itu		
_	leted by the Complia nunication of Correct			-	nility identified in its	
Verify annual communication of Corrective Action Plans to address any instability identified in its Planning Assessment of the Near-Term Transmission Planning Horizon to each impacted Reliability						
Coordinator and Tr	ansmission Operator	•				
·	e Actions Plans inclu					
, ,	•	_			ty, including any automati	
- control or operator	•	n as kemed	iai Action Scr	iemes, unae	r voltage load shedding, o	
•				an log stoa	d1-11/ 12 1	
any Operating Proc (7.2) The type of in voltage instability,	stability addressed by					
any Operating Proc (7.2) The type of in voltage instability, damping);	stability addressed by angular instability inc	luding gene	rating unit lo	ss of synchro		
any Operating Proc (7.2) The type of in voltage instability, damping); (7.3) The associate	stability addressed by angular instability inc	luding gene ation requir	rating unit lo	ss of synchro	onism and/or unacceptable	
any Operating Proc (7.2) The type of in voltage instability, damping); (7.3) The associated transient voltage re (7.4) The planning	stability addressed by angular instability inc d stability criteria viol esponse criteria or da event Contingency(ie	luding gene ation requir mping rate	rating unit lo	ss of synchro	Plan (e.g. violation of	
any Operating Processing (7.2) The type of involtage instability, damping); (7.3) The associated transient voltage response (7.4) The planning Corrective Action Processing (7.4)	stability addressed by angular instability inc d stability criteria viol esponse criteria or da event Contingency(ie	luding gene ation requir mping rate (s) s) associated	rating unit lo	ective Action	Plan (e.g. violation of bility requiring the	
any Operating Processing (7.2) The type of involtage instability, damping); (7.3) The associated transient voltage response (7.4) The planning Corrective Action Processing (7.4)	stability addressed by angular instability income distability criteria violesponse criteria or da event Contingency(ie: lan; onditions and Facilitie	luding gene ation requir mping rate (s) s) associated	rating unit lo	ective Action	Plan (e.g. violation of bility requiring the	



R8 Supporting Evidence and Documentation

- R8. Each Planning Coordinator and each Transmission Planner shall annually communicate any instability, Cascading or uncontrolled separation that adversely impact the reliability of the Bulk Electric System identified in its Planning Assessment of the Near-Term Transmission Planning Horizon to each impacted Transmission Owner and Generation Owner. This communication shall include those Facilities that comprise the Contingency(ies) (planning events only) and any Facilities critical to the instability, Cascading or uncontrolled separation identified.
- **M8.** Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation demonstrating the Planning Coordinator and Transmission Planner communicated the information in accordance with Requirement R8.

Registered Entity Response (Required):

Question: Has the entity identified instability, Cascading or uncontrolled separation in its Planning Assessment of the Near-Term Transmission Planning Horizon?

☐ Yes ☐ No

If Yes, provide a list of instances of instability, Cascading or uncontrolled separation identified in either the Planning Assessment of the Near-Term Transmission Planning Horizon. If No, explain how the entity made this determination.

[Note: A separate spreadsheet or other document may be used. If so, provide the document reference below.]

Registered Entity Response (Required):

Compliance Narrative:

Provide a brief explanation, in your own words, of how you comply with this Requirement. References to supplied evidence, including links to the appropriate page, are recommended.

Evidence Requested ii

Provide the following evidence, or other evidence to demonstrate compliance.

Evidence the entity communicated any instability, Cascading or uncontrolled separation identified in its Planning Assessment of the Near-Term Transmission Planning Horizon that adversely impacted the reliability of the Bulk Electric System to each impacted Transmission Owner and Generation Owner.

The entity's most recent Planning Assessment of the Near-Term Transmission Planning Horizon.

Registered Entity Evidence (Required):

The following information is requested for each document submitted as evidence. Also, evidence submitted should be highlighted and bookmarked, as appropriate, to identify the exact location where evidence of compliance may be found.

		Revision		Relevant				
		or	Document	Page(s) or	Description of Applicability			
File Name	Document Title	Version	Date	Section(s)	of Document			
				, ,				
Audit Team Evidence Reviewed (This section to be completed by the Compliance Enforcement Authority):								
					,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			
Camadiana Assassa	. Ammunaalı Curaifia tı	- 546 044 3	, Do					
Compliance Assessment This section to be comp	• •			ity				
•				-	ad in the entity's Planning			
	For each instance of instability, Cascading or uncontrolled separation identified in the entity's Planning Assessment of the Near-Term Transmission Planning Horizon that adversely impacted the reliability of							
				•	ading or uncontrolled			
•	impacted Transmission	•		• •	admig or uncontrolled			
•	of, communication fr				ion Owners and			
Generation Owners	s, verify the communi	cation inclu	ded each of	those owner	's Facilities that comprise			
the Contingency(ie	s) (planning events or	nly) and any	Facilities crit	ical to the in	stability, Cascading or			
uncontrolled separ	ation identified.							
Note to Auditor: Planning Coordinators are required to prepare a Planning Assessment of the Near-Term								
Transmission Planning Horizon in TPL-001-4 R2. The Facilities communicated to an owner are only required								
to be those facilities that impact the owner.								
Auditor Notes:								
Additor Notes.								

Additional Information:

Reliability Standard

The RSAW developer should provide the following information without hyperlinks. Update the information below as appropriate.

The full text of STD-0XX-N may be found on the NERC Web Site (www.nerc.com) under "Program Areas & Departments", "Reliability Standards."

In addition to the Reliability Standard, there is an applicable Implementation Plan available on the NERC Web Site.

In addition to the Reliability Standard, there is background information available on the NERC Web Site.

Capitalized terms in the Reliability Standard refer to terms in the NERC Glossary, which may be found on the NERC Web Site.

Sampling Methodology [If developer deems reference applicable]

Sampling is essential for auditing compliance with NERC Reliability Standards since it is not always possible or practical to test 100% of either the equipment, documentation, or both, associated with the full suite of enforceable standards. The Sampling Methodology Guidelines and Criteria (see NERC website), or sample guidelines, provided by the Electric Reliability Organization help to establish a minimum sample set for monitoring and enforcement uses in audits of NERC Reliability Standards.

Regulatory Language [Developer to ensure RSAW has been provided to NERC Legal for links to appropriate Regulatory Language – See example below]

E.g. FERC Order No. 742 paragraph 34: "Based on NERC's......

E.g. FERC Order No. 742 Paragraph 55, Commission Determination: "We affirm NERC's......

Selected Glossary Terms [If developer deems applicable]

The following Glossary terms are provided for convenience only. Please refer to the NERC web site for the current enforceable terms.

Revision History for RSAW

Version	Date	Reviewers	Revision Description
1	10/10/2017	NERC Compliance Assurance, RSAW Task Force	New Document

ⁱ Items in the Evidence Requested section are suggested evidence that may, but will not necessarily, demonstrate compliance. These items are not mandatory and other forms and types of evidence may be submitted at the entity's discretion.