Standard Development Timeline

This section is maintained by the drafting team during the development of the standard and will be removed when the standard is adopted by the NERC Board of Trustees (Board).

Description of Current Draft

Completed Actions	Date
Standards Committee approved Standard Authorization Request (SAR) for posting	08/19/15
SAR posted for comment	08/20/15 – 09/21/15
Draft Reliability Standard posted for Informal Comment Period	07/14/16 – 08/12/16
45-day formal comment period with ballot	09/29/17 – 11/14/17

Anticipated Actions	Date
45-day formal comment period with additional ballot	August 2018 – October 2018
10-day final ballot	October 2018
NERC Board adoption	November 2018

A. Introduction

1. **Title:** Establish and Communicate System Operating Limits
2. **Number:** FAC-014-3
3. **Purpose:** To ensure that System Operating Limits (SOLs) used in the reliable operation of the Bulk Electric System (BES) are determined based on an established methodology or methodologies.
4. **Applicability:**
   - **4.1. Functional Entities:**
     - **4.1.1.** Reliability Coordinator
     - **4.1.2.** Transmission Operator
5. **Effective Date:** See Implementation Plan for Project 2015-09.

B. Requirements and Measures

R1. Each Reliability Coordinator shall establish Interconnection Reliability Operating Limits (IROLs) for its Reliability Coordinator Area in accordance with its System Operating Limit Methodology (SOL Methodology). *[Violation Risk Factor: High] [Time Horizon: Operations Planning]*

M1. Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation that demonstrates the Reliability Coordinator established IROLs in accordance with it SOL Methodology.

R2. Each Transmission Operator shall establish System Operating Limits (SOLs) for its portion of the Reliability Coordinator Area in accordance with its Reliability Coordinator's SOL Methodology. *[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]*

M2. Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation that demonstrates the Transmission Operator established SOLs in accordance with its Reliability Coordinator's SOL Methodology.

R3. The Transmission Operator shall provide its SOLs to its Reliability Coordinator in accordance with its Reliability Coordinator's SOL Methodology. *[Violation Risk Factor: Medium] [Time Horizon: Operations Planning, Same-day Operations, Real-Time Operations]*

M3. Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation that demonstrates the Transmission Operator provided its SOLs in accordance with its Reliability Coordinator's SOL Methodology.

R4. Each Reliability Coordinator shall establish stability limits to be used in operations when the limit impacts more than one Transmission Operator in its Reliability

Coordinator Area in accordance with its SOL Methodology. *[Violation Risk Factor: High] [Time Horizon: Operations Planning]*

M4. Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation that demonstrates the Reliability Coordinator established stability limits in accordance with Requirement R4.

R5. Each Reliability Coordinator shall provide: *[Violation Risk Factor: High] [Time Horizon: Operations Planning, Same-day Operations, Real-Time Operations]*

5.1 Each Planning Coordinator within its Reliability Coordinator Area, the SOLs for its Reliability Coordinator Area (including the subset of SOLs that are IROLs) at least once every twelve calendar months.

5.2 Each impacted Planning Coordinator within its Reliability Coordinator Area, the following information for each established stability limit and each established IROL at least once every twelve calendar months:

5.2.1 The value of the stability limit or IROL;

5.2.2 Identification of the Facilities that are critical to the stability limit or IROL;

5.2.3 The associated IROL T_v for any IROL;

5.2.4 The associated Contingency(ies);

5.2.5 A description of the associated system conditions; and

5.2.6 The type of limitation represented by the stability limit or IROL (*e.g.*, voltage collapse, angular stability).

5.3 Each impacted Transmission Operator within its Reliability Coordinator Area, the value of the stability limits established pursuant to Requirement R4 and each IROL established pursuant to Requirement R1, in an agreed upon time frame necessary for inclusion in the Transmission Operator's Operational Planning Analyses, Real-time monitoring, and Real-time Assessments.

5.4 Each impacted Transmission Operator within its Reliability Coordinator Area, the information identified in Requirement R5 Parts 5.2.2 – 5.2.5 for each established stability limit or each IROL, and any updates to that information within an agreed upon time frame necessary for inclusion in the Transmission Operator's Operational Planning Analyses.

5.5 Each requesting Transmission Operator within its Reliability Coordinator Area, requested SOL information for its Reliability Coordinator Area, on a mutually agreed upon schedule.

M5. Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation, posting to a secure website, or other electronic means, that demonstrates the Reliability Coordinator provided the information in accordance with Requirement R5.

R6. Each Transmission Operator and Reliability Coordinator shall use the Bulk Electric System performance criteria specified in the Reliability Coordinator's SOL Methodology when performing OPAs, RTAs, and Real-time monitoring to determine SOL exceedances. *[Violation Risk Factor: High] [Time Horizon: Operations Planning, Same-day Operations, Real-time Operations]*

M6. Acceptable evidence may include, but is not limited to, dated electronic or hard copy documentation, that demonstrates the Transmission Operator and Reliability Coordinator used the Bulk Electric System performance criteria specified in the Reliability Coordinator's SOL methodology when performing OPAs, RTAs and Real-Time Monitoring.

C. Compliance

1. Compliance Monitoring Process

1.1. Compliance Enforcement Authority:

"Compliance Enforcement Authority" means NERC or the Regional Entity, or any entity as otherwise designated by an Applicable Governmental Authority, in their respective roles of monitoring and/or enforcing compliance with mandatory and enforceable Reliability Standards in their respective jurisdictions.

1.2. Evidence Retention:

The following evidence retention period(s) identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full-time period since the last audit.

The applicable entity shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation.

- The Reliability Coordinator or Transmission Operator shall keep data or evidence of Requirements R1 through R8 for the current year plus the previous 12 calendar months.

1.3. Compliance Monitoring and Enforcement Program

As defined in the NERC Rules of Procedure, "Compliance Monitoring and Enforcement Program" refers to the identification of the processes that will be used to evaluate data or information for the purpose of assessing performance or outcomes with the associated Reliability Standard.

Violation Severity Levels

R #	Violation Severity Levels			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
R1.	N/A	N/A	N/A	The Reliability Coordinator failed to establish Interconnection Reliability Operating Limits (IROLs) for its Reliability Coordinator Area in accordance with its System Operating Limit Methodology ("SOL Methodology") as established in FAC-011-4.
R2.	N/A	N/A	N/A	The Transmission Operator failed to establish SOLs for its portion of the Reliability Coordinator Area in accordance with its Reliability Coordinator's SOL Methodology.
R3.	N/A	N/A	The Transmission Operator provided its SOLs to its Reliability Coordinator, but failed to provide its SOLs at the periodicity at which the RC needs such information	The Transmission Operator failed to provide its SOLs to its Reliability Coordinator.

			to perform its reliability functions.	
R4.	N/A	N/A	N/A	The Reliability Coordinator failed to determine stability limits to be used in operations when the limit impacts more than one Transmission Operator in its Reliability Coordinator Area in accordance with its SOL Methodology.
R5.	The Reliability Coordinator failed to provide one of the items listed in Requirement R5, Parts 5.1 through 5.6.	The Reliability Coordinator failed to provide two of the items listed in Requirement R5, Parts 5.1 through 5.6.	The Reliability Coordinator failed to provide three of the items listed in Requirement R5, Parts 5.1 through 5.6.	The Reliability Coordinator failed to provide four or more of the items listed in Requirement R5, Parts 5.1 through 5.6.
R6.	N/A	N/A	N/A	A Transmission Operator or Reliability Coordinator failed to use the Bulk Electric System performance criteria specified in the Reliability Coordinator's SOL Methodology.

D. Regional Variances

None

E. Interpretations

None

F. Associated Documents

Implementation Plan

Version History

Version	Date	Action	Change Tracking
1	November 1, 2006	Adopted by Board	New
2		Changed the effective date to January 1, 2009 Replaced Levels of Non-compliance with Violation Severity Levels	Revised
2	June 24, 2008	Adopted by Board: FERC Order	Revised
2	January 22, 2010	Updated effective date and footer to April 29, 2009 based on the March 20, 2009 FERC Order	Update
2	April 29, 2015 – July 23, 2015	Incorrectly included TOP as the applicable function for Requirement R5. 7/23/15: Corrected to designate R5 as: RC, PA and TP.	Revised
3		Project 2015-09 Adopt revised standard.	Revision