

Standards Authorization Request Form

When completed, please email this form to:
sarcomm@nerc.com

NERC welcomes suggestions to improve the reliability of the bulk power system through improved Reliability Standards. Please use this form to submit your request to propose a new or a revision to a NERC Reliability Standard.

Request to propose a new or a revision to a Reliability Standard

Title of Proposed Standard:	PRC-025-1 – Generator Relay Loadability		
Date Submitted:	August 25, 2016		
SAR Requester Information for #1			
Name:	Rich Quest		
Organization:	Midwest Reliability Organization		
Telephone:	(651) 855-1704	Email:	rp.quest@midwestreliability.org
SAR Requester Information for #2			
Name:	Jerry Thompson, E.I.T.		
Organization:	Kestrel Power Engineering		
Telephone:	(571) 293-1119	Email:	jerry@kestrelpower.com
SAR Requester Information for #3			
Name:	Joe DePoorter		
Organization:	Madison Gas & Electric		
Telephone:	(608) 252-1599	Email:	JDePoorter@mge.com

Request to propose a new or a revision to a Reliability Standard			
SAR Requester Information for #4			
Name:	Éric Loiselle, ing.		
Organization:	Hydro-Québec TransÉnergie		
Telephone:	(514) 879-4100	Email:	Loiselle.Eric2@hydro.qc.ca
SAR Type (Check as many as applicable)			
<input type="checkbox"/>	New Standard	<input type="checkbox"/>	Withdrawal of Existing Standard
<input checked="" type="checkbox"/>	Revision to Existing Standard	<input checked="" type="checkbox"/>	Urgent Action

SAR Information
Industry Need (What is the industry problem this request is trying to solve?):
<p>This SAR proposes revising PRC-025-1 the following specific problems.</p> <ol style="list-style-type: none"> 1. Prevent instances of non-compliance for conditions where the Generator Owner may be prevented from achieving the margin specified by the standard for dispersed power producing resources. 2. Prevent a lowering of reliability and potential non-compliance where the Generator Owner might apply a non-standard relay element application and undermine the goal of the standard. 3. Prevent a lowering of reliability where the Generator Owner might only apply part of the Table 1 application(s) thereby misapplying the loadability margins to relays for the stated application(s). 4. Prevent a lowering of dependability of protective relays directional toward the Transmission system at generating facilities that are remote to the transmission network. 5. Modify or eliminate the use of the term “pickup setting” and other terms or phrases that relate to initial measurements and specific detection methods, and instead, use a term or phrase that clearly aligns with the intent of the standard for relays to “not trip” based on the criteria in Table 1. 6. Miscellaneous considerations for clarifications to the standard, Attachment 1, and/or Application Guidelines.
Purpose or Goal (How does this request propose to address the problem described above?):
Consider revising the PRC-025-1 standard through the standards development process to: (1) provide alternative loadability Options for Table 1 specific to dispersed power producing resources; (2) address

SAR Information

the inclusion or exclusion of the 50 element¹ (i.e., instantaneous), (3) review Table 1 for proper application where there is more than one application for the available Option(s), (4) provide alternative or additional Options for Table 1 specific to relay applications that are directional toward the Transmission system where the interconnecting transmission line impedance may be a factor in determining the maximum Reactive Power output of the generators and associated relay settings, (5) provide an alternative to the term “pickup setting” in Table 1 that will better align with the intent of the standard for relays to “not trip”, and (6) provide clarity on identified miscellaneous items.

Identify the Objectives of the proposed standard’s requirements (What specific reliability deliverables are required to achieve the goal?):

This SAR proposes the need for revising PRC-025-1 for the following specific problems.

1. PRC-025-1, Table 1 requires setting the overcurrent relay of a Protection System applied to an asynchronous generating unit or an Element utilized in the aggregation of dispersed power producing resources to a margin greater than 130% of the calculated current derived from the maximum aggregate nameplate MVA output at rated power factor. This may result in instances of non-compliance due manufacturer requirements or physical limitations of dispersed power producing resources and may result in an overly conservative relay setting. Consider revising the standard to provide alternative options for setting the overcurrent element of a Protection System applied to an asynchronous generating unit and an Element utilized in the aggregation of dispersed power producing resources.
2. There is potential for Generator Owners to apply a pick up setting of the 50 element (i.e., instantaneous overcurrent) of a Protection System, which is not applicable to the standard, that is lower than the minimum pick up established by the standard for the 51 element (i.e., time delayed overcurrent). The 50 element is generally not used in the generator applications where the 51 element is found in the standard. In addition, there are some applications in which protective functions utilized measure and react to current but do not use ANSI device numbers. Consider revising the standard to address the inclusion or exclusion of the 50 element and other similar elements that may not use ANSI device numbers for the various overcurrent applications within Table 1.

¹ Refer to Institute of Electronics and Electrical Engineers (IEEE) Standard C37.2-2008 for American National Standards Institute (ANSI) device numbers.

SAR Information

3. There is potential for Generator Owners not to apply loadability margins to all load-responsive protective relays in Table 1 of PRC-025-1 under the “Application” column that may affect loadability. For example, the Application column from Table 1 (Options 4, 5, and 6):
*“Asynchronous generating unit(s) (including inverter-based installations), **or** Elements utilized in the aggregation of dispersed power producing resources.”*
 The above clause is separated by an “or” conjunction and may lead the Generator Owner to set one particular application and not the other. This may create a gap in achieving the goal of the standard when loadability margins are not applied to relays on certain Elements. Consider revising the standard to make it clear whether either or both of the listed Elements in the Application column of Options 1-6 must meet the criteria of the particular Option. For “Elements utilized in the aggregation of dispersed power producing resources”, clarify that the standard is requiring an assessment from each generating source through the feeders and up through the interconnecting transmission line by adding a bulleted list. Alternatively, develop a section of Table 1 that specifically addresses relays applied on these Elements, making certain it is clear this statement applies to feeders in collection systems, and potentially then removing this statement from the current Options 1-6.
4. In the case of remote generating facilities that are electrically weak at its connection to the transmission network, the maximum Reactive Power required by the specific Table 1 Options is too high to be observed in any recoverable stressed condition. This is due to the system impedance (mainly line impedance) restricting the maximum Reactive Power output by the generator, no matter the generator characteristics. Lastly, applying the existing Table 1 Options for relay applications directional toward the Transmission system results in an overly conservative relay setting and could require reducing the backup protection coverage in order to comply with the stressed system condition anticipated by the standard.
5. The use of the term “pickup setting” and other terms or phrases that relate to initial measurements and specific detection methods does not align with the intent of the standard for relays to “not trip” based on the criteria in Table 1. Clarify that multiple methods/curve types are acceptable so long as the applied protection does not trip the generator(s) under the conditions described in the table. For example, using such language could more clearly allow use of blinders, non-mho relay characteristics and other schemes in which the relay’s initial measurement may detect a condition (e.g., may “pickup”) but the relay is blocked from operating.

SAR Information

6. Miscellaneous items that may result in a lack of clarity in the standard, Attachment 1, and/or the Application Guidelines:
- a. It is not clear that the ANSI device numbers within the standard refer to the IEEE Standard C37.2-2008 reference document. Adding an appropriate reference will improve clarity.
 - b. It is unclear when resources are described with the following terms in the Standard: asynchronous, synchronous, inverter-based, and dispersed power producing resources. The description of what is classified as an asynchronous generator should be clarified. For example, the statement in Application Guidelines that “asynchronous generators... do not have excitation systems and will not respond to a disturbance with the same magnitude of apparent power that a synchronous generator will respond” should be clarified/corrected or replaced since this category is intended to include inverter based, doubly-fed induction generator based, and induction generator based resources. Clarify the proper treatment of various resources.
 - c. It is not clear that the phrase about unit capability “reported to the Transmission Planner” is a minimum criterion and that a greater unit capability is acceptable. Clarify that the Generator Owner may base settings on a capability higher than what is reported to the Transmission Planner.
 - d. It is not clear that CB103 relay in Figure 1 of the Application Guidelines is applicable to the standard because the Application Guidelines only addresses a directional relay toward the generator plant as not being applicable; however, there are cases where CB103 would be applicable to the standard (e.g., non-directional relays). Provide clarity that would help prevent the overlooking of the CB103 relay as being applicable to the standard, including a potential revision to Figure 1.

Brief Description (Provide a paragraph that describes the scope of this standard action.)

The PRC-025-1 standard became effective on October 1, 2014 and has a phased implementation of five and seven years (i.e., 2019 or 2021) depending on the scope of work required by the Generator Owner. During the early stages of implementation, the above problems were revealed by industry. The scope of work will be to consider providing (1) an alternative loadability margin for dispersed power producing resources, (2) revision that includes or excludes 50 element for overcurrent applications, (3) clarification of the application of the Elements in Table 1 of PRC-025-1 for each option that has two applicable Elements separated by an “or” conjunction, (4) alternative or additional Option(s) (e.g., calculation or method) for determining loadability settings for relays that are directional toward the Transmission

SAR Information

system, (5) modify or eliminate the use of the term “pickup setting,” and (6) miscellaneous consideration of clarifications to the standard, Attachment 1, and/or Application Guidelines.

Detailed Description (Provide a description of the proposed project with sufficient details for the standard drafting team to execute the SAR. Also provide a justification for the development or revision of the standard, including an assessment of the reliability and market interface impacts of implementing or not implementing the standard action.)

1. Consider revising the PRC-025-1 standard concerning #1 above through the standards development process to provide a means to determine alternative loadability Options for Table 1 of the standard specific to dispersed power producing resources where there could be a manufacturer requirement or physical equipment limitation. Similar to the provisions already contained in the standard, consider methods that would eliminate the potential for non-compliance and/or a violation of manufacturer specifications. For example: (a) a provision could allow a margin consistent with the manufacturer’s requirements or based on the limitation of the equipment; (b) a provision to allow the dispersed power producing resource output to be studied through simulation (e.g., similar to Options 1c and 2c) and the relays to be set with an appropriate margin determined through the standard development process; (c) a provision to exempt equipment with fixed limitations installed prior to the effective date of PRC-025-1 or other justifiable date; and/or (d) any other equally effective and efficient method to accomplish the goal.²
2. Consider revising the PRC-025-1 standard concerning #2 above to address the inclusion or exclusion of the 50 element (i.e., instantaneous overcurrent) of a Protection System, and other overcurrent type elements which may not utilize ANSI device numbers, with or without intentional time delay. Newer techniques in generator protection applications and differences in protective elements applied with different generation technologies may result in a gap due to non-traditional applications of generator overcurrent relays.
3. Consider revising the PRC-025-1 standard concerning #3 above through the standards development process to bring awareness and clarification that both of the Elements listed in the “Application” column of Table 1, Options 1-6 are to have loadability margins applied to the load-responsive protective relays.

² Any criteria revised in the standard concerning dispersed power producing resources should also be considered for Elements utilized in the aggregation of dispersed power producing resources, if separated from the dispersed power producing resources application of Table 1.

SAR Information

4. Consider revising the PRC-025-1 standard concerning #4 above through the standards development process to provide a means to determine alternative loadability Option(s) for Table 1 of the standard specific to relays directional toward the Transmission system. Similar to the provisions already contained in the standard, consider: (a) alternative Options for relay settings where the interconnecting transmission line impedance has a significant impact the maximum Reactive Power output of the generating facility and the associated relay settings, (b) the technical validity of the existing options in the presence of significant transmission line impedance between generation and the network, and/or (c) any other equally effective and efficient method to address the problem of significant line impedance effecting how phase protective relays are set not limit generator loadability while maintaining reliable protection of the BES for all fault conditions.
5. Consider revising Table 1 to modify or eliminate the use of the term “pickup setting” and other terms or phrases that relate to initial measurements and specific detection methods and instead, use a term or phrase that clearly aligns with the intent of the standard for relays to “not trip” based on the criteria in Table 1. Consider clarifying wherever necessary that multiple methods/curve types are acceptable so long as the applied protection does not trip the generator(s) under the conditions described in the table. For example, using such language could more clearly allow use of blinders, non-mho relay characteristics and other schemes in which the relay’s initial measurement may detect a condition (e.g., may “pickup”) but the relay is blocked from operating.
6. Miscellaneous considerations for the standard, Attachment 1, and/or Application Guidelines:
 - a. Consider including a reference in the standard to clarify that the ANSI device numbers within the standard refers to IEEE Standard C37.2-2008 reference document.
 - b. Consider whether it is clear and appropriate when resources are described with the following terms in the Standard: asynchronous, synchronous, inverter-based and dispersed power producing resources. The description of what is classified as an asynchronous generator should be clarified. For example, Asynchronous generators do not have excitation systems and will not respond to a disturbance with the same magnitude of apparent power that a synchronous generator will respond; therefore, are treated as “asynchronous” in Table 1.
 - c. Consider clarifying the use of the phrase about unit capability “reported to the Transmission Planner” as being a minimum criterion and that a greater unit capability is acceptable.

SAR Information

- d. Consider clarifying that CB103 relay in Figure 1 of the Application Guidelines is applicable to the standard and correct the figure to show CB103 as also possibly being subject to the standard. The Application Guidelines only addresses a directional relay and that non-directional relays would be applicable to the standard.

Reliability Functions

The Standard will Apply to the Following Functions (Check each one that applies.)

<input type="checkbox"/> Reliability Coordinator	Responsible for the real-time operating reliability of its Reliability Coordinator Area in coordination with its neighboring Reliability Coordinator’s wide area view.
<input type="checkbox"/> Balancing Authority	Integrates resource plans ahead of time, and maintains load-interchange-resource balance within a Balancing Authority Area and supports Interconnection frequency in real time.
<input type="checkbox"/> Interchange Authority	Ensures communication of interchange transactions for reliability evaluation purposes and coordinates implementation of valid and balanced interchange schedules between Balancing Authority Areas.
<input type="checkbox"/> Planning Coordinator	Assesses the longer-term reliability of its Planning Coordinator Area.
<input type="checkbox"/> Resource Planner	Develops a one year plan for the resource adequacy of its specific loads within a Planning Coordinator area.
<input type="checkbox"/> Transmission Planner	Develops a one year plan for the reliability of the interconnected Bulk Electric System within its portion of the Planning Coordinator area.
<input type="checkbox"/> Transmission Service Provider	Administers the transmission tariff and provides transmission services under applicable transmission service agreements (e.g., the pro forma tariff).
<input checked="" type="checkbox"/> Transmission Owner	Owns and maintains transmission facilities.
<input type="checkbox"/> Transmission Operator	Ensures the real-time operating reliability of the transmission assets within a Transmission Operator Area.
<input checked="" type="checkbox"/> Distribution Provider	Delivers electrical energy to the end-use customer.

Reliability Functions	
<input checked="" type="checkbox"/> Generator Owner	Owns and maintains generation facilities.
<input type="checkbox"/> Generator Operator	Operates generation unit(s) to provide real and reactive power.
<input type="checkbox"/> Purchasing-Selling Entity	Purchases or sells energy, capacity, and necessary reliability-related services as required.
<input type="checkbox"/> Market Operator	Interface point for reliability functions with commercial functions.
<input type="checkbox"/> Load-Serving Entity	Secures energy and transmission service (and reliability-related services) to serve the end-use customer.

Reliability and Market Interface Principles	
Applicable Reliability Principles (Check all that apply).	
<input checked="" type="checkbox"/>	1. Interconnected bulk power systems shall be planned and operated in a coordinated manner to perform reliably under normal and abnormal conditions as defined in the NERC Standards.
<input type="checkbox"/>	2. The frequency and voltage of interconnected bulk power systems shall be controlled within defined limits through the balancing of real and reactive power supply and demand.
<input type="checkbox"/>	3. Information necessary for the planning and operation of interconnected bulk power systems shall be made available to those entities responsible for planning and operating the systems reliably.
<input type="checkbox"/>	4. Plans for emergency operation and system restoration of interconnected bulk power systems shall be developed, coordinated, maintained and implemented.
<input type="checkbox"/>	5. Facilities for communication, monitoring and control shall be provided, used and maintained for the reliability of interconnected bulk power systems.
<input type="checkbox"/>	6. Personnel responsible for planning and operating interconnected bulk power systems shall be trained, qualified, and have the responsibility and authority to implement actions.
<input type="checkbox"/>	7. The security of the interconnected bulk power systems shall be assessed, monitored and maintained on a wide area basis.
<input type="checkbox"/>	8. Bulk power systems shall be protected from malicious physical or cyber attacks.
Does the proposed Standard comply with all of the following Market Interface Principles?	
1. A reliability standard shall not give any market participant an unfair competitive advantage.	Enter (yes/no) Yes
2. A reliability standard shall neither mandate nor prohibit any specific market structure.	Yes

Reliability and Market Interface Principles	
3. A reliability standard shall not preclude market solutions to achieving compliance with that standard.	Yes
4. A reliability standard shall not require the public disclosure of commercially sensitive information. All market participants shall have equal opportunity to access commercially non-sensitive information that is required for compliance with reliability standards.	Yes

Related Standards	
Standard No.	Explanation
None.	

Related SARs	
SAR ID	Explanation
None.	

Regional Variances	
Region	Explanation
ERCOT	None.
FRCC	None.
MRO	None.
NPCC	None.
RFC	None.
SERC	None.
SPP	None.
WECC	None.

Version History

Version	Date	Owner	Change Tracking
1	June 3, 2013		Revised
1	August 29, 2014	Standards Information Staff	Updated template