

## Standard Development Timeline

This section is maintained by the drafting team during the development of the standard and will be removed when the standard is adopted by the NERC Board of Trustees (Board).

### Description of Current Draft

This is the ~~initial~~second draft of ~~the~~ proposed standard.

Completed Actions	Date
Standards Committee (SC) approved Standard Authorization Request (SAR) for posting	March 9, 2016
SAR posted for comment	March 23–April 21, 2016
SAR posted for comment	June 1–June 30, 2016
SC Accepted the SAR	July 20, 2016
<del>45</del> <u>60</u> -day formal comment period with ballot	January 21– <del>February 8</del> <u>March 22</u> , 2021
<del>45-day formal comment period with ballot</del>	<del>June 30 – August 13, 2021</del>

Anticipated Actions	Date
<del>45-day formal comment period with ballot</del>	<del>May 11–June 24, 2021</del>
45-day formal comment period with ballot	August <del>3</del> <u>29</u> – <del>September 16</del> <u>October 11</u> , 2021
Final Ballot	October 19–28, 2021
Board adoption	November 4, 2021

## A. Introduction

1. **Title:** Cyber Security — System Security Management
2. **Number:** CIP-007-7
3. **Purpose:** To manage system security by specifying select technical, operational, and procedural requirements in support of protecting BES Cyber Systems (BCS) against compromise that could lead to misoperation or instability in the Bulk Electric System (BES).

4. **Applicability:**

**4.1. Functional Entities:** For the purpose of the requirements contained herein, the following list of functional entities will be collectively referred to as “Responsible Entities.” For requirements in this standard where a specific functional entity or subset of functional entities are the applicable entity or entities, the functional entity or entities are specified explicitly.

**4.1.1 Balancing Authority**

**4.1.2 Distribution Provider** that owns one or more of the following Facilities, systems, and equipment for the protection or restoration of the BES:

**4.1.2.1** Each underfrequency Load shedding (UFLS) or undervoltage Load shedding (UVLS) system that:

**4.1.2.1.1** is part of a Load shedding program that is subject to one or more requirements in a NERC or Regional Reliability Standard; and

**4.1.2.1.2** performs automatic Load shedding under a common control system owned by the Responsible Entity, without human operator initiation, of 300 MW or more.

**4.1.2.2** Each Remedial Action Scheme (RAS) where the RAS is subject to one or more requirements in a NERC or Regional Reliability Standard.

**4.1.2.3** Each Protection System (excluding UFLS and UVLS) that applies to Transmission where the Protection System is subject to one or more requirements in a NERC or Regional Reliability Standard.

**4.1.2.4** Each Cranking Path and group of Elements meeting the initial switching requirements from a Blackstart Resource up to and including the first interconnection point of the starting station service of the next generation unit(s) to be started.

**4.1.3 Generator Operator**

**4.1.4 Generator Owner**

**4.1.5 Reliability Coordinator**

**4.1.6 Transmission Operator**

**4.1.7 Transmission Owner**

**4.2. Facilities:** For the purpose of the requirements contained herein, the following Facilities, systems, and equipment owned by each Responsible Entity in 4.1 above are those to which these requirements are applicable. For requirements in this standard where a specific type of Facilities, system, or equipment or subset of Facilities, systems, and equipment are applicable, these are specified explicitly.

**4.2.1 Distribution Provider:** One or more of the following Facilities, systems and equipment owned by the Distribution Provider for the protection or restoration of the BES:

**4.2.1.1** Each UFLS or UVLS System that:

**4.2.1.1.1** is part of a Load shedding program that is subject to one or more requirements in a NERC or Regional Reliability Standard; and

**4.2.1.1.2** performs automatic Load shedding under a common control system owned by the Responsible Entity, without human operator initiation, of 300 MW or more.

**4.2.1.2** Each RAS where the RAS is subject to one or more requirements in a NERC or Regional Reliability Standard.

**4.2.1.3** Each Protection System (excluding UFLS and UVLS) that applies to Transmission where the Protection System is subject to one or more requirements in a NERC or Regional Reliability Standard.

**4.2.1.4** Each Cranking Path and group of Elements meeting the initial switching requirements from a Blackstart Resource up to and including the first interconnection point of the starting station service of the next generation unit(s) to be started.

**4.2.2 Responsible Entities listed in 4.1 other than Distribution Providers:**  
All BES Facilities.

**4.2.3 Exemptions:** The following are exempt from Standard CIP-007-7:

**4.2.3.1** Cyber ~~S~~systems at Facilities regulated by the Canadian Nuclear Safety Commission.

**4.2.3.2** Cyber ~~S~~systems associated with communication links ~~logically isolated from, but not providing logical isolation for, BCS or~~

~~Shared Cyber Infrastructure (SCI) between discrete Electronic Security Perimeters (ESP).~~

**4.2.3.3** Cyber ~~s~~Systems, associated with communication links, between ~~the Cyber Systems providing confidentiality and integrity of an ESP that Cyber Assets, Virtual Cyber Assets, or SCI performing logical isolation that~~ extends to one or more geographic locations.

**4.2.3.4** The systems, structures, and components that are regulated by the Nuclear Regulatory Commission under a cyber security plan pursuant to 10 C.F.R. Section 73.54.

**4.2.3.5** For Distribution Providers, the systems and equipment that are not included in section 4.2.1 above.

**4.2.3.6** Responsible Entities that identify that they have no BCS categorized as high impact or medium impact according to the CIP-002-~~5.1~~ identification and categorization processes.

**4.3. “Applicable Systems” Columns in Tables:** Each table has an “Applicable Systems” column to ~~further~~ define the scope of systems to which a specific requirement ~~row part~~ applies. ~~This concept was adapted from the National Institute of Standards and Technology (“NIST”) Risk Management Framework as a way of applying requirements more appropriately based on impact and connectivity characteristics.~~

**5. Effective Dates:**

See “Project 2016-02 ~~Virtualization~~ Modification to CIP Standards Implementation Plan.”

## B. Requirements and Measures

- R1.** Each Responsible Entity shall implement one or more documented process(es) that collectively include each of the applicable requirement parts in *CIP-007-7 Table R1 – System Hardening*. [Violation Risk Factor: Medium] [Time Horizon: Same Day Operations.]
- M1.** Evidence must include the documented processes that collectively include each of the applicable requirement parts in *CIP-007-7 Table R1 – System Hardening* and additional evidence to demonstrate implementation as described in the Measures column of the table.

CIP-007-7 Table R1–System Hardening			
Part	Applicable Systems	Requirements	Measures
1.1	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS with <del>External Routable Connectivity</del>ERC and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><u>SCI identified independently supporting an Applicable System above.</u></p>	<p>Enable only <del>logical</del> network accessible <u>Internet Protocol (IP) ports (or services if unable to determine ports)</u> <del>that have been</del> determined to be needed by the Responsible Entity, <del>(or logical network accessible ports if unable to determine service,</del> including port ranges where needed to handle dynamic ports), per system capability. If a device has no provision for disabling or restricting <del>network accessible services (or logical ports)</del> on the device, then those <del>services (or logical ports)</del>, that are open are deemed needed.</p>	<p>Examples of evidence may include, but are not limited to:</p> <ul style="list-style-type: none"> <li>• Documentation of the need for all enabled <u>network accessible IP ports or services</u>, individually or by group.</li> <li>• Listings of the listening ports, individually or by group, from either configuration files, command output (such as netstat), or network scans of open ports; or</li> <li>• Configuration of host-based firewalls, policy, or other mechanisms that only allow needed <u>IP ports or services</u> and deny all others.</li> </ul>

CIP-007-7 Table R1—System Hardening			
Part	Applicable Systems	Requirements	Measures
1.2	<p>High Impact BCS and their associated:  <u>1. PCA; and</u>  <del>1.2. Non-programmable communications components located inside both a PSP and ESP.</del></p> <p>Medium Impact BCS at Control Centers and their associated:  <u>1. PCA; and</u>  <del>1.2. Non-programmable communications components located inside both a PSP and ESP.</del></p> <p><u>SCI identified independently supporting an Applicable System above</u></p> <p><del>SCI at Control Centers hosting High or Medium Impact BCS or their associated PCA</del></p> <p><del>Management Modules of SCI at Control Centers hosting High or Medium Impact BCS or their associated PACS, EACMS, or PCA</del></p> <p><del>Non-programmable communications components within a PSP that are not logically isolated from High or Medium impact BCS at Control Centers</del></p>	<p>Protect against the use of unnecessary physical input/output ports used for network connectivity, console commands, or Removable Media.</p>	<p>An example of evidence may include, but is not limited to, documentation showing types of protection of physical input/output ports, either logically through system configuration or physically using a port lock or signage.</p>

CIP-007-7 Table R1—System Hardening			
Part	Applicable Systems	Requirements	Measures
<del>1.3</del>	<p><del>SCI hosting High or Medium Impact BCS or their associated: PACS; EACMS; or PCA</del></p> <p><del>Management Modules of SCI hosting High or Medium Impact BCS or their associated: PACS; EACMS; or PCA</del></p>	<p><del>Enable only services that have been determined to be needed by the Responsible Entity, per system capability.</del></p>	<p><del>Examples of evidence may include, but are not limited to:</del></p> <ul style="list-style-type: none"> <li><del>• Documentation of implemented hardening guidelines</del></li> <li><del>• Configuration management reporting</del></li> </ul> <p><del>that demonstrates the need for all enabled services.</del></p>
<u>1.43</u>	<p><u>SCI identified independently supporting:</u></p> <ul style="list-style-type: none"> <li><u>• High Impact BCS and their associated:</u> <ol style="list-style-type: none"> <li><u>1. EACMS</u></li> <li><u>2. PACS; and</u></li> <li><u>3. PCA</u></li> </ol> </li> <li><u>• Medium Impact BCS with External Routable Connectivity and their associated:</u> <ol style="list-style-type: none"> <li><u>1. EACMS;</u></li> <li><u>2. PACS; and</u></li> <li><u>3. PCA</u></li> </ol> </li> </ul>	<p><u>Prevent the sharing of the CPU and memory of Management Interfaces of SCI with non-CIP Systems.</u></p>	<p><u>Examples of evidence may include, but is not limited to, documentation of the configuration showing that the CPU and memory cannot be shared with non-CIP Systems.</u></p>

- R2.** Each Responsible Entity shall implement one or more documented process(es) that collectively include each of the applicable requirement parts in *CIP-007-7 Table R2 – Security Patch Management*. [*Violation Risk Factor: Medium*] [*Time Horizon: Operations Planning*].
- M2.** Evidence must include each of the applicable documented processes that collectively include each of the applicable requirement parts in *CIP-007-7 Table R2 – Security Patch Management* and additional evidence to demonstrate implementation as described in the Measures column of the table.

CIP-007-7 Table R2 – Security Patch Management			
Part	Applicable Systems	Requirements	Measures
2.1	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><del>SCI identified independently supporting an Applicable System above.</del></p> <p><del>SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> </ul> <p><del>Management Modules of SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> </ul>	<p>A patch management process for tracking, evaluating, and installing cyber security patches. The tracking portion shall include the identification of a source or sources that the Responsible Entity tracks for the release of cyber security patches for systems that are updateable and for which a patching source exists.</p>	<p>An example of evidence may include, but is not limited to, documentation of a patch management process and documentation or lists of sources that are monitored.</p>

CIP-007-7 Table R2 – Security Patch Management			
Part	Applicable Systems	Requirements	Measures
2.2	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><del>SCI identified independently supporting an Applicable System above</del></p> <p><del>SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> </ul> <p><del>Management Modules of SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> <li><del>●</del></li> </ul>	<p>At least once every 35 calendar days, evaluate <u>cyber</u> security patches for applicability that have been released since the last evaluation from the source or sources identified in Part 2.1.</p>	<p>An example of evidence may include, but is not limited to, an evaluation conducted by, referenced by, or on behalf of a Responsible Entity of security-related patches released by the documented sources at least once every 35 calendar days.</p>

<p><b>2.3</b></p>	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><u>SCI identified independently supporting an Applicable System above</u></p> <p><u>SCI hosting High or Medium Impact BCS or their associated:</u></p> <ul style="list-style-type: none"> <li>● <del>PACS;</del></li> <li>● <del>EACMS; or</del></li> <li>● <del>PCA</del></li> </ul> <p><u>Management Modules of SCI hosting High or Medium Impact BCS or their associated:</u></p> <ul style="list-style-type: none"> <li>● <del>PACS;</del></li> <li>● <del>EACMS; or</del></li> <li>● <del>PCA</del></li> <li>●</li> </ul>	<p>For applicable patches identified in Part 2.2, within 35 calendar days of the evaluation completion, take one of the following actions:</p> <ul style="list-style-type: none"> <li>● Apply the applicable patches;</li> <li>● Create a dated mitigation plan; or</li> <li>● Revise an existing mitigation plan.</li> </ul> <p>Mitigation plans shall include the Responsible Entity’s planned actions to mitigate the vulnerabilities addressed by each <u>cyber</u> security patch and a timeframe to complete these mitigations.</p>	<p>Examples of evidence may include, but are not limited to:</p> <ul style="list-style-type: none"> <li>● Records of the installation of the patch (e.g., exports from automated patch management tools that provide installation date, verification of BES Cyber System Component software revision, or registry exports that show software has been installed); or</li> <li>● A dated plan showing when and how the vulnerability will be addressed, to include documentation of the actions to be taken by the Responsible Entity to mitigate the vulnerabilities addressed by the security patch and a timeframe for the completion of these mitigations.</li> </ul>
-------------------	---	---	--

CIP-007-7 Table R2 – Security Patch Management			
Part	Applicable Systems	Requirements	Measures
2.4	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact <del>BES Cyber Systems</del> BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><u>SCI identified independently supporting an Applicable System above</u></p> <p><del>SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> </ul> <p><del>Management Modules of SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li>● PCA</li> </ul>	<p>For each mitigation plan created or revised in Part 2.3, implement the plan within the timeframe specified in the plan, unless a revision to the plan or an extension to the timeframe specified in Part 2.3 is approved by the CIP Senior Manager or delegate.</p>	<p>An example of evidence may include, but is not limited to, records of implementation of mitigations.</p>

- R3.** Each Responsible Entity shall implement one or more documented process(es) that collectively include each of the applicable requirement parts in *CIP-007-7 Table R3 – Malicious Code Protection [Violation Risk Factor: Medium] [Time Horizon: Same Day Operations]*.
- M3.** Evidence must include each of the documented processes that collectively include each of the applicable requirement parts in *CIP-007-7 Table R3 – Malicious Code Protection* and additional evidence to demonstrate implementation as described in the Measures column of the table.

CIP-007-7 Table R3 – Malicious Code Protection			
Part	Applicable Systems	Requirements	Measures
3.1	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><del>SCI identified independently supporting an Applicable System above</del></p> <p><del>SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> </ul> <p><del>Management Modules of SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li>● PCA</li> </ul>	<p>Deploy method(s) to deter, detect, or prevent malicious code.</p>	<p>An example of evidence may include, but is not limited to, records of the Responsible Entity’s performance of these processes (e.g., through traditional antivirus, system hardening, policies, white-listing, privileged introspection, etc.).</p>

CIP-007-7 Table R3 – Malicious Code Protection			
Part	Applicable Systems	Requirements	Measures
3.2	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><del>SCI identified independently supporting an Applicable System above</del></p> <p><del>SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> </ul> <p><del>Management Modules of SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li>● PCA</li> </ul>	Mitigate the threat of detected malicious code.	<p>Examples of evidence may include, but are not limited to:</p> <ul style="list-style-type: none"> <li>● Records of response processes for malicious code detection</li> <li>● Records of the performance of these processes when malicious code is detected.</li> </ul>

CIP-007-7 Table R3 – Malicious Code Protection			
Part	Applicable Systems	Requirements	Measures
3.3	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><del>SCI identified independently supporting an Applicable System above</del></p> <p><del>SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> </ul> <p><del>Management Modules of SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> </ul>	<p>For those methods identified in Part 3.1 that use signatures or patterns, have a process for the update of the signatures or patterns. The process must address testing and installing the signatures or patterns.</p>	<p>An example of evidence may include, but is not limited to, documentation showing the process used for the update of signatures or patterns.</p>

- R4.** Each Responsible Entity shall implement one or more documented process(es) that collectively include each of the applicable requirement parts in *CIP-007-7 Table R4 – Security Event Monitoring*. [*Violation Risk Factor: Medium*] [*Time Horizon: Same Day Operations and Operations Assessment.*]
- M4.** Evidence must include each of the documented processes that collectively include each of the applicable requirement parts in *CIP-007-7 Table R4 – Security Event Monitoring* and additional evidence to demonstrate implementation as described in the Measures column of the table.

CIP-007-7 Table R4 – Security Event Monitoring			
Part	Applicable Systems	Requirements	Measures
4.1	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><del>SCI identified independently supporting an applicable system above</del></p> <p><del>SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> </ul> <p><del>Management Modules of SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li>● PCA</li> </ul>	<p>Log security events, per system capability, for identification of, and after-the-fact investigations of, Cyber Security Incidents that includes, at a minimum, each of the following types of events:</p> <ol style="list-style-type: none"> <li>4.1.1. Detected successful login attempts;</li> <li>4.1.2. Detected failed access attempts and failed login attempts; <u>and</u></li> <li>4.1.3. Detected malicious code.</li> </ol>	<p>Examples of evidence may include, but are not limited to, a paper or system generated listing of event types for which the BCS is capable of detecting and, for generated events, is configured to log. This listing must include the required types of events.</p>

<p><b>4.2</b></p>	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS with External Routable Connectivity and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><u>SCI identified independently supporting an Applicable System above</u></p> <p><del>SCI with ERC hosting High Impact BCS or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS;</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> </ul> <p><del>Management Modules with ERC of SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>● PACS</del></li> <li><del>● EACMS; or</del></li> <li><del>● PCA</del></li> </ul>	<p>Generate alerts for security events that the Responsible Entity determines necessitates an alert; that includes, at a minimum, each of the following types of events, per system capability:</p> <ol style="list-style-type: none"> <li>4.2.1. Detected malicious code from Part 4.1; and</li> <li>4.2.2. Detected failure of Part 4.1 event logging.</li> </ol>	<p>Examples of evidence may include, but are not limited to, paper or system-generated listing of security events that the Responsible Entity determined necessitate alerts, including paper or system generated list showing how alerts are configured.</p>
-------------------	--	---	--

<p><b>4.3</b></p>	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS at Control Centers and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><u>SCI identified independently supporting an Applicable System above</u></p> <p><u>SCI at Control Centers hosting High Impact BCS, Medium Impact BCS, or their associated:</u></p> <ul style="list-style-type: none"> <li>● <del>PACS;</del></li> <li>● <del>EACMS; or</del></li> <li>● <del>PCA</del></li> </ul> <p><u>Management Modules of SCI at Control Centers hosting High or Medium Impact BCS or their associated:</u></p> <ul style="list-style-type: none"> <li>● <del>PACS;</del></li> <li>● <del>EACMS; or</del></li> <li>● <del>PCA</del></li> </ul>	<p>Retain applicable security event logs identified in Part 4.1 for at least the last 90 consecutive calendar days, per system capability, except under CIP Exceptional Circumstances.</p>	<p>Examples of evidence may include, but are not limited to, documentation of the event log retention process and paper or system generated reports showing log retention configuration set at 90 days or greater.</p>
-------------------	---	--	--

CIP-007-7 Table R4 – Security Event Monitoring			
Part	Applicable Systems	Requirements	Measures
4.4	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS; and</li> <li>2. PCA</li> </ol> <p><del>SCI identified independently supporting an Applicable System above</del></p> <p><del>SCI hosting High Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>• EACMS; or</del></li> <li><del>• PCA</del></li> </ul> <p><del>Management Modules of SCI hosting High BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>• EACMS; or</del></li> <li><del>• PCA</del></li> </ul>	<p>Review a summarization or sampling of logged events as determined by the Responsible Entity at intervals no greater than 15 calendar days to identify undetected Cyber Security Incidents.</p>	<p>Examples of evidence may include, but are not limited to, documentation describing the review, any findings from the review (if any), and dated documentation showing the review occurred.</p>

**R5.** Each Responsible Entity shall implement one or more documented process(es) that collectively include each of the applicable requirement parts in *CIP-007-7 Table R5 – System Access Controls*. [Violation Risk Factor: Medium] [Time Horizon: Operations Planning].

**M5.** Evidence must include each of the applicable documented processes that collectively include each of the applicable requirement parts in *CIP-007-7 Table 5 – System Access Controls* and additional evidence to demonstrate implementation as described in the Measures column of the table.

CIP-007-7 Table R5 – System Access Controls			
Part	Applicable Systems	Requirements	Measures
5.1	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS at Control Centers and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS with External Routable Connectivity (ERC) and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><u>SCI identified independently supporting an Applicable System above</u></p> <p><del>SCI at Control Centers with ERC hosting High Impact BCS, Medium Impact BCS, or their associated:</del></p> <p>• <del>PACS;</del></p>	<p>Have a method(s) to enforce authentication of interactive user access, per system capability.</p>	<p>An example of evidence may include, but is not limited to, documentation describing how access is authenticated.</p>

CIP-007-7 Table R5 – System Access Controls			
Part	Applicable Systems	Requirements	Measures
	<ul style="list-style-type: none"> <li><del>• EACMS; or</del></li> <li><del>• PCA</del></li> </ul> <p><del>Management Modules of SCI at Control Centers hosting High or Medium Impact BCS or their associated:</del></p> <p><del>PACS;</del></p> <p><del>EACMS; or</del></p> <p><del>PCA</del></p>		
5.2	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS- and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><u>SCI identified independently supporting an Applicable System above</u></p> <p><del>SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>• PACS;</del></li> <li><del>• EACMS; or</del></li> <li><del>• PCA</del></li> </ul>	<p>Identify and inventory all known enabled default or other generic account types, either by system, by groups of systems, by location, or by system type(s).</p>	<p>An example of evidence may include, but is not limited to, a listing of accounts by account types showing the enabled or generic account types in use.</p>

CIP-007-7 Table R5 – System Access Controls			
Part	Applicable Systems	Requirements	Measures
	<p>Management Modules of SCI hosting High or Medium Impact BCS or their associated:</p> <ul style="list-style-type: none"> <li>• PACS;</li> <li>• EACMS; or</li> <li>PCA</li> </ul>		

CIP-007-7 Table R5 – System Access Controls			
Part	Applicable Systems	Requirements	Measures
5.3	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS with External Routable Connectivity and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><del>SCI identified independently supporting an Applicable System above</del></p> <p><del>SCI with ERC hosting High Impact BCS, Medium Impact BCS, or their associated:</del></p> <ul style="list-style-type: none"> <li><del>• PACS;</del></li> <li><del>• EACMS; or</del></li> <li><del>• PCA</del></li> </ul> <p><del>Management Modules with ERC of SCI hosting High Impact BCS, Medium Impact BCS, or their associated</del></p> <ul style="list-style-type: none"> <li><del>• PACS;</del></li> <li><del>• EACMS; or</del></li> <li><del>• PCA</del></li> </ul>	<p>Identify individuals who have authorized access to shared accounts.</p>	<p>An example of evidence may include, but is not limited to, listing of shared accounts and the individuals who have authorized access to each shared account.</p>

CIP-007-7 Table R5 – System Access Control			
Part	Applicable Systems	Requirements	Measures
5.4	<p>High Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BCS and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><del>SCI identified independently supporting an Applicable System above</del></p> <p><del>SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>• PACS;</del></li> <li><del>• EACMS; or</del></li> <li><del>• PCA</del></li> </ul> <p><del>Management Modules of SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>• PACS;</del></li> <li><del>• EACMS; or</del></li> <li>• PCA</li> </ul>	<p>Change known default passwords, per system capability.</p>	<p>Examples of evidence may include, but are not limited to:</p> <ul style="list-style-type: none"> <li>• Records of a procedure that passwords are changed when new devices are in production; or</li> <li>• Documentation in system manuals or other vendor documents showing default vendor passwords were generated pseudo-randomly and are thereby unique.</li> </ul>

CIP-007-7 Table R5 – System Access Control			
Part	Applicable Systems	Requirements	Measures
5.5	<p>High Impact BES Cyber Systems and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BES Cyber Systems and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><u>SCI identified independently supporting an Applicable System above</u></p> <p><del>SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>• PACS;</del></li> <li><del>• EACMS; or</del></li> <li><del>• PCA</del></li> </ul> <p><del>Management Modules of SCI hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>• PACS;</del></li> <li><del>• EACMS; or</del></li> <li><del>• PCA</del></li> </ul>	<p>For password-only authentication for interactive user access, either technically or procedurally enforce the following password parameters:</p> <p>5.5.1. Password length that is, at least, the lesser of eight characters or the maximum length supported by the <u>Applicable sSystem</u>; and</p> <p>5.5.2 Minimum password complexity that is the lesser of three or more different types of characters (e.g., uppercase alphabetic, lowercase alphabetic, numeric, non-alphanumeric) or the maximum complexity supported by the <u>Applicable sSystem</u>.</p>	<p>Examples of evidence may include, but are not limited to:</p> <ul style="list-style-type: none"> <li>• System-generated reports or screen-shots of the system-enforced password parameters, including length and complexity; or</li> <li>• Attestations that include a reference to the documented procedures that were followed.</li> </ul>

CIP-007-7 Table R5 – System Access Control			
Part	Applicable Systems	Requirements	Measures
5.6	<p>High Impact BES Cyber Systems and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BES Cyber Systems with External Routable Connectivity and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><u>SCI identified independently supporting an Applicable System above</u></p> <p><u>SCI with ERC hosting High Impact BCS, Medium Impact BCS or their associated:</u></p> <ul style="list-style-type: none"> <li>• PACS;</li> <li>• EACMS; or</li> <li>• PCA</li> </ul> <p><u>Management Modules with ERC of SCI hosting High Impact BCS, Medium Impact BCS or their associated:</u></p> <ul style="list-style-type: none"> <li>• PACS;</li> <li>• EACMS; or</li> <li>• PCA</li> </ul>	<p>For password-only authentication for interactive user access, either technically or procedurally enforce password changes or an obligation to change the password at least once every 15 calendar months, per system capability.</p>	<p>Examples of evidence may include, but are not limited to:</p> <ul style="list-style-type: none"> <li>• System-generated reports or screenshots of the system-enforced periodicity of changing passwords; or</li> <li>• Attestations that include a reference to the documented procedures that were followed.</li> </ul>

	•		
--	---	--	--

CIP-007-7 Table R5 – System Access Control			
Part	Applicable Systems	Requirements	Measures
<b>5.7</b>	<p>High Impact BES Cyber Systems and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p>Medium Impact BES Cyber Systems at Control Centers and their associated:</p> <ol style="list-style-type: none"> <li>1. EACMS;</li> <li>2. PACS; and</li> <li>3. PCA</li> </ol> <p><del>SCI identified independently supporting an Applicable System above</del></p> <p><del>SCI at Control Centers with ERC hosting High Impact BCS, Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>• PACS;</del></li> <li><del>• EACMS; or</del></li> <li><del>• PCA</del></li> </ul> <p><del>Management Modules of SCI at Control Centers hosting High or Medium Impact BCS or their associated:</del></p> <ul style="list-style-type: none"> <li><del>• PACS;</del></li> </ul>	<p>Limit the number of unsuccessful authentication attempts or generate alerts after a threshold of unsuccessful authentication attempts, per system capability.</p>	<p>Examples of evidence may include, but are not limited to:</p> <ul style="list-style-type: none"> <li>• Documentation of the account lockout parameters; or</li> <li>• Rules in the alerting configuration showing how the system notified individuals after a determined number of unsuccessful login attempts.</li> </ul>

	<ul style="list-style-type: none"><li>• <del>EACMS; of</del></li><li>• <del>PCA</del></li></ul>		
--	---	--	--

## C. Compliance

### 1. Compliance Monitoring Process:

#### 1.1. Compliance Enforcement Authority:

As defined in the NERC Rules of Procedure, “Compliance Enforcement Authority” (CEA) means NERC or the Regional Entity in their respective roles of monitoring and enforcing compliance with the NERC Reliability Standards.

#### 1.2. Evidence Retention:

The following evidence retention periods identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the CEA may ask an entity to provide other evidence to show that it was compliant for the full time period since the last audit.

The Responsible Entity shall keep data or evidence to show compliance as identified below unless directed by its CEA to retain specific evidence for a longer period of time as part of an investigation:

- Each Responsible Entity shall retain evidence of each requirement in this standard for three calendar years.
- If a Responsible Entity is found non-compliant, it shall keep information related to the non-compliance until mitigation is complete and approved or for the time specified above, whichever is longer.
- The CEA shall keep the last audit records and all requested and submitted subsequent audit records.

#### 1.3. Compliance Monitoring and Enforcement Program

As defined in the NERC Rules of Procedure, “Compliance Monitoring and Enforcement Program” refers to the identification of the processes that will be used to evaluate data or information for the purpose of assessing performance or outcomes with the associated Reliability Standard.

## Violation Severity Levels

R #	Violation Severity Levels (CIP-007-7)			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
R1	N/A	<p>The Responsible Entity has implemented and documented processes for <del>s</del>System <del>h</del>Hardening but had no methods to protect against unnecessary physical input/output ports used for network connectivity, console commands, or Removable Media. (Requirement R1 Part 1.2)</p> <p><u>OR</u></p> <p><u>The Responsible Entity has implemented and documented processes for system hardening, but has not prevented the sharing of the CPU and memory of Management Interfaces of SCI with non-CIP Systems. (Requirement R1 Part 1.4)</u></p>	<p>The Responsible Entity has implemented and documented processes for determining necessary <del>s</del>System <del>H</del>ardening, but had one or more unneeded network accessible services enabled. (Requirement R1 Part 1.1)</p> <p>OR</p> <p>The Responsible Entity has implemented and documented processes for determining necessary <del>S</del>ystem <del>H</del>ardening, but had one or more unneeded services enabled. (Requirement R1 Part 1.3)</p>	<p>The Responsible Entity did not implement or document one or more process(es) that included the applicable items in CIP-007-7 Table R1. (Requirement R1)</p>
R2	The Responsible Entity has documented and implemented one or more process(es) to evaluate uninstalled released	The Responsible Entity has documented or implemented one or more process(es) for patch management but did not include any processes, including the	The Responsible Entity has documented or implemented one or more process(es) for patch management but did not	The Responsible Entity did not implement or document one or more process(es) that included the applicable

R #	Violation Severity Levels (CIP-007-7)			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
	<p>security patches for applicability but did not evaluate the security patches for applicability within 35 calendar days but less than 50 calendar days of the last evaluation for the source or sources identified. (Requirement R2 Part 2.2)</p> <p>OR</p> <p>The Responsible Entity has one or more documented process(es) for evaluating cyber security patches but, in order to mitigate the vulnerabilities exposed by applicable security patches, did not apply the applicable patches, create a dated mitigation plan, or revise an existing mitigation plan within 35 calendar days but less than 50 calendar days of the evaluation</p>	<p>identification of sources, for tracking or evaluating cyber security patches for applicable systems. (Requirement R2 Part 2.1)</p> <p>OR</p> <p>The Responsible Entity has documented and implemented one or more process(es) to evaluate uninstalled released security patches for applicability but did not evaluate the security patches for applicability within 50 calendar days but less than 65 calendar days of the last evaluation for the source or sources identified. (Requirement R2 Part 2.2)</p> <p>OR</p> <p>The Responsible Entity has one or more documented process(es) for evaluating cyber security patches but, in order to mitigate the vulnerabilities exposed by applicable security patches, did not apply the applicable patches, create a dated mitigation plan, or revise an existing mitigation plan within 50</p>	<p>include any processes for installing cyber security patches for applicable systems. (Requirement R2 Part 2.1)</p> <p>OR</p> <p>The Responsible Entity has documented and implemented one or more process(es) to evaluate uninstalled released security patches for applicability but did not evaluate the security patches for applicability within 65 calendar days of the last evaluation for the source or sources identified. (Requirement R2 Part 2.2)</p> <p>OR</p> <p>The Responsible Entity has one or more documented process(es) for evaluating cyber security patches but, in order to mitigate the</p>	<p>items in CIP-007-7 Table R2. (Requirement R2)</p> <p>OR</p> <p>The Responsible Entity has documented or implemented one or more process(es) for patch management but did not include any processes for tracking, evaluating, or installing cyber security patches for applicable systems. (Requirement R2 Part 2.1)</p> <p>OR</p> <p>The Responsible Entity documented a mitigation plan for an applicable cyber security patch and documented a revision or extension to the timeframe but did not obtain approval by the</p>

R #	Violation Severity Levels (CIP-007-7)			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
	completion. (Requirement R2 Part 2.3)	calendar days but less than 65 calendar days of the evaluation completion. (Requirement R2 Part 2.3)	vulnerabilities exposed by applicable security patches, did not apply the applicable patches, create a dated mitigation plan, or revise an existing mitigation plan within 65 calendar days of the evaluation completion. (Requirement R2 Part 2.3)	CIP Senior Manager or delegate. (Requirement R2 Part 2.4)  OR The Responsible Entity documented a mitigation plan for an applicable cyber security patch but did not implement the plan as created or revised within the timeframe specified in the plan. (Requirement R2 Part 2.4)
R3	N/A	The Responsible Entity has implemented one or more documented process(es), but, where signatures or patterns are used, the Responsible Entity did not address testing the signatures or patterns. (Requirement R3 Part 3.3)	The Responsible Entity has implemented one or more documented process(es) for malicious code prevention but did not mitigate the threat of detected malicious code. (Requirement R3 Part 3.2)  OR	The Responsible Entity did not implement or document one or more process(es) that included the applicable items in CIP-007-7 Table R3. (Requirement R3).  OR

R #	Violation Severity Levels (CIP-007-7)			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
			The Responsible Entity has implemented one or more documented process(es) for malicious code prevention, but where signatures or patterns are used, the Responsible Entity did not update malicious code protections. (Requirement R3 Part 3.3).	The Responsible Entity has implemented one or more documented process(es) for malicious code prevention but did not deploy method(s) to deter, detect, or prevent malicious code. (Requirement R3 Part 3.1)
<b>R4</b>	The Responsible Entity has documented and implemented one or more process(es) to identify undetected Cyber Security Incidents by reviewing an entity-determined summarization or sampling of logged events at least every 15 calendar days but missed an interval and completed the review within 22 calendar days of the prior review. (Requirement R4 Part 4.4)	The Responsible Entity has documented and implemented one or more process(es) to identify undetected Cyber Security Incidents by reviewing an entity-determined summarization or sampling of logged events at least every 15 calendar days but missed an interval and completed the review within 30 calendar days of the prior review. (Requirement R4 Part 4.4)	The Responsible Entity has documented and implemented one or more process(es) to generate alerts for necessary security events (as determined by the responsible entity) for the Applicable Systems (per device or system capability) but did not generate alerts for all of the required types of events described in 4.2.1 through 4.2.2. (Requirement R4 Part 4.2)  OR	The Responsible Entity did not implement or document one or more process(es) that included the applicable items in CIP-007-7 Table R4. (Requirement R4)  OR  The Responsible Entity has documented and implemented one or more process(es) to log events for the Applicable Systems (per device or system

R #	Violation Severity Levels (CIP-007-7)			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
			<p>The Responsible Entity has documented and implemented one or more process(es) to log applicable events identified in 4.1 (-except during CIP Exceptional Circumstances) but did not retain applicable event logs for at least the last 90 consecutive days. (Requirement R4 Part 4.3)</p> <p>OR</p> <p>The Responsible Entity has documented and implemented one or more process(es) to identify undetected Cyber Security Incidents by reviewing an entity-determined summarization or sampling of logged events at least every 15 calendar days but missed two or more intervals. (Requirement R4 Part 4.4)</p>	<p>capability) but did not detect and log all of the required types of events described in 4.1.1 through 4.1.3. (Requirement R4 Part 4.1)</p>

R #	Violation Severity Levels (CIP-007-7)			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
<b>R5</b>	<p>The Responsible Entity has implemented one or more documented process(es) for password-only authentication for interactive user access but did not technically or procedurally enforce password changes or an obligation to change the password within 15 calendar months but less than or equal to 16 calendar months of the last password change. (Requirement R5 Part 5.6)</p>	<p>The Responsible Entity has implemented one or more documented process(es) for password-only authentication for interactive user access but did not technically or procedurally enforce password changes or an obligation to change the password within 16 calendar months but less than or equal to 17 calendar months of the last password change. (Requirement R5 Part 5.6)</p>	<p>The Responsible Entity has implemented one or more documented process(es) for System Access Controls but, did not include the identification or inventory of all known enabled default or other generic account types, either by system, by groups of systems, by location, or by system type(s). (Requirement R5 Part 5.2)</p> <p>OR</p> <p>The Responsible Entity has implemented one or more documented process(es) for System Access Controls but, did not include the identification of the individuals with authorized access to shared accounts. (Requirement R5 Part 5.3)</p> <p>OR</p> <p>The Responsible Entity has implemented one or more</p>	<p>The Responsible Entity did not implement or document one or more process(es) that included the applicable items in CIP-007-7 Table R5. (Requirement R5)</p> <p>OR</p> <p>The Responsible Entity has implemented one or more documented process(es) for System Access Controls but, where technically feasible, does not have a method(s) to enforce authentication of interactive user access. (Requirement R5 Part 5.1)</p> <p>OR</p> <p>The Responsible Entity has implemented one or more documented process(es) for System</p>

R #	Violation Severity Levels (CIP-007-7)			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
			<p>documented process(es) for password-only authentication for interactive user access that did not technically or procedurally enforce one of the two password parameters as described in 5.5.1 and 5.5.2. (Requirement R5 Part 5.5)</p> <p>OR</p> <p>The Responsible Entity has implemented one or more documented process(es) for password-only authentication for interactive user access that did not technically or procedurally enforce one of the two password parameters as described in 5.5.1 and 5.5.2. (Requirement R5 Part 5.5)</p> <p>OR</p> <p>The Responsible Entity has implemented one or more</p>	<p>Access Controls but, where technically feasible, does not have a method(s) to enforce authentication of interactive user access. (Requirement R5 Part 5.1)</p> <p>OR</p> <p>The Responsible Entity has implemented one or more documented process(es) for System Access Controls but did not, per device capability, change known default passwords. (Requirement R5 Part 5.4)</p> <p>OR</p> <p>The Responsible Entity has implemented one or more documented process(es) for password-only</p>

R #	Violation Severity Levels (CIP-007-7)			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
			<p>documented process(es) for password-only authentication for interactive user access but did not technically or procedurally enforce password changes or an obligation to change the password within 17 calendar months but less than or equal to 18 calendar months of the last password change. (Requirement R5 Part 5.6)</p>	<p>authentication for interactive user access but the Responsible Entity did not technically or procedurally enforce all of the password parameters described in 5.5.1 and 5.5.2. (Requirement R5 Part 5.5) OR The Responsible Entity has implemented one or more documented process(es) for password-only authentication for interactive user access but did not technically or procedurally enforce password changes or an obligation to change the password within 18 calendar months of the last password change. (5.6)</p>

R #	Violation Severity Levels (CIP-007-7)			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
				OR The Responsible Entity has implemented one or more documented process(es) for System Access Control but, did not either limit the number of unsuccessful authentication attempts or generate alerts after a threshold of unsuccessful authentication attempts. (5.7)

**D. Regional Variances**

None.

**E. Interpretations**

None.

**F. Associated Documents**

- See Project 2016-02 Virtualization Implementation Plan.
- See Technical Rationale for CIP-007-7

## Version History

Version	Date	Action	Change Tracking
1	1/16/06	R3.2 — Change “Control Center” to “control center.”	3/24/06
2	9/30/09	Modifications to clarify the requirements and to bring the compliance elements into conformance with the latest guidelines for developing compliance elements of standards.  Removal of reasonable business judgment.  Replaced the RRO with the RE as a responsible entity.  Reworking of Effective Date.  Changed compliance monitor to Compliance Enforcement Authority.	
3	12/16/09	Updated Version Number from -2 to -3  In Requirement 1.6, deleted the sentence pertaining to removing component or system from service in order to perform testing, in response to FERC order issued September 30, 2009.	
3	12/16/09	Approved by the NERC Board of Trustees.	
3	3/31/10	Approved by FERC.	
4	1/24/11	Approved by the NERC Board of Trustees.	
5	11/26/12	Adopted by the NERC Board of Trustees.	Modified to coordinate with other CIP standards and to revise format to use RBS Template.
5	11/22/13	FERC Order issued approving CIP-007-5.	

Version	Date	Action	Change Tracking
6	11/13/14	Adopted by the NERC Board of Trustees.	Addressed two FERC directives from Order No. 791 related to identify, assess, and correct language and communication networks.
6	2/15/15	Adopted by the NERC Board of Trustees.	Replaces the version adopted by the Board on 11/13/2014. Revised version addresses remaining directives from Order No. 791 related to transient devices and low impact BES Cyber Systems.
6	1/21/16	FERC order issued approving CIP-007-6. Docket No. RM15-14-000	
7	TBD	Virtualization modifications	