



The Summary of the changes to the *PRC-006-SERC-02 Automatic Underfrequency Loading Shedding (UFLS)* include the following:

1. Removal of the requirement (Requirement R1) to allow Planning Coordinators to build a contiguous island, due to entities moving from one Planning Coordinator to another and no longer being contiguous with the existing island;
2. Modification of UFLS settings to account for the existing settings of the Florida peninsula in Requirement R2;
3. Addition of a second method to calculate the percent of load shed based on existing Florida peninsula practices in Requirements R4 and R5;
4. Removal of the SERC UFLS Database requirement, Requirement R7, to remove an unnecessary burden on entities; and
5. Addition of Planning Coordinator as a requestor in Requirement R8 to facilitate post-event analysis of frequency disturbances.