

**ICTE TLR 5 Investigation Report**  
**Flowgate 16272**  
**(Nelson AT1 500/230 kV for the loss of Hartburg 500 kV - Cypress)**  
**TLR Level 5: March 3, 2011**  
**Report Issued:**

**1. Description of purpose/cause of hold/curtailment.**

This report is submitted in accordance with the NERC Transmission Loading Relief Investigation Procedure for the TLR 5 event that occurred on Flowgate 16272 on March 3, 2011. Flowgate 16272 is an Entergy flowgate. The TLR 5 was in effect from 10:38 AM on March 3, 2011 until 12:27 AM on March 4, 2011. Projected post-contingent flows on the Nelson AT1 500/230 kV line for the loss of the Hartburg 500 kV - Cypress line exceeded the SOL.

**2. Facility/flowgate limitations and flows at the time the TLR was initiated.**

At the time the TLR 5b was issued, the Limiting Element was rated at 560 MVA. Flow on the Limiting Element was 424 MVA. Flow on the Contingent Element was 461 MVA. The LODF was approximately 55%. Post-contingent flow on the Limiting Element was approximately 678 MVA.

**3. TLR levels, timing, and relief requested amounts.**

TLRs levels, timing and relief requested amounts are shown on pages 4 through 13.

**4. Transmission and generation outages or changes from prediction that may have contributed.**

- There was an unplanned outage on the Nelson 6 generator on the ICTE system associated with this flowgate.
- There were no abnormal load changes.
- There was 0 mw of non-firm service impacting the flowgate day of since the RC was in a TLR 5 event.

There was a scheduled outage on Inland Orange-McLewis 230kv line that contributed to the increased flow on the flowgate. The flowgate was under control with the scheduled outage until the Nelson 6 generator was forced offline which negatively impacted the flowgate. The TLR 5 was issued to relieve the flow on the constrained facility. Additional generation was placed in start up in the area to replace the Nelson 6 outage. Once generation was online to support the outage the TLR 5 was ended. Entergy continued to support the Inland Orange-McLewis outage with internal generation.

**5. Procedures implemented prior to hold/curtailment.**

There were not enough non-firm transactions available for curtailment to alleviate the flowgate. The system was not re-dispatched to prevent curtailment of firm service. The ICT RC verifies with Entergy's Shift Supervisor before a TLR 5 event is called if there

are any re-dispatch options available. The Entergy Shift Supervisor to-date has not offered any re-dispatch solutions to prevent a TLR 5 event.

**6. The initial investigation shall compare all transaction curtailment lists as generated by the IDC with the list of transactions flowing as determined by the IDC (Whole Transaction Lists) both before and after curtailment. The reasons for any transactions that were excluded from curtailment shall be provided. For those transactions not curtailed, the Reliability Authority will identify those entities and any affiliation with said entities.**

There were no known transactions excluded from curtailment for this TLR.

**7. List of known transactions not in the IDC with Transaction Contribution Factors greater than the curtailment threshold and actions taken to curtail such transactions.**

There were no known transactions not in the IDC.

**8. Excerpts from the RA Operations Log containing information relevant to the TLR event.**

Information was provided to Reliability Coordinators through the IDC and the RCIS. Also the ICTE Reliability Coordinators logged information describing the actions taken at each issuance of the TLR.

**9. Flowgate limitations as identified by security analysis processes conducted by the Reliability Authority for the day prior to the TLR event.**

In the next day process, we did see an issue with this flowgate however it was below 100%, based off of the peak study.

**10. State Estimator snapshots and security analysis, including any contingency analysis or stability analysis, along with any other recorded data indicating need for TLR.**

The ICTE Reliability Coordinator was monitoring their state estimator for potential issues during this time. Screen shots were taken during each issuance of the TLR level 5.

**11. ATC limitations before, during, and after the TLR event.**

ICT Tariff Administration grants transmission service using an AFC process. This process evaluates each transmission request on a case by case basis. There are no ATC values for individual corridors to or from the Entergy system. ICT Tariff Administration was not granting any transmission requests that impacted the congested flowgate by 3 % or greater at the time of the TLR 5.

		Firm AFC available on NELXF_HBCYP (MW)														03/04
AFC Initialization Summary Report		03/03	11	12	13	14	15	16	17	18	19	20	21	22	23	03/04
Timestamp		HB10														HB 0
Prior to Day Ahead	3/1/11 18:43	180	202	212	202	195	192	192	191	189	189	175	185	185	246	293
Day Ahead	3/2/11 11:01	217	231	195	187	182	176	177	183	154	143	193	189	189	204	311
Prior to Day Ahead	3/2/11 18:44															313
Day Ahead	3/3/11 11:00															294

		Sum of impact of firm reservations and rfoal bas flow on NELXF_HBCYP (MW)														03/04
AFC Initialization Summary Report		03/03	11	12	13	14	15	16	17	18	19	20	21	22	23	03/04
Timestamp		HB10														HB 0
Prior to Day Ahead	12/30/10 18:32	380	355	343	355	365	368	368	369	371	371	385	374	374	314	267
Day Ahead	12/31/10 10:44	343	329	365	373	378	384	383	377	408	417	367	371	371	366	249
Prior to Day Ahead	12/31/10 18:30															247
Day Ahead	1/1/11 10:39															266
Difference for Prior to Day Ahead		37	29	-17	-15	-13	-16	-15	-8	-35	-46	18	3	3	-42	18
Difference for Day Ahead																-19

TFC of NELXF\_HBCYP  
560

AFC Initialization Summary Report		Average Firm AFC available on NELXF_HBCYP (MW)
Timestamp		
Prior to Day Ahead	3/1/2011 18:43, 3/2/2011 18:44	209
Day Ahead	3/2/2011 11:01, 3/3/2011 11:00	202
Difference		-7

AFC Initialization Summary Report		Ave. of impact of firm reservations and rfoal bas flow on NELXF_HBCYP (MW)
Timestamp		
Prior to Day Ahead	3/1/2011 18:43, 3/2/2011 18:44	351
Day Ahead	3/2/2011 11:01, 3/3/2011 11:00	358
Difference		7

		AFC available on NELXF_HBCYP (MW)														03/04
AFC Initialization Summary Report		03/03	11	12	13	14	15	16	17	18	19	20	21	22	23	03/04
Timestamp (CST)		HB10														HB 0
Day Ahead	3/3/11 11:00															294
Operating Horizon	3/3/11 11:15		307	-117	-117	-107	-72	-67	-62	-84	-82	-50	-59	27	132	
Operating Horizon	3/3/11 12:39			0	0	0	0	0	-63	-85	-83	-51	-60	27	134	106
Operating Horizon	3/3/11 13:27				0	0	0	0	-59	-81	-79	-47	-56	34	134	127
Operating Horizon	3/3/11 14:30					0	0	0	-61	-83	-82	-50	-58	32	132	124
Operating Horizon	3/3/11 15:55						0	0	169	-7	-2	26	24	72	171	161
Operating Horizon	3/3/11 16:35							0	17	29	-123	-90	-97	-37	43	59
Operating Horizon	3/3/11 17:26								0	0	0	0	0	0	124	157
Operating Horizon	3/3/11 18:51									0	0	0	0	0	117	149
Operating Horizon	3/3/11 19:22										0	0	0	0	51	71
Operating Horizon	3/3/11 20:22											0	0	0	128	148
Operating Horizon	3/3/11 21:22												0	0	264	145
Operating Horizon	3/3/11 22:21													0	97	110
Operating Horizon	3/3/11 23:21														0	0
Operating Horizon	3/4/11 0:20															0

## 12. Description of actions taken to avoid future hold/curtailments.

This TLR was caused by a combination of generation patterns, load, and system flows along with a forced generator outage. Actions taken are Entergy agreed to support the Inland Orange-McLewiss outage with internal generation dispatch.

## 13. Provide IDC generated Congestion Management Reports showing transaction curtailment list and Control Area NNL (network and native load) curtailment responsibility.

Congestion Management Reports for each issuance of the TLR have been reviewed and kept on file. These screen shots are not being provided to reduce the size of this report.

## 14. Re-dispatch actions taken.

Entergy had 2299 MW of NNL.

CLEC had 39 MW of NNL.  
LAGN had 334 MW of NNL.

## Event History

Event History								
Issuing RC: ICTE								
Flowgate: 16272 - Nelson AT1 500/230 (ftlo) Hartburg 500kv - Cypress								
Event Begin: 2011-03-03 11:20								
Event End: 2011-03-08 00:15								
Event Duration: 109 Hours								
TLR Level	TLR Date	TLR Confirm Time	Run Time	Requested Relief	Remaining Relief	Relief Provided	Total Cuts	
							Tags	MW
<a href="#">TLR Level 1</a>	03/03/2011 11:20	03/03/2011 11:09	03/03/2011 11:08:27	0.0	0.0	0.0	0	0
<a href="#">TLR Level 5A</a>	03/03/2011 12:00	03/03/2011 11:41	03/03/2011 11:38:36	46.0	0.0	46.7	14	73
<a href="#">TLR Level 5B</a>	03/03/2011 12:20	03/03/2011 12:05	03/03/2011 12:03:30	150.0	0.0	150.6	18	170
<a href="#">TLR Level 5A</a>	03/03/2011 13:00	03/03/2011 12:38	03/03/2011 12:35:48	166.0	0.0	266.3	18	379
<a href="#">TLR Level 5A</a>	03/03/2011 14:00	03/03/2011 13:29	03/03/2011 13:26:08	139.0	0.0	340.1	30	619
<a href="#">TLR Level 5A</a>	03/03/2011 15:00	03/03/2011 14:30	03/03/2011 14:26:45	108.0	0.0	331.1	28	518
<a href="#">TLR Level 5A</a>	03/03/2011 16:00	03/03/2011 15:28	03/03/2011 15:25:48	131.0	0.0	356.5	30	558
<a href="#">TLR Level 5A</a>	03/03/2011 17:00	03/03/2011 16:29	03/03/2011 16:26:36	66.0	0.0	320.1	29	466
<a href="#">TLR Level 5A</a>	03/03/2011 18:00	03/03/2011 17:37	03/03/2011 17:34:05	72.0	0.0	299.3	31	415
<a href="#">TLR Level 5A</a>	03/03/2011 19:00	03/03/2011 18:28	03/03/2011 18:26:01	81.0	0.0	292.9	33	411
<a href="#">TLR Level 5A</a>	03/03/2011 20:00	03/03/2011 19:33	03/03/2011 19:30:14	102.0	0.0	312.8	33	442
<a href="#">TLR Level 5A</a>	03/03/2011 21:00	03/03/2011 20:28	03/03/2011 20:26:58	113.0	0.0	338.3	32	517
<a href="#">TLR Level 5A</a>	03/03/2011 22:00	03/03/2011 21:33	03/03/2011 21:29:34	98.0	0.0	329.2	28	391
<a href="#">TLR Level 5A</a>	03/03/2011 23:00	03/03/2011 22:28	03/03/2011 22:25:54	25.0	0.0	262.1	23	323
<a href="#">TLR Level 5A</a>	03/04/2011 00:00	03/03/2011 23:29	03/03/2011 23:27:45	0.0	0.0	181.3	21	461
<a href="#">TLR Level 5A</a>	03/04/2011 01:00	03/04/2011 00:33	03/04/2011 00:28:31	76.0	0.0	163.9	21	474
<a href="#">TLR Level 5A</a>	03/04/2011 02:00	03/04/2011 01:28	03/04/2011 01:27:00	54.0	0.0	102.4	4	425
<a href="#">TLR Level 4</a>	03/04/2011 02:40	03/04/2011 02:28	03/04/2011 02:26:36	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 03:35	03/04/2011 03:26	03/04/2011 03:26:00	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 04:40	03/04/2011 04:27	03/04/2011 04:26:54	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 05:40	03/04/2011 05:26	03/04/2011 05:26:38	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 06:35	03/04/2011 06:25	03/04/2011 06:25:29	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 07:40	03/04/2011 07:27	03/04/2011 07:26:30	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 08:40	03/04/2011 08:29	03/04/2011 08:28:59	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 09:40	03/04/2011 09:27	03/04/2011 09:26:30	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 10:35	03/04/2011 10:27	03/04/2011 10:26:04	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 11:40	03/04/2011 11:27	03/04/2011 11:26:40	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 12:40	03/04/2011 12:26	03/04/2011 12:26:10	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 13:40	03/04/2011 13:28	03/04/2011 13:28:19	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 14:40	03/04/2011 14:27	03/04/2011 14:26:23	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 15:40	03/04/2011 15:27	03/04/2011 15:27:14	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 16:35	03/04/2011 16:26	03/04/2011 16:25:57	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 17:40	03/04/2011 17:28	03/04/2011 17:27:38	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 18:35	03/04/2011 18:26	03/04/2011 18:26:11	0.0	0.0	0.0	0	0

<a href="#">TLR Level 4</a>	03/04/2011 19:45	03/04/2011 19:26	03/04/2011 19:26:19	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 20:45	03/04/2011 20:27	03/04/2011 20:27:19	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 21:45	03/04/2011 21:27	03/04/2011 21:26:55	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 22:40	03/04/2011 22:27	03/04/2011 22:26:41	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/04/2011 23:40	03/04/2011 23:26	03/04/2011 23:26:16	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 00:40	03/05/2011 00:27	03/05/2011 00:26:44	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 01:40	03/05/2011 01:27	03/05/2011 01:26:29	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 02:40	03/05/2011 02:27	03/05/2011 02:27:06	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 03:40	03/05/2011 03:27	03/05/2011 03:26:55	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 04:40	03/05/2011 04:27	03/05/2011 04:26:52	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 05:40	03/05/2011 05:27	03/05/2011 05:26:50	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 06:40	03/05/2011 06:26	03/05/2011 06:25:36	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 07:40	03/05/2011 07:26	03/05/2011 07:26:09	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 08:40	03/05/2011 08:28	03/05/2011 08:27:47	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 09:40	03/05/2011 09:28	03/05/2011 09:28:24	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 10:40	03/05/2011 10:27	03/05/2011 10:26:31	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 11:40	03/05/2011 11:26	03/05/2011 11:26:33	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 12:40	03/05/2011 12:26	03/05/2011 12:26:26	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 13:40	03/05/2011 13:26	03/05/2011 13:26:37	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 14:40	03/05/2011 14:28	03/05/2011 14:27:56	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 15:40	03/05/2011 15:29	03/05/2011 15:28:52	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 16:45	03/05/2011 16:33	03/05/2011 16:33:06	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 17:40	03/05/2011 17:27	03/05/2011 17:27:00	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 18:40	03/05/2011 18:28	03/05/2011 18:27:46	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 19:40	03/05/2011 19:26	03/05/2011 19:26:26	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 20:40	03/05/2011 20:26	03/05/2011 20:25:55	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 21:40	03/05/2011 21:27	03/05/2011 21:26:51	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 22:40	03/05/2011 22:26	03/05/2011 22:26:08	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/05/2011 23:40	03/05/2011 23:26	03/05/2011 23:26:23	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 00:40	03/06/2011 00:26	03/06/2011 00:26:13	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 01:40	03/06/2011 01:27	03/06/2011 01:26:31	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 02:40	03/06/2011 02:26	03/06/2011 02:25:46	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 03:40	03/06/2011 03:25	03/06/2011 03:25:33	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 04:40	03/06/2011 04:26	03/06/2011 04:26:18	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 05:40	03/06/2011 05:26	03/06/2011 05:26:19	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 06:40	03/06/2011 06:26	03/06/2011 06:26:12	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 07:40	03/06/2011 07:27	03/06/2011 07:26:26	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 08:40	03/06/2011 08:29	03/06/2011 08:28:12	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 09:45	03/06/2011 09:33	03/06/2011 09:33:08	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 10:35	03/06/2011 10:26	03/06/2011 10:26:09	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 11:35	03/06/2011 11:26	03/06/2011 11:25:34	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 12:55	03/06/2011 12:49	03/06/2011 12:49:05	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 13:40	03/06/2011 13:27	03/06/2011 13:26:37	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 14:40	03/06/2011 14:26	03/06/2011 14:26:23	0.0	0.0	0.0	0	0

<a href="#">TLR Level 4</a>	03/06/2011 15:40	03/06/2011 15:29	03/06/2011 15:28:06	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 16:55	03/06/2011 16:58	03/06/2011 16:57:40	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 17:45	03/06/2011 17:36	03/06/2011 17:36:18	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 18:40	03/06/2011 18:30	03/06/2011 18:30:27	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 19:40	03/06/2011 19:28	03/06/2011 19:28:07	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 20:40	03/06/2011 20:26	03/06/2011 20:26:26	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 21:40	03/06/2011 21:29	03/06/2011 21:28:40	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 22:40	03/06/2011 22:26	03/06/2011 22:26:35	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/06/2011 23:40	03/06/2011 23:26	03/06/2011 23:25:49	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 00:40	03/07/2011 00:27	03/07/2011 00:27:13	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 01:40	03/07/2011 01:26	03/07/2011 01:26:18	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 02:40	03/07/2011 02:26	03/07/2011 02:26:17	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 03:40	03/07/2011 03:25	03/07/2011 03:25:33	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 04:40	03/07/2011 04:28	03/07/2011 04:27:38	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 05:40	03/07/2011 05:27	03/07/2011 05:27:27	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 06:40	03/07/2011 06:26	03/07/2011 06:26:22	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 07:40	03/07/2011 07:31	03/07/2011 07:30:44	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 08:40	03/07/2011 08:28	03/07/2011 08:28:33	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 09:40	03/07/2011 09:28	03/07/2011 09:27:38	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 10:45	03/07/2011 10:31	03/07/2011 10:31:30	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 11:40	03/07/2011 11:27	03/07/2011 11:26:49	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 12:45	03/07/2011 12:32	03/07/2011 12:32:14	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 13:40	03/07/2011 13:27	03/07/2011 13:26:45	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 14:40	03/07/2011 14:28	03/07/2011 14:28:22	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 15:40	03/07/2011 15:26	03/07/2011 15:26:33	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 16:35	03/07/2011 16:25	03/07/2011 16:25:41	0.0	0.0	0.0	1	52
<a href="#">TLR Level 4</a>	03/07/2011 17:40	03/07/2011 17:26	03/07/2011 17:26:36	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 18:40	03/07/2011 18:28	03/07/2011 18:27:59	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 19:45	03/07/2011 19:30	03/07/2011 19:30:05	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 20:40	03/07/2011 20:30	03/07/2011 20:29:12	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 21:40	03/07/2011 21:29	03/07/2011 21:29:08	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 22:35	03/07/2011 22:26	03/07/2011 22:25:55	0.0	0.0	0.0	0	0
<a href="#">TLR Level 4</a>	03/07/2011 23:40	03/07/2011 23:28	03/07/2011 23:27:00	0.0	0.0	0.0	0	0
<a href="#">TLR Level 1</a>	03/08/2011 00:00	03/07/2011 23:41	03/07/2011 23:39:38	0.0	0.0	0.0	0	0
<a href="#">TLR Level 0</a>	03/08/2011 00:15	03/08/2011 00:03	03/08/2011 00:02:32	0.0	0.0	0.0	0	0

## Event Summary

FILE SAVED AS: ICTE\_16272\_20110303\_1020.htm

Incident: ICTE_16272_20110303_1020	Date: 03/03/2011	Reliability Coordinator: ICTE
Initial Conditions: N/A		
Flowgate: 16272 - Nelson AT1 500/230 (ftto) Hart...	Rating: 560	LODF: 56.59%
TLR Direction: Normal		
Effective StartTime: 03/03/2011 11:20	Effective EndTime: 03/08/2011 00:15	TLR Duration: 108 Hours and 55 Minutes

### TLR Actions

Confirm Time	Level	Effective Hour	Priority	Schedule								NHL Relief			Market Relief				Flow			TLR Action Comments
				Total Tags Cut / Hold	IDC Cut MW	Relief	RC Cut Acknowledge MW	Relief	Hold MW	Relief	CA	IDC MW	RC Ackn MW	Type	Mkt	IDC MW	RC Ackn MW	Current	Post Cont.	Cont. Flow		
Mar 03 11:08	TLR 1	CURRENT		NONE								NONE			NONE				340	577	419	N/A
Mar 03 11:41	TLR 5A	NEXT	8-NN 7-F	1 / 0 13 / 0	40 33	4.2 4.0	40 33	4.2 4.0	0 0	0.0 0.0	EES LAGN	12.0 2.0	12.0 2.0	ED-2 ED-5	SWPP SWPP	0.0 16.0	0.0 16.0	424	684	461	N/A	
			<b>Total</b>	<b>14 / 0</b>	<b>73</b>	<b>8.2</b>	<b>73</b>	<b>8.2</b>	<b>0</b>	<b>0.0</b>	<b>Total</b>	<b>14.0</b>	<b>14.0</b>	<b>Total</b>	<b>SWPP</b>	<b>8.8</b>	<b>8.8</b>					
Mar 03 12:05	TLR 5B	CURRENT	7-F	18 / 0	170	10.6	170	10.6	0	0.0	CLEC EES LAGN	2.0 85.0 13.0	2.0 85.0 13.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 43.0 45.9	0.0 43.0 45.9	458	688	408	N/A	
			<b>Total</b>	<b>18 / 0</b>	<b>170</b>	<b>10.6</b>	<b>170</b>	<b>10.6</b>	<b>0</b>	<b>0.0</b>	<b>Total</b>	<b>101.0</b>	<b>101.0</b>	<b>Total</b>	<b>SWPP</b>	<b>89.9</b>	<b>89.9</b>					
		NEXT	1-NS 7-F	0 / 1 17 / 1	0 198	0.0 12.4	0 198	0.0 12.4	100 3	11.5 0.2	NONE			NONE								
			<b>Total</b>	<b>17 / 2</b>	<b>170</b>	<b>12.4</b>	<b>198</b>	<b>12.4</b>	<b>103</b>	<b>11.7</b>												
Mar 03 12:38	TLR 5A	NEXT	1-NS 7-F	0 / 1 18 / 0	0 379	0.0 23.7	0 379	0.0 23.7	100 100	11.8 11.6	CLEC EES LAGN	3.0 171.0 25.0	3.0 171.0 25.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 26.0 16.8	0.0 26.0 16.8	457	677	389	N/A	
			<b>Total</b>	<b>18 / 1</b>	<b>379</b>	<b>23.7</b>	<b>379</b>	<b>23.7</b>	<b>100</b>	<b>11.6</b>	<b>Total</b>	<b>199.0</b>	<b>199.0</b>	<b>Total</b>	<b>SWPP</b>	<b>42.8</b>	<b>42.8</b>					
Mar 03 13:29	TLR 5A	NEXT	1-NS 2-NH 7-F	1 / 0 2 / 0 27 / 1	100 80 438	11.6 8.2 53.3	100 80 438	11.6 8.2 53.3	0 0 0	0.0 0.0 0.0	CLEC EES LAGN	3.0 191.0 28.0	3.0 191.0 28.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 27.0 15.0	0.0 27.0 15.0	407	590	325	N/A	
			<b>Total</b>	<b>30 / 1</b>	<b>619</b>	<b>73.1</b>	<b>619</b>	<b>73.1</b>	<b>250</b>	<b>18.3</b>	<b>Total</b>	<b>222.0</b>	<b>222.0</b>	<b>Total</b>	<b>SWPP</b>	<b>45.0</b>	<b>45.0</b>					
Mar 03 14:30	TLR 5A	NEXT	2-NH 7-F	2 / 0 26 / 2	80 438	8.2 53.3	80 438	8.2 53.3	0 12	0.0 0.9	CLEC EES LAGN	3.0 183.0 28.0	3.0 183.0 28.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 12.0 33.0	0.0 12.0 33.0	414	600	330	N/A	
			<b>Total</b>	<b>28 / 2</b>	<b>518</b>	<b>61.5</b>	<b>518</b>	<b>61.5</b>	<b>12</b>	<b>0.9</b>	<b>Total</b>	<b>224.0</b>	<b>224.0</b>	<b>Total</b>	<b>SWPP</b>	<b>45.0</b>	<b>45.0</b>					
Mar 03 15:28	TLR 5A	NEXT	2-NH 7-F	2 / 0 28 / 0	80 478	8.2 53.5	80 478	8.2 53.5	0 0	0.0 0.0	CLEC EES LAGN	4.0 218.0 31.0	4.0 218.0 31.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 25.0 17.2	0.0 25.0 17.2	421	611	337	N/A	
			<b>Total</b>	<b>30 / 0</b>	<b>558</b>	<b>61.7</b>	<b>558</b>	<b>61.7</b>	<b>0</b>	<b>0.0</b>	<b>Total</b>	<b>253.0</b>	<b>253.0</b>	<b>Total</b>	<b>SWPP</b>	<b>42.2</b>	<b>42.2</b>					
Mar 03 16:29	TLR 5A	NEXT	2-NH 7-F	1 / 0 26 / 0	30 438	3.0 48.8	30 438	3.0 48.8	0 0	0.0 0.0	CLEC EES LAGN	3.0 186.0 27.0	3.0 186.0 27.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 29.3 13.7	0.0 29.3 13.7	338	507	299	N/A	
			<b>Total</b>	<b>29 / 0</b>	<b>466</b>	<b>51.6</b>	<b>466</b>	<b>51.6</b>	<b>0</b>	<b>0.0</b>	<b>Total</b>	<b>225.0</b>	<b>225.0</b>	<b>Total</b>	<b>SWPP</b>	<b>42.7</b>	<b>42.7</b>					
Mar 03 17:37	TLR 5A	NEXT	7-F	31 / 0	415	46.0	415	46.0	0	0.0	CLEC EES LAGN	3.0 182.0 28.0	3.0 182.0 28.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 31.0 11.9	0.0 31.0 11.9	340	554	379	N/A	
			<b>Total</b>	<b>31 / 0</b>	<b>415</b>	<b>46.0</b>	<b>415</b>	<b>46.0</b>	<b>0</b>	<b>0.0</b>	<b>Total</b>	<b>211.0</b>	<b>211.0</b>	<b>Total</b>	<b>SWPP</b>	<b>42.9</b>	<b>42.9</b>					
Mar 03 18:28	TLR 5A	NEXT	7-F	33 / 0	411	45.2	411	45.2	0	0.0	CLEC EES LAGN	3.0 181.0 26.0	3.0 181.0 26.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 32.0 8.1	0.0 32.0 8.1	338	545	371	N/A	
			<b>Total</b>	<b>33 / 0</b>	<b>411</b>	<b>45.2</b>	<b>411</b>	<b>45.2</b>	<b>0</b>	<b>0.0</b>	<b>Total</b>	<b>209.0</b>	<b>209.0</b>	<b>Total</b>	<b>SWPP</b>	<b>38.1</b>	<b>38.1</b>					
Mar 03 19:33	TLR 5A	NEXT	1-NS 7-F	0 / 1 33 / 0	0 442	0.0 48.5	0 442	0.0 48.5	25 0	2.6 2.6	CLEC EES LAGN	3.0 194.0 28.0	3.0 194.0 27.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 23.0 17.1	0.0 23.0 17.1	360	578	368	N/A	
			<b>Total</b>	<b>33 / 1</b>	<b>442</b>	<b>48.5</b>	<b>442</b>	<b>48.5</b>	<b>25</b>	<b>2.6</b>	<b>Total</b>	<b>223.0</b>	<b>224.0</b>	<b>Total</b>	<b>SWPP</b>	<b>40.1</b>	<b>40.1</b>					
Mar 03 20:28	TLR 5A	NEXT	1-NS 2-NH 7-F	1 / 0 1 / 0 30 / 0	50 25 442	5.4 2.2 53.5	50 25 442	5.4 2.2 53.5	0 0 0	0.0 0.0 0.0	CLEC EES LAGN	3.0 199.0 28.0	4.0 199.0 28.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 44.0 3.3	0.0 44.0 3.3	354	567	378	N/A	
			<b>Total</b>	<b>32 / 0</b>	<b>517</b>	<b>61.1</b>	<b>517</b>	<b>61.1</b>	<b>0</b>	<b>0.0</b>	<b>Total</b>	<b>230.0</b>	<b>231.0</b>	<b>Total</b>	<b>SWPP</b>	<b>47.3</b>	<b>47.3</b>					
Mar 03 21:53	TLR 5A	NEXT	7-F	28 / 0	391	46.9	391	46.9	0	0.0	CLEC EES LAGN	3.0 203.0 30.0	3.0 203.0 30.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 34.0 12.0	0.0 34.0 12.0	345	553	369	N/A	
			<b>Total</b>	<b>28 / 0</b>	<b>391</b>	<b>46.9</b>	<b>391</b>	<b>46.9</b>	<b>0</b>	<b>0.0</b>	<b>Total</b>	<b>236.0</b>	<b>236.0</b>	<b>Total</b>	<b>SWPP</b>	<b>46.0</b>	<b>46.0</b>					
Mar 03 22:28	TLR 5A	NEXT	8-NN 7-F	2 / 0 21 / 0	150 173	15.3 20.0	150 173	15.3 20.0	0 0	0.0 0.0	CLEC EES LAGN	3.0 182.0 25.0	3.0 182.0 25.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 24.0 13.4	0.0 24.0 13.4	308	474	298	N/A	
			<b>Total</b>	<b>23 / 0</b>	<b>323</b>	<b>35.3</b>	<b>323</b>	<b>35.3</b>	<b>0</b>	<b>0.0</b>	<b>Total</b>	<b>190.0</b>	<b>190.0</b>	<b>Total</b>	<b>SWPP</b>	<b>37.4</b>	<b>37.4</b>					
Mar 03 23:29	TLR 5A	NEXT	8-NN 7-F	2 / 0 19 / 0	400 81	48.7 6.8	400 81	48.7 6.8	0 0	0.0 0.0	CLEC EES LAGN	1.0 73.0 12.0	1.0 73.0 12.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 29.0 12.0	0.0 29.0 12.0	302	408	188	N/A	
			<b>Total</b>	<b>21 / 0</b>	<b>461</b>	<b>53.5</b>	<b>461</b>	<b>53.5</b>	<b>0</b>	<b>0.0</b>	<b>Total</b>	<b>85.0</b>	<b>85.0</b>	<b>Total</b>	<b>SWPP</b>	<b>41.0</b>	<b>41.0</b>					
Mar 04 00:33	TLR 5A	NEXT	8-NN 7-F	4 / 0 17 / 0	432 42	51.8 4.6	432 42	51.8 4.6	0 0	0.0 0.0	CLEC EES LAGN	1.0 39.0 7.0	1.0 39.0 7.0	ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 44.0 17.2	0.0 44.0 17.2	374	474	178	N/A	
			<b>Total</b>	<b>21 / 0</b>	<b>474</b>	<b>56.4</b>	<b>474</b>	<b>56.4</b>	<b>0</b>	<b>0.0</b>	<b>Total</b>	<b>47.0</b>	<b>47.0</b>	<b>Total</b>	<b>SWPP</b>	<b>61.2</b>	<b>61.2</b>					
Mar 04 01:28	TLR 5A	NEXT	8-NN	4 / 0	425	45.4	425	45.4	0	0.0	NONE			ED-2 ED-5 FIRM-7	SWPP SWPP SWPP	0.0 50.0 7.0	0.0 50.0 7.0	377	495	209	N/A	
			<b>Total</b>	<b>4 / 0</b>	<b>425</b>	<b>45.4</b>	<b>425</b>	<b>45.4</b>	<b>0</b>	<b>0.0</b>				<b>Total</b>	<b>SWPP</b>	<b>57.0</b>	<b>57.0</b>					

Mar 04 02.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 59.0 4.0 <b>63.0</b>	0.0 59.0 4.0 <b>63.0</b>	388	509	218	N/A
		NEXT	8-NN <b>Total</b>	3 / 0 <b>3 / 0</b>	374 <b>374</b>	41.0 <b>41.0</b>	374 <b>374</b>	41.0 <b>41.0</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE						
Mar 04 03.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 49.0 19.0 <b>68.0</b>	0.0 49.0 19.0 <b>68.0</b>	427	574	260	N/A
		NEXT	8-NN <b>Total</b>	3 / 0 <b>3 / 0</b>	374 <b>374</b>	41.0 <b>41.0</b>	374 <b>374</b>	41.0 <b>41.0</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE						
Mar 04 04.27	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 44.0 19.0 <b>63.0</b>	0.0 44.0 19.0 <b>63.0</b>	380	499	212	N/A
		NEXT	8-NN <b>Total</b>	3 / 0 <b>3 / 0</b>	377 <b>377</b>	41.3 <b>41.3</b>	377 <b>377</b>	41.3 <b>41.3</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE						
Mar 04 05.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 35.0 21.0 <b>56.0</b>	0.0 35.0 21.0 <b>56.0</b>	409	553	255	N/A
		NEXT	8-NN <b>Total</b>	2 / 0 <b>2 / 0</b>	142 <b>142</b>	13.2 <b>13.2</b>	142 <b>142</b>	13.2 <b>13.2</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE						
Mar 04 06.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 21.0 25.0 <b>46.0</b>	0.0 21.0 25.0 <b>46.0</b>	448	615	300	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 07.27	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 19.0 <b>31.0</b>	0.0 12.0 19.0 <b>31.0</b>	333	504	303	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 08.29	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 19.0 18.0 <b>37.0</b>	0.0 19.0 18.0 <b>37.0</b>	348	548	358	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 09.27	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 40.0 6.0 <b>46.0</b>	0.0 40.0 6.0 <b>46.0</b>	357	565	365	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 10.27	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 23.0 <b>35.0</b>	0.0 12.0 23.0 <b>35.0</b>	345	551	385	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 11.27	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 27.0 14.0 <b>41.0</b>	0.0 27.0 14.0 <b>41.0</b>	389	590	391	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 12.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 34.0 11.0 <b>45.0</b>	0.0 34.0 11.0 <b>45.0</b>	380	578	383	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 13.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 30.0 18.0 <b>48.0</b>	0.0 30.0 18.0 <b>48.0</b>	350	554	382	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 14.27	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 31.0 16.0 <b>47.0</b>	0.0 31.0 16.0 <b>47.0</b>	353	588	331	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 15.27	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 37.0 12.0 <b>49.0</b>	0.0 37.0 12.0 <b>49.0</b>	341	555	379	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 16.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 27.0 16.0 <b>43.0</b>	0.0 27.0 16.0 <b>43.0</b>	342	560	388	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 17.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 19.0 17.0 <b>35.0</b>	0.0 19.0 17.0 <b>35.0</b>	293	544	445	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 18.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 22.0 <b>34.0</b>	0.0 12.0 22.0 <b>34.0</b>	338	569	397	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 19.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 23.0 <b>35.0</b>	0.0 12.0 23.0 <b>35.0</b>	289	507	388	N/A
		NEXT	NONE							NONE	NONE							
Mar 04 20.27	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 24.0 <b>36.0</b>	0.0 12.0 24.0 <b>36.0</b>	299	529	407	N/A
		NEXT	NONE							NONE	NONE							

Mar 04 21:27	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 28.0 <b>40.0</b>	0.0 12.0 28.0 <b>40.0</b>	279	479	365	N/A
		NEXT	NONE							NONE	NONE	NONE							
Mar 04 22:27	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 24.0 <b>36.0</b>	0.0 12.0 24.0 <b>36.0</b>	305	500	348	N/A
		NEXT	S-NN <b>Total</b>	2 / 0 <b>2 / 0</b>	148 <b>148</b>	10.5 <b>10.5</b>	148 <b>148</b>	10.5 <b>10.5</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							
Mar 04 23:26	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 16.0 <b>28.0</b>	0.0 12.0 16.0 <b>28.0</b>	312	438	224	N/A
		NEXT	S-NN <b>Total</b>	2 / 0 <b>2 / 0</b>	143 <b>143</b>	10.2 <b>10.2</b>	143 <b>143</b>	10.2 <b>10.2</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							
Mar 05 00:27	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 34.0 <b>46.0</b>	0.0 12.0 34.0 <b>46.0</b>	335	488	272	N/A
		NEXT	S-NN <b>Total</b>	2 / 1 <b>2 / 1</b>	100 <b>100</b>	5.3 <b>5.3</b>	100 <b>100</b>	5.3 <b>5.3</b>	50 <b>50</b>	2.9 <b>2.9</b>	NONE	NONE							
Mar 05 01:27	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 33.0 21.0 <b>54.0</b>	0.0 33.0 21.0 <b>54.0</b>	340	507	298	N/A
		NEXT	S-NN <b>Total</b>	3 / 0 <b>3 / 0</b>	150 <b>150</b>	8.1 <b>8.1</b>	150 <b>150</b>	8.1 <b>8.1</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							
Mar 05 02:27	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 60.0 7.0 <b>67.0</b>	0.0 60.0 7.0 <b>67.0</b>	327	482	274	N/A
		NEXT	S-NN <b>Total</b>	3 / 0 <b>3 / 0</b>	150 <b>150</b>	13.0 <b>13.0</b>	150 <b>150</b>	13.0 <b>13.0</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							
Mar 05 03:27	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 67.0 5.0 <b>72.0</b>	0.0 67.0 5.0 <b>72.0</b>	332	491	282	N/A
		NEXT	S-NN <b>Total</b>	2 / 0 <b>2 / 0</b>	100 <b>100</b>	8.8 <b>8.8</b>	100 <b>100</b>	8.8 <b>8.8</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							
Mar 05 04:27	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 42.0 14.0 <b>56.0</b>	0.0 42.0 14.0 <b>56.0</b>	327	474	280	N/A
		NEXT	S-NN <b>Total</b>	2 / 0 <b>2 / 0</b>	100 <b>100</b>	8.8 <b>8.8</b>	100 <b>100</b>	8.8 <b>8.8</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							
Mar 05 05:27	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 43.0 10.0 <b>53.0</b>	0.0 43.0 10.0 <b>53.0</b>	326	469	255	N/A
		NEXT	S-NN <b>Total</b>	3 / 0 <b>3 / 0</b>	150 <b>150</b>	13.1 <b>13.1</b>	150 <b>150</b>	13.1 <b>13.1</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							
Mar 05 06:26	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 42.0 10.0 <b>52.0</b>	0.0 42.0 10.0 <b>52.0</b>	336	491	275	N/A
		NEXT	NONE							NONE	NONE	NONE							
Mar 05 07:26	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 15.0 18.0 <b>33.0</b>	0.0 15.0 18.0 <b>33.0</b>	303	437	238	N/A
		NEXT	NONE							NONE	NONE	NONE							
Mar 05 08:26	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 31.0 11.0 <b>42.0</b>	0.0 31.0 11.0 <b>42.0</b>	315	491	312	N/A
		NEXT	NONE							NONE	NONE	NONE							
Mar 05 09:26	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 31.0 5.0 <b>36.0</b>	0.0 31.0 5.0 <b>36.0</b>	300	496	347	N/A
		NEXT	NONE							NONE	NONE	NONE							
Mar 05 10:27	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 18.0 4.0 <b>22.0</b>	0.0 18.0 4.0 <b>22.0</b>	316	527	374	N/A
		NEXT	NONE							NONE	NONE	NONE							
Mar 05 11:26	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 12.0 <b>24.0</b>	0.0 12.0 12.0 <b>24.0</b>	302	511	370	N/A
		NEXT	NONE							NONE	NONE	NONE							
Mar 05 12:26	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 22.0 <b>34.0</b>	0.0 12.0 22.0 <b>34.0</b>	250	388	241	N/A
		NEXT	NONE							NONE	NONE	NONE							
Mar 05 13:26	TLR 4	CURRENT	NONE							NONE	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 21.0 20.0 <b>41.0</b>	0.0 21.0 20.0 <b>41.0</b>	332	559	419	N/A
		NEXT	NONE							NONE	NONE	NONE							

Mar 05 14.28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 35.0 21.0 <b>56.0</b>	0.0 35.0 21.0 <b>56.0</b>	302	519	385	N/A
		NEXT	NONE								NONE	NONE							
Mar 05 15.29	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 83.0 10.0 <b>73.0</b>	0.0 83.0 10.0 <b>73.0</b>	313	543	408	N/A
		NEXT	NONE								NONE	NONE							
Mar 05 16.33	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 55.0 14.0 <b>69.0</b>	0.0 55.0 14.0 <b>69.0</b>	299	512	378	N/A
		NEXT	NONE								NONE	NONE							
Mar 05 17.27	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 83.0 17.0 <b>70.0</b>	0.0 83.0 17.0 <b>70.0</b>	297	518	392	N/A
		NEXT	NONE								NONE	NONE							
Mar 05 18.28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 58.0 14.0 <b>70.0</b>	0.0 58.0 14.0 <b>70.0</b>	318	548	404	N/A
		NEXT	NONE								NONE	NONE							
Mar 05 19.29	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 81.0 18.0 <b>79.0</b>	0.0 81.0 18.0 <b>79.0</b>	292	468	290	N/A
		NEXT	NONE								NONE	NONE							
Mar 05 20.28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 59.0 7.0 <b>66.0</b>	0.0 59.0 7.0 <b>66.0</b>	380	589	405	N/A
		NEXT	NONE								NONE	NONE							
Mar 05 21.27	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 61.0 15.0 <b>76.0</b>	0.0 61.0 15.0 <b>76.0</b>	315	516	358	N/A
		NEXT	NONE								NONE	NONE							
Mar 05 22.28	TLR 4	CURRENT	8-NN	3 / 0	150	12.6	150	12.6	0	0.0	NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 77.0 9.0 <b>86.0</b>	0.0 77.0 9.0 <b>86.0</b>	324	533	371	N/A
		<b>Total</b>	<b>3 / 0</b>	<b>150</b>	<b>12.6</b>	<b>150</b>	<b>12.6</b>	<b>0</b>	<b>0.0</b>	NONE									
Mar 05 23.28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 82.0 15.0 <b>97.0</b>	0.0 82.0 15.0 <b>97.0</b>	288	514	403	N/A
		NEXT	8-NN	3 / 0	150	12.0	150	12.0	0	0.0	NONE								

Mar 06 01.28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 78.0 22.0 <b>100.0</b>	0.0 78.0 22.0 <b>100.0</b>	288	477	374	N/A
		NEXT	8-NN	2 / 0	100	8.6	100	8.6	0	0.0	NONE								
Mar 06 01.27	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 80.0 18.0 <b>98.0</b>	0.0 80.0 18.0 <b>98.0</b>	319	537	388	N/A
		NEXT	8-NN	2 / 0	100	8.6	100	8.6	0	0.0	NONE								
Mar 06 02.28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 82.0 22.0 <b>104.0</b>	0.0 82.0 22.0 <b>104.0</b>	352	613	462	N/A
		NEXT	8-NN	2 / 0	100	8.6	100	8.6	0	0.0	NONE								
Mar 06 03.28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 108.0 30.0 <b>138.0</b>	0.0 108.0 30.0 <b>138.0</b>	310	523	377	N/A
		NEXT	8-NN	2 / 0	100	8.7	100	8.7	0	0.0	NONE								
Mar 06 04.28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 87.0 43.0 <b>130.0</b>	0.0 87.0 43.0 <b>130.0</b>	299	497	350	N/A
		NEXT	8-NN	2 / 0	100	8.6	100	8.6	0	0.0	NONE								
Mar 06 05.28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 76.0 57.0 <b>133.0</b>	0.0 76.0 57.0 <b>133.0</b>	303	508	384	N/A
		NEXT	8-NN	2 / 0	100	8.5	100	8.5	0	0.0	NONE								
Mar 06 06.28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 88.0 56.0 <b>144.0</b>	0.0 88.0 56.0 <b>144.0</b>	313	518	384	N/A
		NEXT	NONE								NONE	NONE							
Mar 06 07.27	TLR 4	CURRENT	NONE								NONE	ED-2 ED-6 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 84.0 82.0 <b>116.0</b>	0.0 84.0 82.0 <b>116.0</b>	342	578	414	N/A
		NEXT	NONE								NONE	NONE							

Mar 08 08:29	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 68.0 50.0 <b>118.0</b>	0.0 68.0 50.0 <b>118.0</b>	332	573	427	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 09:33	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 84.0 61.0 <b>145.0</b>	0.0 84.0 61.0 <b>145.0</b>	350	538	421	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 10:26	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 73.0 63.0 <b>136.0</b>	0.0 73.0 63.0 <b>136.0</b>	306	478	302	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 11:20	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 75.0 65.0 <b>140.0</b>	0.0 75.0 65.0 <b>140.0</b>	308	469	289	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 12:49	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 70.0 44.0 <b>114.0</b>	0.0 70.0 44.0 <b>114.0</b>	293	433	248	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 13:27	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 84.0 47.0 <b>111.0</b>	0.0 84.0 47.0 <b>111.0</b>	314	487	307	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 14:26	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 58.0 45.0 <b>106.0</b>	0.0 58.0 45.0 <b>106.0</b>	298	448	266	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 15:29	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 72.0 49.0 <b>121.0</b>	0.0 72.0 49.0 <b>121.0</b>	300	427	228	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 16:58	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 72.0 51.0 <b>123.0</b>	0.0 72.0 51.0 <b>123.0</b>	313	443	230	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 17:36	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 82.0 42.0 <b>124.0</b>	0.0 82.0 42.0 <b>124.0</b>	325	458	288	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 18:30	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 38.0 5.0 <b>43.0</b>	0.0 38.0 5.0 <b>43.0</b>	330	503	308	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 19:28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 35.0 1.0 <b>36.0</b>	0.0 35.0 1.0 <b>36.0</b>	323	456	289	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 20:28	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 42.0 0.0 <b>42.0</b>	0.0 42.0 0.0 <b>42.0</b>	372	567	345	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 21:59	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 42.0 0.0 <b>42.0</b>	0.0 42.0 0.0 <b>42.0</b>	382	580	350	N/A
		NEXT	NONE								NONE	NONE							
Mar 08 22:30	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 50.0 13.0 <b>63.0</b>	0.0 50.0 13.0 <b>63.0</b>	359	535	312	N/A
		NEXT	5-NN <b>Total</b>	3 / 0 <b>3 / 0</b>	150 <b>150</b>	14.1 <b>14.1</b>	150 <b>150</b>	14.1 <b>14.1</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							
Mar 08 23:26	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 84.0 43.0 <b>107.0</b>	0.0 84.0 43.0 <b>107.0</b>	266	418	287	N/A
		NEXT	5-NN <b>Total</b>	3 / 0 <b>3 / 0</b>	150 <b>150</b>	14.1 <b>14.1</b>	150 <b>150</b>	14.1 <b>14.1</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							
Mar 07 00:27	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 67.0 66.0 <b>133.0</b>	0.0 67.0 66.0 <b>133.0</b>	286	453	296	N/A
		NEXT	5-NN <b>Total</b>	2 / 0 <b>2 / 0</b>	100 <b>100</b>	10.8 <b>10.8</b>	100 <b>100</b>	10.8 <b>10.8</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							
Mar 07 01:20	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 82.0 64.0 <b>146.0</b>	0.0 82.0 64.0 <b>146.0</b>	356	545	335	N/A
		NEXT	5-NN <b>Total</b>	2 / 0 <b>2 / 0</b>	100 <b>100</b>	9.6 <b>9.6</b>	100 <b>100</b>	9.6 <b>9.6</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							
Mar 07 02:26	TLR 4	CURRENT	NONE								NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 77.0 66.0 <b>143.0</b>	0.0 77.0 66.0 <b>143.0</b>	338	508	301	N/A
		NEXT	5-NN <b>Total</b>	2 / 0 <b>2 / 0</b>	100 <b>100</b>	9.4 <b>9.4</b>	100 <b>100</b>	9.4 <b>9.4</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE							

Mar 07 03.26	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 76.0 73.0 145.0	0.0 76.0 70.0 145.0	324	486	288	N/A	
		NEXT	6-NN Total	2 / 0 2 / 0	100 100	9.6 9.6	100 100	9.6 9.6	0 0	0.0 0.0	NONE								
Mar 07 04.26	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 70.0 73.0 143.0	0.0 70.0 73.0 143.0	334	504	301	N/A	
		NEXT	6-NN Total	2 / 0 2 / 0	100 100	9.6 9.6	100 100	9.6 9.6	0 0	0.0 0.0	NONE								
Mar 07 05.27	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 63.0 73.0 136.0	0.0 63.0 73.0 136.0	345	528	324	N/A	
		NEXT	6-NN Total	2 / 0 2 / 0	100 100	9.7 9.7	100 100	9.7 9.7	0 0	0.0 0.0	NONE								
Mar 07 06.26	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 52.0 77.0 129.0	0.0 52.0 77.0 129.0	340	496	276	N/A	
		NEXT	2-NH 6-NN Total	1 / 0 1 / 0 2 / 0	52 2 54	3.1 0.3 3.3	52 2 54	3.1 0.3 3.3	0 0 0	0.0 0.0 0.0	NONE								
Mar 07 07.31	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 57.0 69.0 126.0	0.0 57.0 69.0 126.0	334	564	407	N/A	
		NEXT	6-NN Total	1 / 0 1 / 0	3 3	0.3 0.3	3 3	0.3 0.3	0 0	0.0 0.0	NONE								
Mar 07 08.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 63.0 66.0 119.0	0.0 63.0 66.0 119.0	335	564	406	N/A	
		NEXT	2-NH 6-NN Total	1 / 0 1 / 0 2 / 0	52 6 57	3.0 0.7 3.7	52 6 57	3.0 0.7 3.7	0 0 0	0.0 0.0 0.0	NONE								
Mar 07 09.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 66.0 40.0 99.0	0.0 66.0 40.0 99.0	324	533	371	N/A	
		NEXT	2-NH 6-NN Total	1 / 0 1 / 0 2 / 0	52 6 58	3.1 0.8 3.9	52 6 58	3.1 0.8 3.9	0 0 0	0.0 0.0 0.0	NONE								
Mar 07 10.31	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 71.0 38.0 109.0	0.0 71.0 38.0 109.0	305	499	343	N/A	
		NEXT	2-NH Total	1 / 0 1 / 0	52 52	3.0 3.0	52 52	3.0 3.0	0 0	0.0 0.0	NONE								
Mar 07 11.27	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 65.0 26.0 91.0	0.0 65.0 26.0 91.0	260	441	321	N/A	
		NEXT	2-NH Total	1 / 0 1 / 0	52 52	3.1 3.1	52 52	3.1 3.1	0 0	0.0 0.0	NONE								
Mar 07 12.32	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 61.0 49.0 100.0	0.0 61.0 49.0 100.0	245	428	325	N/A	
		NEXT	2-NH Total	1 / 0 1 / 0	52 52	3.0 3.0	52 52	3.0 3.0	0 0	0.0 0.0	NONE								
Mar 07 13.27	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 65.0 43.0 108.0	0.0 65.0 43.0 108.0	308	527	391	N/A	
		NEXT	2-NH Total	1 / 0 1 / 0	52 52	3.1 3.1	52 52	3.1 3.1	0 0	0.0 0.0	NONE								
Mar 07 14.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 35.0 0.0 35.0	0.0 35.0 0.0 35.0	289	509	390	N/A	
		NEXT	2-NH Total	1 / 0 1 / 0	52 52	3.7 3.7	52 52	3.7 3.7	0 0	0.0 0.0	NONE								
Mar 07 15.26	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 42.0 9.0 51.0	0.0 42.0 9.0 51.0	296	514	388	N/A	
		NEXT	2-NH Total	1 / 0 1 / 0	52 52	3.7 3.7	0 0	0.0 0.0	0 0	0.0 0.0	NONE								
Mar 07 16.26	TLR 4	CURRENT	2-NH Total	1 / 0 1 / 0	52 104	3.6 3.6	52 52	3.6 3.6	0 0	0.0 0.0	NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 49.0 10.0 59.0	0.0 49.0 10.0 59.0	291	510	388	N/A
		NEXT	2-NH Total	1 / 0 1 / 0	52 104	3.6 3.6	52 52	3.6 3.6	0 0	0.0 0.0	NONE	NONE							
Mar 07 17.26	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 32.0 9.0 41.0	0.0 32.0 9.0 41.0	305	525	389	N/A	
		NEXT	2-NH Total	1 / 0 1 / 0	52 52	3.6 3.6	52 52	3.6 3.6	0 0	0.0 0.0	NONE								
Mar 07 18.28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-6 FIRM-7 Total	SWPP SWPP SWPP	0.0 23.0 17.0 40.0	0.0 23.0 17.0 40.0	283	492	371	N/A	
		NEXT	2-NH Total	1 / 0 1 / 0	52 52	3.4 3.4	52 52	3.4 3.4	0 0	0.0 0.0	NONE								

Mar 07 19:30	TLR 4	CURRENT	NONE							NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 20.0 <b>32.0</b>	0.0 12.0 20.0 <b>32.0</b>	343	600	456	N/A
		NEXT	2-NH <b>Total</b>	1 / 0 <b>1 / 0</b>	52 <b>52</b>	3.6 <b>3.6</b>	52 <b>52</b>	3.6 <b>3.6</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE						
Mar 07 20:30	TLR 4	CURRENT	NONE							NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 20.0 <b>32.0</b>	0.0 12.0 20.0 <b>32.0</b>	304	531	402	N/A
		NEXT	2-NH <b>Total</b>	1 / 0 <b>1 / 0</b>	52 <b>52</b>	3.6 <b>3.6</b>	52 <b>52</b>	3.6 <b>3.6</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE						
Mar 07 21:29	TLR 4	CURRENT	NONE							NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 12.0 18.0 <b>30.0</b>	0.0 12.0 18.0 <b>30.0</b>	328	563	416	N/A
		NEXT	2-NH <b>Total</b>	1 / 0 <b>1 / 0</b>	52 <b>52</b>	3.6 <b>3.6</b>	52 <b>52</b>	3.6 <b>3.6</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE						
Mar 07 22:26	TLR 4	CURRENT	NONE							NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 38.0 12.0 <b>48.0</b>	0.0 38.0 12.0 <b>48.0</b>	307	530	395	N/A
		NEXT	5-NH <b>Total</b>	3 / 0 <b>3 / 0</b>	150 <b>150</b>	14.5 <b>14.5</b>	150 <b>150</b>	14.5 <b>14.5</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE						
Mar 07 23:28	TLR 4	CURRENT	NONE							NONE	ED-2 ED-5 FIRM-7 <b>Total</b>	SWPP SWPP SWPP	0.0 31.0 10.0 <b>41.0</b>	0.0 31.0 10.0 <b>41.0</b>	213	353	248	N/A
		NEXT	5-NH <b>Total</b>	2 / 0 <b>2 / 0</b>	100 <b>100</b>	9.7 <b>9.7</b>	100 <b>100</b>	9.7 <b>9.7</b>	0 <b>0</b>	0.0 <b>0.0</b>	NONE	NONE						
Mar 07 23:41	TLR 1	CURRENT	NONE							NONE	NONE	NONE						
Mar 08 00:03	TLR 0	CURRENT	NONE							NONE	NONE	NONE						

#### TLR Schedule Totals

Priority	Schedule			
	Total Tags Cut / Hold	IDC Cut MW	RC Cut Acknowledge MW	Hold MW
0	0	0	0	0
3	0	0	0	0
6	88	5821	5821	50
7	387	4948	4948	265
1	2	150	150	225
4	0	0	0	0
2	24	1127	1075	0
5	0	0	0	0
<b>Total</b>	<b>501</b>	<b>12046</b>	<b>11994</b>	<b>540</b>

#### TLR>NNL Totals

CA	NNL Relief	
	IDC MW	RC Ackn MW
CLEC	38.0	39.0
EES	2299.0	2299.0
LAGN	333.0	334.0
<b>Total</b>	<b>2670.0</b>	<b>2672.0</b>

#### TLR Market Flow Totals

Market	Type	Market Relief	
		IDC MW	RC Ackn MW
SWPP	ED-2	0.0	0.0
	ED-5	4938.0	4938.0
	FIRM-7	2809.4	2809.4
<b>Total for SWPP</b>		<b>7747.4</b>	<b>7747.4</b>
<b>Total</b>		<b>7747.4</b>	<b>7747.4</b>

Date	Time	Category	Issue
03/03/11	0706	Flow Gate Assessment	Assessed as ICP PC 97%
03/03/11	1008	TLR - 1	Issued TLR 1 on flowgate OASIS Ref#387083
03/03/11	1058	TLR - Redispatch Question	No known redispatch options available. No conditional firm per Kel
		Internal Non-Firm	Informed Kelly, EES, As provided in the email to the Shift Supervis should remain in place until the TLR level is reduced below a TLR
03/03/11	1100	TLR - 5a Initial	Issued TLR 5 on the flowgate. Nelson G6 went offline causing flow
03/03/11	1100	TA Notification	Informed ICT Tariff to zero AFCs for flowgate until 1700
03/03/11	1120	TLR - 5b Initial	Reissued as 5B for additional relief

03/03/11	1135	TLR - 5a Reissue	Reissued as 5A
03/03/11	1145	Internal Non-Firm	none
03/03/11	1226	TLR - 5a Reissue	Reissued as 5A PC 105%
03/03/11	1237	Internal Non-Firm	none
03/03/11	1326	Internal Non-Firm	none
03/03/11	1326	TLR - 5a Reissue	Reissued TLR on flowgate. PC 106%
03/03/11	1425	TLR - 5a Reissue	Reissued TLR PC 108%
03/03/11	1431	Internal Non-Firm	none
03/03/11	1450	IDC	LAGN BA to self-curtail schedules for TLR due to not acknowledging
03/03/11	1530	Internal Non-Firm	none
03/03/11	1535	TLR - 5a Reissue	reissue tlr 5a pc 99% nnl ees=195 clec=3.3 lagn=27.4 another calc
03/03/11	1640	Internal Non-Firm	none
03/03/11	1645	Internal Non-Firm	none
03/03/11	1740	Internal Non-Firm	none
03/03/11	1740	TLR - 5a Reissue	re-issue tlr 5a pc 98% nnl ees=181.3 clec=3.3 lagn=24.9 nelson 3
03/03/11	1830	Internal Non-Firm	None available
03/03/11	1830	TLR - 5a Reissue	re-issue tlr 5a pc 102% nnl ees=194.3 clec=3.4 lagn=26.5 nelson 3
03/03/11	1926	TLR - 5a Reissue	re-issue tlr 5a pc 101% nnl ees=198.5 clec=3.5 lagn=28 nelson 3 c
03/03/11	2029	TLR - 5a Reissue	re-issue tlr 5a pc 98% nnl ees=203.2 clec=3.4 lagn=29.7 nelson 3
03/03/11	2125	TLR - 5a Reissue	re-issue tlr 5a pc 84% nnl ees=161.6 clec=2.6 lagn=25.2 nelson 3
03/03/11	2227	TLR - 5a Reissue	re-issue tlr 5a pc 72% nnl ees=73.4 clec=1.2 lagn=12.3 nelson 3 n
03/03/11	2328	TLR - 5a Reissue	re-issue tlr 5a pc 84% nnl ees=38.9 clec=.7 lagn=6.8 nelson 3 no l
03/04/11	0027	TLR - 5a Reissue	re-issue tlr 5a pc 88% nnl ees=0 clec=0 lagn=0 nelson 3 no longer
03/04/11	0126	TLR - 4 Reissue	Issued TLR4, PC 90%, EES notified, no non-firm internal available that ICT would stay in a TLR4.
03/04/11	0225	TLR - 4 Reissue	Reissued TLR4, PC 102%, EES notified, no non-firm internal available
03/04/11	0326	TLR - 4 Reissue	Reissued TLR4, PC 102%, EES notified, no non-firm internal available
03/04/11	0426	TLR - 4 Reissue	Reissued TLR4, PC 98%, EES notified, no non-firm internal available
03/04/11	0525	TLR - 4 Reissue	Reissued TLR4, PC 109%, EES notified, no non-firm internal available
03/04/11	0630	TLR - 4 Reissue	reissued TLR 4 PC 89%
03/04/11	0700	Internal Non-Firm	none
03/04/11	0728	TLR - 4 Reissue	Reissued TLR PC 97%
03/04/11	0738	Internal Non-Firm	none
03/04/11	0826	TLR - 4 Reissue	Reissued TLR PC 100%
03/04/11	0834	Internal Non-Firm	None
03/04/11	0926	TLR - 4 Reissue	Reissued TLR PC 98%
03/04/11	0930	Internal Non-Firm	None
03/04/11	1026	TLR - 4 Reissue	Reissued TLR PC 104%
03/04/11	1035	Internal Non-Firm	None
03/04/11	1126	TLR - 4 Reissue	Reissued TLR PC 102%
03/04/11	1132	Internal Non-Firm	None
03/04/11	1228	TLR - 4 Reissue	Reissued TLR PC 98%. Continued to zero AFC for flowgate until 1
03/04/11	1235	Internal Non-Firm	None
03/04/11	1331	TLR - 4 Reissue	reissue TLR 4 pc 100%
03/04/11	1340	Internal Non-Firm	none
03/04/11	1427	Internal Non-Firm	none
03/04/11	1427	TLR - 4 Reissue	reissue tlr 4 pc 98%
03/04/11	1532	TLR - 4 Reissue	re-issue tlr 4 pc 98%
03/04/11	1533	Internal Non-Firm	none

03/04/11	1628	Internal Non-Firm	none
03/04/11	1628	TLR - 4 Reissue	reissue tlr 4 pc 96%
03/04/11	1726	Internal Non-Firm	none
03/04/11	1726	TLR - 4 Reissue	reissue tlr 4 PC 99%
03/04/11	1745	TA Notification	Notified ICT TA to Zero out AFC's on FG thru 2400hrs.
03/04/11	1826	TLR - 4 Reissue	Reissue PC90%
03/04/11	1830	Internal Non-Firm	none
03/04/11	1927	TLR - 4 Reissue	Reissue PC93%
03/04/11	1930	Internal Non-Firm	none
03/04/11	2026	TLR - 4 Reissue	Reissue PC85%
03/04/11	2030	Internal Non-Firm	None
03/04/11	2126	TLR - 4 Reissue	Reissue PC88%
03/04/11	2130	Internal Non-Firm	None
03/04/11	2226	TLR - 4 Reissue	Reissue PC78%
03/04/11	2230	Internal Non-Firm	None
03/04/11	2326	TLR - 4 Reissue	Reissue PC86%
03/04/11	2330	Internal Non-Firm	None
03/04/11	2355	TA Notification	AFC's to Zero thru 03/05 0600hrs.
03/05/11	0026	TLR - 4 Reissue	Reissue PC90%
03/05/11	0030	Internal Non-Firm	None
03/05/11	0127	TLR - 4 Reissue	Reissue PC85%
03/05/11	0130	Internal Non-Firm	None
03/05/11	0226	TLR - 4 Reissue	Reissue PC87%
03/05/11	0230	Internal Non-Firm	None
03/05/11	0326	TLR - 4 Reissue	Reissue PC 84%
03/05/11	0330	Internal Non-Firm	None
03/05/11	0426	TLR - 4 Reissue	Reissue PC83%
03/05/11	0430	Internal Non-Firm	None
03/05/11	0525	TLR - 4 Reissue	Reissue PC87%
03/05/11	0530	Internal Non-Firm	None
03/05/11	0630	TLR - 4 Reissue	reissue tlr 4 pc 77%
03/05/11	0631	Internal Non-Firm	none
03/05/11	0728	Internal Non-Firm	none
03/05/11	0728	TLR - 4 Reissue	reissue tlr 4 pc 87%
03/05/11	0828	Internal Non-Firm	none
03/05/11	0828	TLR - 4 Reissue	reissue tlr 4 pc 88%
03/05/11	0927	Internal Non-Firm	none
03/05/11	0927	TLR - 4 Reissue	reissue tlr 4 pc 91%
03/05/11	1026	Internal Non-Firm	none
03/05/11	1026	TLR - 4 Reissue	reissue tlr 4 pc 90%
03/05/11	1126	Internal Non-Firm	none
03/05/11	1126	TLR - 4 Reissue	reissue tlr 4 pc 68%
03/05/11	1226	Internal Non-Firm	none
03/05/11	1226	TLR - 4 Reissue	reissue tlr 4 pc 100% afc's set to 0 for next 6 hours
03/05/11	1328	Internal Non-Firm	none
03/05/11	1328	TLR - 4 Reissue	reissue tlr 4 pc 92%
03/05/11	1428	Internal Non-Firm	none
03/05/11	1429	TLR - 4 Reissue	reissue tlr pc 96%

03/05/11	1533	Internal Non-Firm	none
03/05/11	1533	TLR - 4 Reissue	reissue tlr pc 91%
03/05/11	1627	Internal Non-Firm	none
03/05/11	1629	TLR - 4 Reissue	reissue tlr pc 92%
03/05/11	1727	TLR - 4 Reissue	Reissue Pc 97%
03/05/11	1730	Internal Non-Firm	None
03/05/11	1826	TLR - 4 Reissue	Reissue PC80%
03/05/11	1830	Internal Non-Firm	None
03/05/11	1925	TLR - 4 Reissue	Reissue PC 104%
03/05/11	1930	Internal Non-Firm	None
03/05/11	2026	TLR - 4 Reissue	Reissue PC91%
03/05/11	2030	Internal Non-Firm	None
03/05/11	2126	TLR - 4 Reissue	Reissue PC94%
03/05/11	2130	Internal Non-Firm	None
03/05/11	2226	TLR - 4 Reissue	Reissue PC91%
03/05/11	2230	Internal Non-Firm	None
03/05/11	2326	Internal Non-Firm	None
03/05/11	2326	TLR - 4 Reissue	Reissue PC84%
03/05/11	2330	TA Notification	AFC's zeroed out thru 0600
03/06/11	0026	TLR - 4 Reissue	Reissue PC95%
03/06/11	0030	Internal Non-Firm	None
03/06/11	0125	TLR - 4 Reissue	Reissue PC108%
03/06/11	0130	Internal Non-Firm	None
03/06/11	0225	TLR - 4 Reissue	Reissue PC93%
03/06/11	0326	TLR - 4 Reissue	Reissue PC88%
03/06/11	0330	Internal Non-Firm	None
03/06/11	0426	TLR - 4 Reissue	Reissue PC 90%
03/06/11	0430	Internal Non-Firm	None
03/06/11	0526	TLR - 4 Reissue	Reissue PC92%
03/06/11	0530	Internal Non-Firm	None
03/06/11	0627	Internal Non-Firm	none
03/06/11	0627	TLR - 4 Reissue	Reissue PC102%
03/06/11	0729	Internal Non-Firm	none
03/06/11	0729	TLR - 4 Reissue	Reissue PC102%
03/06/11	0833	Internal Non-Firm	none
03/06/11	0833	Internal Non-Firm	none
03/06/11	0833	TLR - 4 Reissue	Reissue PC104%
03/06/11	0926	TLR - 4 Reissue	Reissue PC85%
03/06/11	1026	Internal Non-Firm	none
03/06/11	1026	TLR - 4 Reissue	Reissue PC83%
03/06/11	1149	Internal Non-Firm	none
03/06/11	1149	TLR - 4 Reissue	Reissue PC77%
03/06/11	1227	Internal Non-Firm	none
03/06/11	1227	TLR - 4 Reissue	Reissue PC87% extended afc's another 6 hours
03/06/11	1326	Internal Non-Firm	none
03/06/11	1326	TLR - 4 Reissue	reissue TLR 4 PC 80%
03/06/11	1429	Internal Non-Firm	none
03/06/11	1429	TLR - 4 Reissue	reissue TLR 4 PC 76%

03/06/11	1555	Internal Non-Firm	none
03/06/11	1555	TLR - 4 Reissue	reissue TLR 4 PC 79%
03/06/11	1636	Internal Non-Firm	none
03/06/11	1636	TLR - 4 Reissue	reissue TLR 4 PC 87%
03/06/11	1730	Internal Non-Firm	none
03/06/11	1730	TLR - 4 Reissue	re-issued TLR 4 pc 89%
03/06/11	1828	TLR - 4 Reissue	Reissue PC86%
03/06/11	1830	Internal Non-Firm	none
03/06/11	1926	TLR - 4 Reissue	Reissue PC 100%
03/06/11	1930	Internal Non-Firm	none
03/06/11	2028	TLR - 4 Reissue	Reissue PC104%
03/06/11	2030	Internal Non-Firm	none
03/06/11	2126	TLR - 4 Reissue	Reissue PC96%
03/06/11	2130	Internal Non-Firm	none
03/06/11	2212	TA Notification	none
03/06/11	2225	TLR - 4 Reissue	Reissue PC75%
03/06/11	2230	Internal Non-Firm	none
03/06/11	2327	TLR - 4 Reissue	Reissue PC81%
03/06/11	2327	Internal Non-Firm	none
03/07/11	0005	TA Notification	Called ICT TA (Derek) to Zero out AFC's on FG thru 0600hrs
03/07/11	0026	TLR - 4 Reissue	Reissue PC98%
03/07/11	0030	Internal Non-Firm	none
03/07/11	0126	TLR - 4 Reissue	Reissue PC91%
03/07/11	0130	Internal Non-Firm	none
03/07/11	0225	TLR - 4 Reissue	Reissue PC 87%
03/07/11	0227	Internal Non-Firm	none
03/07/11	0327	TLR - 4 Reissue	Reissue PC91%
03/07/11	0330	Internal Non-Firm	none
03/07/11	0427	TLR - 4 Reissue	Reissue PC95%
03/07/11	0430	Internal Non-Firm	none
03/07/11	0526	TLR - 4 Reissue	Reissue PC89%
03/07/11	0530	Internal Non-Firm	none
03/07/11	0630	TLR - 4 Reissue	Reissue PC 102%, AFCs extended to 12:00, no internal non-firm
03/07/11	0728	TLR - 4 Reissue	Reissue PC 102%, AFCs extended to 12:00. "As provided in the email 53340. These curtailments should remain in place until the TLR level is reduced below a TLR 3."
03/07/11	0728	Internal Non-Firm	As provided in the email to the Shift Supervisor, the ICT RC has is until the TLR level is reduced below a TLR 3."
03/07/11	0827	TLR - 4 Reissue	Reissue PC 97%, AFCs extended to 12:00, no internal non-firm
03/07/11	0931	TLR - 4 Reissue	Reissue PC 90%, AFCs extended to 12:00, no internal non-firm
03/07/11	1026	TLR - 4 Reissue	Reissue PC 80%, AFCs extended to 12:00, no internal non-firm
03/07/11	1132	TLR - 4 Reissue	Reissue PC 78%, AFCs extended to 12:00, no internal non-firm
03/07/11	1226	TLR - 4 Reissue	Reissue PC 96%, AFCs extended to 18:00, no internal non-firm
03/07/11	1328	TLR - 4 Reissue	Reissue PC 92%, AFCs extended to 18:00, no internal non-firm
03/07/11	1426	TLR - 4 Reissue	Reissue PC 93%, AFCs extended to 18:00, no internal non-firm
03/07/11	1525	TLR - 4 Reissue	Reissue PC 93%, AFCs extended to 18:00, no internal non-firm
03/07/11	1626	TLR - 4 Reissue	Reissue PC 95%, AFCs extended to 18:00, no internal non-firm
03/07/11	1727	TLR - 4 Reissue	Reissue PC 89%, AFCs extended to 24:00, no internal non-firm
03/07/11	1830	TLR - 4 Reissue	Re-issue PC 110%, no internal non-firm
03/07/11	1830	Internal Non-Firm	none

03/07/11	1929	TLR - 4 Reissue	Re-issue PC 96%, no internal non-firm
03/07/11	1929	Internal Non-Firm	none
03/07/11	2029	TLR - 4 Reissue	Re-issue PC 103%, no internal non-firm
03/07/11	2029	Internal Non-Firm	none
03/07/11	2125	TLR - 4 Reissue	Re-issue PC 97%, no internal non-firm
03/07/11	2126	Internal Non-Firm	none
03/07/11	2228	TLR - 4 Reissue	Re-issue PC 64%, no internal non-firm
03/07/11	2229	Internal Non-Firm	none
03/07/11	2241	TLR - 1	Issued TLR 1 PC 64%, Updated REF # 387083
03/07/11	2241	LAP - 3	Ryan called to post LAP REF#389973
03/07/11	2241	TA Notification	Called Bill ICT Tariff to restore AFC effective 23:00
03/07/11	2303	TLR - 0	Issued TLR 0 PC 92%, Updated REF # 387083