

NERC Control Performance Honor Roll

Control Areas That Achieved 95% or Greater A1 and A2
Compliance for 12 Months Ending: January 1998

Control Performance Surveys measure how well each control area matches its actual to its scheduled interchange. The closer the match, the greater the control area's contribution to Interconnection reliability.

Note that some Control Areas are not shown because they are measuring compliance to the new CPS 1 and 2 standards.*

Region	% Compliance
FRCC	
Reedy Creek	100.0
Gainesville Regional Utilities	97.9
City of Homestead	97.7
City of Key West	97.4
City of Lake Worth	96.1
Seminole Electric Cooperative	95.9
FRCC areas on list:	6 of 16
MAPP	
Muscataine Power & Water	99.1
MAPP areas on list:	1 of 16
SERC	
South Mississippi Electric Power	98.4
Duke Power Company	96.3
SERC areas on list:	2 of 14
SPP	
Grand River Dam Authority	95.6
SPP areas on list:	1 of 21
WSCC-AZNM	
Salt River Project	98.7
Public Service of New Mexico	96.6
WSCC-AZNM areas on list:	2 of 7
WSCC-CANV	
City of Pasadena	96.8
WSCC-CANV areas on list:	1 of 7
WSCC-NWPP	
British Columbia Hydro & Power	99.3
Tacoma City Light	98.5
Portland General Electric Company	98.0
Seattle City Light	98.0
Washington Water Power Company	97.2
Idaho Power Company	96.6
Montana Power Company	95.0
WSCC-NWPP areas on list:	7 of 16
WSCC-RMPP	
WAPA - Colorado Missouri	98.1
WSCC-RMPP areas on list:	1 of 3