

Dear John,

Following are GLPL - Transmission responses to the specific questions posed.

***1. If you are a Transmission Owner, do you currently collect transmission outage data similar to TADS? If “yes,” please explain.***

YES, as part of normal internal business processes, GLPL collects data for all transmission forced outages.

***2. Is the data being requested reasonable and obtainable? See Section 3 of the Report. If “no,” please explain.***

YES, the data is reasonable and obtainable. All transmission lines length are in metric that is in kilometers.

***3. Are the metrics appropriate? See Section 4.b and Appendix 4 of the Report. If “no,” please explain.***

YES.

***4. Is the data reporting process reasonable? See Section 5.2 of the Report. If “no,” please explain.***

YES. The reporting process is reasonable.

***5. Is the implementation schedule for Phase I TADS for 2008 reasonable? See Section 5.3.1 of the Report. If “no,” please explain.***

YES.

***6. Are there ambiguities in the Manual that need clarification? If “yes,” please explain.***

The task force should further elaborate the cause code 12 ( Human Error ). Use this code for those outages caused by the company employees unintentional or accidental.

The task force should create new code 15 ( Foreign Interference ). Use this code for Forced Outages caused by the action of Non-company personnel or public or animals.

Alex Lee P.Eng  
Manager - Transmission Engineering .  
Great Lakes Power  
Brookfield Power Corporation  
2 Sackville Road  
Sault Ste. Marie, Ontario, P6B 6J6  
Phone: 705-256-3841  
Cell: 705-971-0613  
Fax: 705-759 2218