
PRC-006-FRCC-01 - *FRCC Automatic Underfrequency Load Shedding Program*

- Contents:**
- A. Prerequisite Approvals
 - B. Revision to Sections of Approved Standards
 - C. Compliance with Standard
 - D. Other Considerations

A. Prerequisite Approvals: None

B. Revision to Sections of Approved Standards: None

C. Compliance with Standard:

1. Compliance to this standard applies to:

a.) Load Serving Entity (LSE) within the FRCC Region

(LSE with prior actual summer peak demand (integrated hourly) > 25 MW and responsible for facilities that are part of the required underfrequency load shedding (UFLS) program designed, installed, and operated for the protection of the Bulk Electric System.)

b.) Distribution Provider (DP) within the FRCC Region

(DP with prior actual summer peak demand (integrated hourly) > 25 MW and owns, controls, or operates relays that are part of the required underfrequency load shedding (UFLS) program designed, installed, and operated for the protection of the Bulk Electric System.)

c.) The LSE or DP may meet these requirements through participation in an aggregated UFLS Program.

2. The effective date of this standard is: One (1) calendar year after FERC approval.

D. Other Considerations: None