

Mapping Document for COM-002-3

Revisions or Retirements to Already Approved Standards

The following tables identify the sections of the approved standard that shall be retired or revised when this standard is implemented. If the drafting team is recommending the retirement or revision of a requirement, that text is blue.

Already Approved Standard	Proposed Replacement Requirement(s)
<p>COM-002-2</p> <p>R1. Each Transmission Operator, Balancing Authority, and Generator Operator shall have communications (voice and data links) with appropriate Reliability Coordinators, Balancing Authorities, and Transmission Operators. Such communications shall be staffed and available for addressing a real-time emergency condition. <i>[Violation Risk Factor: High]</i></p> <p>R1.1 Each Balancing Authority and Transmission Operator shall notify its Reliability Coordinator, and all other potentially affected Balancing Authorities and Transmission Operators through predetermined communication paths of any condition that could threaten the reliability of its area or when firm load shedding is anticipated. <i>[Violation Risk Factor: High]</i></p>	<p>The RC SDT proposes retiring COM-002-1, R1 and R1.1.</p> <p><u>The communications requirements of R1 are addressed in existing COM-001-1.1 as well as the proposed COM-001-2 requirements. Additionally, IRO-010-1a addresses data provisions.</u></p> <p>The RC SDT contends that COM-002-1, R1 <u>R1.1 and its subrequirements are is</u> a low level facilitating requirements that <u>isafe</u> more appropriately and inherently monitored under various higher level performance-based reliability requirements for each entity throughout the body of standards. Examples include:</p> <p>IRO-001-1, R3 requires adequate telecommunication for the Reliability Coordinator to direct actions of multiple entities, including TOPs and BAs.</p> <p>TOP-005-1, R1 and R3 require adequate telecommunications for BAs and TOPs to provide each other with operating data as well as providing data to the RC.</p> <p>TOP-001-1, R3 requires adequate telecommunications facilities for the TOP, BA, and GOP to be able to receive directives from the RC.</p> <p>TOP-006-1, R1 requires adequate telecommunications for the GOP to inform the BA and TOP of resources. The BA and TOP will then inform the RC, other TOP and BAs of all transmission and generation available for use.</p> <p>PER-001-1, R1 and PER-004-1, R1 set forth the staffing requirements.</p> <p>TOP-001-1, R5 requires communications between TOPs and RCs for emergency situations.</p> <p>EOP-002-1, R3 – outlines BA to RC communications.</p>

Notes: Based on the above information, the RCS DT recommends retiring R1 and R1.1.

Already Approved Standard	Proposed Replacement Requirement(s)
<p>COM-002-2</p> <p>R2. Each Reliability Coordinator, Transmission Operator, and Balancing Authority shall issue directives in a clear, concise, and definitive manner; shall ensure the recipient of the directive repeats the information back correctly; and shall acknowledge the response as correct or repeat the original statement to resolve any misunderstandings. <i>[Violation Risk Factor: Medium]</i></p>	<p>COM-002-3</p> <p>R1. When a Reliability Coordinator, Transmission Operator or Balancing Authority requires actions to be executed as a Reliability Directive, the Reliability Coordinator, Transmission Operator or Balancing Authority shall identify the action as a Reliability Directive to the recipient. <i>[Violation Risk Factor: High][Time Horizon: Real-Time]</i></p> <p>R2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, Transmission Service Provider, Load-Serving Entity, and Distribution Provider, and Purchasing-Selling Entity that is the recipient of a Reliability Directive issued per Requirement R1, shall repeat, restate, rephrase or recapitulate the Reliability Directive, with enough details that the accuracy of the message has been confirmed <i>[Violation Risk Factor: High][Time Horizon: Real-Time]</i></p> <p>R3. Each Reliability Coordinator, Transmission Operator, and Balancing Authority that issues a Reliability Directive shall <u>either</u> <i>[Violation Risk Factor: High][Time Horizon: Real-Time]</i>:</p> <ul style="list-style-type: none"> • <u>Confirm state or respond</u> that the response from the recipient of the Reliability Directive <u>(in accordance with per Requirement R2 as correct,</u> or • R <u>re</u>issue the Reliability Directive to resolve any misunderstandings. <i>[Violation Risk Factor: High][Time Horizon: Real-Time]</i>
<p>Notes: The RC SDT expanded the list of responsible entities to include the DP, GOP, TSP, LSE and PSE and subdivided the requirement for improved clarity.</p>	

Functions that Must Comply with the Requirements in the Standard

Standard	Functions that Must Comply With the Requirements							
	Reliability Coordinator	Balancing Authority	Purchasing Selling Entity	Transmission Operator	Transmission Service Provider	Distribution Provider	Generator Operator	Load Serving Entity
COM-002-3	X	X	✗	X	✗	X	X	✗

Effective Dates

~~The first day of the first calendar quarter following applicable regulatory approval—or in those jurisdictions where no regulatory approval is required, the first day of the first calendar quarter following Board of Trustees adoption.~~