

Interpretation of CIP-006-1 — Physical Security of Critical Cyber Assets

Request for Interpretation received from South Carolina Electric & Gas on August 9, 2007:

Are dial-up RTUs that use non-routable protocols and have dial-up access required to have a six-wall perimeters or are they exempted from CIP-006-1 and required to have only electronic security perimeters? This has a direct impact on how any identified RTUs will be physically secured.

Interpretation provided by a subgroup of CIP Standard Drafting Team members on September 7, 2007:

Dial-up assets are Critical Cyber Assets, assuming they meet the criteria in CIP-002-1, and they must reside within an Electronic Security Perimeter. However, physical security control over a critical cyber asset is not required if that asset does not have a routable protocol. Since there is minimal risk of compromising other critical cyber assets dial-up devices such as Remote Terminals Units that do not use routable protocols are not required to be enclosed within a “six-wall” border.

CIP-006-1 — Requirement 1.1 requires a Responsible Entity to have a physical security plan that stipulate cyber assets that are within the Electronic Security Perimeter also be within a Physical Security Perimeter.

R1. Physical Security Plan — The Responsible Entity shall create and maintain a physical security plan, approved by a senior manager or delegate(s) that shall address, at a minimum, the following:

R1.1. Processes to ensure and document that all Cyber Assets within an Electronic Security Perimeter also reside within an identified Physical Security Perimeter. Where a completely enclosed (“six-wall”) border cannot be established, the Responsible Entity shall deploy and document alternative measures to control physical access to the Critical Cyber Assets.

CIP-006-1 – Additional Compliance Information 1.4.4 identifies dial-up accessible assets that use non-routable protocols as a special class of cyber assets that are not subject to the Physical Security Perimeter requirement of this standard.

1.4. Additional Compliance Information

1.4.4 For dial-up accessible Critical Cyber Assets that use non-routable protocols, the Responsible Entity shall not be required to comply with Standard CIP-006 for that single access point at the dial-up device.