



NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

Standards Announcement

Ballot Pool and Pre-ballot Window

November 19, 2009–January 5, 2010

Now available at: <https://standards.nerc.net/BallotPool.aspx>

Project 2009-24: Interpretation of EOP-005-1 for the Florida Municipal Power Agency

An interpretation of standard EOP-005-1 — System Restoration Plans, Requirement R7, for the Florida Municipal Power Agency is posted for a 30-day pre-ballot review. This pre-ballot review will run longer than usual so that voting will not begin during the last two weeks of December, when many members are out of the office. Registered Ballot Body members may join the ballot pool to be eligible to vote on this interpretation **until 8 a.m. EST on January 5, 2010**.

During the pre-ballot window, members of the ballot pool may communicate with one another by using their “ballot pool list server.” (Once the balloting begins, ballot pool members are prohibited from using the ballot pool list servers.) The list server for this ballot pool is: [bp-2009-24_RFI_FMPA_in](#).

Next Steps

Voting will begin shortly after the pre-ballot review closes.

Project Background

The Florida Municipal Power Agency requested clarification on Requirement R7 regarding the terminology of “verify the restoration procedure” and “simulation” and clarification for whether a Transmission Operator without blackstart facilities in its restoration plan could use exercises and tabletop drills to meet the requirement.

The request and interpretation can be found on the project page:

http://www.nerc.com/filez/standards/Project2009-24_EOP-005-1_R7%20_RFI_FMPA.html

Standards Development Process

The [Reliability Standards Development Procedure](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance,
please contact Shaun Streeter at shaun.streeter@nerc.net or at 609.452.8060.*