



# **Compliance Audit Report Public Version**

**Nevada Cogeneration Company #1  
(NVI)  
NCR10044  
July 14, 2008**

**Confidential Information (including Privileged  
and Critical Energy Infrastructure Information)  
Has Been Removed**

**Final – November 12, 2008**

## Audit Overview

The WECC Compliance Department conducted an off-site compliance audit of the Nevada Cogeneration Company #1 (NVI) on July 14, 2008. The off-site audit was conducted at the WECC Compliance Department offices at 615 Arapeen Drive, Suite 210, Salt Lake City, Utah.

NVI personnel were notified at the start of the off-site audit and kept informed as the audit progressed. NVI had personnel available via the telephone during the audit and at the closing presentation.

At the time of the off-site audit, NVI was registered for the following functions: Generator Owner (GO) and Generator Operator (GOP).

The following functions were audited: Generator Owner (GO) and Generator Operator (GOP).

The NVI Internal Compliance Program (ICP) was not reviewed during this audit.

The audit team used the Reliability Standard Audit Worksheets (RSAWs) during the compliance review of each reliability standard. The evidence provided was reviewed for the period June 18, 2007 through the off-site audit date of July 14, 2008. The June 18, 2007 date is when FERC made compliance to eighty-three (83) of the NERC Reliability Standards mandatory and enforceable in the United States. No violations were identified by the audit team during this audit.

### ***Confidentiality and Conflict of Interest***

Confidentiality agreements, executed by the WECC independent contractors (consultants) and code of conduct documentation for the NERC representative and WECC compliance staff, were available to NVI in advance of the off-site audit, if requested. Work history and conflict of interest forms submitted by each audit team member were also provided. NVI was given an opportunity to object to an audit team member on the basis of a possible conflict of interest or the existence of other circumstances that could interfere with that audit team member's impartial performance of duties. NVI accepted the audit team member participants with no objections.

### ***Off-site Audit***

Off-site audits of Generator Operator (GOP) and Generator Owner (GO) are conducted on a six-year cycle. If a Registered Entity is registered for other functions (such as PA, TP, RP, etc.), it had the option of having these other functions audited during the off-site audit.

NVI was officially notified of the off-site audit with a 60-day Notice of Compliance Audit letter. Accompanying this notification were attachments relating to the audit as listed below:

- Pre-audit introduction letter
- Audit team bios
- Pre-audit questionnaire
- Audit documentation matrix
- WECC 2008 Auditing, Monitoring and Reporting Requirements for NERC Standards

NVI was notified in the Pre-Audit letter that personnel (subject matter experts representing all the registered functions) would need to be available to answer questions (interviews) the audit team might have regarding the documentation.

NVI was also informed that the off-site compliance audit would be conducted consistent with the following WECC Regional and NERC documents:

- WECC Compliance Monitoring and Enforcement Program
- NERC Reliability Standard Audit Worksheets

NVI was asked to submit the completed questionnaire, the audit documentation matrix and other requested documents back to the WECC Compliance Department.

A pre-audit conference call was held by WECC compliance staff with all the Registered Entities scheduled for an off-site audit.

Professional judgment was used by the audit team during the off-site audit. The audit team leader may have requested interviews with employees representing subject matter expertise regarding the registered functions being audited. These interviews in conjunction with the evidence, gave the audit team a factual basis for determining compliance with the NERC reliability standards.

Reference - Generally accepted government auditing standard 3.31 - Auditors must use professional judgment in planning and performing audits and attestation engagements and in reporting the results.

Reference - Generally accepted government auditing standard 3.39 - While this standard places responsibility on each auditor and audit organization to exercise professional judgment in planning and performing an audit or attestation engagement, it does not imply unlimited responsibility, nor does it imply infallibility on the part of either the individual auditor or the audit organization. Absolute assurance is not attainable because of the nature of evidence and the characteristics of fraud. Professional judgment does not mean eliminating all possible limitations or weaknesses associated with a specific audit, but rather identifying, considering, minimizing, mitigating, and explaining them.

### ***Methodology***

Methodology: the auditing of reliability standards and best practices to be followed by compliance auditors in carrying out their work. The methodology is objective, measurable, complete and relevant to the audit objectives. The auditors identify potential sources of audit evidence and consider the amount and type of evidence needed given the risk and significance when defining the audit methodology.

***Audit Specifics***

**Audit Team**

<b>Audit Team Role</b>	<b>Title</b>	<b>Company</b>
Lead	Senior Compliance Engineer	WECC
Member	Senior Compliance Engineer	WECC
Observer	Regional Compliance Program Coordinator	NERC

**Registered Entity Audit Participants (Attending/Interviewed/Listening)**

<b>Title</b>	<b>Audited Organization</b>
Plant Manager NCA #1	NVI
Operations & Maintenance Supervisor NCA #1	NVI
Executive Director NCA #1 & NCA #2	NVI
Operations Engineer NCA#1 & NCA #2	NVI
Operations and Maintenance Supervisor NCA #2	NVI

***Findings***

The preliminary findings of the audit team at the off-site audit were presented to NV1 at the closing presentation. These findings are indicated in Table A below. The “Finding” column contains one of the following: Compliant, Possible Violation (PV), New Possible Violation (NPV), Not Applicable (NA), Not Audited, Outstanding Alleged Violation (OV), Retraction requested (Retract), Self-reported Violation (Self-Report), or other appropriate description.

***Table A***

<b>Reliability Standard</b>	<b>Requirement</b>	<b>Finding</b>
BAL-005-0	R1.	Compliant
BAL-005-0	R2.	Not Applicable
BAL-005-0	R3.	Not Applicable
BAL-005-0	R4.	Not Applicable
BAL-005-0	R5.	Not Applicable
BAL-005-0	R6.	Not Applicable

Confidential Information (including Privileged and  
Critical Energy Infrastructure Information) Has Been Removed

<b>Reliability Standard</b>	<b>Requirement</b>	<b>Finding</b>
BAL-005-0	R7.	Not Applicable
BAL-005-0	R8.	Not Applicable
BAL-005-0	R9.	Not Applicable
BAL-005-0	R10.	Not Applicable
BAL-005-0	R11.	Not Applicable
BAL-005-0	R12.	Not Applicable
BAL-005-0	R13.	Not Applicable
BAL-005-0	R14.	Not Applicable
BAL-005-0	R15.	Not Applicable
BAL-005-0	R16.	Not Applicable
BAL-005-0	R17.	Not Applicable
CIP-001-1	R1.	Compliant
CIP-001-1	R2.	Compliant
CIP-001-1	R3.	Compliant
CIP-001-1	R4.	Compliant
COM-002-2	R1.	Compliant
COM-002-2	R2.	Not Applicable
EOP-004-1	R1.	Not Applicable
EOP-004-1	R2.	Compliant
EOP-004-1	R3.	Compliant
EOP-004-1	R4.	Not Applicable
EOP-004-1	R5.	Not Applicable
EOP-009-0	R1.	Not Applicable
EOP-009-0	R2.	Not Applicable
FAC-008-1	R1.	Compliant
FAC-008-1	R2.	Compliant
FAC-008-1	R3.	Compliant
FAC-009-1	R1.	Compliant
FAC-009-1	R2.	Compliant
IRO-001-1	R1.	Not Applicable
IRO-001-1	R2.	Not Applicable
IRO-001-1	R3.	Compliant
IRO-001-1	R4.	Not Applicable
IRO-001-1	R5.	Not Applicable
IRO-001-1	R6.	Not Applicable
IRO-001-1	R7.	Not Applicable
IRO-001-1	R8.	Compliant
IRO-001-1	R9.	Not Applicable
IRO-004-1	R1.	Not Applicable
IRO-004-1	R2.	Not Applicable
IRO-004-1	R3.	Not Applicable
IRO-004-1	R4.	Compliant

Confidential Information (including Privileged and  
Critical Energy Infrastructure Information) Has Been Removed

<b>Reliability Standard</b>	<b>Requirement</b>	<b>Finding</b>
IRO-004-1	R5.	Not Applicable
IRO-004-1	R6.	Not Applicable
IRO-004-1	R7.	Not Applicable
IRO-005-1	R1.	Not Applicable
IRO-005-1	R2.	Not Applicable
IRO-005-1	R3.	Not Applicable
IRO-005-1	R4.	Not Applicable
IRO-005-1	R5.	Not Applicable
IRO-005-1	R6.	Not Applicable
IRO-005-1	R7.	Not Applicable
IRO-005-1	R8.	Not Applicable
IRO-005-1	R9.	Compliant
IRO-005-1	R10.	Not Applicable
IRO-005-1	R11.	Not Applicable
IRO-005-1	R12.	Not Applicable
IRO-005-1	R13.	Compliant
IRO-005-1	R14.	Not Applicable
IRO-005-1	R15.	Not Applicable
IRO-005-1	R16.	Not Applicable
IRO-005-1	R17.	Compliant
MOD-010-0	R1.	Compliant
MOD-010-0	R2.	Compliant
MOD-012-0	R1.	Compliant
MOD-012-0	R2.	Compliant
PRC-004-1	R1.	Not Applicable
PRC-004-1	R2.	Compliant
PRC-004-1	R3.	Compliant
PRC-005-1	R1.	Compliant
PRC-005-1	R2.	Compliant
PRC-016-0	R1.	Not Applicable
PRC-016-0	R2.	Not Applicable
PRC-016-0	R3.	Not Applicable
PRC-017-0	R1.	Not Applicable
PRC-017-0	R2.	Not Applicable
TOP-001-1	R1.	Not Applicable
TOP-001-1	R2.	Not Applicable
TOP-001-1	R3.	Compliant
TOP-001-1	R4.	Not Applicable
TOP-001-1	R5.	Not Applicable
TOP-001-1	R6.	Compliant
TOP-001-1	R7.	Compliant
TOP-001-1	R8.	Not Applicable

Confidential Information (including Privileged and  
Critical Energy Infrastructure Information) Has Been Removed

<b>Reliability Standard</b>	<b>Requirement</b>	<b>Finding</b>
TOP-002-2	R1.	Not Applicable
TOP-002-2	R2.	Not Applicable
TOP-002-2	R3.	Compliant
TOP-002-2	R4.	Not Applicable
TOP-002-2	R5.	Not Applicable
TOP-002-2	R6.	Not Applicable
TOP-002-2	R7.	Not Applicable
TOP-002-2	R8.	Not Applicable
TOP-002-2	R9.	Not Applicable
TOP-002-2	R10.	Not Applicable
TOP-002-2	R11.	Not Applicable
TOP-002-2	R12.	Not Applicable
TOP-002-2	R13.	Compliant
TOP-002-2	R14.	Compliant
TOP-002-2	R15.	Compliant
TOP-002-2	R16.	Not Applicable
TOP-002-2	R17.	Not Applicable
TOP-002-2	R18.	Compliant
TOP-002-2	R19.	Not Applicable
TOP-003-0	R1.	Compliant
TOP-003-0	R2.	Compliant
TOP-003-0	R3.	Compliant
TOP-004-0	R4.	Not Applicable
VAR-002-1	R1.	Compliant
VAR-002-1	R2.	Compliant
VAR-002-1	R3.	Compliant
VAR-002-1	R4.	Compliant
VAR-002-1	R5.	Compliant
VAR-STD-002a-1	WR1.	Compliant
VAR-STD-002b-1	WR1.	Not Applicable