

C. Energy Emergency Alert 3 Report

NERC policy 9B section B paragraph 3.5 requires that a Deficient Control Area or Load Serving Entity declaring an Energy Emergency Alert 3 must complete the following report. Upon completion of this report it is to be sent to the Security Coordinator for review within two business days of the incident.

Requesting Control Area: Lafayette Utilities System

Entity experiencing energy deficiency (if different from Control Area):

Date/Time Implemented: June 30, 2009 13:37 CDT

Date/Time Released: June 30, 2009 21:00 CDT

Declared Deficiency Amount (MW): Varying up to 225 MW per hour during 7 hour period.

Total Energy supplied by other Control Areas During the Alert 3 period:

0 MW

Conditions that precipitated call for "Energy Deficiency Alert 3":

TLR 5a declared by ICTE on FG# 15878 resulted in firm trans. schedules to LAFA to be curtailed.

If "Energy Deficiency Alert 3" had not been called, would firm load be cut? If no, explain:

Yes

Explain what action was taken in each step to avoid calling for “Energy Deficiency Alert 3”:

1. All generation capable of being on line in the time frame of the energy deficiency was on line (including quick start and peaking units) without regard to cost.

YES

2. All firm and non-firm purchases were made regardless of cost.

Yes. All available Firm Transmission into LAFA’s System was already in use.

ENTR and CLEC Oasis indicated 0 ATC to LAFA for non-firm trans.

3. All non-firm sales were recalled within provisions of the sale agreement.

LAFA did not have any sales, non firm or otherwise .

4. Interruptible load was curtailed where either advance notice restrictions were met or the interruptible load was considered part of spinning reserve.

Lafayette has no interruptible load.

5. Available load reduction programs were exercised (public appeals, voltage reductions, etc.).

Yes

6. Operating Reserves being utilized.

Yes

Comments:

Reported By: Stewart Dover

Organization: Lafayette Utilities System

Title: Energy Control System Operator