

IDC
Cumulative Operational Statistics for 12 Months
Ending 07/01/12 00:00

IDC	Totals	From: 06/01/2011 00:00	From: 05/01/2011 00:00	From: 04/01/2011 00:00	From: 03/01/2011 00:00	From: 02/01/2011 00:00	From: 01/01/2011 00:00
Operational Statistics	12 Months	To: 07/01/2012 00:00	To: 06/01/2012 00:00	To: 05/01/2012 00:00	To: 04/01/2012 00:00	To: 03/01/2012 00:00	To: 02/01/2012 00:00
Total TLR Events[1]	1,240	92	105	104	104	88	102
Total TLR Actions[2]	10,971	692	897	863	1,309	931	896
TLR Events with Cuts	1,137	85	95	97	101	82	89
TLR Actions with Cuts	8,229	509	657	649	1,000	690	690
Total Tag Cuts	69,785	6,687	8,032	4,419	7,651	6,005	5,151
Total On-Path Tag Cut[3]	37,749	4,113	4,948	2,160	4,741	1,593	1,239
Total Loop Flow Tag Cut [4]	32,036	2,574	3,084	2,259	2,910	4,412	3,912
% On-Path Tag Cut	54.09%	61.51%	61.60%	48.88%	61.97%	26.53%	24.05%
% Loop Flow Tag Cut	45.91%	38.49%	38.40%	51.12%	38.03%	73.47%	75.95%
Total MW Cuts[5] (MW)	2,515,748	211,917	254,082	182,405	283,061	226,129	196,937
Total On-Path MW Cut (MW)	901,296	69,399	111,124	73,784	91,677	31,676	54,967
Total Loop Flow MW Cut (MW)	1,614,452	142,518	142,958	108,621	191,384	194,453	141,970
% On-Path MW Cut	35.83%	32.75%	43.74%	40.45%	32.39%	14.01%	27.91%
% Loop Flow MW Cut	64.17%	67.25%	56.26%	59.55%	67.61%	85.99%	72.09%
Total Denied IDC Cuts[6]	791	69	113	99	56	31	27
Total Tags in IDC	709,520	57,802	58,731	54,349	54,437	49,985	57,559
Total Tag Requests	2,157,012	182,373	180,227	160,486	167,600	159,509	169,584
Total Cut Requests	937,754	81,811	79,386	68,116	74,421	72,958	72,040
Total Energy Schedules[7]	5,365,324	444,785	449,366	435,456	451,272	414,697	437,807
Total Cut Schedules	952,902	83,144	81,701	68,937	76,245	73,802	73,284
Total Transm. Schedules (OASIS Reservations)	10,236,470	851,596	833,584	818,500	842,477	789,514	837,243
Total Tag Energy Scheduled (GWh)	924,120	80,752	76,987	70,617	67,098	70,676	74,776
Total IDC Energy Cut (GWh)	2,471	210	250	177	280	223	192
On-Path Energy Cut (GWh)	882	68	109	71	91	30	54
Loop Flow Energy Cut (GWh)	1,591	142	141	106	190	193	139
IDC Energy Cut (%)	0.27%	0.26%	0.33%	0.25%	0.42%	0.32%	0.26%
Actual Energy Flow post curtailment (% Sched)	99.73%	99.74%	99.67%	99.75%	99.58%	99.68%	99.74%
On-Path Energy Cut (%)	35.69%	32.40%	43.64%	40.03%	32.30%	13.55%	27.93%
Loop-Flow Energy Cut (%)	64.39%	67.60%	56.36%	59.97%	67.70%	86.45%	72.07%
[1] TLR Event Comprises all the TLR Actions from initial TLR Issuance (Level 2 and higher) until the TLR is Terminated with a TLR Level 0							
[2] Each one of the TLR issuances of the RC. The action can be Level 2, 3A, 3B, 4, 5A, 5B and 6							
[3] Constrained Path Method (CPM) Computation							
[4] Weakest Link (WK)							
[5] As acknowledged by the Sink RC							
[6] Active and Passive							
[7] Indicates Different Schedule Blocks							

IDC
Cumulative Operational Statistics for 12 Months
Ending 07/01/12 00:00

IDC	From: 12/01/2011 00:00	From: 11/01/2011 00:00	From: 10/01/2011 00:00	From: 9/01/2011 00:00	From: 8/01/2011 00:00	From: 7/01/2011 00:00
Operational Statistics	To: 01/01/2012 00:00	To: 12/01/2011 00:00	To: 11/01/2011 00:00	To: 10/01/2011 00:00	To: 9/01/2011 00:00	To: 8/01/2011 00:00
Total TLR Events[1]	99	97	108	120	97	124
Total TLR Actions[2]	1,000	787	1,137	858	653	948
TLR Events with Cuts	87	93	102	113	80	113
TLR Actions with Cuts	745	684	828	669	421	687
Total Tag Cuts	8,753	5,984	3,931	5,125	3,574	4,473
Total On-Path Tag Cut[3]	6,242	4,043	2,251	2,815	1,768	1,836
Total Loop Flow Tag Cut [4]	2,511	1,941	1,680	2,310	1,806	2,637
% On-Path Tag Cut	71.31%	67.56%	57.26%	54.93%	49.47%	41.05%
% Loop Flow Tag Cut	28.69%	32.44%	42.74%	45.07%	50.53%	58.95%
Total MW Cuts[5] (MW)	200,839	193,458	172,866	221,286	148,688	224,080
Total On-Path MW Cut (MW)	100,810	90,453	75,750	91,045	48,627	61,984
Total Loop Flow MW Cut (MW)	100,029	103,005	97,116	130,241	100,061	162,096
% On-Path MW Cut	50.19%	46.76%	43.82%	41.14%	32.70%	27.66%
% Loop Flow MW Cut	49.81%	53.24%	56.18%	58.86%	67.30%	72.34%
Total Denied IDC Cuts[6]	102	90	62	77	31	34
Total Tags in IDC	56,829	57,233	59,340	62,167	73,942	67,146
Total Tag Requests	169,164	172,758	173,756	194,517	224,141	202,897
Total Cut Requests	70,983	73,215	73,736	85,884	97,366	87,838
Total Energy Schedules[7]	451,871	435,496	435,251	442,265	491,240	475,818
Total Cut Schedules	71,835	73,590	75,603	86,317	99,232	89,212
Total Transm. Schedules (OASIS Reservations)	865,301	840,083	843,384	849,446	935,811	929,531
Total Tag Energy Scheduled (GWh)	80,197	71,945	75,404	74,944	92,241	88,483
Total IDC Energy Cut (GWh)	196	189	170	216	147	221
On-Path Energy Cut (GWh)	99	89	74	89	48	60
Loop Flow Energy Cut (GWh)	97	100	95	128	99	161
IDC Energy Cut (%)	0.24%	0.26%	0.22%	0.29%	0.16%	0.25%
Actual Energy Flow post curtailment (% Sched)	99.76%	99.74%	99.78%	99.71%	99.84%	99.75%
On-Path Energy Cut (%)	50.41%	46.88%	43.77%	40.93%	32.42%	27.29%
Loop-Flow Energy Cut (%)	49.59%	53.12%	56.23%	59.07%	67.58%	72.71%
[1] TLR Event Comprises all the TLR Actions from initial TLR Issuance (Level 2 and higher) until the TLR is Terminated with a TLR Level 0						
[2] Each one of the TLR issuances of the RC. The action can be Level 2, 3A, 3B, 4, 5A, 5B and 6						
[3] Constrained Path Method (CPM) Computation						
[4] Weakest Link (WK)						
[5] As acknowledged by the Sink RC						
[6] Active and Passive						
[7] Indicates Different Schedule Blocks						