

**IDC**  
**Cumulative Operational Statistics for 12 Months**  
**Ending 06/01/12 00:00**

IDC	Totals	From: 05/01/2011 00:00	From: 04/01/2011 00:00	From: 03/01/2011 00:00	From: 02/01/2011 00:00	From: 01/01/2011 00:00	From: 12/01/2011 00:00
Operational Statistics	12 Months	To: 06/01/2012 00:00	To: 05/01/2012 00:00	To: 04/01/2012 00:00	To: 03/01/2012 00:00	To: 02/01/2012 00:00	To: 01/01/2012 00:00
Total TLR Events[1]	1,311	105	104	104	88	102	99
Total TLR Actions[2]	11,972	897	863	1,309	931	896	1,000
TLR Events with Cuts	1,206	95	97	101	82	89	87
TLR Actions with Cuts	9,055	657	649	1,000	690	690	745
Total Tag Cuts	74,254	8,032	4,419	7,651	6,005	5,151	8,753
Total On-Path Tag Cut[3]	39,354	4,948	2,160	4,741	1,593	1,239	6,242
Total Loop Flow Tag Cut [4]	34,900	3,084	2,259	2,910	4,412	3,912	2,511
% On-Path Tag Cut	53.00%	61.60%	48.88%	61.97%	26.53%	24.05%	71.31%
% Loop Flow Tag Cut	47.00%	38.40%	51.12%	38.03%	73.47%	75.95%	28.69%
Total MW Cuts[5] (MW)	2,812,404	254,082	182,405	283,061	226,129	196,937	200,839
Total On-Path MW Cut (MW)	1,032,688	111,124	73,784	91,677	31,676	54,967	100,810
Total Loop Flow MW Cut (MW)	1,779,716	142,958	108,621	191,384	194,453	141,970	100,029
% On-Path MW Cut	36.72%	43.74%	40.45%	32.39%	14.01%	27.91%	50.19%
% Loop Flow MW Cut	63.28%	56.26%	59.55%	67.61%	85.99%	72.09%	49.81%
Total Denied IDC Cuts[6]	1,015	113	99	56	31	27	102
Total Tags in IDC	716,241	58,731	54,349	54,437	49,985	57,559	56,829
Total Tag Requests	2,182,703	180,227	160,486	167,600	159,509	169,584	169,164
Total Cut Requests	952,258	79,386	68,116	74,421	72,958	72,040	70,983
Total Energy Schedules[7]	5,395,997	449,366	435,456	451,272	414,697	437,807	451,871
Total Cut Schedules	966,875	81,701	68,937	76,245	73,802	73,284	71,835
Total Transm. Schedules (OASIS Reservations)	10,317,147	833,584	818,500	842,477	789,514	837,243	865,301
Total Tag Energy Scheduled (GWh)	921,557	76,987	70,617	67,098	70,676	74,776	80,197
Total IDC Energy Cut (GWh)	2,761	250	177	280	223	192	196
On-Path Energy Cut (GWh)	1,011	109	71	91	30	54	99
Loop Flow Energy Cut (GWh)	1,752	141	106	190	193	139	97
IDC Energy Cut (%)	0.30%	0.33%	0.25%	0.42%	0.32%	0.26%	0.24%
Actual Energy Flow post curtailment (% Sched)	99.70%	99.67%	99.75%	99.58%	99.68%	99.74%	99.76%
On-Path Energy Cut (%)	36.62%	43.64%	40.03%	32.30%	13.55%	27.93%	50.41%
Loop-Flow Energy Cut (%)	63.46%	56.36%	59.97%	67.70%	86.45%	72.07%	49.59%
[1] TLR Event Comprises all the TLR Actions from initial TLR Issuance (Level 2 and higher) until the TLR is Terminated with a TLR Level 0							
[2] Each one of the TLR issuances of the RC. The action can be Level 2, 3A, 3B, 4, 5A, 5B and 6							
[3] Constrained Path Method (CPM) Computation							
[4] Weakest Link (WK)							
[5] As acknowledged by the Sink RC							
[6] Active and Passive							
[7] Indicates Different Schedule Blocks							

**IDC**  
**Cumulative Operational Statistics for 12 Months**  
**Ending 06/01/12 00:00**

IDC	From: 11/01/2011 00:00	From: 10/01/2011 00:00	From: 9/01/2011 00:00	From: 8/01/2011 00:00	From: 7/01/2011 00:00	From: 6/01/2011 00:00
Operational Statistics	To: 12/01/2011 00:00	To: 11/01/2011 00:00	To: 10/01/2011 00:00	To: 9/01/2011 00:00	To: 8/01/2011 00:00	To: 7/01/2011 00:00
Total TLR Events[1]	97	108	120	97	124	163
Total TLR Actions[2]	787	1,137	858	653	948	1,693
TLR Events with Cuts	93	102	113	80	113	154
TLR Actions with Cuts	684	828	669	421	687	1,335
Total Tag Cuts	5,984	3,931	5,125	3,574	4,473	11,156
Total On-Path Tag Cut[3]	4,043	2,251	2,815	1,768	1,836	5,718
Total Loop Flow Tag Cut [4]	1,941	1,680	2,310	1,806	2,637	5,438
% On-Path Tag Cut	67.56%	57.26%	54.93%	49.47%	41.05%	51.25%
% Loop Flow Tag Cut	32.44%	42.74%	45.07%	50.53%	58.95%	48.75%
Total MW Cuts[5] (MW)	193,458	172,866	221,286	148,688	224,080	508,573
Total On-Path MW Cut (MW)	90,453	75,750	91,045	48,627	61,984	200,791
Total Loop Flow MW Cut (MW)	103,005	97,116	130,241	100,061	162,096	307,782
% On-Path MW Cut	46.76%	43.82%	41.14%	32.70%	27.66%	39.48%
% Loop Flow MW Cut	53.24%	56.18%	58.86%	67.30%	72.34%	60.52%
Total Denied IDC Cuts[6]	90	62	77	31	34	293
Total Tags in IDC	57,233	59,340	62,167	73,942	67,146	64,523
Total Tag Requests	172,758	173,756	194,517	224,141	202,897	208,064
Total Cut Requests	73,215	73,736	85,884	97,366	87,838	96,315
Total Energy Schedules[7]	435,496	435,251	442,265	491,240	475,818	475,458
Total Cut Schedules	73,590	75,603	86,317	99,232	89,212	97,117
Total Transm. Schedules (OASIS Reservations)	840,083	843,384	849,446	935,811	929,531	932,273
Total Tag Energy Scheduled (GWh)	71,945	75,404	74,944	92,241	88,483	78,189
Total IDC Energy Cut (GWh)	189	170	216	147	221	500
On-Path Energy Cut (GWh)	89	74	89	48	60	197
Loop Flow Energy Cut (GWh)	100	95	128	99	161	303
IDC Energy Cut (%)	0.26%	0.22%	0.29%	0.16%	0.25%	0.64%
Actual Energy Flow post curtailment (% Sched)	99.74%	99.78%	99.71%	99.84%	99.75%	99.36%
On-Path Energy Cut (%)	46.88%	43.77%	40.93%	32.42%	27.29%	39.39%
Loop-Flow Energy Cut (%)	53.12%	56.23%	59.07%	67.58%	72.71%	60.61%
[1] TLR Event Comprises all the TLR Actions from initial TLR Issuance (Level 2 and higher) until the TLR is Terminated with a TLR Level 0						
[2] Each one of the TLR issuances of the RC. The action can be Level 2, 3A, 3B, 4, 5A, 5B and 6						
[3] Constrained Path Method (CPM) Computation						
[4] Weakest Link (WK)						
[5] As acknowledged by the Sink RC						
[6] Active and Passive						
[7] Indicates Different Schedule Blocks						