

Flood Loss	Metric	Definition	Score	S	M	A	R	T	Team Assigned	Action	2010 Metrics	Status
ALR1-1	Generator Reactive Limit Metric: Voltage schedules	How many times did generators encounter var limits associated with holding voltage schedule.	10	3	2	1	1	3	1	Initial pilot effort completed, reaching to other groups for more feedback		Withdrawn
ALR1-2	Maintaining the required amount of reserve (BAL-002, reserve contingency requirement)	Under normal operating conditions Operating hour by hour - Operating metric (BAs and REs may have the data via compliance audits) - may be able to link to frequency response/frequency excursion issues we are currently experiencing	13	3	2	2	3	3	1	RMWG Discussion was held		Considered not advanced
ALR1-3	Planning Reserve Margin (15% fossil, 10% hydro per NERC staff and RAS)	Reserve Margin % = (Capacity-Load)/LoadX100 - planning metric - use seasonal and LTRA data (RAS has LT metric and data, 1 year historic data available)	13	2	3	3	2	3	1 (Team 3)	Proposed by Team 3		Approved
ALR1-4	BPS Transmission Related Events Resulting in Loss of Load	Approved	15	3	3	3	3	3	3	RMWG Discussion was held		Approved
ALR1-5	System Voltage Performance	At select transmission system nodes (e.g., busses), record node (bus) voltage level in one minute time increments. Record the number of minutes the actual voltage level is outside a predetermined range around nominal.	???	John Simpson need to assign SMART rating						Pilot effort is completed. To be considered in November Face to Face		Approved
ALR1-10	Average Frequency Error	Average of frequency deviation on a monthly basis	Dismissed							Proposed by RS		Considered not advanced
ALR1-11	Daily Frequency Outlier Noise	Number of outlier days per month or mean time between outlier days	Dismissed							Proposed by RS		Considered not advanced
ALR1-12	Interconnection Frequency Response	Average frequency responses for all events where frequency drops more than 35 mHz within a year	11	2	2	2	3	2	1	RMWG Discussion was held		Approved
ALR1-13	Large Unit Trips	Number of large unit trips each quarter	Dismissed							Proposed by RS		Considered not advanced
ALR2-2	SPS Operations	Number of inter regional-impactive SPS operations (ref. PRC-001), including SPS misoperations – ref. PRC-016	10	3	2	1	2	2	1 (Team 2)	Proposed by Team 2		Considered not advanced
ALR2-3	UFLS Usage	UFLS and UVLS resulting in loss of load: Standards cover reporting UFLS and UVLS are PRC-009 and PRC-002	10	3	2	1	2	2	1	Considered not advanced		Considered not advanced

Flood Loss	Metric	Definition	Score	S	M	A	R	T	Team Assigned	Action	2010 Metrics	Status
ALR2-4	Average Percent Non-Recovery of Disturbance Control Standard (DCS) Events	100% Recovery within the Recovery Period (BAs, or Reserve Sharing Group), measure individual BA/RSG per BAL-002; benchmark all Bas/RSG and 4 interconnections	15	3	3	3	3	3	1	RMWG Discussion was held		Approved
ALR2-5	DCS Events Greater than MSSC (reported per standard requirement, but there is no limit)	Number of DCS Events Greater than MSSC; Measure how much risk system imposes to for extreme/unusual contingencies; should we carry more reserves? How often these contingencies occur?	12	3	3	2	2	2	1	RMWG Discussion was held		Approved
ALR2-6	RC Directives – Reliability Coordination	Manual Dispatch of Resources for Contingency Control per standard IRO-001, 004, 005, 006	9	1	2	2	2	2	1	Team 1 to provide response and post		Considered not advanced
ALR2-7	Reliability Coordination Transmission Reconfiguration for Contingency Control	Transmission Reconfiguration for Contingency Control	9	1	1	2	3	2	1	Team 1 to provide response and post to the web		Considered not advanced
ALR2-8	Reliability Coordination Contingency Control (held for future consideration)	Contingency Control (not market redispatch/intervention) – # of hours over limits, how long flows get back to normal	7	1	1	1	3	1	1	No action required mitigation plans are being collected under ALR6-1.		Considered not advanced
ALR2-9	Min Gen Management (held for future consideration)	Min Gen alerts, including sudden wind generation coming on line	0						1	RMWG Discussion was held	For future consideration	
ALR3-1	Disturbance Containment	Number and conditions of extreme events or planning scenarios/cases, resulting in deployment of SPS due to the loss of the following (also defined in TPL standards):-Two or more elements cascading out of service, generation, load -System stability (voltage, transient, dynamic), generation, load (ref. EOP-004 Disturbance Reporting)	7	1	1	1	2	2	2	RMWG Discussion was held		Considered not advanced
ALR3-2	IROL (same as 3-5), can be deleted	Actual overload (pre and post contingency)	7	1	2	1	2	1	2 (Team 1)	RMWG Discussion was held -Combined with 3-5		Considered not advanced
ALR3-3	IROL Flow Duration Curve (will need discussion)	flow duration curve to measure how close we are to the IROs	?	2	3	3	2	2	2 (Team 1)	RMWG Discussion was held		Considered not advanced
ALR3-4	IROL Standard Violations (has been combined in ALR3-5)	Number of times an IROL has been exceeded for greater than 30 min (ref. TOP-004, TOP-007, IRO-009)	15	3	3	3	3	3	2	RMWG Discussion was held		Considered not advanced

Flood Loss	Metric	Definition	Score	S	M	A	R	T	Team Assigned	Action	2010 Metrics	Status
ALR3-5	Operating Limit (OL) Excursion	Number of times an IROL has been exceeded for less than 30 min (ref. TOP-004), including basecase and under contingency, divide them into less than 10, 20, 30 mins categories	14	2	3	3	3	3	2	Approved, In the process of data request, comments received from 8 entities		Approved
ALR4-1	Automatic Transmission Outages Caused by Protection System	Percent correct trips = # of correct trips / total trips (which = correct trips + misops)	14	3	2	3	3	3	2	Approved - No data, will discuss next steps in Minneapolis		Approved
ALR5-1	Stability restoration (unstable conditions have occurred)	Average (or median) time to restore compliance with system ready for next credible contingency	9	2	1	2	2	2	3		For Future consideration	
ALR5-2	Cascading outage restoration	Average time to restore compliance with system ready for next credible contingency	11	2	1	2	3	3	3		For Future consideration	
ALR5-3	Uncontrolled separation restoration (BA restorations may have clearly identified completion	Average time to restore compliance with system ready for next credible contingency	12	2	2	2	3	3	3		For Future consideration	
ALR5-4	Widespread outage restoration (TADS may collect median time)	Average time to restore compliance with system ready for next credible contingency	12	2	2	2	3	3	3		For Future consideration	
ALR6-1	Transmission Constraint Mitigation	Number of mitigation plans used in planning and operating horizon, including SPS, RAS, operating procedures, deployment of Must-Run units, and load shedding (perhaps only count those in planning horizon per TPL standards) - Results require interpretation of true meaning of trends	14	3	3	3	3	2	3	Approved		Approved
ALR6-2	EEA 3	Number of times EEA 3 are issued - solutions may be different from the ones for ALR 6-3 - check EEA3 reports to see if event descriptions cover all detailed	15	3	3	3	3	3	3 (Team 1)	Approved		Approved
ALR6-3	Energy Emergency Alert 2	Number of events BAs declared capacity and energy emergencies during annual peak load periods (consider system minutes of unserved load)	15	3	3	3	3	3	3	Approved		Approved

Flood Loss	Metric	Definition	Score	S	M	A	R	T	Team Assigned	Action	2010 Metrics	Status
ALR6-4	Demand Side management (DSM)	measure DSM performance to BA's instructions -Use operating data (DRDTF has LT data, no actual available) DRDTF recommendations – check into DSM classes	8	1	1	2	2	2	3	Considered not advanced		Considered not advanced
ALR6-5	Facility Redundancy? – Performance requirements? (held for future consideration) - probability-based performance requirements	Consider different degrees of reliability requirements, recognizing importance of critical corridors (n-x): element redundancy								Held for future consideration		Follow up on Nov face to face meeting
ALR6-11	ALR6-11 Automatic AC Transmission Outages Initiated by Failed Protection System Equipment	The normalized count provides an indication of the relative protection system equipment performance, specifically the AC Transmission Element outage rate for momentary and sustained outages initiated by Failed Protection System Equipment. Failed Protection System Equipment is one of the highest causes for initiating	14	3	3	3	3	2	2	Discuss next steps in Minneapolis		Approved
ALR6-12	Automatic AC Circuit Outages Initiated by Human Error	The normalized count provides an indication of the relative human factor performance, specifically the AC Transmission Element outage rate for momentary and sustained outages initiated by Human Errors. Human Error is one of the highest causes for initiating automatic transmission system outages.	14	3	3	3	3	2	2	Discuss next steps in Minneapolis		Approved
ALR6-13	Automatic AC Circuit Outages Initiated by Failed AC Substation Equipment	The normalized count provides an indication of the relative substation equipment performance, specifically the AC Transmission Element outage rate for momentary and sustained outages initiated by AC substation equipment. AC substation equipment is one of the highest causes for initiating automatic transmission system outages.	14	3	3	3	3	2	2	Discuss next steps in Minneapolis		Approved

Flood Loss	Metric	Definition	Score	S	M	A	R	T	Team Assigned	Action	2010 Metrics	Status
ALR6 -14	Automatic AC Circuit Outages Initiated by Failed AC Circuit Equipment	The normalized count provides an indication of the relative transmission circuit equipment performance, specifically the AC Transmission Element outage rate for momentary and sustained	14	3	3	3	3	2	2	Discuss next steps in Minneapolis		Approved
ALR6 -15	Element Availability Percentage (APC)	The overall availability is the percentage of time the transmission system is available (i.e., in service) for the transmission of electricity. The relative percentage provides an indication of the overall availability of the transmission system operated at 200 kV and above, which indicates reliability performance.	13	3	3	3	3	2	2	Discuss next steps in Minneapolis		Approved
ALR6-16	Transmission System Unavailability due to Automatic Outages	The unavailability is the percentage of time the entire transmission system is not available (i.e., out of service) for the transmission of electricity due to sustained automatic outages. The relative percentage provides an indication of the overall unavailability of the transmission system operated at 200 kV and above, which indicates reliability performance.	13	3	3	3	3	2	2	Under Discussion		Not Approved
ALR6-20	Frequency of Delivery Interruptions	The metric tracks the number and impact of scheduled and unscheduled events that result in the loss of supply voltage to a Delivery Point[1] for a duration of one minute or more, during a period of time.								Initiated on 2010, discuss next steps. Proposed by Jeff Schaeffer		

Flood Loss	Metric	Definition	Score	S	M	A	R	T	Team Assigned	Action	2010 Metrics	Status
No ALR	Breaker Failures	The sum number of breaker failures over specified time periods	Dismissed							Proposed by Entergy Services		Considered not advanced
No ALR	Exposure to Cascading Event Reliability	Sum of the number of minutes above IROL limits for any and all IROLs that	Dismissed							Proposed by Entergy Services		Considered not advanced
No ALR	Magnitude of IROL Exceedance	Magnitude of peak loading less IROL rating in MWs for any and all IROLs	Dismissed							Proposed by Entergy Services		Considered not advanced
No ALR	Simultaneous TLRs	Determine the number of simultaneous TLRs at a particular hour of the day.	Dismissed							Proposed by Entergy Services		Considered not advanced
No ALR	Simultaneous EEAs	Determine the number of simultaneous EEAs.	Dismissed							Proposed by Entergy Services		Considered not advanced
No ALR	LMP Divergence	Determine maximum LMP divergence for each LMP clearing time for each	Dismissed							Proposed by Entergy Services		Considered not advanced
No ALR	Number of Negative Frequency Excursions	By Interconnection, determine the number (count) of negative frequency	Dismissed							Proposed by Entergy Services		Considered not advanced
No ALR	Restoration Metric									Team 3	For Future consideration	
No ALR	Reclosing Metric									Team 3	For Future consideration	
No ALR	Expected Reserve Margin	Excess of expected resources over expected peak demand expressed as a								Team 3	For Future consideration	
No ALR	Annual Loss Of Load Hours	Calculation result comes from a probability based computer simulation.								Proposed by GTRPMTF	For Future consideration	
No ALR	Annual Expected Unserved Energy	Calculation result comes from a probability based computer simulation.								Proposed by GTRPMTF	For Future consideration	
No ALR	Frequency of Control Performance (from Resource	Frequency bound, epsilon 1 (€1) is based on historic measured frequency	Future							Team 1/ for future discussion	For Future consideration	
No ALR	Number of Negative Frequency Excursions	By Interconnection, determine the number (count) of negative frequency	Future							Team 1/ for future discussion	For Future consideration	
No ALR	Integral of Negative Frequency Excursions	By Interconnection, determine the integral of the negative frequency excursions beyond FTL in hour ending 4 pm CPT / 5 pm EPT for EI and	Future							Team 1/ for future discussion	For Future consideration	
										Future	13	
										Dismissed		40
										Approved		
										NET		53