
**BEFORE THE
NOVA SCOTIA UTILITY AND REVIEW BOARD
OF THE PROVINCE OF NOVA SCOTIA**

**NORTH AMERICAN ELECTRIC)
RELIABILITY CORPORATION)**

**THIRD QUARTER 2011 APPLICATION
FOR APPROVAL OF RELIABILITY STANDARDS OF THE
NORTH AMERICAN ELECTRIC RELIABILITY CORPORATION**

Gerald W. Cauley
President and Chief Executive Officer
North American Electric Reliability
Corporation
3353 Peachtree Road NE
Suite 600, North Tower
Atlanta, GA 30326-1001

David N. Cook
Senior Vice President and General Counsel
North American Electric Reliability
Corporation
1120 G Street N.W., Suite 990
Washington, D.C. 20005-3801
david.cook@nerc.net

Holly A. Hawkins
Assistant General Counsel for Standards
and Critical Infrastructure Protection
Willie L. Phillips
Attorney
North American Electric Reliability
Corporation
1120 G Street, N.W.
Suite 990
Washington, DC 20005-3801
(202) 393-3998
(202) 393-3955 – facsimile
holly.hawkins@nerc.net
willie.phillips@nerc.net

November 30, 2011

TABLE OF CONTENTS

I. INTRODUCTION 1

II. NOTICES AND COMMUNICATIONS..... 1

III. REQUEST FOR APPROVAL OF RELIABILITY STANDARDS 2

VI. CONCLUSION6

Exhibit A – List of Currently Effective NERC Reliability Standards

Exhibit B –

- 1.) NERC Reliability Standards Applicable to Nova Scotia Approved by FERC in Third Quarter 2011
- 2.) PDF Copies of Reliability Standards being filed for approval; and
- 3.) Updated NERC Glossary of Terms for approval

Exhibit C – Informational Summary of Each Reliability Standard Approved by FERC

I. INTRODUCTION

The North American Electric Reliability Corporation (“NERC”)¹ hereby submits to the Nova Scotia Utility and Review Board (“NSUARB”) an application for approval of the NERC Reliability Standards and an updated NERC Glossary of Terms approved by the United States Federal Energy Regulatory Commission (“FERC” or “Commission”). This filing covers the time period from July 1, 2011 through September 30, 2011. NERC requests that the Reliability Standards and updated NERC Glossary of Terms be made mandatory and enforceable for users, owners, and operators of the bulk power system within the Province of Nova Scotia.

In support of this request for approval by the NSUARB of the proposed Reliability Standards, NERC submits the following information: (1) an updated list of the currently-effective Reliability Standards as approved by FERC (*see Exhibit A*); (2) Reliability Standards approved by FERC in the third quarter and the associated NERC Glossary of Terms (*see Exhibit B*); and (3) informational summary of each Reliability Standard approved by FERC in the third quarter, including each standard’s purpose, applicability, and ballot body approval percentages (*see Exhibit C*).

By this filing, NERC seeks NSUARB approval of the standards that FERC has taken final action on in the third quarter of 2011.

¹ The Federal Energy Regulatory Commission (“FERC”) certified NERC as the electric reliability organization (“ERO”) in its order issued July 20, 2006 in Docket No. RR06-1-000,116 FERC ¶ 61,062 (2006) (“ERO Certification Order”).

II. NOTICES AND COMMUNICATIONS

Notices and communications regarding this Application may be addressed to:

Gerald W. Cauley
President and Chief Executive Officer
North American Electric Reliability
Corporation
3353 Peachtree Road NE
Suite 600, North Tower
Atlanta, GA 30326-1001

David N. Cook
Senior Vice President and General Counsel
North American Electric Reliability
Corporation
1120 G Street N.W., Suite 990
Washington, D.C. 20005-3801
david.cook@nerc.net

Holly A. Hawkins
Assistant General Counsel for Standards
and Critical Infrastructure Protection
North American Electric Reliability
Corporation
Willie L. Phillips
Attorney
North American Electric Reliability
Corporation
1120 G Street, N.W.
Suite 990
Washington, D.C. 20005-3801
(202) 393-3998
(202) 393-3955 – facsimile
holly.hawkins@nerc.net
willie.phillips@nerc.net

III. REQUEST FOR APPROVAL OF RELIABILITY STANDARDS

A. NERC Quarterly Filing of Proposed Reliability Standards

On July 20, 2011, NSUARB issued a decision approving the Reliability Standards and NERC Glossary of Terms that NERC submitted to NSUARB on June 30, 2010, and accepted as guidance the Violation Risk Factors (“VRF”) and Violation Severity Levels (“VSL”) associated with the currently-effective Reliability Standards.²

² *In the Matter of an Application by North American Electric Reliability Corporation for Approval of its Reliability Standards, and an application by Northeast Power Coordinating Council, Inc. for Approval of its Regional Reliability Criteria*, NSUARB-NERC-R-10 (July 20, 2011) (“NSUARB Decision”).

NERC has been certified as the Electric Reliability Organization (“ERO”)³ in the United States under Section 215 of the Federal Power Act.⁴ The Reliability Standards contained in Exhibit B have been approved as mandatory and enforceable for users, owners, and operators within the United States by FERC.⁵ Some or all of NERC’s Reliability Standards are now mandatory in the Canadian Provinces of Alberta, British Columbia, New Brunswick, Nova Scotia, Ontario, and Saskatchewan.

NERC entered into a Memorandum of Understanding (“MOU”) with NSUARB⁶ and a separate MOU with Nova Scotia Power Incorporated (“NSPI”), and the Northeast Power Coordinating Council, Inc. (“NPCC”),⁷ which became effective on December 22, 2006 and May 11, 2010, respectively. The May 11, 2010 MOU sets forth the mutual understandings of NERC, NSPI, and NPCC regarding the approval and implementation of NERC Reliability Standards and NPCC Regional Reliability Criteria in Nova Scotia and other related matters.

In addition to approving the currently-effective NERC Reliability Standards, the NSUARB Decision approved a “quarterly review” process for considering new and amended NERC standards and criteria.⁸ On September 2, 2011, NERC submitted its Second Quarter 2011 application filing to NSUARB, in which NERC committed to file a quarterly application with the NSUARB within sixty days after the end of each quarter

³ Through enactment of the Energy Policy Act of 2005, the U.S. Congress entrusted FERC with the duties of approving and enforcing rules in the U.S. to ensure the reliability of the Nation’s bulk power system, and with the duties of certifying an ERO. On July 20, 2006, FERC certified NERC as the ERO, charged with developing mandatory and enforceable Reliability Standards, which are subject to FERC review and approval.

⁴ 16 U.S.C. § 824o(f) (2006).

⁵ Those standards marked with an asterisk are not yet effective, but have been approved by FERC.

⁶ See Memorandum of Understanding between Nova Scotia Utility and Review Board and North American Electric Reliability Corporation (signed December 22, 2006).

⁷ See Memorandum of Understanding between Nova Scotia Power Incorporated and the Northeast Power Coordinating Council, Inc. and the North American Electric Reliability Corporation (signed May 11, 2010).

⁸ NSUARB Decision at P 30.

for approval of all NERC Reliability Standards and updated Glossary of Terms approved by FERC during that quarter, as necessary.⁹

The NSUARB Decision also determined that quarterly “applications will not be processed by the Board until [FERC] has approved or remanded the standards in the United States.”¹⁰ Accordingly, NERC is only requesting NSUARB approval for those Reliability Standards approved by FERC.

The NSUARB Decision also concluded that formal approval is not required for VRFs and VSLs associated with proposed Reliability Standards.¹¹ Accordingly, NERC will not seek formal approval of VRFs and VSLs associated with the Reliability Standards submitted in this or future quarterly applications. However, because the NSUARB has determined that it will accept the VRFs and VSLs as guidance, NERC is providing a link to the associated FERC-approved VRFs and VSLs for the Reliability Standards for information only.¹²

NERC has not included in this filing the full developmental record for the standards, which consists of the draft standards, comments received, responses to the comments by the drafting teams, and the full voting record, because the record for each standard may consist of several thousand pages. NERC will make the full developmental record available to the NSUARB or other interested parties upon request and as needed.

⁹ NERC’s September 2, 2011 filing sought approval for Reliability Standards CIP-002-3, CIP-003-3, CIP-004-3, CIP-007-3, CIP-008-3, CIP-009-3, INT-005-3, INT-006-3, INT-008-3, MOD-004-1, MOD-008-1, MOD-028-1, MOD-030-2, and PRC-023-1, which were also included in Exhibit E (Future Reliability Standards and List of Effective Dates for Approval) to NERC’s June 30, 2010 filing. Given that the NSUARB Decision approved NERC’s June 30, 2010 filing, NERC hereby clarifies that the effective date in Nova Scotia for these standards is July 20, 2011, and that no further action is required.

¹⁰ NSUARB Decision at P 30.

¹¹ *Id.* at P 33.

¹² NERC’s VRF and VSL matrices can be found at: <http://www.nerc.com/page.php?cid=2|20>. See left-hand side of webpage for downloadable documents.

B. Overview of Reliability Standards Development Process

NERC Reliability Standards define the requirements for reliably planning and operating the North American bulk power system. These standards are developed by industry stakeholders using a balanced, open, fair and inclusive process managed by the NERC Standards Committee. The Standards Committee is facilitated by NERC staff and comprised of representatives from ten electricity stakeholder segments. Stakeholders, through the balloting process, and the NERC Board of Trustees have approved the standards provided in **Exhibit B**.

NERC develops Reliability Standards in accordance with Section 300 (Reliability Standards Development) and Appendix 3A, (Standards Processes Manual) of its Rules of Procedure.¹³ A detailed overview of the process for standards development process was provided in the June 30, 2010 application.¹⁴ That overview included an explanation of the requirements in Section 300 of the NERC Rules of Procedure and the benchmarks of an excellent Reliability Standard. In addition, NERC's application explained that the Reliability Standards development process has been approved by the American National Standards Institute ("ANSI") as being open, inclusive, balanced, and fair.¹⁵

C. Description of Proposed Reliability Standards

The Reliability Standards presented in Exhibit B are grouped by topical area, as summarized below.¹⁶

¹³ NERC's Rules of Procedure are available at: <http://www.nerc.com/page.php?cid=1|8|169>.

¹⁴ NERC June 30, 2010 Application at pp. 8-13.

¹⁵ *Id.* at pp. 13-19.

¹⁶ Reliability Standards marked with an asterisk are not yet mandatorily effective, but have been approved by FERC and have a future mandatory effective date.

Reliability Standard	Effective Date
Critical Infrastructure Protection (CIP) Standards	
CIP-001-2a – Sabotage Reporting (formerly CIP-001-1a)	August 2, 2011
Personnel Performance, Training, and Qualification (PER) Standards	
PER-003-1 – Operating Personnel Credentials	October 1, 2012*
Protection and Control (PRC) Standards	
PRC-004-1a – Analysis and Mitigation of Transmission and Generation Protection System Misoperations	September 26, 2011
PRC-005-1a – Transmission and Generation Protection System Maintenance and Testing	September 26, 2011
Transmission Operations (TOP) Standards	
TOP-001-1a – Reliability Responsibilities and Authorities	November 21, 2011
Transmission Planning (TPL) Standards	
TPL-002-0b - System Performance Following Loss of a Single Bulk Electric System Element (Category B)	October 24, 2011

The NERC Glossary of Terms used in Reliability Standards – most recently updated October 26, 2011 – lists each term that is defined for use in one or more of NERC’s continent-wide or Regional Reliability Standards adopted by the NERC Board of Trustees.

IV. CONCLUSION

By this filing, NERC requests that the NSUARB approve the Reliability Standards and NERC Glossary of Terms Used in Reliability Standards, as set out in Exhibit B.

Respectfully submitted,

/s/ Willie L. Phillips

Gerald W. Cauley
President and Chief Executive Officer
North American Electric Reliability
Corporation
3353 Peachtree Road NE
Suite 600, North Tower
Atlanta, GA 30326-1001

David N. Cook
Senior Vice President and General Counsel
North American Electric Reliability
Corporation
1120 G Street N.W., Suite 990
Washington, D.C. 20005-3801
david.cook@nerc.net

Holly A. Hawkins
Assistant General Counsel for Standards
and Critical Infrastructure Protection
Willie L. Phillips
Attorney
North American Electric Reliability
Corporation
1120 G Street, N.W.
Suite 990
Washington, DC 20005-3801
(202) 393-3998
(202) 393-3955 – facsimile
holly.hawkins@nerc.net
willie.phillips@nerc.net

Exhibit A

List of Currently Effective FERC-Approved Reliability Standards

Resource and Demand Balancing (BAL) Standards
BAL-001-0.1a
BAL-002-0
BAL-003-0.1b
BAL-004-0
BAL-004-WECC-01
BAL-005-0.1b
BAL-006-2
BAL-STD-002-0
BAL-502-RFC-02
Critical Infrastructure Protection (CIP) Standards
CIP-001-2a
CIP-002-3
CIP-003-3
CIP-004-3
CIP-005-3a
CIP-006-3c
CIP-007-3
CIP-008-3
CIP-009-3
Communications (COM) Standards
COM-001-1.1
COM-002-2
Emergency Preparedness and Operations (EOP) Standards
EOP-001-0
EOP-002-3
EOP-003-1
EOP-004-1
EOP-005-1
EOP-006-1
EOP-008-0
EOP-009-0
Facilities Design, Connections, and Maintenance (FAC) Standards
FAC-001-0
FAC-002-1
FAC-003-1
FAC-008-1
FAC-009-1
FAC-010-2.1
FAC-011-2
FAC-013-1
FAC-014-2
FAC-501-WECC-1

Standards Interchange Scheduling and Coordination (INT)
INT-001-3
INT-003-3
INT-004-2
INT-005-3
INT-006-3
INT-007-1
INT-008-3
INT-009-1
INT-010-1
Interconnection Reliability Operations and Coordination (IRO)
IRO-001-1.1
IRO-002-2
IRO-003-2
IRO-004-2
IRO-005-3a
IRO-006-5
IRO-008-1
IRO-009-1
IRO-010-1a
IRO-014-1
IRO-015-1
IRO-016-1
IRO-006-EAST-1
IRO-006-WECC-1
Modeling, Data, and Analysis (MOD) Standards
MOD-001-1a
MOD-004-1
MOD-008-1
MOD-010-0
MOD-012-0
MOD-016-1.1
MOD-017-0.1
MOD-018-0
MOD-019-0.1
MOD-020-0
MOD-021-1
MOD-028-1
MOD-029-1a
MOD-030-2
Nuclear (NUC) Standards
NUC-001-2
Personnel Performance, Training, and Qualification (PER) Standards
PER-001-0.1
PER-002-0

PER-003-0
PER-004-1
PER-004-2
PER-005-1
Protection and Control (PRC) Standards
PRC-001-1
PRC-002-NPCC-01
PRC-004-1a
PRC-004-WECC-1
PRC-005-1a
PRC-007-0
PRC-008-0
PRC-009-0
PRC-010-0
PRC-011-0
PRC-015-0
PRC-016-0.1
PRC-017-0
PRC-018-1
PRC-021-1
PRC-022-1
PRC-023-1
Transmission Operations (TOP) Standards
TOP-001-1
TOP-002-2b
TOP-003-1
TOP-004-2
TOP-005-2a
TOP-006-2
TOP-007-0
TOP-008-1
TOP-007-WECC-1
Transmission Planning (TPL) Standards
TPL-001-0.1
TPL-002-0b
TPL-003-0a
TPL-004-0
Voltage and Reactive (VAR) Standards
VAR-001-2
VAR-002-1.1b
VAR-002-WECC-1
VAR-501-WECC-1

Exhibit B

- 1.) NERC Reliability Standards Applicable to Nova Scotia Approved by FERC in Third Quarter 2011**
- 2.) PDF Copies of Reliability Standards being filed for approval; and**
- 3.) Updated NERC Glossary of Terms for approval**

**1.) NERC Reliability Standards Applicable to Nova Scotia Approved by
FERC in Third Quarter 2011**

Reliability Standard	Effective Date
Critical Infrastructure Protection (CIP) Standards	
CIP-001-2a – Sabotage Reporting (formerly CIP-001-1a)	August 2, 2011
Personnel Performance, Training, and Qualification (PER) Standards	
PER-003-1 – Operating Personnel Credentials	October 1, 2012*
Protection and Control (PRC) Standards	
PRC-004-1a – Analysis and Mitigation of Transmission and Generation Protection System Misoperations	September 26, 2011
PRC-005-1a – Transmission and Generation Protection System Maintenance and Testing	September 26, 2011
Transmission Operations (TOP) Standards	
TOP-001-1a – Reliability Responsibilities and Authorities	November 21, 2011
Transmission Planning (TPL) Standards	
TPL-002-0b - System Performance Following Loss of a Single Bulk Electric System Element (Category B)	October 24, 2011

***At the time of this filing, all standards marked with an asterisk are not yet mandatorily effective, but have been approved by FERC and have a future mandatory effective date.**

2.) PDF Copies of Reliability Standards being filed for approval

A. Introduction

1. **Title:** **Sabotage Reporting**
2. **Number:** CIP-001-2a
3. **Purpose:** Disturbances or unusual occurrences, suspected or determined to be caused by sabotage, shall be reported to the appropriate systems, governmental agencies, and regulatory bodies.
4. **Applicability**
 - 4.1. Reliability Coordinators.
 - 4.2. Balancing Authorities.
 - 4.3. Transmission Operators.
 - 4.4. Generator Operators.
 - 4.5. Load Serving Entities.
 - 4.6. Transmission Owners (only in ERCOT Region).
 - 4.7. Generator Owners (only in ERCOT Region).
5. **Effective Date:** ERCOT Regional Variance will be effective the first day of the first calendar quarter after applicable regulatory approval.

B. Requirements

- R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.
- R2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.
- R3. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.
- R4. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.

C. Measures

- M1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement 1
- M2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements 2 and 3.

- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to procedures, policies, a letter of understanding, communication records, or other equivalent evidence that will be used to confirm that it has established communications contacts with the applicable, local FBI or RCMP officials to communicate sabotage events (Requirement 4).

D. Compliance

1. Compliance Monitoring Process

1.1. Compliance Monitoring Responsibility

Regional Reliability Organizations shall be responsible for compliance monitoring.

1.2. Compliance Monitoring and Reset Time Frame

One or more of the following methods will be used to verify compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

1.3. Data Retention

Each Reliability Coordinator, Transmission Operator, Generator Operator, Distribution Provider, and Load Serving Entity shall have current, in-force documents available as evidence of compliance as specified in each of the Measures.

If an entity is found non-compliant the entity shall keep information related to the non-compliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

1.4. Additional Compliance Information

None.

2. Levels of Non-Compliance:

2.1. Level 1: There shall be a separate Level 1 non-compliance, for every one of the following requirements that is in violation:

- 2.1.1** Does not have procedures for the recognition of and for making its operating personnel aware of sabotage events (R1).

- 2.1.2 Does not have procedures or guidelines for the communication of information concerning sabotage events to appropriate parties in the Interconnection (R2).
- 2.1.3 Has not established communications contacts, as specified in R4.
- 2.2. **Level 2:** Not applicable.
- 2.3. **Level 3:** Has not provided its operating personnel with sabotage response procedures or guidelines (R3).
- 2.4. **Level 4:** Not applicable.

E. ERCOT Interconnection-wide Regional Variance

Requirements

- EA.1.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.
- EA.2.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.
- EA.3.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.
- EA.4.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall establish communications contacts with local Federal Bureau of Investigation (FBI) officials and develop reporting procedures as appropriate to their circumstances.

Measures

- M.A.1.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement EA1.
- M.A.2.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements EA2 and EA3.
- M.A.3.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to, procedures, policies, a letter of understanding, communication records,

or other equivalent evidence that will be used to confirm that it has established communications contacts with the local FBI officials to communicate sabotage events (Requirement EA4).

Compliance

1. Compliance Monitoring Process

1.1. Compliance Enforcement Authority

Regional Entity shall be responsible for compliance monitoring.

1.2. Data Retention

Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have current, in-force documents available as evidence of compliance as specified in each of the Measures.

If an entity is found non-compliant the entity shall keep information related to the non-compliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

Version History

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Amended
1	April 4, 2007	Regulatory Approval — Effective Date	New
1a	February 16, 2010	Added Appendix 1 — Interpretation of R2 approved by the NERC Board of Trustees	Addition
1a	February 2, 2011	Interpretation of R2 approved by FERC on February 2, 2011	Same addition
	June 10, 2010	TRE regional ballot approved variance	By Texas RE
	August 24, 2010	Regional Variance Approved by Texas RE Board of Directors	
2a	February 16, 2011	Approved by NERC Board of Trustees	

Standard CIP-001-2a— Sabotage Reporting

2a	August 2, 2011	FERC Order issued approving Texas RE Regional Variance	
----	----------------	--	--

Appendix 1

Requirement Number and Text of Requirement
<p>CIP-001-1:</p> <p>R2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.</p>
Question
<p>Please clarify what is meant by the term, “appropriate parties.” Moreover, who within the Interconnection hierarchy deems parties to be appropriate?</p>
Response
<p>The drafting team interprets the phrase “appropriate parties in the Interconnection” to refer collectively to entities with whom the reporting party has responsibilities and/or obligations for the communication of physical or cyber security event information. For example, reporting responsibilities result from NERC standards IRO-001 Reliability Coordination — Responsibilities and Authorities, COM-002-2 Communication and Coordination, and TOP-001 Reliability Responsibilities and Authorities, among others. Obligations to report could also result from agreements, processes, or procedures with other parties, such as may be found in operating agreements and interconnection agreements.</p> <p>The drafting team asserts that those entities to which communicating sabotage events is appropriate would be identified by the reporting entity and documented within the procedure required in CIP-001-1 Requirement R2.</p> <p>Regarding “who within the Interconnection hierarchy deems parties to be appropriate,” the drafting team knows of no interconnection authority that has such a role.</p>

A. Introduction

1. **Title:** **Operating Personnel Credentials**
2. **Number:** **PER-003-1**
3. **Purpose:** To ensure that System Operators performing the reliability-related tasks of the Reliability Coordinator, Balancing Authority and Transmission Operator are certified through the NERC System Operator Certification Program when filling a Real-time operating position responsible for control of the Bulk Electric System.
4. **Applicability:**
 - 4.1. Reliability Coordinator
 - 4.2. Transmission Operator
 - 4.3. Balancing Authority
5. **Effective Date:**
 - 5.1. In those jurisdictions where regulatory approval is required, this standard shall become effective the first calendar day of the first calendar quarter twelve months after applicable regulatory approval. In those jurisdictions where no regulatory approval is required, this standard shall become effective the first calendar day of the first calendar quarter twelve months after Board of Trustees adoption.

B. Requirements

- R1.** Each Reliability Coordinator shall staff its Real-time operating positions performing Reliability Coordinator reliability-related tasks with System Operators who have demonstrated minimum competency in the areas listed by obtaining and maintaining a valid NERC Reliability Operator certificate ⁽¹⁾: [*Risk Factor: High*][*Time Horizon: Real-time Operations*]

1.1. Areas of Competency

- 1.1.1. Resource and demand balancing
- 1.1.2. Transmission operations
- 1.1.3. Emergency preparedness and operations
- 1.1.4. System operations
- 1.1.5. Protection and control
- 1.1.6. Voltage and reactive
- 1.1.7. Interchange scheduling and coordination
- 1.1.8. Interconnection reliability operations and coordination

¹ Non-NERC certified personnel performing any reliability-related task of a real-time operating position must be under the direct supervision of a NERC Certified System Operator stationed at that operating position; the NERC Certified System Operator at that operating position has ultimate responsibility for the performance of the reliability-related tasks.

R2. Each Transmission Operator shall staff its Real-time operating positions performing Transmission Operator reliability-related tasks with System Operators who have demonstrated minimum competency in the areas listed by obtaining and maintaining one of the following valid NERC certificates ⁽¹⁾: [*Risk Factor: High*][*Time Horizon: Real-time Operations*]:

2.1. Areas of Competency

- 2.1.1. Transmission operations
- 2.1.2. Emergency preparedness and operations
- 2.1.3. System operations
- 2.1.4. Protection and control
- 2.1.5. Voltage and reactive

2.2. Certificates

- Reliability Operator
- Balancing, Interchange and Transmission Operator
- Transmission Operator

R3. Each Balancing Authority shall staff its Real-time operating positions performing Balancing Authority reliability-related tasks with System Operators who have demonstrated minimum competency in the areas listed by obtaining and maintaining one of the following valid NERC certificates ⁽¹⁾: [*Risk Factor: High*][*Time Horizon: Real-time Operations*]:

3.1. Areas of Competency

- 3.1.1. Resources and demand balancing
- 3.1.2. Emergency preparedness and operations
- 3.1.3. System operations
- 3.1.4. Interchange scheduling and coordination

3.2. Certificates

- Reliability Operator
- Balancing, Interchange and Transmission Operator
- Balancing and Interchange Operator

C. Measures

M1. Each Reliability Coordinator, Transmission Operator and Balancing Authority shall have the following evidence to show that it staffed its Real-time operating positions

¹ Non-NERC certified personnel performing any reliability-related task of an operating position must be under the direct supervision of a NERC Certified System Operator stationed at that operating position; the NERC Certified System Operator at that operating position has ultimate responsibility for the performance of the reliability-related tasks.

performing reliability-related tasks with System Operators who have demonstrated the applicable minimum competency by obtaining and maintaining the appropriate, valid NERC certificate (R1, R2, R3):

- M1.1** A list of Real-time operating positions.
- M1.2** A list of System Operators assigned to its Real-time operating positions.
- M1.3** A copy of each of its System Operator's NERC certificate or NERC certificate number with expiration date which demonstrates compliance with the applicable Areas of Competency.
- M1.4** Work schedules, work logs, or other equivalent evidence showing which System Operators were assigned to work in Real-time operating positions.

D. Compliance

1. Compliance Monitoring Process

1.1. Compliance Monitoring Authority

For Reliability Coordinators and other functional entities that work for their Regional Entity, the ERO shall serve as the Compliance Enforcement Authority.

For entities that do not work for the Regional Entity, the Regional Entity shall serve as the Compliance Enforcement Authority.

1.2. Compliance Monitoring and Enforcement Processes:

Compliance Audits

Self-Certifications

Spot Checking

Compliance Violation Investigations

Self-Reporting

Complaints

1.3. Data Retention

Each Reliability Coordinator, Transmission Operator and Balancing Authority shall keep data or evidence to show compliance for three years or since its last compliance audit, whichever time frame is the greatest, unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation.

If a Reliability Coordinator, Transmission Operator or Balancing Authority is found non-compliant, it shall keep information related to the non-compliance until found compliant or the time period specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent records.

1.4. Additional Compliance Information

None.

2.0 Violation Severity Levels

R#	Lower VSL	Medium VSL	High VSL	Severe VSL
R1				The Reliability Coordinator failed to staff each Real-time operating position performing Reliability Coordinator reliability-related tasks with a System Operator having a valid NERC certificate as defined in Requirement R1.
R2				The Transmission Operator failed to staff each Real-time operating position performing Transmission Operator reliability-related tasks with a System Operator having a valid NERC certificate as defined in Requirement R2, Part 2.2.
R3				The Balancing Authority failed to staff each Real-time operating position performing Balancing Authority reliability-related tasks with a System Operator having a valid NERC certificate as defined in Requirement R3, Part 3.2.

E. Regional Variances

None.

F. Associated Documents

Version History

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
1	February 17, 2011	Complete revision under Project 2007-04	Revision
1	February 17, 2011	Adopted by Board of Trustees	
1	September 15, 2011	FERC Order issued by FERC approving PER-003-1 (effective date of the Order is September 15, 2011)	

A. Introduction

- 1. Title:** Analysis and Mitigation of Transmission and Generation Protection System Misoperations
- 2. Number:** PRC-004-1a
- 3. Purpose:** Ensure all transmission and generation Protection System Misoperations affecting the reliability of the Bulk Electric System (BES) are analyzed and mitigated.
- 4. Applicability**
 - 4.1.** Transmission Owner.
 - 4.2.** Distribution Provider that owns a transmission Protection System.
 - 4.3.** Generator Owner.
- 5. Effective Date:** To be determined

B. Requirements

- R1.** The Transmission Owner and any Distribution Provider that owns a transmission Protection System shall each analyze its transmission Protection System Misoperations and shall develop and implement a Corrective Action Plan to avoid future Misoperations of a similar nature according to the Regional Reliability Organization's procedures developed for Reliability Standard PRC-003 Requirement 1.
- R2.** The Generator Owner shall analyze its generator Protection System Misoperations, and shall develop and implement a Corrective Action Plan to avoid future Misoperations of a similar nature according to the Regional Reliability Organization's procedures developed for PRC-003 R1.
- R3.** The Transmission Owner, any Distribution Provider that owns a transmission Protection System, and the Generator Owner shall each provide to its Regional Reliability Organization, documentation of its Misoperations analyses and Corrective Action Plans according to the Regional Reliability Organization's procedures developed for PRC-003 R1.

C. Measures

- M1.** The Transmission Owner, and any Distribution Provider that owns a transmission Protection System shall each have evidence it analyzed its Protection System Misoperations and developed and implemented Corrective Action Plans to avoid future Misoperations of a similar nature according to the Regional Reliability Organization procedures developed for PRC-003 R1.
- M2.** The Generator Owner shall have evidence it analyzed its Protection System Misoperations and developed and implemented Corrective Action Plans to avoid future Misoperations of a similar nature according to the Regional Reliability Organization's procedures developed for PRC-003 R1.
- M3.** Each Transmission Owner, and any Distribution Provider that owns a transmission Protection System, and each Generator Owner shall have evidence it provided documentation of its Protection System Misoperations, analyses and Corrective Action Plans according to the Regional Reliability Organization procedures developed for PRC-003 R1.

D. Compliance

- 1. Compliance Monitoring Process**

1.1. Compliance Monitoring Responsibility

Regional Reliability Organization.

1.2. Compliance Monitoring Period and Reset Time Frame

One calendar year.

1.3. Data Retention

The Transmission Owner, and Distribution Provider that own a transmission Protection System and the Generator Owner that owns a generation Protection System shall each retain data on its Protection System Misoperations and each accompanying Corrective Action Plan until the Corrective Action Plan has been executed or for 12 months, whichever is later.

The Compliance Monitor shall retain any audit data for three years.

1.4. Additional Compliance Information

The Transmission Owner, and any Distribution Provider that owns a transmission Protection System and the Generator Owner shall demonstrate compliance through self-certification or audit (periodic, as part of targeted monitoring or initiated by complaint or event), as determined by the Compliance Monitor.

2. Levels of Non-Compliance for Transmission Owners and Distribution Providers that own a Transmission Protection System:

2.1. Level 1: Documentation of Misoperations is complete according to PRC-004 R1, but documentation of Corrective Action Plans is incomplete.

2.2. Level 2: Documentation of Misoperations is incomplete according to PRC-004 R1 and documentation of Corrective Action Plans is incomplete.

2.3. Level 3: Documentation of Misoperations is incomplete according to PRC-004 R1 and there are no associated Corrective Action Plans.

2.4. Level 4: Misoperations have not been analyzed and documentation has not been provided to the Regional Reliability Organization according to Requirement 3.

3. Levels of Non-Compliance for Generator Owners

3.1. Level 1: Documentation of Misoperations is complete according to PRC-004 R2, but documentation of Corrective Action Plans is incomplete.

3.2. Level 2: Documentation of Misoperations is incomplete according to PRC-004 R2 and documentation of Corrective Action Plans is incomplete.

3.3. Level 3: Documentation of Misoperations is incomplete according to PRC-004 R2 and there are no associated Corrective Action Plans.

3.4. Level 4: Misoperations have not been analyzed and documentation has not been provided to the Regional Reliability Organization according to R3.

E. Regional Differences

None identified.

Standard PRC-004-1a — Analysis and Mitigation of Transmission and Generation Protection System Misoperations

Version History

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
1	December 1, 2005	<ol style="list-style-type: none"> 1. Changed incorrect use of certain hyphens (-) to “en dash” (–) and “em dash (—).” 2. Added “periods” to items where appropriate. Changed “Timeframe” to “Time Frame” in item D, 1.2.	01/20/06
1a	February 17, 2011	Added Appendix 1 - Interpretation regarding applicability of standard to protection of radially connected transformers	Project 2009-17 interpretation
1a	February 17, 2011	Adopted by the Board of Trustees	
1a	September 26, 2011	FERC Order issued approving the interpretation of R1 and R3 (FERC’s Order is effective as of September 26, 2011)	

Appendix 1

Requirement Number and Text of Requirement
<p>R1. The Transmission Owner and any Distribution Provider that owns a transmission Protection System shall each analyze its transmission Protection System Misoperations and shall develop and implement a Corrective Action Plan to avoid future Misoperations of a similar nature according to the Regional Reliability Organization’s procedures developed for Reliability Standard PRC-003 Requirement 1.</p> <p>R3. The Transmission Owner, any Distribution Provider that owns a transmission Protection System, and the Generator Owner shall each provide to its Regional Reliability Organization, documentation of its Misoperations analyses and Corrective Action Plans according to the Regional Reliability Organization’s procedures developed for PRC-003 R1.</p>
Question:
<p>Is protection for a radially-connected transformer protection system energized from the BES considered a transmission Protection System subject to this standard?</p>
Response:
<p>The request for interpretation of PRC-004-1 Requirements R1 and R3 focuses on the applicability of the term “transmission Protection System.” The NERC Glossary of Terms Used in Reliability Standards contains a definition of “Protection System” but does not contain a definition of transmission Protection System. In these two standards, use of the phrase transmission Protection System indicates that the requirements using this phrase are applicable to any Protection System that is installed for the purpose of detecting faults on transmission elements (lines, buses, transformers, etc.) identified as being included in the Bulk Electric System (BES) and trips an interrupting device that interrupts current supplied directly from the BES.</p> <p>A Protection System for a radially connected transformer energized from the BES would be considered a transmission Protection System and subject to these standards only if the protection trips an interrupting device that interrupts current supplied directly from the BES and the transformer is a BES element.</p>

A. Introduction

- 1. Title:** **Transmission and Generation Protection System Maintenance and Testing**
- 2. Number:** PRC-005-1a
- 3. Purpose:** To ensure all transmission and generation Protection Systems affecting the reliability of the Bulk Electric System (BES) are maintained and tested.
- 4. Applicability**
 - 4.1.** Transmission Owner.
 - 4.2.** Generator Owner.
 - 4.3.** Distribution Provider that owns a transmission Protection System.
- 5. Effective Date:** To be determined

B. Requirements

- R1.** Each Transmission Owner and any Distribution Provider that owns a transmission Protection System and each Generator Owner that owns a generation Protection System shall have a Protection System maintenance and testing program for Protection Systems that affect the reliability of the BES. The program shall include:
- R1.1.** Maintenance and testing intervals and their basis.
 - R1.2.** Summary of maintenance and testing procedures.
- R2.** Each Transmission Owner and any Distribution Provider that owns a transmission Protection System and each Generator Owner that owns a generation Protection System shall provide documentation of its Protection System maintenance and testing program and the implementation of that program to its Regional Reliability Organization on request (within 30 calendar days). The documentation of the program implementation shall include:
- R2.1.** Evidence Protection System devices were maintained and tested within the defined intervals.
 - R2.2.** Date each Protection System device was last tested/maintained.

C. Measures

- M1.** Each Transmission Owner and any Distribution Provider that owns a transmission Protection System and each Generator Owner that owns a generation Protection System that affects the reliability of the BES, shall have an associated Protection System maintenance and testing program as defined in Requirement 1.
- M2.** Each Transmission Owner and any Distribution Provider that owns a transmission Protection System and each Generator Owner that owns a generation Protection System that affects the reliability of the BES, shall have evidence it provided documentation of its associated Protection System maintenance and testing program and the implementation of its program as defined in Requirement 2.

D. Compliance

- 1. Compliance Monitoring Process**
 - 1.1. Compliance Monitoring Responsibility**

Regional Reliability Organization.

1.2. Compliance Monitoring Period and Reset Time Frame

One calendar year.

1.3. Data Retention

The Transmission Owner and any Distribution Provider that owns a transmission Protection System and each Generator Owner that owns a generation Protection System, shall retain evidence of the implementation of its Protection System maintenance and testing program for three years.

The Compliance Monitor shall retain any audit data for three years.

1.4. Additional Compliance Information

The Transmission Owner and any Distribution Provider that owns a transmission Protection System and the Generator Owner that owns a generation Protection System, shall each demonstrate compliance through self-certification or audit (periodic, as part of targeted monitoring or initiated by complaint or event), as determined by the Compliance Monitor.

2. Levels of Non-Compliance

2.1. Level 1: Documentation of the maintenance and testing program provided was incomplete as required in R1, but records indicate maintenance and testing did occur within the identified intervals for the portions of the program that were documented.

2.2. Level 2: Documentation of the maintenance and testing program provided was complete as required in R1, but records indicate that maintenance and testing did not occur within the defined intervals.

2.3. Level 3: Documentation of the maintenance and testing program provided was incomplete, and records indicate implementation of the documented portions of the maintenance and testing program did not occur within the identified intervals.

2.4. Level 4: Documentation of the maintenance and testing program, or its implementation, was not provided.

E. Regional Differences

None identified.

Version History

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
1	December 1, 2005	<ol style="list-style-type: none"> 1. Changed incorrect use of certain hyphens (-) to “en dash” (–) and “em dash (—).” 2. Added “periods” to items where appropriate. 3. Changed “Timeframe” to “Time Frame” in item D, 1.2. 	01/20/05

Standard PRC-005-1a — Transmission and Generation Protection System Maintenance and Testing

1a	February 17, 2011	Added Appendix 1 - Interpretation regarding applicability of standard to protection of radially connected transformers	Project 2009-17 interpretation
1a	February 17, 2011	Adopted by Board of Trustees	
1a	September 26, 2011	FERC Order issued approving interpretation of R1 and R2 (FERC's Order is effective as of September 26, 2011)	

Appendix 1

Requirement Number and Text of Requirement
<p>R1. Each Transmission Owner and any Distribution Provider that owns a transmission Protection System and each Generator Owner that owns a generation Protection System shall have a Protection System maintenance and testing program for Protection Systems that affect the reliability of the BES. The program shall include:</p> <p>R1.1. Maintenance and testing intervals and their basis.</p> <p>R1.2. Summary of maintenance and testing procedures.</p> <p>R2. Each Transmission Owner and any Distribution Provider that owns a transmission Protection System and each Generator Owner that owns a generation Protection System shall provide documentation of its Protection System maintenance and testing program and the implementation of that program to its Regional Reliability Organization on request (within 30 calendar days). The documentation of the program implementation shall include:</p> <p>R2.1 Evidence Protection System devices were maintained and tested within the defined intervals.</p> <p>R2.2 Date each Protection System device was last tested/maintained.</p>
Question:
Is protection for a radially-connected transformer protection system energized from the BES considered a transmission Protection System subject to this standard?
Response:
<p>The request for interpretation of PRC-005-1 Requirements R1 and R2 focuses on the applicability of the term “transmission Protection System.” The NERC Glossary of Terms Used in Reliability Standards contains a definition of “Protection System” but does not contain a definition of transmission Protection System. In these two standards, use of the phrase transmission Protection System indicates that the requirements using this phrase are applicable to any Protection System that is installed for the purpose of detecting faults on transmission elements (lines, buses, transformers, etc.) identified as being included in the Bulk Electric System (BES) and trips an interrupting device that interrupts current supplied directly from the BES.</p> <p>A Protection System for a radially connected transformer energized from the BES would be considered a transmission Protection System and subject to these standards only if the protection trips an interrupting device that interrupts current supplied directly from the BES and the transformer is a BES element.</p>

A. Introduction

1. Title: Reliability Responsibilities and Authorities

2. Number: TOP-001-1a

Purpose: To ensure reliability entities have clear decision-making authority and capabilities to take appropriate actions or direct the actions of others to return the transmission system to normal conditions during an emergency.

3. Applicability

3.1. Balancing Authorities

3.2. Transmission Operators

3.3. Generator Operators

3.4. Distribution Providers

3.5. Load Serving Entities

4. Effective Date: Immediately after approval of applicable regulatory authorities.

B. Requirements

- R1.** Each Transmission Operator shall have the responsibility and clear decision-making authority to take whatever actions are needed to ensure the reliability of its area and shall exercise specific authority to alleviate operating emergencies.
- R2.** Each Transmission Operator shall take immediate actions to alleviate operating emergencies including curtailing transmission service or energy schedules, operating equipment (e.g., generators, phase shifters, breakers), shedding firm load, etc.
- R3.** Each Transmission Operator, Balancing Authority, and Generator Operator shall comply with reliability directives issued by the Reliability Coordinator, and each Balancing Authority and Generator Operator shall comply with reliability directives issued by the Transmission Operator, unless such actions would violate safety, equipment, regulatory or statutory requirements. Under these circumstances the Transmission Operator, Balancing Authority or Generator Operator shall immediately inform the Reliability Coordinator or Transmission Operator of the inability to perform the directive so that the Reliability Coordinator or Transmission Operator can implement alternate remedial actions.
- R4.** Each Distribution Provider and Load Serving Entity shall comply with all reliability directives issued by the Transmission Operator, including shedding firm load, unless such actions would violate safety, equipment, regulatory or statutory requirements. Under these circumstances, the Distribution Provider or Load Serving Entity shall immediately inform the Transmission Operator of the inability to perform the directive so that the Transmission Operator can implement alternate remedial actions.
- R5.** Each Transmission Operator shall inform its Reliability Coordinator and any other potentially affected Transmission Operators of real time or anticipated emergency conditions, and take actions to avoid, when possible, or mitigate the emergency.

- R6.** Each Transmission Operator, Balancing Authority, and Generator Operator shall render all available emergency assistance to others as requested, provided that the requesting entity has implemented its comparable emergency procedures, unless such actions would violate safety, equipment, or regulatory or statutory requirements.
- R7.** Each Transmission Operator and Generator Operator shall not remove Bulk Electric System facilities from service if removing those facilities would burden neighboring systems unless:
 - R7.1.** For a generator outage, the Generator Operator shall notify and coordinate with the Transmission Operator. The Transmission Operator shall notify the Reliability Coordinator and other affected Transmission Operators, and coordinate the impact of removing the Bulk Electric System facility.
 - R7.2.** For a transmission facility, the Transmission Operator shall notify and coordinate with its Reliability Coordinator. The Transmission Operator shall notify other affected Transmission Operators, and coordinate the impact of removing the Bulk Electric System facility.
 - R7.3.** When time does not permit such notifications and coordination, or when immediate action is required to prevent a hazard to the public, lengthy customer service interruption, or damage to facilities, the Generator Operator shall notify the Transmission Operator, and the Transmission Operator shall notify its Reliability Coordinator and adjacent Transmission Operators, at the earliest possible time.
- R8.** During a system emergency, the Balancing Authority and Transmission Operator shall immediately take action to restore the Real and Reactive Power Balance. If the Balancing Authority or Transmission Operator is unable to restore Real and Reactive Power Balance it shall request emergency assistance from the Reliability Coordinator. If corrective action or emergency assistance is not adequate to mitigate the Real and Reactive Power Balance, then the Reliability Coordinator, Balancing Authority, and Transmission Operator shall implement firm load shedding.

C. Measures

- M1.** Each Transmission Operator shall have and provide upon request evidence that could include, but is not limited to, signed agreements, an authority letter signed by an officer of the company, or other equivalent evidence that will be used to confirm that it has the authority, and has exercised the authority, to alleviate operating emergencies as described in Requirement 1.
- M2.** If an operating emergency occurs the Transmission Operator that experienced the emergency shall have and provide upon request evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to determine if it took immediate actions to alleviate the operating emergency including curtailing transmission service or energy schedules, operating equipment (e.g., generators, phase shifters, breakers), shedding firm load, etc. (Requirement 2)
- M3.** Each Transmission Operator, Balancing Authority, and Generator Operator shall have and provide upon request evidence such as operator logs, voice recordings or

transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to determine if it complied with its Reliability Coordinator's reliability directives. If the Transmission Operator, Balancing Authority or Generator Operator did not comply with the directive because it would violate safety, equipment, regulatory or statutory requirements, it shall provide evidence such as operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that it immediately informed the Reliability Coordinator of its inability to perform the directive. (Requirement 3)

- M4.** Each Balancing Authority, Generator Operator, Distribution Provider and Load Serving Entity shall have and provide upon request evidence such as operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to determine if it complied with its Transmission Operator's reliability directives. If the Balancing Authority, Generator Operator, Distribution Provider and Load Serving Entity did not comply with the directive because it would violate safety, equipment, regulatory or statutory requirements, it shall provide evidence such as operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that it immediately informed the Transmission Operator of its inability to perform the directive. (Requirements 3 and 4)
- M5.** The Transmission Operator shall have and provide upon request evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to determine if it informed its Reliability Coordinator and any other potentially affected Transmission Operators of real time or anticipated emergency conditions, and took actions to avoid, when possible, or to mitigate an emergency. (Requirement 5)
- M6.** The Transmission Operator, Balancing Authority, and Generator Operator shall each have and provide upon request evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to determine if it rendered assistance to others as requested, provided that the requesting entity had implemented its comparable emergency procedures, unless such actions would violate safety, equipment, or regulatory or statutory requirements. (Requirement 6)
- M7.** The Transmission Operator and Generator Operator shall each have and provide upon request evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to determine if it notified either their Transmission Operator in the case of the Generator Operator, or other Transmission Operators, and the Reliability Coordinator when it removed Bulk Electric System facilities from service if removing those facilities would burden neighboring systems. (Requirement 7)

D. Compliance

1. Compliance Monitoring Process

1.1. Compliance Monitoring Responsibility

Regional Reliability Organizations shall be responsible for compliance monitoring.

1.2. Compliance Monitoring and Reset Time Frame

One or more of the following methods will be used to assess compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

1.3. Data Retention

Each Transmission Operator shall have the current in-force document to show that it has the responsibility and clear decision-making authority to take whatever actions are needed to ensure the reliability of its area. (Measure 1)

Each Transmission Operator shall keep 90 days of historical data (evidence) for Measures 1 through 7, including evidence of directives issued for Measures 3 and 4.

Each Balancing Authority shall keep 90 days of historical data (evidence) for Measures 3, 4 and 6 including evidence of directives issued for Measures 3 and 4.

Each Generator Operator shall keep 90 days of historical data (evidence) for Measures 3, 4, 6 and 7 including evidence of directives issued for Measures 3 and 4.

Each Distribution Provider and Load-serving Entity shall keep 90 days of historical data (evidence) for Measure 4.

If an entity is found non-compliant the entity shall keep information related to the noncompliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all supporting compliance data

1.4. Additional Compliance Information

None.

2. Levels of Non-Compliance for a Balancing Authority:

2.1. Level 1: Not applicable.

2.2. Level 2: Not applicable.

2.3. Level 3: Not applicable.

2.4. Level 4: There shall be a separate Level 4 non-compliance, for every one of the following requirements that is in violation:

2.4.1 Did not comply with a Reliability Coordinator's or Transmission Operator's reliability directive or did not immediately inform the Reliability Coordinator or Transmission Operator of its inability to perform that directive (R3)

2.4.2 Did not render emergency assistance to others as requested, in accordance with R6.

3. Levels of Non-Compliance for a Transmission Operator

3.1. Level 1: Not applicable.

3.2. Level 2: Not applicable.

3.3. Level 3: Not applicable.

3.4. Level 4: There shall be a separate Level 4 non-compliance, for every one of the following requirements that is in violation:

3.4.1 Does not have the documented authority to act as specified in R1.

3.4.2 Does not have evidence it acted with the authority specified in R1.

3.4.3 Did not take immediate actions to alleviate operating emergencies as specified in R2.

3.4.4 Did not comply with its Reliability Coordinator's reliability directive or did not immediately inform the Reliability Coordinator of its inability to perform that directive, as specified in R3.

3.4.5 Did not inform its Reliability Coordinator and other potentially affected Transmission Operators of real time or anticipated emergency conditions as specified in R5.

3.4.6 Did not take actions to avoid, when possible, or to mitigate an emergency as specified in R5.

3.4.7 Did not render emergency assistance to others as requested, as specified in R6.

3.4.8 Removed Bulk Electric System facilities from service under conditions other than those specified in R7.1, 7.2, and 7.3, and removing those facilities burdened a neighbor system.

4. Levels of Non-Compliance for a Generator Operator:

- 4.1. **Level 1:** Not applicable.
 - 4.2. **Level 2:** Not applicable.
 - 4.3. **Level 3:** Not applicable.
 - 4.4. **Level 4:** There shall be a separate Level 4 non-compliance, for every one of the following requirements that is in violation:
 - 4.4.1 Did not comply with a Reliability Coordinator or Transmission Operator’s reliability directive or did not immediately inform the Reliability Coordinator or Transmission Operator of its inability to perform that directive, as specified in R3.
 - 4.4.2 Did not render all available emergency assistance to others as requested, unless such actions would violate safety, equipment, or regulatory or statutory requirements as specified in R6.
 - 4.4.3 Removed Bulk Electric System facilities from service under conditions other than those specified in R7.1, 7.2, and 7.3, and burdened a neighbor system.
5. **Levels of Non-Compliance for a Distribution Provider or Load Serving Entity**
- 5.1. **Level 1:** Not applicable.
 - 5.2. **Level 2:** Not applicable.
 - 5.3. **Level 3:** Not applicable
 - 5.4. **Level 4:** Did not comply with a Transmission Operator’s reliability directive or immediately inform the Transmission Operator of its inability to perform that directive, as specified in R4.

E. Regional Differences

None identified.

Version History

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Revised
1a	May 12, 2010	Added Appendix 1 – Interpretation of R8 approved by BOT on May 12, 2010	Interpretation
1a	September 15, 2011	FERC Order issued approved the Interpretation of R8 (FERC Order became effective November 21, 2011)	Interpretation

Appendix 1

<p>Requirement Number and Text of Requirement</p>
<p>R8. During a system emergency, the Balancing Authority and Transmission Operator shall immediately take action to restore the Real and Reactive Power Balance. If the Balancing Authority or Transmission Operator is unable to restore Real and Reactive Power Balance it shall request emergency assistance from the Reliability Coordinator. If corrective action or emergency assistance is not adequate to mitigate the Real and Reactive Power Balance, then the Reliability Coordinator, Balancing Authority, and Transmission Operator shall implement firm load shedding.</p>
<p>Question</p>
<p>For Requirement R8 is the Balancing Authority responsibility to immediately take corrective action to restore Real Power Balance and is the TOP responsibility to immediately take corrective action to restore Reactive Power Balance?</p>
<p>Response</p>
<p>The answer to both questions is yes. According to the NERC <i>Glossary of Terms Used in Reliability Standards</i>, the Transmission Operator is responsible for the reliability of its “local” transmission system, and operates or directs the operations of the transmission facilities. Similarly, the Balancing Authority is responsible for maintaining load-interchange-generation balance, i.e., real power balance. In the context of this requirement, the Transmission Operator is the functional entity that balances reactive power. Reactive power balancing can be accomplished by issuing instructions to the Balancing Authority or Generator Operators to alter reactive power injection. Based on NERC Reliability Standard BAL-005-1b Requirement R6, the Transmission Operator has no requirement to compute an Area Control Error (ACE) signal or to balance real power. Based on NERC Reliability Standard VAR-001-1 Requirement R8, the Balancing Authority is not required to resolve reactive power balance issues. According to TOP-001-1 Requirement R3, the Balancing Authority is only required to comply with Transmission Operator or Reliability Coordinator instructions to change injections of reactive power.</p>

A. Introduction

- 1. Title:** System Performance Following Loss of a Single Bulk Electric System Element (Category B)
- 2. Number:** TPL-002-0b
- 3. Purpose:** System simulations and associated assessments are needed periodically to ensure that reliable systems are developed that meet specified performance requirements with sufficient lead time, and continue to be modified or upgraded as necessary to meet present and future system needs.
- 4. Applicability:**
 - 4.1.** Planning Authority
 - 4.2.** Transmission Planner
- 5. Effective Date:** Immediately after approval of applicable regulatory authorities.

B. Requirements

- R1.** The Planning Authority and Transmission Planner shall each demonstrate through a valid assessment that its portion of the interconnected transmission system is planned such that the Network can be operated to supply projected customer demands and projected Firm (non-recallable reserved) Transmission Services, at all demand levels over the range of forecast system demands, under the contingency conditions as defined in Category B of Table I. To be valid, the Planning Authority and Transmission Planner assessments shall:
 - R1.1.** Be made annually.
 - R1.2.** Be conducted for near-term (years one through five) and longer-term (years six through ten) planning horizons.
 - R1.3.** Be supported by a current or past study and/or system simulation testing that addresses each of the following categories, showing system performance following Category B of Table 1 (single contingencies). The specific elements selected (from each of the following categories) for inclusion in these studies and simulations shall be acceptable to the associated Regional Reliability Organization(s).
 - R1.3.1.** Be performed and evaluated only for those Category B contingencies that would produce the more severe System results or impacts. The rationale for the contingencies selected for evaluation shall be available as supporting information. An explanation of why the remaining simulations would produce less severe system results shall be available as supporting information.
 - R1.3.2.** Cover critical system conditions and study years as deemed appropriate by the responsible entity.
 - R1.3.3.** Be conducted annually unless changes to system conditions do not warrant such analyses.
 - R1.3.4.** Be conducted beyond the five-year horizon only as needed to address identified marginal conditions that may have longer lead-time solutions.
 - R1.3.5.** Have all projected firm transfers modeled.
 - R1.3.6.** Be performed and evaluated for selected demand levels over the range of forecast system Demands.

1.2. Compliance Monitoring Period and Reset Timeframe

Annually.

1.3. Data Retention

None specified.

1.4. Additional Compliance Information

None.

2. Levels of Non-Compliance

2.1. Level 1: Not applicable.

2.2. Level 2: A valid assessment and corrective plan for the longer-term planning horizon is not available.

2.3. Level 3: Not applicable.

2.4. Level 4: A valid assessment and corrective plan for the near-term planning horizon is not available.

E. Regional Differences

1. None identified.

Version History

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0a	October 23, 2008	Added Appendix 1 – Interpretation of TPL-002-0 Requirements R1.3.2 and R1.3.12 and TPL-003-0 Requirements R1.3.2 and R1.3.12 for Ameren and MISO	Revised
0b	November 5, 2009	Added Appendix 2 – Interpretation of R1.3.10 approved by BOT on November 5, 2009	Interpretation
0b	September 19, 2011	FERC Order issued approving the Interpretation of R1.3.10 (FERC Order becomes effective October 24, 2011)	Interpretation

Table I. Transmission System Standards — Normal and Emergency Conditions

Category	Contingencies	System Limits or Impacts		
	Initiating Event(s) and Contingency Element(s)	System Stable and both Thermal and Voltage Limits within Applicable Rating ^a	Loss of Demand or Curtailed Firm Transfers	Cascading Outages
A No Contingencies	All Facilities in Service	Yes	No	No
B Event resulting in the loss of a single element.	Single Line Ground (SLG) or 3-Phase (3Ø) Fault, with Normal Clearing: 1. Generator 2. Transmission Circuit 3. Transformer Loss of an Element without a Fault.	Yes Yes Yes Yes	No ^b No ^b No ^b No ^b	No No No No
	Single Pole Block, Normal Clearing ^c : 4. Single Pole (dc) Line	Yes	No ^b	No
C Event(s) resulting in the loss of two or more (multiple) elements.	SLG Fault, with Normal Clearing ^c : 1. Bus Section	Yes	Planned/ Controlled ^c	No
	2. Breaker (failure or internal Fault)	Yes	Planned/ Controlled ^c	No
	SLG or 3Ø Fault, with Normal Clearing ^c , Manual System Adjustments, followed by another SLG or 3Ø Fault, with Normal Clearing ^c : 3. Category B (B1, B2, B3, or B4) contingency, manual system adjustments, followed by another Category B (B1, B2, B3, or B4) contingency	Yes	Planned/ Controlled ^c	No
	Bipolar Block, with Normal Clearing ^c : 4. Bipolar (dc) Line Fault (non 3Ø), with Normal Clearing ^c :	Yes	Planned/ Controlled ^c	No
	5. Any two circuits of a multiple circuit towerline ^f	Yes	Planned/ Controlled ^c	No
SLG Fault, with Delayed Clearing ^c (stuck breaker or protection system failure):	6. Generator	Yes	Planned/ Controlled ^c	No
	7. Transformer	Yes	Planned/ Controlled ^c	No
	8. Transmission Circuit	Yes	Planned/ Controlled ^c	No
	9. Bus Section	Yes	Planned/ Controlled ^c	No

<p>D^d</p> <p>Extreme event resulting in two or more (multiple) elements removed or Cascading out of service</p>	<p>3Ø Fault, with Delayed Clearing^e (stuck breaker or protection system failure):</p> <table border="0"> <tr> <td>1. Generator</td> <td>3. Transformer</td> </tr> <tr> <td>2. Transmission Circuit</td> <td>4. Bus Section</td> </tr> </table> <hr/> <p>3Ø Fault, with Normal Clearing^e:</p> <hr/> <ol style="list-style-type: none"> 5. Breaker (failure or internal Fault) 6. Loss of towerline with three or more circuits 7. All transmission lines on a common right-of way 8. Loss of a substation (one voltage level plus transformers) 9. Loss of a switching station (one voltage level plus transformers) 10. Loss of all generating units at a station 11. Loss of a large Load or major Load center 12. Failure of a fully redundant Special Protection System (or remedial action scheme) to operate when required 13. Operation, partial operation, or misoperation of a fully redundant Special Protection System (or Remedial Action Scheme) in response to an event or abnormal system condition for which it was not intended to operate 14. Impact of severe power swings or oscillations from Disturbances in another Regional Reliability Organization. 	1. Generator	3. Transformer	2. Transmission Circuit	4. Bus Section	<p>Evaluate for risks and consequences.</p> <ul style="list-style-type: none"> ▪ May involve substantial loss of customer Demand and generation in a widespread area or areas. ▪ Portions or all of the interconnected systems may or may not achieve a new, stable operating point. ▪ Evaluation of these events may require joint studies with neighboring systems.
1. Generator	3. Transformer					
2. Transmission Circuit	4. Bus Section					

- a) Applicable rating refers to the applicable Normal and Emergency facility thermal Rating or system voltage limit as determined and consistently applied by the system or facility owner. Applicable Ratings may include Emergency Ratings applicable for short durations as required to permit operating steps necessary to maintain system control. All Ratings must be established consistent with applicable NERC Reliability Standards addressing Facility Ratings.
- b) Planned or controlled interruption of electric supply to radial customers or some local Network customers, connected to or supplied by the Faulted element or by the affected area, may occur in certain areas without impacting the overall reliability of the interconnected transmission systems. To prepare for the next contingency, system adjustments are permitted, including curtailments of contracted Firm (non-recallable reserved) electric power Transfers.
- c) Depending on system design and expected system impacts, the controlled interruption of electric supply to customers (load shedding), the planned removal from service of certain generators, and/or the curtailment of contracted Firm (non-recallable reserved) electric power Transfers may be necessary to maintain the overall reliability of the interconnected transmission systems.
- d) A number of extreme contingencies that are listed under Category D and judged to be critical by the transmission planning entity(ies) will be selected for evaluation. It is not expected that all possible facility outages under each listed contingency of Category D will be evaluated.
- e) Normal clearing is when the protection system operates as designed and the Fault is cleared in the time normally expected with proper functioning of the installed protection systems. Delayed clearing of a Fault is due to failure of any protection system component such as a relay, circuit breaker, or current transformer, and not because of an intentional design delay.
- f) System assessments may exclude these events where multiple circuit towers are used over short distances (e.g., station entrance, river crossings) in accordance with Regional exemption criteria.

Appendix 1

Interpretation of TPL-002-0 Requirements R1.3.2 and R1.3.12 and TPL-003-0 Requirements R1.3.2 and R1.3.12 for Ameren and MISO

NERC received two requests for interpretation of identical requirements (Requirements R1.3.2 and R1.3.12) in TPL-002-0 and TPL-003-0 from the Midwest ISO and Ameren. These requirements state:

TPL-002-0:

[To be valid, the Planning Authority and Transmission Planner assessments shall:]

- R1.3** Be supported by a current or past study and/or system simulation testing that addresses each of the following categories, showing system performance following Category B of Table 1 (single contingencies). The specific elements selected (from each of the following categories) for inclusion in these studies and simulations shall be acceptable to the associated Regional Reliability Organization(s).
- R1.3.2** Cover critical system conditions and study years as deemed appropriate by the responsible entity.
- R1.3.12** Include the planned (including maintenance) outage of any bulk electric equipment (including protection systems or their components) at those demand levels for which planned (including maintenance) outages are performed.

TPL-003-0:

[To be valid, the Planning Authority and Transmission Planner assessments shall:]

- R1.3** Be supported by a current or past study and/or system simulation testing that addresses each of the following categories, showing system performance following Category C of Table 1 (multiple contingencies). The specific elements selected (from each of the following categories) for inclusion in these studies and simulations shall be acceptable to the associated Regional Reliability Organization(s).
- R1.3.2** Cover critical system conditions and study years as deemed appropriate by the responsible entity.
- R1.3.12** Include the planned (including maintenance) outage of any bulk electric equipment (including protection systems or their components) at those demand levels for which planned (including maintenance) outages are performed.

Requirement R1.3.2

Request for Interpretation of TPL-002-0 and TPL-003-0 Requirement R1.3.2 Received from Ameren on July 25, 2007:

Ameren specifically requests clarification on the phrase, 'critical system conditions' in R1.3.2. Ameren asks if compliance with R1.3.2 requires multiple contingent generating unit Outages as part of possible generation dispatch scenarios describing critical system conditions for which the system shall be planned and modeled in accordance with the contingency definitions included in Table 1.

**Request for Interpretation of TPL-002-0 and TPL-003-0 Requirement R1.3.2
Received from MISO on August 9, 2007:**

MISO asks if the TPL standards require that any specific dispatch be applied, other than one that is representative of supply of firm demand and transmission service commitments, in the modeling of system contingencies specified in Table 1 in the TPL standards.

MISO then asks if a variety of possible dispatch patterns should be included in planning analyses including a probabilistically based dispatch that is representative of generation deficiency scenarios, would it be an appropriate application of the TPL standard to apply the transmission contingency conditions in Category B of Table 1 to these possible dispatch pattern.

The following interpretation of TPL-002-0 and TPL-003-0 Requirement R1.3.2 was developed by the NERC Planning Committee on March 13, 2008:

The selection of a credible generation dispatch for the modeling of critical system conditions is within the discretion of the Planning Authority. The Planning Authority was renamed “Planning Coordinator” (PC) in the Functional Model dated February 13, 2007. (TPL -002 and -003 use the former “Planning Authority” name, and the Functional Model terminology was a change in name only and did not affect responsibilities.)

- Under the Functional Model, the Planning Coordinator “Provides and informs Resource Planners, Transmission Planners, and adjacent Planning Coordinators of the methodologies and tools for the simulation of the transmission system” while the Transmission Planner “Receives from the Planning Coordinator methodologies and tools for the analysis and development of transmission expansion plans.” A PC’s selection of “critical system conditions” and its associated generation dispatch falls within the purview of “methodology.”

Furthermore, consistent with this interpretation, a Planning Coordinator would formulate critical system conditions that may involve a range of critical generator unit outages as part of the possible generator dispatch scenarios.

Both TPL-002-0 and TPL-003-0 have a similar measure M1:

- M1.** The Planning Authority and Transmission Planner shall have a valid assessment and corrective plans as specified in Reliability Standard TPL-002-0_R1 [or TPL-003-0_R1] and TPL-002-0_R2 [or TPL-003-0_R2].”

The Regional Reliability Organization (RRO) is named as the Compliance Monitor in both standards. Pursuant to Federal Energy Regulatory Commission (FERC) Order 693, FERC eliminated the RRO as the appropriate Compliance Monitor for standards and replaced it with the Regional Entity (RE). See paragraph 157 of Order 693. Although the referenced TPL standards still include the reference to the RRO, to be consistent with Order 693, the RRO is replaced by the RE as the Compliance Monitor for this interpretation. As the Compliance Monitor, the RE determines what a “valid assessment” means when evaluating studies based upon specific sub-requirements in R1.3 selected by the Planning Coordinator and the Transmission Planner. If a PC has Transmission Planners in more than one region, the REs must coordinate among themselves on compliance matters.

Requirement R1.3.12

Request for Interpretation of TPL-002-0 and TPL-003-0 Requirement R1.3.12 Received from Ameren on July 25, 2007:

Ameren also asks how the inclusion of planned outages should be interpreted with respect to the contingency definitions specified in Table 1 for Categories B and C. Specifically, Ameren asks if R1.3.12 requires that the system be planned to be operated during those conditions associated with planned outages consistent with the performance requirements described in Table 1 plus any unidentified outage.

Request for Interpretation of TPL-002-0 and TPL-003-0 Requirement R1.3.12 Received from MISO on August 9, 2007:

MISO asks if the term “planned outages” means only already known/scheduled planned outages that may continue into the planning horizon, or does it include potential planned outages not yet scheduled that may occur at those demand levels for which planned (including maintenance) outages are performed?

If the requirement does include not yet scheduled but potential planned outages that could occur in the planning horizon, is the following a proper interpretation of this provision?

The system is adequately planned and in accordance with the standard if, in order for a system operator to potentially schedule such a planned outage on the future planned system, planning studies show that a system adjustment (load shed, re-dispatch of generating units in the interconnection, or system reconfiguration) would be required concurrent with taking such a planned outage in order to prepare for a Category B contingency (single element forced out of service)? In other words, should the system in effect be planned to be operated as for a Category C3 n-2 event, even though the first event is a planned base condition?

If the requirement is intended to mean only known and scheduled planned outages that will occur or may continue into the planning horizon, is this interpretation consistent with the original interpretation by NERC of the standard as provided by NERC in response to industry questions in the Phase I development of this standard?

The following interpretation of TPL-002-0 and TPL-003-0 Requirement R1.3.12 was developed by the NERC Planning Committee on March 13, 2008:

This provision was not previously interpreted by NERC since its approval by FERC and other regulatory authorities. TPL-002-0 and TPL-003-0 explicitly provide that the inclusion of planned (including maintenance) outages of any bulk electric equipment at demand levels for which the planned outages are required. For studies that include planned outages, compliance with the contingency assessment for TPL-002-0 and TPL-003-0 as outlined in Table 1 would include any necessary system adjustments which might be required to accommodate planned outages since a planned outage is not a “contingency” as defined in the *NERC Glossary of Terms Used in Standards*.

Appendix 2

Requirement Number and Text of Requirement
<p>R1.3. Be supported by a current or past study and/or system simulation testing that addresses each of the following categories, showing system performance following Category B of Table 1 (single contingencies). The specific elements selected (from each of the following categories) for inclusion in these studies and simulations shall be acceptable to the associated Regional Reliability Organization(s).</p> <p style="padding-left: 40px;">R1.3.10. Include the effects of existing and planned protection systems, including any backup or redundant systems.</p>
Background Information for Interpretation
<p>Requirement R1.3 and sub-requirement R1.3.10 of standard TPL-002-0a contain three key obligations:</p> <ol style="list-style-type: none"> 1. That the assessment is supported by “study and/or system simulation testing that addresses each the following categories, showing system performance following Category B of Table 1 (single contingencies).” 2. “...these studies and simulations shall be acceptable to the associated Regional Reliability Organization(s).” 3. “Include the effects of existing and planned protection systems, including any backup or redundant systems.” <p><i>Category B of Table 1 (single Contingencies) specifies:</i></p> <p>Single Line Ground (SLG) or 3-Phase (3Ø) Fault, with Normal Clearing:</p> <ol style="list-style-type: none"> 1. Generator 2. Transmission Circuit 3. Transformer <p>Loss of an Element without a Fault.</p> <p>Single Pole Block, Normal Clearing^e:</p> <ol style="list-style-type: none"> 4. Single Pole (dc) Line <p><i>Note e specifies:</i></p> <p>e) Normal Clearing is when the protection system operates as designed and the Fault is cleared in the time normally expected with proper functioning of the installed protection systems. Delayed clearing of a Fault is due to failure of any protection system component such as a relay, circuit breaker, or current transformer, and not because of an intentional design delay.</p> <p>The NERC Glossary of Terms defines Normal Clearing as “A protection system operates as designed and the fault is cleared in the time normally expected with proper functioning of the installed protection systems.”</p>
Conclusion
<p>TPL-002-0a requires that System studies or simulations be made to assess the impact of single Contingency operation with Normal Clearing. TPL-002-0a R1.3.10 does require that all elements expected to be removed from service through normal operations of the Protection Systems be removed in simulations.</p> <p>This standard does not require an assessment of the Transmission System performance due to a Protection System failure or Protection System misoperation. Protection System failure or Protection System misoperation is addressed in TPL-003-0 — System Performance following Loss of Two or More Bulk</p>

Electric System Elements (Category C) and TPL-004-0 — System Performance Following Extreme Events Resulting in the Loss of Two or More Bulk Electric System Elements (Category D).

TPL-002-0a R1.3.10 does not require simulating anything other than Normal Clearing when assessing the impact of a Single Line Ground (SLG) or 3-Phase (3 \emptyset) Fault on the performance of the Transmission System.

In regards to PacifiCorp’s comments on the material impact associated with this interpretation, the interpretation team has the following comment:

Requirement R2.1 requires “a written summary of plans to achieve the required system performance,” including a schedule for implementation and an expected in-service date that considers lead times necessary to implement the plan. Failure to provide such summary may lead to noncompliance that could result in penalties and sanctions.

3.) Updated NERC Glossary of Terms for approval

Glossary of Terms Used in NERC Reliability Standards

Updated October 26, 2011

Introduction:

This Glossary lists each term that was defined for use in one or more of NERC's continent-wide or Regional Reliability Standards and adopted by the NERC Board of Trustees from February 8, 2005 through August 4, 2011.

This reference is divided into two sections, and each section is organized in alphabetical order. The first section identifies all terms that have been adopted by the NERC Board of Trustees for use in continent-wide standards; the second section identifies all terms that have been adopted by the NERC Board of Trustees for use in regional standards. (WECC, NPCC and ReliabilityFirst are the only Regions that have definitions approved by the NERC Board of Trustees. If other Regions develop definitions for approved Regional Standards using a NERC-approved standards development process, those definitions will be added to the Regional Definitions section of this glossary.)

Most of the terms identified in this glossary were adopted as part of the development of NERC's initial set of reliability standards, called the "Version 0" standards. Subsequent to the development of Version 0 standards, new definitions have been developed and approved following NERC's Reliability Standards Development Process, and added to this glossary following board adoption, with the "FERC approved" date added following a final Order approving the definition.

Immediately under each term is a link to the archive for the development of that term.

Definitions that have been adopted by the NERC Board of Trustees but have not been approved by FERC, or FERC has not approved but has directed be modified, are shaded in blue. Definitions that have been remanded or retired are shaded in orange.

Any comments regarding this glossary should be reported to the following: sarcomm@nerc.com with "Glossary Comment" in the subject line.

Continent-wide Definitions:

A	4
B	8
C	10
D	14
E	17
F	19
G	22
H	22
I	23
J	25
L	26
M	26
N	27
O	30
P	33
R	35
S	40
T	43
V	46
W	46

Regional Definitions

ReliabilityFirst Regional Definitions 48

NPCC Regional Definitions 49

WECC Regional Definitions 50

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approval Date	FERC Approval Date	Definition
Adequacy [Archive]		2/8/2005	3/16/2007	The ability of the electric system to supply the aggregate electrical demand and energy requirements of the end-use customers at all times, taking into account scheduled and reasonably expected unscheduled outages of system elements.
Adjacent Balancing Authority [Archive]		2/8/2005	3/16/2007	A Balancing Authority Area that is interconnected another Balancing Authority Area either directly or via a multi-party agreement or transmission tariff.
Adverse Reliability Impact [Archive]		2/7/2006	3/16/2007	The impact of an event that results in frequency-related instability; unplanned tripping of load or generation; or uncontrolled separation or cascading outages that affects a widespread area of the Interconnection.
Adverse Reliability Impact [Archive]		8/4/2011		The impact of an event that results in Bulk Electric System instability or Cascading.
After the Fact [Archive]	ATF	10/29/2008	12/17/2009	A time classification assigned to an RFI when the submittal time is greater than one hour after the start time of the RFI.
Agreement [Archive]		2/8/2005	3/16/2007	A contract or arrangement, either written or verbal and sometimes enforceable by law.
Altitude Correction Factor [Archive]		2/7/2006	3/16/2007	A multiplier applied to specify distances, which adjusts the distances to account for the change in relative air density (RAD) due to altitude from the RAD used to determine the specified distance. Altitude correction factors apply to both minimum worker approach distances and to minimum vegetation clearance distances.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approval Date	FERC Approval Date	Definition
Ancillary Service [Archive]		2/8/2005	3/16/2007	Those services that are necessary to support the transmission of capacity and energy from resources to loads while maintaining reliable operation of the Transmission Service Provider's transmission system in accordance with good utility practice. (<i>From FERC order 888-A.</i>)
Anti-Aliasing Filter [Archive]		2/8/2005	3/16/2007	An analog filter installed at a metering point to remove the high frequency components of the signal over the AGC sample period.
Area Control Error [Archive]	ACE	2/8/2005	3/16/2007	The instantaneous difference between a Balancing Authority's net actual and scheduled interchange, taking into account the effects of Frequency Bias and correction for meter error.
Area Interchange Methodology [Archive]		08/22/2008	11/24/2009	The Area Interchange methodology is characterized by determination of incremental transfer capability via simulation, from which Total Transfer Capability (TTC) can be mathematically derived. Capacity Benefit Margin, Transmission Reliability Margin, and Existing Transmission Commitments are subtracted from the TTC, and Postbacks and counterflows are added, to derive Available Transfer Capability. Under the Area Interchange Methodology, TTC results are generally reported on an area to area basis.
Arranged Interchange [Archive]		5/2/2006	3/16/2007	The state where the Interchange Authority has received the Interchange information (initial or revised).
Automatic Generation Control [Archive]	AGC	2/8/2005	3/16/2007	Equipment that automatically adjusts generation in a Balancing Authority Area from a central location to maintain the Balancing Authority's interchange schedule plus Frequency Bias. AGC may also accommodate automatic inadvertent payback and time error correction.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approval Date	FERC Approval Date	Definition
Available Flowgate Capability [Archive]	AFC	08/22/2008	11/24/2009	A measure of the flow capability remaining on a Flowgate for further commercial activity over and above already committed uses. It is defined as TFC less Existing Transmission Commitments (ETC), less a Capacity Benefit Margin, less a Transmission Reliability Margin, plus Postbacks, and plus counterflows.
Available Transfer Capability [Archive]	ATC	2/8/2005	3/16/2007	A measure of the transfer capability remaining in the physical transmission network for further commercial activity over and above already committed uses. It is defined as Total Transfer Capability less existing transmission commitments (including retail customer service), less a Capacity Benefit Margin, less a Transmission Reliability Margin.
Available Transfer Capability [Archive]	ATC	08/22/2008	11/24/2009	A measure of the transfer capability remaining in the physical transmission network for further commercial activity over and above already committed uses. It is defined as Total Transfer Capability less Existing Transmission Commitments (including retail customer service), less a Capacity Benefit Margin, less a Transmission Reliability Margin, plus Postbacks, plus counterflows.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approval Date	FERC Approval Date	Definition
Available Transfer Capability Implementation Document [Archive]	ATCID	08/22/2008	11/24/2009	A document that describes the implementation of a methodology for calculating ATC or AFC, and provides information related to a Transmission Service Provider's calculation of ATC or AFC.
ATC Path [Archive]		08/22/2008	Not approved; Modification directed 11/24/09	Any combination of Point of Receipt and Point of Delivery for which ATC is calculated; and any Posted Path ¹ .

¹ See 18 CFR 37.6(b)(1)

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Balancing Authority [Archive]	BA	2/8/2005	3/16/2007	The responsible entity that integrates resource plans ahead of time, maintains load-interchange-generation balance within a Balancing Authority Area, and supports Interconnection frequency in real time.
Balancing Authority Area [Archive]		2/8/2005	3/16/2007	The collection of generation, transmission, and loads within the metered boundaries of the Balancing Authority. The Balancing Authority maintains load-resource balance within this area.
Base Load [Archive]		2/8/2005	3/16/2007	The minimum amount of electric power delivered or required over a given period at a constant rate.
Blackstart Capability Plan [Archive]		2/8/2005 Approved Retirement when EOP-005-2 becomes effective 8/5/2009	3/16/2007	A documented procedure for a generating unit or station to go from a shutdown condition to an operating condition delivering electric power without assistance from the electric system. This procedure is only a portion of an overall system restoration plan.
Blackstart Resource [Archive]		8/5/2009		A generating unit(s) and its associated set of equipment which has the ability to be started without support from the System or is designed to remain energized without connection to the remainder of the System, with the ability to energize a bus, meeting the Transmission Operator's restoration plan needs for real and reactive power capability, frequency and voltage control, and that has been included in the Transmission Operator's restoration plan

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Block Dispatch [Archive]		08/22/2008	11/24/2009	A set of dispatch rules such that given a specific amount of load to serve, an approximate generation dispatch can be determined. To accomplish this, the capacity of a given generator is segmented into loadable "blocks," each of which is grouped and ordered relative to other blocks (based on characteristics including, but not limited to, efficiency, run of river or fuel supply considerations, and/or "must-run" status).
Bulk Electric System [Archive]		2/8/2005	3/16/2007	As defined by the Regional Reliability Organization, the electrical generation resources, transmission lines, interconnections with neighboring systems, and associated equipment, generally operated at voltages of 100 kV or higher. Radial transmission facilities serving only load with one transmission source are generally not included in this definition.
Burden [Archive]		2/8/2005	3/16/2007	Operation of the Bulk Electric System that violates or is expected to violate a System Operating Limit or Interconnection Reliability Operating Limit in the Interconnection, or that violates any other NERC, Regional Reliability Organization, or local operating reliability standards or criteria.
Business Practices [Archive]		8/22/2008	Not approved; Modification directed 11/24/09	Those business rules contained in the Transmission Service Provider's applicable tariff, rules, or procedures; associated Regional Reliability Organization or regional entity business practices; or NAESB Business Practices.
Bus-tie Breaker [Archive]		8/4/2011		A circuit breaker that is positioned to connect two individual substation bus configurations.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Capacity Benefit Margin [Archive]	CBM	2/8/2005	3/16/2007	The amount of firm transmission transfer capability preserved by the transmission provider for Load-Serving Entities (LSEs), whose loads are located on that Transmission Service Provider's system, to enable access by the LSEs to generation from interconnected systems to meet generation reliability requirements. Preservation of CBM for an LSE allows that entity to reduce its installed generating capacity below that which may otherwise have been necessary without interconnections to meet its generation reliability requirements. The transmission transfer capability preserved as CBM is intended to be used by the LSE only in times of emergency generation deficiencies.
Capacity Benefit Margin Implementation Document [Archive]	CBMID	11/13/2008	11/24/2009	A document that describes the implementation of a Capacity Benefit Margin methodology.
Capacity Emergency [Archive]		2/8/2005	3/16/2007	A capacity emergency exists when a Balancing Authority Area's operating capacity, plus firm purchases from other systems, to the extent available or limited by transfer capability, is inadequate to meet its demand plus its regulating requirements.
Cascading [Archive]		2/8/2005	3/16/2007	The uncontrolled successive loss of system elements triggered by an incident at any location. Cascading results in widespread electric service interruption that cannot be restrained from sequentially spreading beyond an area predetermined by studies.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Cascading Outages [Archive]		11/1/2006 Withdrawn 2/12/2008	FERC Remanded 12/27/2007	The uncontrolled successive loss of Bulk Electric System Facilities triggered by an incident (or condition) at any location resulting in the interruption of electric service that cannot be restrained from spreading beyond a pre-determined area.
Clock Hour [Archive]		2/8/2005	3/16/2007	The 60-minute period ending at :00. All surveys, measurements, and reports are based on Clock Hour periods unless specifically noted.
Cogeneration [Archive]		2/8/2005	3/16/2007	Production of electricity from steam, heat, or other forms of energy produced as a by-product of another process.
Compliance Monitor [Archive]		2/8/2005	3/16/2007	The entity that monitors, reviews, and ensures compliance of responsible entities with reliability standards.
Confirmed Interchange [Archive]		5/2/2006	3/16/2007	The state where the Interchange Authority has verified the Arranged Interchange.
Congestion Management Report [Archive]		2/8/2005	3/16/2007	A report that the Interchange Distribution Calculator issues when a Reliability Coordinator initiates the Transmission Loading Relief procedure. This report identifies the transactions and native and network load curtailments that must be initiated to achieve the loading relief requested by the initiating Reliability Coordinator.
Consequential Load Loss [Archive]		8/4/2011		All Load that is no longer served by the Transmission system as a result of Transmission Facilities being removed from service by a Protection System operation designed to isolate the fault.
Constrained Facility [Archive]		2/8/2005	3/16/2007	A transmission facility (line, transformer, breaker, etc.) that is approaching, is at, or is beyond its System Operating Limit or Interconnection Reliability Operating Limit.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Contingency [Archive]		2/8/2005	3/16/2007	The unexpected failure or outage of a system component, such as a generator, transmission line, circuit breaker, switch or other electrical element.
Contingency Reserve [Archive]		2/8/2005	3/16/2007	The provision of capacity deployed by the Balancing Authority to meet the Disturbance Control Standard (DCS) and other NERC and Regional Reliability Organization contingency requirements.
Contract Path [Archive]		2/8/2005	3/16/2007	An agreed upon electrical path for the continuous flow of electrical power between the parties of an Interchange Transaction.
Control Performance Standard [Archive]	CPS	2/8/2005	3/16/2007	The reliability standard that sets the limits of a Balancing Authority's Area Control Error over a specified time period.
Corrective Action Plan [Archive]		2/7/2006	3/16/2007	A list of actions and an associated timetable for implementation to remedy a specific problem.
Cranking Path [Archive]		5/2/2006	3/16/2007	A portion of the electric system that can be isolated and then energized to deliver electric power from a generation source to enable the startup of one or more other generating units.
Critical Assets [Archive]		5/2/2006	1/18/2008	Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.
Critical Cyber Assets [Archive]		5/2/2006	1/18/2008	Cyber Assets essential to the reliable operation of Critical Assets.
Curtailment [Archive]		2/8/2005	3/16/2007	A reduction in the scheduled capacity or energy delivery of an Interchange Transaction.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Curtailment Threshold [Archive]		2/8/2005	3/16/2007	The minimum Transfer Distribution Factor which, if exceeded, will subject an Interchange Transaction to curtailment to relieve a transmission facility constraint.
Cyber Assets [Archive]		5/2/2006	1/18/2008	Programmable electronic devices and communication networks including hardware, software, and data.
Cyber Security Incident [Archive]		5/2/2006	1/18/2008	Any malicious act or suspicious event that: <ul style="list-style-type: none"> • Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or, • Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Delayed Fault Clearing [Archive]		11/1/2006	12/27/2007	Fault clearing consistent with correct operation of a breaker failure protection system and its associated breakers, or of a backup protection system with an intentional time delay.
Demand [Archive]		2/8/2005	3/16/2007	<ol style="list-style-type: none"> 1. The rate at which electric energy is delivered to or by a system or part of a system, generally expressed in kilowatts or megawatts, at a given instant or averaged over any designated interval of time. 2. The rate at which energy is being used by the customer.
Demand-Side Management [Archive]	DSM	2/8/2005	3/16/2007	The term for all activities or programs undertaken by Load-Serving Entity or its customers to influence the amount or timing of electricity they use.
Direct Control Load Management [Archive]	DCLM	2/8/2005	3/16/2007	Demand-Side Management that is under the direct control of the system operator. DCLM may control the electric supply to individual appliances or equipment on customer premises. DCLM as defined here does not include Interruptible Demand.
Dispatch Order [Archive]		08/22/2008	11/24/2009	A set of dispatch rules such that given a specific amount of load to serve, an approximate generation dispatch can be determined. To accomplish this, each generator is ranked by priority.
Dispersed Load by Substations [Archive]		2/8/2005	3/16/2007	Substation load information configured to represent a system for power flow or system dynamics modeling purposes, or both.
Distribution Factor [Archive]	DF	2/8/2005	3/16/2007	The portion of an Interchange Transaction, typically expressed in per unit that flows across a transmission facility (Flowgate).

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Distribution Provider [Archive]		2/8/2005	3/16/2007	Provides and operates the “wires” between the transmission system and the end-use customer. For those end-use customers who are served at transmission voltages, the Transmission Owner also serves as the Distribution Provider. Thus, the Distribution Provider is not defined by a specific voltage, but rather as performing the Distribution function at any voltage.
Disturbance [Archive]		2/8/2005	3/16/2007	<ol style="list-style-type: none"> 1. An unplanned event that produces an abnormal system condition. 2. Any perturbation to the electric system. 3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.
Disturbance Control Standard [Archive]	DCS	2/8/2005	3/16/2007	The reliability standard that sets the time limit following a Disturbance within which a Balancing Authority must return its Area Control Error to within a specified range.
Disturbance Monitoring Equipment [Archive]	DME	8/2/2006	3/16/2007	<p>Devices capable of monitoring and recording system data pertaining to a Disturbance. Such devices include the following categories of recorders²:</p> <ul style="list-style-type: none"> • Sequence of event recorders which record equipment response to the event • Fault recorders, which record actual waveform data replicating the system primary voltages and currents. This may include protective relays. • Dynamic Disturbance Recorders (DDRs), which record incidents that portray power system behavior during dynamic events such as low-frequency (0.1 Hz – 3 Hz) oscillations and abnormal frequency or voltage excursions

² Phasor Measurement Units and any other equipment that meets the functional requirements of DMEs may qualify as DMEs.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Dynamic Interchange Schedule or Dynamic Schedule [Archive]		2/8/2005	3/16/2007	A telemetered reading or value that is updated in real time and used as a schedule in the AGC/ACE equation and the integrated value of which is treated as a schedule for interchange accounting purposes. Commonly used for scheduling jointly owned generation to or from another Balancing Authority Area.
Dynamic Transfer [Archive]		2/8/2005	3/16/2007	The provision of the real-time monitoring, telemetering, computer software, hardware, communications, engineering, energy accounting (including inadvertent interchange), and administration required to electronically move all or a portion of the real energy services associated with a generator or load out of one Balancing Authority Area into another.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Economic Dispatch [Archive]		2/8/2005	3/16/2007	The allocation of demand to individual generating units on line to effect the most economical production of electricity.
Electrical Energy [Archive]		2/8/2005	3/16/2007	The generation or use of electric power by a device over a period of time, expressed in kilowatthours (kWh), megawatthours (MWh), or gigawatthours (GWh).
Electronic Security Perimeter [Archive]		5/2/2006	1/18/2008	The logical border surrounding a network to which Critical Cyber Assets are connected and for which access is controlled.
Element [Archive]		2/8/2005	3/16/2007	Any electrical device with terminals that may be connected to other electrical devices such as a generator, transformer, circuit breaker, bus section, or transmission line. An element may be comprised of one or more components.
Emergency or BES Emergency [Archive]		2/8/2005	3/16/2007	Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System.
Emergency Rating [Archive]		2/8/2005	3/16/2007	The rating as defined by the equipment owner that specifies the level of electrical loading or output, usually expressed in megawatts (MW) or Mvar or other appropriate units, that a system, facility, or element can support, produce, or withstand for a finite period. The rating assumes acceptable loss of equipment life or other physical or safety limitations for the equipment involved.
Emergency Request for Interchange (Emergency RFI) [Archive]		10/29/2008	12/17/2009	Request for Interchange to be initiated for Emergency or Energy Emergency conditions.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Energy Emergency [Archive]		2/8/2005	3/16/2007	A condition when a Load-Serving Entity has exhausted all other options and can no longer provide its customers' expected energy requirements.
Equipment Rating [Archive]		2/7/2006	3/16/2007	The maximum and minimum voltage, current, frequency, real and reactive power flows on individual equipment under steady state, short-circuit and transient conditions, as permitted or assigned by the equipment owner.
Existing Transmission Commitments [Archive]	ETC	08/22/2008	11/24/2009	Committed uses of a Transmission Service Provider's Transmission system considered when determining ATC or AFC.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Facility [Archive]		2/7/2006	3/16/2007	A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)
Facility Rating [Archive]		2/8/2005	3/16/2007	The maximum or minimum voltage, current, frequency, or real or reactive power flow through a facility that does not violate the applicable equipment rating of any equipment comprising the facility.
Fault [Archive]		2/8/2005	3/16/2007	An event occurring on an electric system such as a short circuit, a broken wire, or an intermittent connection.
Fire Risk [Archive]		2/7/2006	3/16/2007	The likelihood that a fire will ignite or spread in a particular geographic area.
Firm Demand [Archive]		2/8/2005	3/16/2007	That portion of the Demand that a power supplier is obligated to provide except when system reliability is threatened or during emergency conditions.
Firm Transmission Service [Archive]		2/8/2005	3/16/2007	The highest quality (priority) service offered to customers under a filed rate schedule that anticipates no planned interruption.
Flashover [Archive]		2/7/2006	3/16/2007	An electrical discharge through air around or over the surface of insulation, between objects of different potential, caused by placing a voltage across the air space that results in the ionization of the air space.
Flowgate [Archive]		2/8/2005	3/16/2007	A designated point on the transmission system through which the Interchange Distribution Calculator calculates the power flow from Interchange Transactions.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Flowgate [Archive]		08/22/2008	11/24/2009	<p>1.) A portion of the Transmission system through which the Interchange Distribution Calculator calculates the power flow from Interchange Transactions.</p> <p>2.) A mathematical construct, comprised of one or more monitored transmission Facilities and optionally one or more contingency Facilities, used to analyze the impact of power flows upon the Bulk Electric System.</p>
Flowgate Methodology [Archive]		08/22/2008	11/24/2009	The Flowgate methodology is characterized by identification of key Facilities as Flowgates. Total Flowgate Capabilities are determined based on Facility Ratings and voltage and stability limits. The impacts of Existing Transmission Commitments (ETCs) are determined by simulation. The impacts of ETC, Capacity Benefit Margin (CBM) and Transmission Reliability Margin (TRM) are subtracted from the Total Flowgate Capability, and Postbacks and counterflows are added, to determine the Available Flowgate Capability (AFC) value for that Flowgate. AFCs can be used to determine Available Transfer Capability (ATC).
Forced Outage [Archive]		2/8/2005	3/16/2007	<p>1. The removal from service availability of a generating unit, transmission line, or other facility for emergency reasons.</p> <p>2. The condition in which the equipment is unavailable due to unanticipated failure.</p>
Frequency Bias [Archive]		2/8/2005	3/16/2007	A value, usually expressed in megawatts per 0.1 Hertz (MW/0.1 Hz), associated with a Balancing Authority Area that approximates the Balancing Authority Area's response to Interconnection frequency error.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Frequency Bias Setting [Archive]		2/8/2005	3/16/2007	A value, usually expressed in MW/0.1 Hz, set into a Balancing Authority ACE algorithm that allows the Balancing Authority to contribute its frequency response to the Interconnection.
Frequency Deviation [Archive]		2/8/2005	3/16/2007	A change in Interconnection frequency.
Frequency Error [Archive]		2/8/2005	3/16/2007	The difference between the actual and scheduled frequency. ($F_A - F_S$)
Frequency Regulation [Archive]		2/8/2005	3/16/2007	The ability of a Balancing Authority to help the Interconnection maintain Scheduled Frequency. This assistance can include both turbine governor response and Automatic Generation Control.
Frequency Response [Archive]		2/8/2005	3/16/2007	(Equipment) The ability of a system or elements of the system to react or respond to a change in system frequency. (System) The sum of the change in demand, plus the change in generation, divided by the change in frequency, expressed in megawatts per 0.1 Hertz (MW/0.1 Hz).

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Generator Operator [Archive]		2/8/2005	3/16/2007	The entity that operates generating unit(s) and performs the functions of supplying energy and Interconnected Operations Services.
Generator Owner [Archive]		2/8/2005	3/16/2007	Entity that owns and maintains generating units.
Generator Shift Factor [Archive]	GSF	2/8/2005	3/16/2007	A factor to be applied to a generator's expected change in output to determine the amount of flow contribution that change in output will impose on an identified transmission facility or Flowgate.
Generator-to-Load Distribution Factor [Archive]	GLDF	2/8/2005	3/16/2007	The algebraic sum of a Generator Shift Factor and a Load Shift Factor to determine the total impact of an Interchange Transaction on an identified transmission facility or Flowgate.
Generation Capability Import Requirement [Archive]	GCIR	11/13/2008	11/24/2009	The amount of generation capability from external sources identified by a Load-Serving Entity (LSE) or Resource Planner (RP) to meet its generation reliability or resource adequacy requirements as an alternative to internal resources.
Host Balancing Authority [Archive]		2/8/2005	3/16/2007	<ol style="list-style-type: none"> 1. A Balancing Authority that confirms and implements Interchange Transactions for a Purchasing Selling Entity that operates generation or serves customers directly within the Balancing Authority's metered boundaries. 2. The Balancing Authority within whose metered boundaries a jointly owned unit is physically located.
Hourly Value [Archive]		2/8/2005	3/16/2007	Data measured on a Clock Hour basis.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Implemented Interchange [Archive]		5/2/2006	3/16/2007	The state where the Balancing Authority enters the Confirmed Interchange into its Area Control Error equation.
Inadvertent Interchange [Archive]		2/8/2005	3/16/2007	The difference between the Balancing Authority's Net Actual Interchange and Net Scheduled Interchange. ($I_A - I_S$)
Independent Power Producer [Archive]	IPP	2/8/2005	3/16/2007	Any entity that owns or operates an electricity generating facility that is not included in an electric utility's rate base. This term includes, but is not limited to, cogenerators and small power producers and all other nonutility electricity producers, such as exempt wholesale generators, who sell electricity.
Institute of Electrical and Electronics Engineers, Inc. [Archive]	IEEE	2/7/2006	3/16/2007	
Interchange [Archive]		5/2/2006	3/16/2007	Energy transfers that cross Balancing Authority boundaries.
Interchange Authority [Archive]		5/2/2006	3/16/2007	The responsible entity that authorizes implementation of valid and balanced Interchange Schedules between Balancing Authority Areas, and ensures communication of Interchange information for reliability assessment purposes.
Interchange Distribution Calculator [Archive]	IDC	2/8/2005	3/16/2007	The mechanism used by Reliability Coordinators in the Eastern Interconnection to calculate the distribution of Interchange Transactions over specific Flowgates. It includes a database of all Interchange Transactions and a matrix of the Distribution Factors for the Eastern Interconnection.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Interchange Schedule [Archive]		2/8/2005	3/16/2007	An agreed-upon Interchange Transaction size (megawatts), start and end time, beginning and ending ramp times and rate, and type required for delivery and receipt of power and energy between the Source and Sink Balancing Authorities involved in the transaction.
Interchange Transaction [Archive]		2/8/2005	3/16/2007	An agreement to transfer energy from a seller to a buyer that crosses one or more Balancing Authority Area boundaries.
Interchange Transaction Tag or Tag [Archive]		2/8/2005	3/16/2007	The details of an Interchange Transaction required for its physical implementation.
Interconnected Operations Service [Archive]		2/8/2005	3/16/2007	A service (exclusive of basic energy and transmission services) that is required to support the reliable operation of interconnected Bulk Electric Systems.
Interconnection [Archive]		2/8/2005	3/16/2007	When capitalized, any one of the three major electric system networks in North America: Eastern, Western, and ERCOT.
Interconnection Reliability Operating Limit [Archive]	IROL	2/8/2005	3/16/2007 Retired 12/27/2007	The value (such as MW, MVar, Amperes, Frequency or Volts) derived from, or a subset of the System Operating Limits, which if exceeded, could expose a widespread area of the Bulk Electric System to instability, uncontrolled separation(s) or cascading outages.
Interconnection Reliability Operating Limit [Archive]	IROL	11/1/2006	12/27/2007	A System Operating Limit that, if violated, could lead to instability, uncontrolled separation, or Cascading Outages that adversely impact the reliability of the Bulk Electric System.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Interconnection Reliability Operating Limit T_v [Archive]	IROL T_v	11/1/2006	12/27/2007	The maximum time that an Interconnection Reliability Operating Limit can be violated before the risk to the interconnection or other Reliability Coordinator Area(s) becomes greater than acceptable. Each Interconnection Reliability Operating Limit's T_v shall be less than or equal to 30 minutes.
Intermediate Balancing Authority [Archive]		2/8/2005	3/16/2007	A Balancing Authority Area that has connecting facilities in the Scheduling Path between the Sending Balancing Authority Area and Receiving Balancing Authority Area and operating agreements that establish the conditions for the use of such facilities
Interruptible Load or Interruptible Demand [Archive]		11/1/2006	3/16/2007	Demand that the end-use customer makes available to its Load-Serving Entity via contract or agreement for curtailment.
Joint Control [Archive]		2/8/2005	3/16/2007	Automatic Generation Control of jointly owned units by two or more Balancing Authorities.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Limiting Element [Archive]		2/8/2005	3/16/2007	The element that is 1.)Either operating at its appropriate rating, or 2,) Would be following the limiting contingency. Thus, the Limiting Element establishes a system limit.
Load [Archive]		2/8/2005	3/16/2007	An end-use device or customer that receives power from the electric system.
Load Shift Factor [Archive]	LSF	2/8/2005	3/16/2007	A factor to be applied to a load's expected change in demand to determine the amount of flow contribution that change in demand will impose on an identified transmission facility or monitored Flowgate.
Load-Serving Entity [Archive]		2/8/2005	3/16/2007	Secures energy and transmission service (and related Interconnected Operations Services) to serve the electrical demand and energy requirements of its end-use customers.
Long-Term Transmission Planning Horizon [Archive]		8/4/2011		Transmission planning period that covers years six through ten or beyond when required to accommodate any known longer lead time projects that may take longer than ten years to complete.
Market Flow [Archive]		11/4/2010	4/21/2011	The total amount of power flowing across a specified Facility or set of Facilities due to a market dispatch of generation internal to the market to serve load internal to the market.
Misoperation [Archive]		2/7/2006	3/16/2007	<ul style="list-style-type: none"> ▪ Any failure of a Protection System element to operate within the specified time when a fault or abnormal condition occurs within a zone of protection. ▪ Any operation for a fault not within a zone of protection (other than operation as backup protection for a fault in an adjacent zone that is not cleared within a specified time for the protection for that zone). ▪ Any unintentional Protection System operation when no fault or other abnormal condition has occurred unrelated to on-site maintenance and testing activity.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Native Load [Archive]		2/8/2005	3/16/2007	The end-use customers that the Load-Serving Entity is obligated to serve.
Near-Term Transmission Planning Horizon [Archive]		1/24/2011		The transmission planning period that covers Year One through five.
Net Actual Interchange [Archive]		2/8/2005	3/16/2007	The algebraic sum of all metered interchange over all interconnections between two physically Adjacent Balancing Authority Areas.
Net Energy for Load [Archive]		2/8/2005	3/16/2007	Net Balancing Authority Area generation, plus energy received from other Balancing Authority Areas, less energy delivered to Balancing Authority Areas through interchange. It includes Balancing Authority Area losses but excludes energy required for storage at energy storage facilities.
Net Interchange Schedule [Archive]		2/8/2005	3/16/2007	The algebraic sum of all Interchange Schedules with each Adjacent Balancing Authority.
Net Scheduled Interchange [Archive]		2/8/2005	3/16/2007	The algebraic sum of all Interchange Schedules across a given path or between Balancing Authorities for a given period or instant in time.
Network Integration Transmission Service [Archive]		2/8/2005	3/16/2007	Service that allows an electric transmission customer to integrate, plan, economically dispatch and regulate its network reserves in a manner comparable to that in which the Transmission Owner serves Native Load customers.
Non-Consequential Load Loss [Archive]		8/4/2011		Non-Interruptible Load loss that does not include: (1) Consequential Load Loss, (2) the response of voltage sensitive Load, or (3) Load that is disconnected from the System by end-user equipment.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Non-Firm Transmission Service [Archive]		2/8/2005	3/16/2007	Transmission service that is reserved on an as-available basis and is subject to curtailment or interruption.
Non-Spinning Reserve [Archive]		2/8/2005	3/16/2007	<ol style="list-style-type: none"> 1. That generating reserve not connected to the system but capable of serving demand within a specified time. 2. Interruptible load that can be removed from the system in a specified time.
Normal Clearing [Archive]		11/1/2006	12/27/2007	A protection system operates as designed and the fault is cleared in the time normally expected with proper functioning of the installed protection systems.
Normal Rating [Archive]		2/8/2005	3/16/2007	The rating as defined by the equipment owner that specifies the level of electrical loading, usually expressed in megawatts (MW) or other appropriate units that a system, facility, or element can support or withstand through the daily demand cycles without loss of equipment life.
Nuclear Plant Generator Operator [Archive]		5/2/2007	10/16/2008	Any Generator Operator or Generator Owner that is a Nuclear Plant Licensee responsible for operation of a nuclear facility licensed to produce commercial power.
Nuclear Plant Off-site Power Supply (Off-site Power) [Archive]		5/2/2007	10/16/2008	The electric power supply provided from the electric system to the nuclear power plant distribution system as required per the nuclear power plant license.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Nuclear Plant Licensing Requirements (NPLRs) [Archive]		5/2/2007	10/16/2008	Requirements included in the design basis of the nuclear plant and statutorily mandated for the operation of the plant, including nuclear power plant licensing requirements for: <ol style="list-style-type: none"> 1) Off-site power supply to enable safe shutdown of the plant during an electric system or plant event; and 2) Avoiding preventable challenges to nuclear safety as a result of an electric system disturbance, transient, or condition.
Nuclear Plant Interface Requirements (NPIRs) [Archive]		5/2/2007	10/16/2008	The requirements based on NPLRs and Bulk Electric System requirements that have been mutually agreed to by the Nuclear Plant Generator Operator and the applicable Transmission Entities.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Off-Peak [Archive]		2/8/2005	3/16/2007	Those hours or other periods defined by NAESB business practices, contract, agreements, or guides as periods of lower electrical demand.
On-Peak [Archive]		2/8/2005	3/16/2007	Those hours or other periods defined by NAESB business practices, contract, agreements, or guides as periods of higher electrical demand.
Open Access Same Time Information Service [Archive]	OASIS	2/8/2005	3/16/2007	An electronic posting system that the Transmission Service Provider maintains for transmission access data and that allows all transmission customers to view the data simultaneously.
Open Access Transmission Tariff [Archive]	OATT	2/8/2005	3/16/2007	Electronic transmission tariff accepted by the U.S. Federal Energy Regulatory Commission requiring the Transmission Service Provider to furnish to all shippers with non-discriminating service comparable to that provided by Transmission Owners to themselves.
Operating Plan [Archive]		2/7/2006	3/16/2007	A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Operating Procedure [Archive]		2/7/2006	3/16/2007	A document that identifies specific steps or tasks that should be taken by one or more specific operating positions to achieve specific operating goal(s). The steps in an Operating Procedure should be followed in the order in which they are presented, and should be performed by the position(s) identified. A document that lists the specific steps for a system operator to take in removing a specific transmission line from service is an example of an Operating Procedure.
Operating Process [Archive]		2/7/2006	3/16/2007	A document that identifies general steps for achieving a generic operating goal. An Operating Process includes steps with options that may be selected depending upon Real-time conditions. A guideline for controlling high voltage is an example of an Operating Process.
Operating Reserve [Archive]		2/8/2005	3/16/2007	That capability above firm system demand required to provide for regulation, load forecasting error, equipment forced and scheduled outages and local area protection. It consists of spinning and non-spinning reserve.
Operating Reserve – Spinning [Archive]		2/8/2005	3/16/2007	The portion of Operating Reserve consisting of: <ul style="list-style-type: none"> • Generation synchronized to the system and fully available to serve load within the Disturbance Recovery Period following the contingency event; or • Load fully removable from the system within the Disturbance Recovery Period following the contingency event.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Operating Reserve – Supplemental [Archive]		2/8/2005	3/16/2007	The portion of Operating Reserve consisting of: <ul style="list-style-type: none"> • Generation (synchronized or capable of being synchronized to the system) that is fully available to serve load within the Disturbance Recovery Period following the contingency event; or • Load fully removable from the system within the Disturbance Recovery Period following the contingency event.
Operating Voltage [Archive]		2/7/2006	3/16/2007	The voltage level by which an electrical system is designated and to which certain operating characteristics of the system are related; also, the effective (root-mean-square) potential difference between any two conductors or between a conductor and the ground. The actual voltage of the circuit may vary somewhat above or below this value.
Operational Planning Analysis [Archive]		10/17/2008		An analysis of the expected system conditions for the next day's operation. (That analysis may be performed either a day ahead or as much as 12 months ahead.) Expected system conditions include things such as load forecast(s), generation output levels, and known system constraints (transmission facility outages, generator outages, equipment limitations, etc.).
Outage Transfer Distribution Factor [Archive]	OTDF	8/22/2008	11/24/2009	In the post-contingency configuration of a system under study, the electric Power Transfer Distribution Factor (PTDF) with one or more system Facilities removed from service (outaged).
Overlap Regulation Service [Archive]		2/8/2005	3/16/2007	A method of providing regulation service in which the Balancing Authority providing the regulation service incorporates another Balancing Authority's actual interchange, frequency response, and schedules into providing Balancing Authority's AGC/ACE equation.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Participation Factors [Archive]		8/22/2008	11/24/2009	A set of dispatch rules such that given a specific amount of load to serve, an approximate generation dispatch can be determined. To accomplish this, generators are assigned a percentage that they will contribute to serve load.
Peak Demand [Archive]		2/8/2005	3/16/2007	<ol style="list-style-type: none"> 1. The highest hourly integrated Net Energy For Load within a Balancing Authority Area occurring within a given period (e.g., day, month, season, or year). 2. The highest instantaneous demand within the Balancing Authority Area.
Performance-Reset Period [Archive]		2/7/2006	3/16/2007	The time period that the entity being assessed must operate without any violations to reset the level of non compliance to zero.
Physical Security Perimeter [Archive]		5/2/2006	1/18/2008	The physical, completely enclosed (“six-wall”) border surrounding computer rooms, telecommunications rooms, operations centers, and other locations in which Critical Cyber Assets are housed and for which access is controlled.
Planning Assessment [Archive]		8/4/2011		Documented evaluation of future Transmission system performance and Corrective Action Plans to remedy identified deficiencies.
Planning Authority [Archive]		2/8/2005	3/16/2007	The responsible entity that coordinates and integrates transmission facility and service plans, resource plans, and protection systems.
Planning Coordinator [Archive]		8/22/2008	11/24/2009	See Planning Authority.
Point of Delivery [Archive]	POD	2/8/2005	3/16/2007	A location that the Transmission Service Provider specifies on its transmission system where an Interchange Transaction leaves or a Load-Serving Entity receives its energy.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Point of Receipt [Archive]	POR	2/8/2005	3/16/2007	A location that the Transmission Service Provider specifies on its transmission system where an Interchange Transaction enters or a Generator delivers its output.
Point to Point Transmission Service [Archive]	PTP	2/8/2005	3/16/2007	The reservation and transmission of capacity and energy on either a firm or non-firm basis from the Point(s) of Receipt to the Point(s) of Delivery.
Postback [Archive]		08/22/2008	Not approved; Modification directed 11/24/09	Positive adjustments to ATC or AFC as defined in Business Practices. Such Business Practices may include processing of redirects and unscheduled service.
Power Transfer Distribution Factor [Archive]	PTDF	08/22/2008	11/24/2009	In the pre-contingency configuration of a system under study, a measure of the responsiveness or change in electrical loadings on transmission system Facilities due to a change in electric power transfer from one area to another, expressed in percent (up to 100%) of the change in power transfer
Pro Forma Tariff [Archive]		2/8/2005	3/16/2007	Usually refers to the standard OATT and/or associated transmission rights mandated by the U.S. Federal Energy Regulatory Commission Order No. 888.
Protection System [Archive]		2/7/2006	3/17/07	Protective relays, associated communication systems, voltage and current sensing devices, station batteries and DC control circuitry.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Protection System [Archive]		11/19/2010		<p>Protection System –</p> <ul style="list-style-type: none"> • Protective relays which respond to electrical quantities, • Communications systems necessary for correct operation of protective functions • Voltage and current sensing devices providing inputs to protective relays, • Station dc supply associated with protective functions (including batteries, battery chargers, and non-battery-based dc supply), and • Control circuitry associated with protective functions through the trip coil(s) of the circuit breakers or other interrupting devices.
Pseudo-Tie [Archive]		2/8/2005	3/16/2007	A telemetered reading or value that is updated in real time and used as a “virtual” tie line flow in the AGC/ACE equation but for which no physical tie or energy metering actually exists. The integrated value is used as a metered MWh value for interchange accounting purposes.
Purchasing-Selling Entity [Archive]		2/8/2005	3/16/2007	The entity that purchases or sells, and takes title to, energy, capacity, and Interconnected Operations Services. Purchasing-Selling Entities may be affiliated or unaffiliated merchants and may or may not own generating facilities.
Ramp Rate or Ramp [Archive]		2/8/2005	3/16/2007	<p>(Schedule) The rate, expressed in megawatts per minute, at which the interchange schedule is attained during the ramp period.</p> <p>(Generator) The rate, expressed in megawatts per minute, that a generator changes its output.</p>
Rated Electrical Operating Conditions [Archive]		2/7/2006	3/16/2007	The specified or reasonably anticipated conditions under which the electrical system or an individual electrical circuit is intend/designed to operate

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Rating [Archive]		2/8/2005	3/16/2007	The operational limits of a transmission system element under a set of specified conditions.
Rated System Path Methodology [Archive]		08/22/2008	11/24/2009	The Rated System Path Methodology is characterized by an initial Total Transfer Capability (TTC), determined via simulation. Capacity Benefit Margin, Transmission Reliability Margin, and Existing Transmission Commitments are subtracted from TTC, and Postbacks and counterflows are added as applicable, to derive Available Transfer Capability. Under the Rated System Path Methodology, TTC results are generally reported as specific transmission path capabilities.
Reactive Power [Archive]		2/8/2005	3/16/2007	The portion of electricity that establishes and sustains the electric and magnetic fields of alternating-current equipment. Reactive power must be supplied to most types of magnetic equipment, such as motors and transformers. It also must supply the reactive losses on transmission facilities. Reactive power is provided by generators, synchronous condensers, or electrostatic equipment such as capacitors and directly influences electric system voltage. It is usually expressed in kilovars (kvar) or megavars (Mvar).
Real Power [Archive]		2/8/2005	3/16/2007	The portion of electricity that supplies energy to the load.
Reallocation [Archive]		2/8/2005	3/16/2007	The total or partial curtailment of Transactions during TLR Level 3a or 5a to allow Transactions using higher priority to be implemented.
Real-time [Archive]		2/7/2006	3/16/2007	Present time as opposed to future time. (From Interconnection Reliability Operating Limits standard.)
Real-time Assessment [Archive]		10/17/2008		An examination of existing and expected system conditions, conducted by collecting and reviewing immediately available data

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Receiving Balancing Authority [Archive]		2/8/2005	3/16/2007	The Balancing Authority importing the Interchange.
Regional Reliability Organization [Archive]		2/8/2005	3/16/2007	<ol style="list-style-type: none"> 1. An entity that ensures that a defined area of the Bulk Electric System is reliable, adequate and secure. 2. A member of the North American Electric Reliability Council. The Regional Reliability Organization can serve as the Compliance Monitor.
Regional Reliability Plan [Archive]		2/8/2005	3/16/2007	The plan that specifies the Reliability Coordinators and Balancing Authorities within the Regional Reliability Organization, and explains how reliability coordination will be accomplished.
Regulating Reserve [Archive]		2/8/2005	3/16/2007	An amount of reserve responsive to Automatic Generation Control, which is sufficient to provide normal regulating margin.
Regulation Service [Archive]		2/8/2005	3/16/2007	The process whereby one Balancing Authority contracts to provide corrective response to all or a portion of the ACE of another Balancing Authority. The Balancing Authority providing the response assumes the obligation of meeting all applicable control criteria as specified by NERC for itself and the Balancing Authority for which it is providing the Regulation Service.
Reliability Adjustment RFI [Archive]		10/29/2008	12/17/2009	Request to modify an Implemented Interchange Schedule for reliability purposes.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Reliability Coordinator [Archive]		2/8/2005	3/16/2007	The entity that is the highest level of authority who is responsible for the reliable operation of the Bulk Electric System, has the Wide Area view of the Bulk Electric System, and has the operating tools, processes and procedures, including the authority to prevent or mitigate emergency operating situations in both next-day analysis and real-time operations. The Reliability Coordinator has the purview that is broad enough to enable the calculation of Interconnection Reliability Operating Limits, which may be based on the operating parameters of transmission systems beyond any Transmission Operator's vision.
Reliability Coordinator Area [Archive]		2/8/2005	3/16/2007	The collection of generation, transmission, and loads within the boundaries of the Reliability Coordinator. Its boundary coincides with one or more Balancing Authority Areas.
Reliability Coordinator Information System [Archive]	RCIS	2/8/2005	3/16/2007	The system that Reliability Coordinators use to post messages and share operating information in real time.
Remedial Action Scheme [Archive]	RAS	2/8/2005	3/16/2007	See "Special Protection System"
Reportable Disturbance [Archive]		2/8/2005	3/16/2007	Any event that causes an ACE change greater than or equal to 80% of a Balancing Authority's or reserve sharing group's most severe contingency. The definition of a reportable disturbance is specified by each Regional Reliability Organization. This definition may not be retroactively adjusted in response to observed performance.
Request for Interchange [Archive]	RFI	5/2/2006	3/16/2007	A collection of data as defined in the NAESB RFI Datasheet, to be submitted to the Interchange Authority for the purpose of implementing bilateral Interchange between a Source and Sink Balancing Authority.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Reserve Sharing Group [Archive]		2/8/2005	3/16/2007	A group whose members consist of two or more Balancing Authorities that collectively maintain, allocate, and supply operating reserves required for each Balancing Authority's use in recovering from contingencies within the group. Scheduling energy from an Adjacent Balancing Authority to aid recovery need not constitute reserve sharing provided the transaction is ramped in over a period the supplying party could reasonably be expected to load generation in (e.g., ten minutes). If the transaction is ramped in quicker (e.g., between zero and ten minutes) then, for the purposes of Disturbance Control Performance, the Areas become a Reserve Sharing Group.
Resource Planner [Archive]		2/8/2005	3/16/2007	The entity that develops a long-term (generally one year and beyond) plan for the resource adequacy of specific loads (customer demand and energy requirements) within a Planning Authority Area.
Response Rate [Archive]		2/8/2005	3/16/2007	The Ramp Rate that a generating unit can achieve under normal operating conditions expressed in megawatts per minute (MW/Min).
Right-of-Way (ROW) [Archive]		2/7/2006	3/16/2007	A corridor of land on which electric lines may be located. The Transmission Owner may own the land in fee, own an easement, or have certain franchise, prescription, or license rights to construct and maintain lines.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Scenario [Archive]		2/7/2006	3/16/2007	Possible event.
Schedule [Archive]		2/8/2005	3/16/2007	(Verb) To set up a plan or arrangement for an Interchange Transaction. (Noun) An Interchange Schedule.
Scheduled Frequency [Archive]		2/8/2005	3/16/2007	60.0 Hertz, except during a time correction.
Scheduling Entity [Archive]		2/8/2005	3/16/2007	An entity responsible for approving and implementing Interchange Schedules.
Scheduling Path [Archive]		2/8/2005	3/16/2007	The Transmission Service arrangements reserved by the Purchasing-Selling Entity for a Transaction.
Sending Balancing Authority [Archive]		2/8/2005	3/16/2007	The Balancing Authority exporting the Interchange.
Sink Balancing Authority [Archive]		2/8/2005	3/16/2007	The Balancing Authority in which the load (sink) is located for an Interchange Transaction. (This will also be a Receiving Balancing Authority for the resulting Interchange Schedule.)
Source Balancing Authority [Archive]		2/8/2005	3/16/2007	The Balancing Authority in which the generation (source) is located for an Interchange Transaction. (This will also be a Sending Balancing Authority for the resulting Interchange Schedule.)

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Special Protection System (Remedial Action Scheme) [Archive]		2/8/2005	3/16/2007	An automatic protection system designed to detect abnormal or predetermined system conditions, and take corrective actions other than and/or in addition to the isolation of faulted components to maintain system reliability. Such action may include changes in demand, generation (MW and Mvar), or system configuration to maintain system stability, acceptable voltage, or power flows. An SPS does not include (a) underfrequency or undervoltage load shedding or (b) fault conditions that must be isolated or (c) out-of-step relaying (not designed as an integral part of an SPS). Also called Remedial Action Scheme.
Spinning Reserve [Archive]		2/8/2005	3/16/2007	Unloaded generation that is synchronized and ready to serve additional demand.
Stability [Archive]		2/8/2005	3/16/2007	The ability of an electric system to maintain a state of equilibrium during normal and abnormal conditions or disturbances.
Stability Limit [Archive]		2/8/2005	3/16/2007	The maximum power flow possible through some particular point in the system while maintaining stability in the entire system or the part of the system to which the stability limit refers.
Supervisory Control and Data Acquisition [Archive]	SCADA	2/8/2005	3/16/2007	A system of remote control and telemetry used to monitor and control the transmission system.
Supplemental Regulation Service [Archive]		2/8/2005	3/16/2007	A method of providing regulation service in which the Balancing Authority providing the regulation service receives a signal representing all or a portion of the other Balancing Authority's ACE.
Surge [Archive]		2/8/2005	3/16/2007	A transient variation of current, voltage, or power flow in an electric circuit or across an electric system.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Sustained Outage [Archive]		2/7/2006	3/16/2007	The deenergized condition of a transmission line resulting from a fault or disturbance following an unsuccessful automatic reclosing sequence and/or unsuccessful manual reclosing procedure.
System [Archive]		2/8/2005	3/16/2007	A combination of generation, transmission, and distribution components.
System Operating Limit [Archive]		2/8/2005	3/16/2007	The value (such as MW, MVar, Amperes, Frequency or Volts) that satisfies the most limiting of the prescribed operating criteria for a specified system configuration to ensure operation within acceptable reliability criteria. System Operating Limits are based upon certain operating criteria. These include, but are not limited to: <ul style="list-style-type: none"> • Facility Ratings (Applicable pre- and post-Contingency equipment or facility ratings) • Transient Stability Ratings (Applicable pre- and post-Contingency Stability Limits) • Voltage Stability Ratings (Applicable pre- and post-Contingency Voltage Stability) • System Voltage Limits (Applicable pre- and post-Contingency Voltage Limits)
System Operator [Archive]		2/8/2005	3/16/2007	An individual at a control center (Balancing Authority, Transmission Operator, Generator Operator, Reliability Coordinator) whose responsibility it is to monitor and control that electric system in real time.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Telemetry [Archive]		2/8/2005	3/16/2007	The process by which measurable electrical quantities from substations and generating stations are instantaneously transmitted to the control center, and by which operating commands from the control center are transmitted to the substations and generating stations.
Thermal Rating [Archive]		2/8/2005	3/16/2007	The maximum amount of electrical current that a transmission line or electrical facility can conduct over a specified time period before it sustains permanent damage by overheating or before it sags to the point that it violates public safety requirements.
Tie Line [Archive]		2/8/2005	3/16/2007	A circuit connecting two Balancing Authority Areas.
Tie Line Bias [Archive]		2/8/2005	3/16/2007	A mode of Automatic Generation Control that allows the Balancing Authority to 1.) maintain its Interchange Schedule and 2.) respond to Interconnection frequency error.
Time Error [Archive]		2/8/2005	3/16/2007	The difference between the Interconnection time measured at the Balancing Authority(ies) and the time specified by the National Institute of Standards and Technology. Time error is caused by the accumulation of Frequency Error over a given period.
Time Error Correction [Archive]		2/8/2005	3/16/2007	An offset to the Interconnection's scheduled frequency to return the Interconnection's Time Error to a predetermined value.
TLR Log [Archive]		2/8/2005	3/16/2007	Report required to be filed after every TLR Level 2 or higher in a specified format. The NERC IDC prepares the report for review by the issuing Reliability Coordinator. After approval by the issuing Reliability Coordinator, the report is electronically filed in a public area of the NERC Web site.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Total Flowgate Capability [Archive]	TFC	08/22/2008	11/24/2009	The maximum flow capability on a Flowgate, is not to exceed its thermal rating, or in the case of a flowgate used to represent a specific operating constraint (such as a voltage or stability limit), is not to exceed the associated System Operating Limit.
Total Transfer Capability [Archive]	TTC	2/8/2005	3/16/2007	The amount of electric power that can be moved or transferred reliably from one area to another area of the interconnected transmission systems by way of all transmission lines (or paths) between those areas under specified system conditions.
Transaction [Archive]		2/8/2005	3/16/2007	See Interchange Transaction.
Transfer Capability [Archive]		2/8/2005	3/16/2007	The measure of the ability of interconnected electric systems to move or transfer power <i>in a reliable manner</i> from one area to another over all transmission lines (or paths) between those areas under specified system conditions. The units of transfer capability are in terms of electric power, generally expressed in megawatts (MW). The transfer capability from "Area A" to "Area B" is <i>not</i> generally equal to the transfer capability from "Area B" to "Area A."
Transfer Distribution Factor [Archive]		2/8/2005	3/16/2007	See Distribution Factor.
Transmission [Archive]		2/8/2005	3/16/2007	An interconnected group of lines and associated equipment for the movement or transfer of electric energy between points of supply and points at which it is transformed for delivery to customers or is delivered to other electric systems.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Transmission Constraint [Archive]		2/8/2005	3/16/2007	A limitation on one or more transmission elements that may be reached during normal or contingency system operations.
Transmission Customer [Archive]		2/8/2005	3/16/2007	<ol style="list-style-type: none"> 1. Any eligible customer (or its designated agent) that can or does execute a transmission service agreement or can or does receive transmission service. 2. Any of the following responsible entities: Generator Owner, Load-Serving Entity, or Purchasing-Selling Entity.
Transmission Line [Archive]		2/7/2006	3/16/2007	A system of structures, wires, insulators and associated hardware that carry electric energy from one point to another in an electric power system. Lines are operated at relatively high voltages varying from 69 kV up to 765 kV, and are capable of transmitting large quantities of electricity over long distances.
Transmission Operator [Archive]		2/8/2005	3/16/2007	The entity responsible for the reliability of its "local" transmission system, and that operates or directs the operations of the transmission facilities.
Transmission Operator Area [Archive]		08/22/2008	11/24/2009	The collection of Transmission assets over which the Transmission Operator is responsible for operating.
Transmission Owner [Archive]		2/8/2005	3/16/2007	The entity that owns and maintains transmission facilities.
Transmission Planner [Archive]		2/8/2005	3/16/2007	The entity that develops a long-term (generally one year and beyond) plan for the reliability (adequacy) of the interconnected bulk electric transmission systems within its portion of the Planning Authority Area.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Transmission Reliability Margin [Archive]	TRM	2/8/2005	3/16/2007	The amount of transmission transfer capability necessary to provide reasonable assurance that the interconnected transmission network will be secure. TRM accounts for the inherent uncertainty in system conditions and the need for operating flexibility to ensure reliable system operation as system conditions change.
Transmission Reliability Margin Implementation Document [Archive]	TRMID	08/22/2008	11/24/2009	A document that describes the implementation of a Transmission Reliability Margin methodology, and provides information related to a Transmission Operator's calculation of TRM.
Transmission Service [Archive]		2/8/2005	3/16/2007	Services provided to the Transmission Customer by the Transmission Service Provider to move energy from a Point of Receipt to a Point of Delivery.
Transmission Service Provider [Archive]		2/8/2005	3/16/2007	The entity that administers the transmission tariff and provides Transmission Service to Transmission Customers under applicable transmission service agreements.
Vegetation [Archive]		2/7/2006	3/16/2007	All plant material, growing or not, living or dead.
Vegetation Inspection [Archive]		2/7/2006	3/16/2007	The systematic examination of a transmission corridor to document vegetation conditions.
Wide Area [Archive]		2/8/2005	3/16/2007	The entire Reliability Coordinator Area as well as the critical flow and status information from adjacent Reliability Coordinator Areas as determined by detailed system studies to allow the calculation of Interconnected Reliability Operating Limits.

Glossary of Terms Used in NERC Reliability Standards

Continent-wide Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Year One [Archive]		1/24/2011		The first twelve month period that a Planning Coordinator or a Transmission Planner is responsible for assessing. For an assessment started in a given calendar year, Year One includes the forecasted peak Load period for one of the following two calendar years. For example, if a Planning Assessment was started in 2011, then Year One includes the forecasted peak Load period for either 2012 or 2013.

ReliabilityFirst Regional Definitions

The following definitions were developed for use in ReliabilityFirst Regional Standards.

RFC Regional Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Resource Adequacy [Archive]		08/05/2009	03/17/2011	The ability of supply-side and demand-side resources to meet the aggregate electrical demand (including losses)
Net Internal Demand [Archive]		08/05/2009	03/17/2011	Total of all end-use customer demand and electric system losses within specified metered boundaries, less Direct Control Management and Interruptible Demand
Peak Period [Archive]		08/05/2009	03/17/2011	A period consisting of two (2) or more calendar months but less than seven (7) calendar months, which includes the period during which the responsible entity's annual peak demand is expected to occur
Year One [Archive]		08/05/2009	03/17/2011	The planning year that begins with the upcoming annual Peak Period

NPCC Regional Definitions

The following definitions were developed for use in NPCC Regional Standards.

NPCC Regional Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Current Zero Time [Archive]		11/04/2010	10/20/2011	The time of the final current zero on the last phase to interrupt.
Generating Plant [Archive]		11/04/2010	10/20/2011	One or more generators at a single physical location whereby any single contingency can affect all the generators at that location.

WECC Regional Definitions

The following definitions were developed for use in WECC Regional Standards.

WECC Regional Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Area Control Error [†] [Archive]	ACE	3/12/2007	6/8/2007	Means the instantaneous difference between net actual and scheduled interchange, taking into account the effects of Frequency Bias including correction for meter error.
Automatic Generation Control [†] [Archive]	AGC	3/12/2007	6/8/2007	Means equipment that automatically adjusts a Control Area's generation from a central location to maintain its interchange schedule plus Frequency Bias.
Automatic Time Error Correction [Archive]		3/26/2008	5/21/2009	A frequency control automatic action that a Balancing Authority uses to offset its frequency contribution to support the Interconnection's scheduled frequency.
Average Generation [†] [Archive]		3/12/2007	6/8/2007	Means the total MWh generated within the Balancing Authority Operator's Balancing Authority Area during the prior year divided by 8760 hours (8784 hours if the prior year had 366 days).
Business Day [†] [Archive]		3/12/2007	6/8/2007	Means any day other than Saturday, Sunday, or a legal public holiday as designated in section 6103 of title 5, U.S. Code.
Disturbance [†] [Archive]		3/12/2007	6/8/2007	Means (i) any perturbation to the electric system, or (ii) the unexpected change in ACE that is caused by the sudden loss of generation or interruption of load.

Glossary of Terms Used in NERC Reliability Standards

WECC Regional Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Extraordinary Contingency [†] [Archive]		3/12/2007	6/8/2007	Shall have the meaning set out in Excuse of Performance, section B.4.c. language in section B.4.c: <i>means any act of God, actions by a non-affiliated third party, labor disturbance, act of the public enemy, war, insurrection, riot, fire, storm or flood, earthquake, explosion, accident to or breakage, failure or malfunction of machinery or equipment, or any other cause beyond the Reliability Entity's reasonable control; provided that prudent industry standards (e.g. maintenance, design, operation) have been employed; and provided further that no act or cause shall be considered an Extraordinary Contingency if such act or cause results in any contingency contemplated in any WECC Reliability Standard (e.g., the "Most Severe Single Contingency" as defined in the WECC Reliability Criteria or any lesser contingency).</i>
Frequency Bias [†] [Archive]		3/12/2007	6/8/2007	Means a value, usually given in megawatts per 0.1 Hertz, associated with a Control Area that relates the difference between scheduled and actual frequency to the amount of generation required to correct the difference.
Generating Unit Capability [†] [Archive]		3/12/2007	6/8/2007	Means the MVA nameplate rating of a generator.
Non-spinning Reserve [†] [Archive]		3/12/2007	6/8/2007	Means that Operating Reserve not connected to the system but capable of serving demand within a specified time, or interruptible load that can be removed from the system in a specified time.
Normal Path Rating [†] [Archive]		3/12/2007	6/8/2007	Is the maximum path rating in MW that has been demonstrated to WECC through study results or actual operation, whichever is greater. For a path with transfer capability limits that vary seasonally, it is the maximum of all the seasonal values.

Glossary of Terms Used in NERC Reliability Standards

WECC Regional Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Operating Reserve [†] [Archive]		3/12/2007	6/8/2007	Means that capability above firm system demand required to provide for regulation, load-forecasting error, equipment forced and scheduled outages and local area protection. Operating Reserve consists of Spinning Reserve and Nonspinning Reserve.
Operating Transfer Capability Limit [†] [Archive]	OTC	3/12/2007	6/8/2007	Means the maximum value of the most critical system operating parameter(s) which meets: (a) precontingency criteria as determined by equipment loading capability and acceptable voltage conditions, (b) transient criteria as determined by equipment loading capability and acceptable voltage conditions, (c) transient performance criteria, and (d) post-contingency loading and voltage criteria.
Primary Inadvertent Interchange [Archive]		3/26/2008	5/21/2009	The component of area (n) inadvertent interchange caused by the regulating deficiencies of the area (n).
Secondary Inadvertent Interchange [Archive]		3/26/2008	5/21/2009	The component of area (n) inadvertent interchange caused by the regulating deficiencies of area (i).
Spinning Reserve [†] [Archive]		3/12/2007	6/8/2007	Means unloaded generation which is synchronized and ready to serve additional demand. It consists of Regulating reserve and Contingency reserve (as each are described in Sections B.a.i and ii).
WECC Table 2 [†] [Archive]		3/12/2007	6/8/2007	Means the table maintained by the WECC identifying those transfer paths monitored by the WECC regional Reliability coordinators. As of the date set out therein, the transmission paths identified in Table 2 are as listed in Attachment A to this Standard.

Glossary of Terms Used in NERC Reliability Standards

WECC Regional Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Functionally Equivalent Protection System [Archive]	FEPS	10/29/2008	4/21/2011	A Protection System that provides performance as follows: <ul style="list-style-type: none"> • Each Protection System can detect the same faults within the zone of protection and provide the clearing times and coordination needed to comply with all Reliability Standards. • Each Protection System may have different components and operating characteristics.
Functionally Equivalent RAS [Archive]	FERAS	10/29/2008	4/21/2011	A Remedial Action Scheme (“RAS”) that provides the same performance as follows: <ul style="list-style-type: none"> • Each RAS can detect the same conditions and provide mitigation to comply with all Reliability Standards. • Each RAS may have different components and operating characteristics.
Security-Based Misoperation [Archive]		10/29/2008	4/21/2011	A Misoperation caused by the incorrect operation of a Protection System or RAS. Security is a component of reliability and is the measure of a device’s certainty not to operate falsely.
Dependability-Based Misoperation [Archive]		10/29/2008	4/21/2011	Is the absence of a Protection System or RAS operation when intended. Dependability is a component of reliability and is the measure of a device’s certainty to operate when required.
Commercial Operation [Archive]		10/29/2008	4/21/2011	Achievement of this designation indicates that the Generator Operator or Transmission Operator of the synchronous generator or synchronous condenser has received all approvals necessary for operation after completion of initial start-up testing.
Qualified Transfer Path Curtailment Event [Archive]		2/10/2009	3/17/2011	Each hour that a Transmission Operator calls for Step 4 or higher for one or more consecutive hours (See Attachment 1 IRO-006-WECC-1) during which the curtailment tool is functional.

Glossary of Terms Used in NERC Reliability Standards

WECC Regional Term	Acronym	BOT Approved Date	FERC Approved Date	Definition
Relief Requirement [Archive]		2/10/2009	3/17/2011	The expected amount of the unscheduled flow reduction on the Qualified Transfer Path that would result by curtailing each Sink Balancing Authority's Contributing Schedules by the percentages listed in the columns of WECC Unscheduled Flow Mitigation Summary of Actions Table in Attachment 1 WECC IRO-006-WECC-1.
Transfer Distribution Factor [Archive]	TDF	2/10/2009	3/17/2011	The percentage of USF that flows across a Qualified Transfer Path when an Interchange Transaction (Contributing Schedule) is implemented. [See the WECC Unscheduled Flow Mitigation Summary of Actions Table (Attachment 1 WECC IRO-006-WECC-1).]
Contributing Schedule [Archive]		2/10/2009	3/17/2011	A Schedule not on the Qualified Transfer Path between a Source Balancing Authority and a Sink Balancing Authority that contributes unscheduled flow across the Qualified Transfer Path.
Qualified Transfer Path [Archive]		2/10/2009	3/17/2011	A transfer path designated by the WECC Operating Committee as being qualified for WECC unscheduled flow mitigation.
Qualified Controllable Device [Archive]		2/10/2009	3/17/2011	A controllable device installed in the Interconnection for controlling energy flow and the WECC Operating Committee has approved using the device for controlling the USF on the Qualified Transfer Paths.

Glossary of Terms Used in NERC Reliability Standards

Endnotes

[†] FERC approved the WECC Tier One Reliability Standards in the Order Approving Regional Reliability Standards for the Western Interconnection and Directing Modifications, 119 FERC ¶ 61,260 (June 8, 2007). In that Order, FERC directed WECC to address the inconsistencies between the regional definitions and the NERC Glossary in developing permanent replacement standards. The replacement standards designed to address the shortcomings were filed with FERC in 2009.

Exhibit C

Informational Summary of Each Reliability Standard Approved by FERC

CIP-001-2a – Sabotage Reporting - Disturbances or unusual occurrences, suspected or determined to be caused by sabotage, shall be reported to the appropriate systems, governmental agencies, and regulatory bodies.

Applicability:

- Reliability Coordinators.
- Balancing Authorities.
- Transmission Operators.
- Generator Operators.
- Load Serving Entities.
- Transmission Owners (only in ERCOT Region).
- Generator Owners (only in ERCOT Region).

The CIP-001-2a standard was approved by the ERCOT Registered Ballot Pool with 6.05 affirmative segment-weighted votes out of 6.25 total votes cast.

On February 16, 2011, CIP-001-2a was adopted by the NERC Board of Trustees.

On August 2, 2011, CIP-001-2a was approved by the Federal Energy Regulatory Commission.

PER-003-1 – Operating Personnel Credentials - To ensure that System Operators performing the reliability-related tasks of the Reliability Coordinator, Balancing Authority and Transmission Operator are certified through the NERC System Operator Certification Program when filling a Real-time operating position responsible for control of the Bulk Electric System.

Applicability:

- Reliability Coordinator
- Transmission Operator
- Balancing Authority

The PER-003-1 standard was approved by the registered ballot body by an 86.91% affirmative vote.

On February 17, 2011, PER-003-1 was adopted by the NERC Board of Trustees.

On September 15, 2011, PER-003-1 was approved by the Federal Energy Regulatory Commission.

PRC-004-1a – Analysis and Mitigation of Transmission and Generation Protection System Misoperations - Ensure all transmission and generation Protection System Misoperations affecting the reliability of the Bulk Electric System (BES) are analyzed and mitigated.

Applicability:

- Transmission Owner.
- Distribution Provider that owns a transmission Protection System.
- Generator Owner.

The PRC-004-1a standard was approved by the registered ballot body by an 82.41% affirmative vote.

On February 17, 2011, PRC-004-1a was adopted by the NERC Board of Trustees.

On September 26, 2011, PRC-004-1a was approved by the Federal Energy Regulatory Commission.

PRC-005-1a – Transmission and Generation Protection System Maintenance and Testing -
To ensure all transmission and generation Protection Systems affecting the reliability of the Bulk Electric System (BES) are maintained and tested.

Applicability:

- Transmission Owner.
- Generator Owner.
- Distribution Provider that owns a transmission Protection System.

The PRC-005-1a standard was approved by the registered ballot body by an 82.41% affirmative vote.

On February 17, 2011, PRC-005-1a was adopted by the NERC Board of Trustees.

On September 26, 2011, PRC-005-1a was approved by the Federal Energy Regulatory Commission.

TOP-001-1a – Reliability Responsibilities and Authorities - To ensure reliability entities have clear decision-making authority and capabilities to take appropriate actions or direct the actions of others to return the transmission system to normal conditions during an emergency.

Applicability:

- Balancing Authorities
- Transmission Operators
- Generator Operators
- Distribution Providers
- Load Serving Entities

The TOP-001-1a standard was approved by the registered ballot body by a 98.27% affirmative vote.

On May 12, 2010, TOP-001-1a was adopted by the NERC Board of Trustees.

On September 15, 2011, TOP-001-1a was approved by the Federal Energy Regulatory Commission.

TPL-002-0b - System Performance Following Loss of a Single Bulk Electric System Element (Category B) - System simulations and associated assessments are needed periodically to ensure that reliable systems are developed that meet specified performance requirements with sufficient lead time, and continue to be modified or upgraded as necessary to meet present and future system needs.

Applicability:

- Planning Authority
- Transmission Planner

The TPL-002-0b standard was approved by the registered ballot body by a 98.85% affirmative vote.

On November 5, 2009, TPL-002-0b was adopted by the NERC Board of Trustees.

On September 19, 2011, TPL-002-0b was approved by the Federal Energy Regulatory Commission.