

# NERC

NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION

# Standards Actions

Howard Gugel, Vice President of Engineering and Standards  
Board of Trustees Meeting  
February 6, 2020

RELIABILITY | RESILIENCE | SECURITY



- Background
  - Address Reliability Standards impacted by the Risk Based Registration (RBR) initiative
- Action
  - Adopt:
    - FAC-002-3 – Facility Interconnection Studies; IRO-010-3 – Reliability Coordinator Data Specification and Collection; MOD-031-3 – Demand and Energy Data; MOD-033-2 – Steady-State and Dynamic System Model Validation; NUC-001-4 – Nuclear Plant Interface Coordination; PRC-006-4 – Automatic Underfrequency Load Shedding; and TOP-003-4 – Operational Reliability Data.

- Background
  - Based on disturbance analyses and the [PRC-024-2 Gaps Whitepaper](#)
  - Clarifies and corrects technical issues for inverter-based resources
- Action
  - Adopt PRC-024-3 – Frequency and Voltage Protection Settings for Generating Resources

- **Background**
  - Corrective action plans (CAP) for supplemental GMD event vulnerabilities
  - ERO approval required for CAP extension requests
- **Action**
  - Adopt TPL-007-4 – Transmission System Planned Performance for Geomagnetic Disturbance Events

- Reliability Benefits

- Drafting team revised BAL-001-TRE-1 to:
  - remove the governor deadband and droop setting requirements for steam turbines in a combined cycle train; and
  - seek clarification of the responsible entity for Frequency Measurable Event exclusion requests.
- Drafting team made changes specified in the [Summary of Changes](#)

- Action

- Adopt BAL-001-TRE-2 - Primary Frequency Response in the ERCOT Region



# Questions and Answers

# NERC

NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION

# 2019 ERO Enterprise Dashboard

## Fourth Quarter Status

Thomas Coleman, Director of Risk Issue Management  
Board of Trustees Meeting  
February 6, 2020

RELIABILITY | RESILIENCE | SECURITY





- **Why is it important?**

- Measures risk to the bulk power system (BPS) from events on the Bulk Electric System (BES)

- **How is it measured?**

- Cumulative eSRI line in the composite daily event Severity Risk Index (eSRI) for Category 1–3 events (see pages 2-3 of [ERO Event Analysis Process](#) for category determination)

<p><b>Data (Annual Measurement)</b></p> <ul style="list-style-type: none"> <li>▪ Threshold: No Category 3 or above events: <i>Zero is green, else is red</i></li> </ul>	<p><b>2019 Status</b></p> 
<p><b>Data (Compared to a 5-year rolling average)</b></p> <ul style="list-style-type: none"> <li>▪ Slope of eSRI line is flat to decreasing and does not show an increase above zero that is statistically significant (95% Confidence Interval).</li> <li>▪ “2019 Status” relates to the slope of the 5-year rolling average (Positive, Flat or Negative), not just the 2019 performance.</li> </ul>	






- **Why is it important?**

- Reduce risk to BPS reliability from Standard violations by registered entities

- **How is it measured?**

- Compliance History\* of with moderate/serious risk noncompliance
- The number of violations discovered through self-reports, audits, etc.
- Risk to the BPS based on the severity of Standard violations

<p><b>Data (Annual Measurement)</b></p> <ul style="list-style-type: none"> <li>▪ Moderate and serious risk repeat violations filed with FERC on organizations that have Compliance History (based on 2017 metric) ---- Current number is 102</li> </ul>	<p><b>2019 Status</b></p> 
<p><b>Data (Annual Measurement)</b></p> <ul style="list-style-type: none"> <li>▪ Percent of noncompliance self-reported (Self-certified noncompliance is not included) (same as 2018 metric) ----Current number is 75%</li> </ul>	
<p><b>Data (Compared to a 3-year rolling average)</b></p> <ul style="list-style-type: none"> <li>▪ The number of serious risk violations resolved compared to the total noncompliance resolved (based on 2018 metric) --- Current number is 1.4%</li> </ul>	

\* To measure the effectiveness of the risk-based CMEP in reducing noncompliance, NERC reviews moderate and serious risk violations and includes them in one of three categories: 1) noncompliance with no prior compliance history; 2) noncompliance with prior compliance history that does not involve similar conduct; and 3) noncompliance with compliance history that includes similar conduct.

- **Why is it important?**
  - Protection system misoperations exacerbate the impacts
- **How is it measured?**
  - Annual Misoperations rate and the annual loss of load for events with misoperations

**Data (Year-Over-Year Comparison)**

- Q3-Q2 comparison misoperations rate based on collection interval (95% Confidence Interval) (Based on 2018 Metric)
- *Includes four years through Q2 2018. Data for year five not available until Q3 dashboard.*


**2019 Status**



**Data (Year-Over-Year Comparison)**

- Q3-Q2 comparison for qualified events with misoperations and loss of load (load loss/number of events) during the collection interval (95% Confidence Interval)

**No Change**







- **Why is it important?**

- Reduce risk to BPS reliability due to gas-fired unit outages during cold weather or gas unavailability

- **How is it measured?**

- Firm load loss due to cold weather or gas unavailability
- MWh of potential production lost initiated by cold weather and gas unavailability


<p><b>Data (Annual Measurement)</b></p> <ul style="list-style-type: none"> <li>▪ No firm load loss due to gas-fired unit outages during cold weather: <i>Zero is green, else is red</i> (Cold weather months: January – March and December of the same calendar year) <i>As of 12/31/2019, Metric status is Green.</i></li> </ul>	<p><b>2019 Status</b></p> 
<p><b>Data (Annual Measurement)</b> (Match with 4.4, year defined as Q3-Q2)</p> <ul style="list-style-type: none"> <li>▪ No firm load loss due to gas unavailability: <i>Zero is green, else is red</i> <i>As of 12/31/2019, Metric status is Green.</i></li> </ul>	
<p><b>Data (Compared to a 5-year rolling average)</b></p> <ul style="list-style-type: none"> <li>▪ Percentage of winter period net MWh of potential production lost due to gas-fired unit outages during cold weather (Cold weather months: January – March and December of the same calendar year) <i>Five-year average: 0.0067%</i></li> </ul>	<p>0.00149%      0.00053%</p> 
<p><b>Data (Compared to a 5-year rolling average)</b></p> <ul style="list-style-type: none"> <li>▪ Percentage of annual net MWh of potential production lost due gas unavailability compared to a 5-year rolling average (Due to data availability, year defined as Q3-Q2) <i>Five-year average: 0.1483%</i></li> </ul>	<p>0.192%      0.0898%</p> 

- **Why is it important?**

- Measures risks to BPS reliability from three priority causes:
  1. Operator or other human performance issues
  2. Substation equipment failures or failed circuit equipment
  3. Vegetation encroachment


- **How is it measured?**

- Number of transmission line outages caused by Human Error divided by the total inventory of circuits



## Data (Compared to a 5-year rolling average)


- Annual outage rate\* decreasing compared to a 5-year rolling average (95% Confidence Interval) (Based on 2018 metric)



\*Due to data availability, collection year defined as Q3-Q2


## • How is it measured?

- Number of transmission line outages caused by AC substation equipment outage failures and failed AC circuit equipment (such as transformers), divided by the total inventory of circuits



## Data (Compared to a 5-year rolling average)

- Annual outage rate\* decreasing compared to a 5-year rolling average (95% Confidence Interval) (Based on 2018 metric)



\*Due to data availability, collection year defined as Q3-Q2

- **How is it measured?**

- Number of potential FAC-003 violations\*

Year: #

2019: 0


2018: 3

2017: 6

2016: 0


2015: 3

Mean = 3 Standard deviation = 2.7




**Data\* (Compared to a 5-year rolling average)**

- Number of vegetation encroachments, excluding fall-ins, decreasing (within one standard deviation, based on small sample size) (Based on 2018 metric) -- 5-year average is 3.0



**Data\*\* (Compared to a 5-year rolling average)**

- Fall-ins: Number of vegetation encroachments decreasing (within one standard deviation, based on 6-year sample) -- 5-year average is 23.8



- **Why is it important?**

- Measures risk and impact to the BPS from cyber or physical security attacks

- **How is it measured?**

- Based on industry-submitted OE-417 and/or EOP-004 Electric Emergency Incident and Disturbance Reports\*

*One cyber security and 34 physical security events were reported in Q4 2019.*


\*As more data becomes available this metric will be enhanced to provide increased granularity of this risk

**Data (Annual Measurement), based on 2018 metric**

- No disruption\*\* of BES operations due to cyber attacks  
*Zero disruptions of BES operations due to cyber attacks in 2019 Q4*
- No disruption\*\* of BES operations due to physical attacks: *Zero is green, else is red*  
*Five disruptions of BES operations due to physical attacks in 2019 Q4*

\*\*A disruption means that a BES facility was removed from service as a result of the cyber or physical incident

**2019 Status**





- **Why is it important?**


- Measures risk to the BPS by monitoring the number of Disturbance Control Standard (DCS) events that are greater than the Most Severe Single Contingency (MSSC)

- **How is it measured?**

- Information received by NERC based on the BAL-002 Reliability Standard
- Due to the timing in Balancing Authority data submittals the metric is updated one quarter in arrears
- Measures a rolling 7 year quarterly time trend testing for statistical significance

**Data (Quarterly Measurement), New**

- **Green:** a time trend line of the most recent 7 years of quarterly DCS events > MSSC has a statistically significant negative slope
- **Middle:** no statistically significant trend for the slope
- **Red:** a time trend line of the most recent 7 years of quarterly DCS events > MSSC has a statistically significant positive slope
- **Metric Results through 3Q19: Green** - DCS data for the most recent 28 quarters shows a statistically significant decreasing trend



- **Why is it important?**

- Measures risk and impact to the BPS by measuring the interconnection frequency response performance measure (IFRM) for each BAL-003-1 event as compared to the Interconnection Frequency Response Obligation (IFRO)

- **How is it measured?**

- IFROs are calculated and recommended in the Frequency Response Annual Analysis Report for Reliability Standard BAL-003-1.1 implementation
- IFRM performance is measured for each event by comparing the resource (or load) MW loss to the frequency deviation
- Due to the timing in selection of events the metric is updated one quarter in arrears.

**Data (Quarterly & Annual Measurement), New**

- IFRM for each BAL-003-1 event is compared to the IFRO for each quarter of the 2019 operating year
- Success is no Interconnection experiencing a BAL-003-1 frequency event where IFRM performance is below their respective IFRO:  
*Zero is green, else is red*
- **Metric Results through 3Q19:** No Interconnection experienced a BAL-003-1 event where their IFRM was below their IFRO

**2019 Status**





# Questions and Answers



**WECC**

Reliability  
Coordination in the  
Western  
Interconnection

February , 2020

Branden Sudduth  
Vice President RPPA


# RC Transition Status

---


- RC West began operations of its expanded RC footprint on November 1
- SPP RC began operations of the SPP West RC footprint on December 3
- Peak Reliability ceased operations December 3



# 2019 RC Transition



# Transition Accomplishments



# Next Steps

---

- Transition to Reliability and Security Oversight activities
- Assurance visits around coordination and collaboration
- Regular updates at WECC Operating Committee meetings
- Engagement with RC governance and coordination committees







WECC

Electric Reliability and Security for the West

## Contact:

Branden Sudduth

Vice President RPPA

[bsudduth@wecc.org](mailto:bsudduth@wecc.org)

