

**A. Introduction**

1. **Title:** Transmission Operations
2. **Number:** TOP-004-~~0~~1
3. **Purpose:** To ensure that the transmission system is operated so that instability, uncontrolled separation, or cascading outages will not occur as a result of the most severe single Contingency and specified multiple Contingencies.
4. **Applicability:**
  - 4.1. Transmission Operators
5. **Proposed Effective Date:** ~~April July 1, 2005~~Twelve months after BOT adoption of FAC-014.

**B. Requirements**

- R1. Each Transmission Operator shall operate within the Interconnection Reliability Operating Limits (IROLs) and System Operating Limits (SOLs).
- R2. Each Transmission Operator shall operate so that instability, uncontrolled separation, or cascading outages will not occur as a result of the most severe single contingency.
- R3. Each Transmission Operator shall, ~~when practical,~~ operate to protect against instability, uncontrolled separation, or cascading outages resulting from multiple outages, as specified by its Reliability Coordinator~~Regional Reliability Organization policy.~~
- R4. If a Transmission Operator enters an unknown operating state (i.e. any state for which valid operating limits have not been determined), it will be considered to be in an emergency and shall restore operations to respect proven reliable power system limits within 30 minutes.
- R5. Each Transmission Operator shall make every effort to remain connected to the Interconnection. If the Transmission Operator determines that by remaining interconnected, it is in imminent danger of violating an IROL or SOL, the Transmission Operator may take such actions, as it deems necessary, to protect its area.
- R6. Transmission Operators, individually and jointly with other Transmission Operators, shall develop, maintain, and implement formal policies and procedures to provide for transmission reliability. These policies and procedures shall address the execution and coordination of activities that impact inter- and intra-Regional reliability, including:

~~R6.1. Equipment ratings.~~

~~R6.2.~~R6.1. Monitoring and controlling voltage levels and real and reactive power flows.

~~R6.3.~~R6.2. Switching transmission elements.

~~R6.4.~~R6.3. Planned outages of transmission elements.

~~R6.5. Development of IROLs and SOLs.~~

~~R6.6.~~R6.4. Responding to IROL and SOL violations.

**C. Measures**

Not specified.

**D. Compliance**

Not specified.

**E. Regional Differences**

**Standard TOP-004-~~0~~1— Transmission Operations**

---

None identified.

**Version History**

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata