



Implementation Plan for SPP Underfrequency Load Shedding, PRC-006-SPP-01

Prerequisite Approvals

SPP Regional Entity Trustees

Proposed Effective Date

Requirements R4, R5, and R6 shall become effective the first day of the first calendar quarter one year after regulatory approval. The one year phase in for compliance is needed for the Planning Coordinator to perform the studies necessary to assess the effectiveness of the UFLS program.

The remaining requirements shall become effective the first day of the first calendar quarter three years after regulatory approval. The additional two year phase in for compliance is needed for any necessary changes to be made to the existing UFLS schemes.

Applicability

The entities listed in the Applicability section will be held responsible for their requirements according to the effective dates listed above.

Field Testing

None

Other Considerations

UFLS entities may implement an aggregated UFLS program with other UFLS entities. In R1 and R2, the 100 MW limit refers to the aggregated UFLS program, if one exists.