

Standards Authorization Request Form

NERC welcomes suggestions to improve the reliability of the bulk power system through improved reliability standards. Please use this form to submit your request to propose a new or a revision to a NERC's Reliability Standard.

Request to propose a new or a revision to a Reliability Standard

Title of Proposed Standard: Retirement of Reliability Standard Requirements

Date Submitted: September 12, 2012

SAR Requester Information

Name: Brian J. Murphy on behalf of the following:

Organization: P81 Interim Standards Drafting Team, as originally supported by Edison Electric Institute, American Public Power Association, National Rural Electric Cooperative Association, Large Public Power Council, Electricity Consumers Resource Council, The Electric Power Supply Association, Transmission Access Policy Study Group, the North American Electric Reliability Corporation, and the Regional Entity Management Group

Telephone: 305-442-5132

SAR Type (Check as many as applicable)

- | | |
|---|---|
| <input type="checkbox"/> New Standard | <input checked="" type="checkbox"/> Withdrawal of existing Standard |
| <input checked="" type="checkbox"/> Revision to existing Standard | <input type="checkbox"/> Urgent Action |

SAR Information

Industry Need (What is the industry problem this request is trying to solve?):

On March 15, 2012, the Federal Energy Regulatory Commission (FERC) issued an order on NERC's Find, Fix and Track process that stated:

"The Commission notes that NERC's FFT initiative is predicated on the view that many violations of requirements currently included in Reliability Standards pose lesser

SAR Information

risk to the Bulk-Power System. If so, some current requirements likely provide little protection for Bulk-Power System reliability or may be redundant. The Commission is interested in obtaining views on whether such requirements could be removed from the Reliability Standards with little effect on reliability and an increase in efficiency of the ERO compliance program. If NERC believes that specific Reliability Standards or specific requirements within certain Standards should be revised or removed, we invite NERC to make specific proposals to the Commission identifying the Standards or requirements and setting forth in detail the technical basis for its belief. In addition, or in the alternative, we invite NERC, the Regional Entities and other interested entities to propose appropriate mechanisms to identify and remove from the Commission-approved Reliability Standards unnecessary or redundant requirements. We will not impose a deadline on when these comments should be submitted, but ask that to the extent such comments are submitted NERC, the Regional Entities, and interested entities coordinate to submit their respective comments concurrently.”

North American Electric Reliability Corporation, 138 FERC ¶ 61,193 at p 81 (March 15, 2012) (“P81”).

Consistent with P81, the problem this SAR is resolving is to identify Reliability Standards requirements that either: (a) provide little protection to the BPS;¹ (b) are unnecessary or (c) are redundant; and, thereafter, to have NERC file the identified Reliability Standard requirements with FERC to have them removed from the FERC-approved list of Reliability Standards.

In addition to addressing P81, this SAR is also consistent with Recommendation #4 set forth in *NERC’s Recommendations to Improve The Standards Development Process* at page 12 (April 2012), which states:

Recommendation 4: Standards Product Issues — The NERC board is encouraged to require that the standards development process address: . . . The retirement of standards no longer needed to meet an adequate level of reliability.

¹ Given NERC’s Reliability Standards are based on the definition of a Bulk Electric System (BES), the remainder of this SAR will use the term BES rather than Bulk Power System or BPS.

SAR Information

Purpose or Goal (How does this request propose to address the problem described above?):

The SAR addresses the problem identified above by:

(1) Setting forth the initial phase-specific criteria (below) to evaluate whether a Reliability Standard requirement provides little protection to BES reliability or is unnecessary or redundant.

(2) Establishing a multi-phased process for addressing these Reliability Standard requirements. During the initial phase, the standard drafting team will identify those Reliability Standard requirements that satisfy the criteria, set forth below, without the need for extensive technical justification or a modification to the requirement, and recommend the retirement of the requirement.² During subsequent phases, the standard drafting team may build upon the initial phase criteria, as applicable, to that phase that will identify the remaining appropriate Reliability Standard requirements that could not be included in the initial phase due to the need for additional analysis or a modification of language. This multi-phased approach is also proposed to address FERC's interest in increasing the efficiency of the ERO compliance program, so that the first set of identified Reliability Standard requirements may be filed with FERC on an expedited basis, and, therefore, start increasing ERO efficiencies as soon as practical.

(3) At this time, the standard drafting team has identified a list of Reliability Standard requirements to be included in the initial phase that satisfy the criteria set forth below.

(4) During each phase, as a list of Reliability Standard requirements is identified, the standard drafting team will also assist NERC staff to file these requirements with FERC so the requirements are removed from the FERC-approved list, including providing additional technical justification, as needed.

² The Standards Drafting Team will work with NERC staff to determine the manner to eliminate the identified Reliability Standard requirements.

SAR Information
Identify the Objectives of the proposed standard’s requirements (What specific reliability deliverables are required to achieve the goal?):
The objectives of this SAR for all phases of this project are to retire or modify FERC-approved Reliability Standard requirements that provide little protection to the reliable operations of the BES, are redundant or unnecessary, or to retire or modify a FERC-approved Reliability Standard requirement to increase the efficiency of the ERO’s compliance programs.
Brief Description (Provide a paragraph that describes the scope of this standard action.)
The scope of this SAR is all FERC-approved Reliability Standards. ³
Detailed Description (Provide a description of the proposed project with sufficient details for the standard drafting team to execute the SAR. Also provide a justification for the development or revision of the standard, including an assessment of the reliability and market interface impacts of implementing or not implementing the standard action.)
<p>The standard drafting team shall implement a phased process. The Initial Phase shall identify all FERC-approved Reliability Standard requirements that satisfy both: (i) Criteria A (the overarching criteria) and (ii) at least one of the Criteria B listed below (identifying criteria). In addition, for all phases, the standard drafting team shall also consider the data and reference points set forth below in Criterion C when deciding whether a Reliability Standard requirement should be retired or modified.</p> <p>A. Overarching Criterion:</p> <p>The Reliability Standard requirement requires responsible entities to conduct an activity or task that does little, if anything, to benefit or protect the reliable operation of the BES.</p> <p>Section 215(a)(4) of the Federal Power Act defines “reliable operation” as: “... operating the elements of the bulk-power system within equipment and electric system thermal, voltage, and stability limits so</p>

³ The scope of this SAR with regard to those requirements that are proposed for retirement includes any currently pending versions of the listed Reliability Standards and any additional version of these Reliability Standards that may be submitted. In other words, the intent is to carry forward these retirements based on substance which is not dependent on the exact numbering or placement within a Reliability Standard.

SAR Information

that instability, uncontrolled separation, or cascading failures of such system will not occur as a result of a sudden disturbance, including a cybersecurity incident, or unanticipated failure of system elements.”

B. Identifying Criteria:**1. Administrative**

The Reliability Standard requirement requires responsible entities to perform a function that is administrative in nature, does not support reliability and is needlessly burdensome.

2. Data Collection/Data Retention

These are requirements that obligate responsible entities to produce and retain data which document prior events or activities, and should be collected via some other method under NERC’s rules and processes.

3. Documentation

The Reliability Standard requirement requires responsible entities to develop a document (*e.g.*, plan, policy or procedure) which is not necessary to protect BES reliability.

4. Reporting

The Reliability Standard requirement obligates responsible entities to report to a Regional Entity, NERC or another party or entity. These are requirements that obligate responsible entities to report to a Regional Entity on activities which have no discernible impact on promoting the reliable operation of the BES and if the entity failed to meet this requirement there would be little reliability impact.

5. Periodic Updates

The Reliability Standard requirement requires responsible entities to periodically update (*e.g.*, annually) documentation, such as a plan, procedure or policy without an operational benefit to reliability.

6. Commercial or Business Practice

The Reliability Standard requirement is a commercial or business practice, or implicates commercial rather than reliability issues.

SAR Information

7. Redundant

The Reliability Standard requirement is redundant with (i) another FERC-approved Reliability Standard requirement; (ii) the ERO compliance and monitoring program; or (iii) a governmental regulation (*e.g.*, Open Access Transmission Tariff, North American Energy Standards Board (“NAESB”), etc.).

C. Additional data and reference points

In those instances where there is a need for additional information to assist in the determination of whether a Reliability Standard requirement satisfies both Criteria A and B, the standard drafting team shall consider the following data and reference points to make a more informed decision:

1. Was the Reliability Standard requirement part of a Find, Fix and Track filing?
2. Is the Reliability Standard requirement being reviewed in an on-going Standards Development Project?
3. What is the Violation Risk Factor of the Reliability Standard requirement?
4. In which tier of the 2013 Actively Monitored List does the Reliability Standard requirement fall?
5. Is there a possible negative impact on NERC’s published and posted reliability principles?
6. Is there any negative impact on the defense-in-depth protection of the BES?
7. Does the retirement promote results- or performance-based Reliability Standards?

To facilitate the standard drafting team’s consideration of the above questions, NERC staff will provide the team with relevant known data and statistics.

SAR Information

**List of Initial Phase Reliability Standard requirements that satisfy both Criteria A and B,
with consideration of Criterion C**

To be retired:⁴

BAL-005-0.2b R2

Each Balancing Authority shall maintain Regulating Reserve that can be controlled by AGC to meet the Control Performance Standard.

Criterion B 7.

Statement:⁵ BAL-005-0.2b is redundant with the Control Performance Standard defined in BAL-001-0.1a R1 and R2. This is also redundant in that it is measured by whether or not BAL-001-0.1a R1 and R2 are met.

Conclusion: This is redundant with the Control Performance Standard defined in BAL-001-0.1a R1 and R2. This is also redundant in that it is measured by whether or not BAL-001-0.1a R1 and R2 are met. This may be double jeopardy in that failure to achieve compliance with BAL-001-0.1a R1 and R2 could imply failure of this standard as well. This is misleading in requiring entities to maintain Regulating

⁴ The following requirements that were originally presented in the draft SAR, and now in this final SAR are denoted with a “*” are so denoted because research shows that they are already scheduled to be retired via another Standards Development Project that has been approved by stakeholders and the NERC Board of Trustees (or due to be before the Board in November – *i.e.*, PRC-005-2), and, thus, are presented here for informational purposes only: COM-001-1.1 R6, EOP-009-0 R2; FAC-008-1 R1.3.5; PRC-008-0 R1; PRC-008-0 R2; PRC-009-0 R1; PRC-009-0 R1.1; PRC-009-0 R1.2; PRC-009-0 R1.3; PRC-009-0 R1.4; PRC-009-0 R2; TOP-001-1a R3 and TOP-005-2a R1. These requirements are generally scheduled to be retired within the next year, and, therefore, to subject them to additional stakeholder vote, comment and Board of Trustees approval does not seem warranted or efficient. Consequently, these requirements will not be presented to stakeholders for comment and vote.

⁵ The “Statement” and “Conclusion” sections are brief statements that provide context. The technical justification for each Reliability Standards requirement is contained in a separate Technical White Paper that will also be posted for comment.

SAR Information

Reserve, but providing no way to measurably comply, apart from achieving compliance with BAL-001-0.1a R1 and R2.

CIP-001-2a R4.

Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.

Criterion B 1, 2 and 3.

Statement: CIP-001-2a is administrative, documentation and data collection in nature, because the establishment of communication contacts, in and of itself, with the FBI and RCMP has little or no impact on protection or the reliable operation of the BES. Instead, compliance with R1 through R3 of CIP-001-2a provides the actions that responsible entities take to protect the BES in the event of sabotage. Specifically, R1 through R3 require that the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity have procedures for the recognition of sabotage, reporting of sabotage and communication of sabotage events to appropriate parties in the Interconnection, which may include local law enforcement, the FBI, etc. Thus, CIP-001-2a R1 through R3 serve a reliability function, while R4 is a static, administrative requirement that has no clear results-based nexus to protecting the BES.

Conclusion: Since this requirement provides little protection to the BES and is administrative in nature, Requirement 4 should be removed from Reliability Standard CIP-001-2a.

CIP-003-3, -4 R1.2

The cyber security policy is readily available to all personnel who have access to, or are responsible for, Critical Cyber Assets.

Criterion B 1.

SAR Information

Statement: Whether there is a robust CIP compliance plan on which employees are trained may impact reliability, not whether the cyber security policy is readily available. Employees that are responsible for executing the cyber security policy are required to undergo a variety of training and follow multiple processes and procedures that are already required by the CIP requirements. Simply requiring that the policy be readily available is an administrative task that provides little, if any, benefit to reliability of the BES.

Conclusion: Since this requirement provides little protection to the BES and is purely administrative in nature, Requirement 1.2 should be removed from Reliability Standards CIP-003-3 and CIP-003-4.

CIP-003-3, -4 R3, R3.1, R3.2, R3.3

R3 Exceptions – Instances where the Responsible Entity cannot conform to its cyber security policy must be documented as exceptions and authorized by the senior manager or delegate(s).

R3.1 Exceptions to the Responsible Entity’s cyber security policy must be documented within thirty days of being approved by the senior manager or delegate(s).

R3.2 Documented exceptions to the cyber security policy must include an explanation as to why the exception is necessary and any compensating measures.

R3.3 Authorized exceptions to the cyber security policy must be reviewed and approved annually by the senior manager or delegate(s) to ensure the exceptions are still required and valid. Such review and approval shall be documented.

Criterion B 1 and 3.

Statement: Over time, these exception requirements have proven to not be useful and have been subject to misinterpretation, including responsible entities believing they can exempt themselves from compliance with the CIP requirements.

SAR Information

Conclusion: For regulatory efficiency, since these requirements provide little protection to the BES and are open to misinterpretation, in addition to being entirely documentation, Requirement 3 and its sub-requirements should be removed from Reliability Standards CIP-003-3 and CIP-003-4.

CIP-003-3, -4 R4.2.

The Responsible Entity shall classify information to be protected under this program based on the sensitivity of the Critical Cyber Asset information.

Criterion B 1, 3 and 7.

Statement: CIP-003-3, -4 R4 already requires the classification of information associated with Critical Cyber Assets, which makes R4.2 redundant. The only difference in R4.2 is the term, “based on the sensitivity” has been added. The addition of this term can be viewed as overly managing the responsible entities’ process of classification or simply not adding sufficient value to reliability to require a new requirement over and above R4.

Conclusion: Since this requirement is redundant and provides little protection to the BES, Requirement 4.2 should be removed from both Reliability Standards CIP-003-3 and CIP-003-4.

CIP-005-3a, -4a R2.6.

Appropriate Use Banner -- Where technically feasible, electronic access control devices shall display an appropriate use banner on the user screen upon all interactive access attempts. The Responsible Entity shall maintain a document identifying the content of the banner.

Criterion B 1 and 3.

Statement: Over time, the banner requirement (or no trespass sign) has not been shown to be useful or consistent with a results-based approach to implementing a cyber security program. Additionally, it is administrative in nature.

SAR Information

Conclusion: Since this requirement provides little protection to the BES and is purely administrative in nature, Requirement R2 should be removed from Reliability Standards CIP-005-3a and CIP-005-4.

CIP-007-3, -4 R7.3

The Responsible Entity shall maintain records that such assets were disposed of or redeployed in accordance with documented procedures.

Criterion B 1 and 2.

Statement: CIP-007-3, -4 R7.3 is evidence collection and possible for inclusion in an RSAW.

Conclusion: Since this requirement provides little protection to the BES and is data collection in nature, it should be removed from CIP-007-3, -4.

***COM-001-1.1 R6.**

Each NERCNet User Organization shall adhere to the requirements in Attachment 1-COM-001-0, "NERCNet Security Policy."

Criterion B 6 and 7.

Statement: This requirement has been approved by stakeholders for removal per Project 2006-06 (Reliability Coordination) and will be presented to the NERC Board of Trustees for approval in November. Thus, COM-001-1.1 R6 is presented here for informational purposes only.

EOP-004-1 R1.

Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.

SAR Information

Criterion B 1 and 3.

Statement: Whether or not there is a Regional Entity procedure to report disturbances has no impact on reliability. In other words, while a procedure for the collection of reports on disturbances may be useful information for purposes of Regional Entities to stay informed during events, is not an activity that protects the reliability of BES. The collection of such information should be established outside mandatory Reliability Standards.

Conclusion: Since this requirement provides little protection to the BES and is purely documentation, Requirement 1 should be removed from Reliability Standard EOP-004-1.

EOP-005-2 R3.1.

If there are no changes to the previously submitted restoration plan, the Transmission Operator shall confirm annually on a predetermined schedule to its Reliability Coordinator that it has reviewed its restoration plan and no changes were necessary.

Criterion B 1, 5 and 7.

Statement: EOP-005-2 R3 reads: “Each Transmission Operator shall review its restoration plan and submit it to its Reliability Coordinator annually on a mutually agreed predetermined schedule.” This requirement requires the Transmission Operator to submit its restoration plan to the Reliability Coordinator whether or not there have been changes. Therefore, R3.1 only adds a duplicative administrative burden for the entity to also confirm that there were no changes based upon another possible pre-determined schedule. Whether or not there was a change from year to year in the restoration plan will be documented in the revision history of the restoration plan, and thus the Reliability Coordinator will be able to ascertain whether or not there were changes based on R3. Thus, EOP-005-2 R3.1 provides little, if any, value to promoting the protection of the BES.

Conclusion: For regulatory efficiency, and since this requirement appears redundant to R3, Requirement 3.1 should be removed from Reliability Standard EOP-005-2.

SAR Information

***EOP-009-0 R2.**

The Generator Owner or Generator Operator shall provide documentation of the test results of the startup and operation of each blackstart generating unit to the Regional Reliability Organizations and upon request to NERC.

Criterion B 4.

Statement: In Order No. 749, the Commission approved the retirement of EOP-009-0 R2 as of July 1, 2013, and, thus, it is presented here for informational purposes only.

FAC-002-1 R2.

The Planning Authority, Transmission Planner, Generator Owner, Transmission Owner, Load-Serving Entity, and Distribution Provider shall each retain its documentation (of its evaluation of the reliability impact of the new facilities and their connections on the interconnected transmission systems) for three years and shall provide the documentation to the Regional Reliability Organization(s) and NERC on request (within 30 calendar days).

Criterion B 1 and 2.

Statement: Requiring the retention of studies for three years has no impact on protecting or the reliable operation of the BES, and is merely a data retention requirement that is better suited to be considered during an audit or in the context of compliance monitoring.

Conclusion: Since this requirement provides little protection to the BES and is purely data collection/retention, Requirement 2 should be removed from Reliability Standard FAC-002-1.

***FAC-008-1 R1.3.5.**

Other assumptions.

SAR Information

Criterion B 1.

Statement: The term “other assumptions” has already been removed via FAC-008-3, which will be effective on January 1, 2013, and, thus, it is presented here for informational purposes only.

FAC-008-1 R2; FAC-008-1 R3; FAC-008-3 R4; FAC-008-3 R5

FAC-008-1 R2 The Transmission Owner and Generator Owner shall each make its Facility Ratings Methodology available for inspection and technical review by those Reliability Coordinators, Transmission Operators, Transmission Planners, and Planning Authorities that have responsibility for the area in which the associated Facilities are located, within 15 business days of receipt of a request.

FAC-008-1 R3 If a Reliability Coordinator, Transmission Operator, Transmission Planner, or Planning Authority provides written comments on its technical review of a Transmission Owner’s or Generator Owner’s Facility Ratings Methodology, the Transmission Owner or Generator Owner shall provide a written response to that commenting entity within 45 calendar days of receipt of those comments. The response shall indicate whether a change will be made to the Facility Ratings Methodology and, if no change will be made to that Facility Ratings Methodology, the reason why.

FAC-008-3 R4 Each Transmission Owner shall make its Facility Ratings methodology and each Generator Owner shall each make its documentation for determining its Facility Ratings and its Facility Ratings methodology available for inspection and technical review by those Reliability Coordinators, Transmission Operators, Transmission Planners and Planning Coordinators that have responsibility for the area in which the associated Facilities are located, within 21 calendar days of receipt of a request.

FAC-008-3 R5 If a Reliability Coordinator, Transmission Operator, Transmission Planner or Planning Coordinator provides documented comments on its technical review of a Transmission Owner’s Facility Ratings methodology or Generator Owner’s documentation for determining its Facility Ratings and its Facility Rating methodology, the Transmission Owner or Generator Owner shall provide a response to that commenting entity within 45 calendar days of receipt of those comments. The response shall indicate whether a change will be made to the Facility Ratings methodology and, if no change will be made to that Facility Ratings methodology, the reason why.

SAR Information

Criterion B 1, 4 and 6.

Statement: For purposes of reliability, facility ratings are transmitted and used via the FAC (System Operating Limits), MOD and TPL Standards,⁶ and posting the rating methodology for comment and responding to comments in and of itself has no reliability benefit. Furthermore, these requirements do not appear appropriate given the possible commercial or market related implications of sharing and debating with a competitor the facility ratings methodology of a facility.

Conclusion: For regulatory efficiency and possible commercial or market implications in sharing the facility ratings, and since these requirements are purely administrative in nature along with reporting activities, Requirements R2 and R3 of Reliability Standard FAC-008-1 and Requirements 4 and 5 of Reliability Standard FAC-008-3 should be removed from the Standards.

FAC-010-2.1 R5; FAC-011-2 R5

FAC-010-2.1 R5 If a recipient of the SOL Methodology provides documented technical comments on the methodology, the Planning Authority shall provide a documented response to that recipient within 45 calendar days of receipt of those comments. The response shall indicate whether a change will be made to the SOL Methodology and, if no change will be made to that SOL Methodology, the reason why.

FAC-011-2 R5 If a recipient of the SOL Methodology provides documented technical comments on the methodology, the Reliability Coordinator shall provide a documented response to that recipient within 45 calendar days of receipt of those comments. The response shall indicate whether a change will be made to the SOL Methodology and, if no change will be made to that SOL Methodology, the reason why.

⁶ MOD-001-1a R9, MOD-028-1 R2.3; MOD-029-1a R2.1; MOD-030-02 R3.1, PRC-023-2, Attachment A 2.7; TPL-001-0.1 Footnote a; TPL-002-1b, footnotes a and b; TPL-003-0a, footnote a and TPL-004-0, footnote a. Also, via FAC-011-2 the System Operating Limits methodology of Reliability Coordinator may also use facility ratings as a key element. Also, FAC-008-3 R7 and R8 require the transmission of facility ratings to reliability entities.

SAR Information

Criterion B 1, 4 and 6.

Statement: A review of FAC-010-2.1 R5 and FAC-011-2 R5 indicate they are administrative requirements for the Planning Authority and Reliability Coordinator to respond to comments on its SOL methodology. Thus, similar to FAC-008-3 R4 and R5, there is no or little protection for BES reliability for a Planning Coordinator or Reliability Coordinator to enter into a give and take with the recipient on its SOL methodology.

Conclusion: Since these requirements are purely administrative, FAC-010-2.1 R5 and FAC-011-2 R5 should be removed from the Standards.

FAC-013-2 R3

If a recipient of the Transfer Capability methodology provides documented concerns with the methodology, the Planning Coordinator shall provide a documented response to that recipient within 45 calendar days of receipt of those comments. The response shall indicate whether a change will be made to the Transfer Capability methodology and, if no change will be made to that Transfer Capability methodology, the reason why.

Criterion B 1, 4 and 6.

Statement: Similar to the concerns with FAC-008, the FAC-013-2 requirement to reply to comments on a transfer capability methodology has no reliability benefit, and, moreover, a back and forward on transfer capability could have commercial or market implications.

Conclusion: For regulatory efficiency and possible commercial or market implications in sharing transfer capability methodology, and since these requirements are purely administrative in nature along with reporting activities, Requirement R3 of Reliability Standard FAC-013-2 should be removed from the Standards.

INT-007-1 R1.2

SAR Information

All reliability entities involved in the Arranged Interchange are currently in the NERC registry.

Criterion B 1.

Statement: INT-007-1 R1.2 is administrative in nature, and adds little to reliability.

Conclusion: Since INT-007-1 R1.2 provides little protection to the BES, it should be removed.

IRO-016-1 R2

The Reliability Coordinator shall document (via operator logs or other data sources) its actions taken for either the event or for the disagreement on the problem(s) or for both.

Criterion B 1 and 2.

Statement:

IRO-016-1 R2 is an evidence requirement and is a candidate to go into an RSAW.

Conclusion: Since IRO-016-1 R2 provides little protection to the BES and is data collection in nature, it should be removed.

NUC-001-2 R9.1; NUC-001-2 R9.1.1; NUC-001-2 R9.1.2; NUC-001-2 R9.1.3; NUC-001-2 R9.1.4

R9.1 Administrative elements:

R9.1.1 Definitions of key terms used in the agreement.

R9.1.2 Names of the responsible entities, organizational relationships, and responsibilities related to the NPIRs.

SAR Information

R9.1.3 A requirement to review the agreement(s) at least every three years.

R9.1.4 A dispute resolution mechanism.

Criterion B 1.

Statement: These requirements of NUC-001-2 do not address reliability, rather they address administrative and commercial terms of an agreement. Given there is no clear nexus between these requirements and reliability, they should be retired.

Conclusion: Since these requirements are purely administrative in nature, provide for a periodic update and commercial terms of the agreement, they provide little protection to the BES. Requirement 9.1 and associated sub-requirements should be removed from Reliability Standard NUC-001-2.

***PRC-008-0 R1; *PRC-008-0 R2; *PRC-009-0 R1; *PRC-009-0 R1.1; *PRC-009-0 R1.2; *PRC-009-0 R1.3; *PRC-009-0 R1.4; *PRC-009-0 R2; PRC-010-0 R2; PRC-022-1 R2.**

PRC-008-0 R1 The Transmission Owner and Distribution Provider with a UFLS program (as required by its Regional Reliability Organization) shall have a UFLS equipment maintenance and testing program in place. This UFLS equipment maintenance and testing program shall include UFLS equipment identification, the schedule for UFLS equipment testing, and the schedule for UFLS equipment maintenance.

PRC-008-0 R2 The Transmission Owner and Distribution Provider with a UFLS program (as required by its Regional Reliability Organization) shall implement its UFLS equipment maintenance and testing program and shall provide UFLS maintenance and testing program results to its Regional Reliability Organization and NERC on request (within 30 calendar days).

PRC-009-0 R1 The Transmission Owner, Transmission Operator, Load-Serving Entity and Distribution Provider that owns or operates a UFLS program (as required by its Regional Reliability Organization)

SAR Information

shall analyze and document its UFLS program performance in accordance with its Regional Reliability Organization's UFLS program. The analysis shall address the performance of UFLS equipment and program effectiveness following system events resulting in system frequency excursions below the initializing set points of the UFLS program. The analysis shall include, but not be limited to:

PRC-009-0 R1.1 A description of the event including initiating conditions.

PRC-009-0 R1.2 A review of the UFLS set points and tripping times.

PRC-009-0 R1.3 A simulation of the event.

PRC-009-0 R1.4 A summary of the findings.

PRC-009-0 R2 The Transmission Owner, Transmission Operator, Load-Serving Entity, and Distribution Provider that owns or operates a UFLS program (as required by its Regional Reliability Organization) shall provide documentation of the analysis of the UFLS program to its Regional Reliability Organization and NERC on request 90 calendar days after the system event.

PRC-010-0 R2 The Load-Serving Entity, Transmission Owner, Transmission Operator, and Distribution Provider that owns or operates a UVLS program shall provide documentation of its current UVLS program assessment to its Regional Reliability Organization and NERC on request (30 calendar days).

PRC-022-1 R2 Each Transmission Operator, Load-Serving Entity, and Distribution Provider that operates a UVLS program shall provide documentation of its analysis of UVLS program performance to its Regional Reliability Organization within 90 calendar days of a request.

Criterion B 1 and 2.

Statement: Under Standards Development Project 2007-17 Protection System Maintenance, which recently passed on August 27, 2012, PRC-008-0 is scheduled to be retired and replaced with PRC-005-2.

SAR Information

PRC-005-2 will likely be presented to the NERC Board of Trustees in November for approval, and, thus, PRC-008-0 is only presented here for informational purposes. In Order No. 763 at Paragraph 103 the Commission accepted the retirement of PRC-009-0 as appropriately replaced with PRC-006-1. Consistent with Order No. 763, PRC-009-0 will become inactive on September 30, 2013 and will be replaced by PRC-006-1. Thus, PRC-009-0 is presented here for informational purposes only.

Conversely, PRC-010-0 R2 and PRC-022-1 R2 are not scheduled to be retired and are purely administrative and data collection requirements that are better and more appropriately handled via spot checks/compliance audit request for evidence and the applicable RSAW.

Conclusion: Since PRC-010-0 R2 and PRC-022-1 R2 provide little protection to the BES and better handled via the compliance and monitoring program.

***TOP-001-1a R3**

Each Transmission Operator, Balancing Authority, and Generator Operator shall comply with reliability directives issued by the Reliability Coordinator, and each Balancing Authority and Generator Operator shall comply with reliability directives issued by the Transmission Operator, unless such actions would violate safety, equipment, regulatory or statutory requirements. Under these circumstances the Transmission Operator, Balancing Authority, or Generator Operator shall immediately inform the Reliability Coordinator or Transmission Operator of the inability to perform the directive so that the Reliability Coordinator or Transmission Operator can implement alternate remedial actions.

Criterion B 7.

Statement: Although there is redundancy between TOP-001-1a R3 and IRO-001-1a R8 related to Reliability Coordinators, this redundancy was addressed in Standards Development Project 2007-03 (Real-time Operations). Specifically, Project 2007-03 eliminated the redundancy in the current version of TOP-001-2 R1 that replaces TOP-001-1a R3 and reads:

Each Balancing Authority, Generator Operator, Distribution Provider, and Load-Serving Entity shall comply with each Reliability Directive issued and identified as such by its

SAR Information

Transmission Operator(s), unless such action would violate safety, equipment, regulatory, or statutory requirements.

TOP-001-2 has been approved by the NERC Board of Trustees and will be filed with the Commission for approval; therefore, TOP-001-1a R3 is presented for informational purposes only.

***TOP-005-2a R1**

As a condition of receiving data from the Interregional Security Network (ISN), each ISN data recipient shall sign the NERC Confidentiality Agreement for “Electric System Reliability Data.”

Criterion B 3.

Statement:

TOP-005-2a R1 is better suited for ROP than reliability requirement. A review of Standards Development Project 2007-03 Real-time Transmission Operations indicates it proposes R1 of TOP-005-1 to be retired. As stated above in the context of TOP-001, this project was approved by the NERC Board of Trustees and will be filed with the Commission for approval; therefore, TOP-005-2a R1 is presented for informational purposes only.

Conclusion: Since TOP-005-2a R1 provides little protection to the BES and is purely documentation in nature, it should be removed.

VAR-001-2 R5

Each Purchasing-Selling Entity and Load Serving Entity shall arrange for (self-provide or purchase) reactive resources – which may include, but is not limited to, reactive generation scheduling; transmission line and reactive resource switching; and controllable load– to satisfy its reactive requirements identified by its Transmission Service Provider.

Criterion B 7.

SAR Information

Statement: VAR-001-2 R5 is redundant with FERC’s pro forma open access transmission tariff (OATT) Specifically, the requirement provides for the PSE and LSE to arrange for reactive resources to satisfy the reactive requirements of the Transmission Service Provider, which is already required under Schedule No. 2 of the OATT.

Conclusion: Since VAR-001-2 R5 is redundant with requirements already under FERC’s OATT, and, thus, it should be removed.

Reliability Functions

The Standard will Apply to the Following Functions (Check each one that applies.)

<input checked="" type="checkbox"/> Regional Reliability Organization	Conducts the regional activities related to planning and operations, and coordinates activities of responsible entities to secure the reliability of the Bulk Electric System within the region and adjacent regions.
<input checked="" type="checkbox"/> Reliability Coordinator	Responsible for the real-time operating reliability of its Reliability Coordinator Area in coordination with its neighboring Reliability Coordinator’s wide area view.
<input checked="" type="checkbox"/> Balancing Authority	Integrates resource plans ahead of time, and maintains load-interchange-resource balance within a Balancing Authority Area and supports Interconnection frequency in real time.
<input checked="" type="checkbox"/> Interchange Authority	Ensures communication of interchange transactions for reliability evaluation purposes and coordinates implementation of valid and balanced interchange schedules between Balancing Authority Areas.
<input checked="" type="checkbox"/> Planning Coordinator	Assesses the longer-term reliability of its Planning Coordinator Area.
<input checked="" type="checkbox"/> Resource Planner	Develops a >one year plan for the resource adequacy of its specific loads within a Planning Coordinator area.
<input checked="" type="checkbox"/> Transmission Planner	Develops a >one year plan for the reliability of the interconnected Bulk

Reliability Functions	
	Electric System within its portion of the Planning Coordinator area.
<input checked="" type="checkbox"/> Transmission Service Provider	Administers the transmission tariff and provides transmission services under applicable transmission service agreements (e.g., the pro forma tariff).
<input checked="" type="checkbox"/> Transmission Owner	Owns and maintains transmission facilities.
<input checked="" type="checkbox"/> Transmission Operator	Ensures the real-time operating reliability of the transmission assets within a Transmission Operator Area.
<input checked="" type="checkbox"/> Distribution Provider	Delivers electrical energy to the End-use customer.
<input checked="" type="checkbox"/> Generator Owner	Owns and maintains generation facilities.
<input checked="" type="checkbox"/> Generator Operator	Operates generation unit(s) to provide real and reactive power.
<input checked="" type="checkbox"/> Purchasing-Selling Entity	Purchases or sells energy, capacity, and necessary reliability-related services as required.
<input type="checkbox"/> Market Operator	Interface point for reliability functions with commercial functions.
<input checked="" type="checkbox"/> Load-Serving Entity	Secures energy and transmission service (and reliability-related services) to serve the End-use Customer.

Reliability and Market Interface Principles	
Applicable Reliability Principles (Check all that apply).	
<input checked="" type="checkbox"/>	1. Interconnected bulk power systems shall be planned and operated in a coordinated manner to perform reliably under normal and abnormal conditions as defined in the NERC Standards.
<input checked="" type="checkbox"/>	2. The frequency and voltage of interconnected bulk power systems shall be controlled within defined limits through the balancing of real and reactive power supply and demand.
<input checked="" type="checkbox"/>	3. Information necessary for the planning and operation of interconnected bulk power systems shall be made available to those entities responsible for planning and operating the systems reliably.
<input checked="" type="checkbox"/>	4. Plans for emergency operation and system restoration of interconnected bulk power systems shall be developed, coordinated, maintained and implemented.
<input checked="" type="checkbox"/>	5. Facilities for communication, monitoring and control shall be provided, used and maintained for the reliability of interconnected bulk power systems.

Reliability and Market Interface Principles	
<input checked="" type="checkbox"/>	6. Personnel responsible for planning and operating interconnected bulk power systems shall be trained, qualified, and have the responsibility and authority to implement actions.
<input checked="" type="checkbox"/>	7. The security of the interconnected bulk power systems shall be assessed, monitored and maintained on a wide area basis.
<input checked="" type="checkbox"/>	8. Bulk power systems shall be protected from malicious physical or cyber attacks.
Does the proposed Standard comply with all of the following Market Interface Principles?	
	Enter (yes/no)
1. A reliability standard shall not give any market participant an unfair competitive advantage.	Yes
2. A reliability standard shall neither mandate nor prohibit any specific market structure.	Yes
3. A reliability standard shall not preclude market solutions to achieving compliance with that standard.	Yes
4. A reliability standard shall not require the public disclosure of commercially sensitive information. All market participants shall have equal opportunity to access commercially non-sensitive information that is required for compliance with reliability standards.	Yes

Related Standards	
Standard No.	Explanation

Related SARs	
SAR ID	Explanation

Related SARs	

Regional Variances	
Region	Explanation
ERCOT	
FRCC	
MRO	
NPCC	
RFC	
SERC	
SPP	
WECC	