

Standard Development Timeline

This section is maintained by the drafting team during the development of the standard and will be removed when the standard is adopted by the NERC Board of Trustees (Board).

Description of Current Draft

PRC-024-3 is posted for a 45-day formal comment period with initial ballot.

Completed Actions	Date
Standards Committee approved Standard Authorization Request (SAR) for posting	December 2018
SAR posted for comment	December 19, 2018 – January 19, 2019
Standards Committee accepted the revised SAR	February 20, 2019

Anticipated Actions	Date
45-day formal or informal comment period with ballot	April – June 2019
45-day formal or informal comment period with additional ballot	July – August 2019
10-day final ballot	October 2019
Board adoption	November 2019

A. Introduction

1. **Title:** Generator Frequency and Voltage ~~Protection Protective Relay~~ Settings
2. **Number:** ~~PRC-024-3~~ PRC-024-2
3. **Purpose:** ~~Ensure Generator Owners To set their generator protection, protective relays~~ such that generating ~~resource(s) units~~ remain connected, continuing to support the BES during defined frequency and voltage excursions.
4. **Applicability:**
 - 4.1. Generator Owner Functional Entities:
 - 4.1.1. Generator Owners that apply protection listed in Section 4.2.1.
 - 4.1.2. Transmission Owners that own a BES generator step-up (GSU) transformer or collector transformer and apply protection listed in Section 4.2.1.
 - 4.2. Facilities:
 - 4.2.1 Frequency, voltage or volts per hertz protection, including frequency or voltage protective functions within control systems that provide tripping or momentary cessation signals to all or part of the generating resource, applied to the following:
 - 4.2.1.1 Bulk Electric System (BES) generating resource(s).
 - 4.2.1.2 BES GSU transformer(s).
 - 4.2.1.3 High side of the generator-connected unit auxiliary transformer installed on BES generating resource(s).
 - 4.2.1.4 Individual dispersed power producing resources identified in the BES Definition, Inclusion I4.
 - 4.2.1.5 Elements utilized in aggregation of the dispersed power producing resources.
 - 4.2.1.6 Collector transformer of resources identified in the BES Definition, Inclusion I4.
5. **Effective Date:** See Implementation Plan for ~~PRC-024-2~~ PRC-024-3

B. Requirements and Measures

- R1.** Each Generator Owner or Transmission Owner that has generator frequency ~~protective relaying¹ activated to trip its applicable generating unit(s)~~ shall set its applicable frequency protection protective relaying such that ~~the the generator frequency protective relaying~~ generating resource does not trip or enter momentary cessation the applicable generating unit(s) within the “no trip zone” of PRC-024 Attachment 1, subject to the following exceptions²: [*Violation Risk Factor: Medium*] [*Time Horizon: Long-term Planning*]
- ~~Generating unit(s) may trip if the protective functions (such as out-of-step functions or loss of field functions) operate due to an impending or actual loss of synchronism or, for asynchronous generating units, due to instability in power conversion control equipment.~~
 - ~~Generating unit(s) may trip if clearing a system fault necessitates disconnecting (a) generating unit(s).~~
 - Generating resource(s) unit(s) may be set to trip or enter momentary cessation within a portion of the “no trip zone” of PRC-024 Attachment 1 for documented and communicated regulatory or equipment limitations in accordance with Requirement R3.
- M1.** Each Generator Owner or Transmission Owner shall have evidence that the applicable frequency protection has generator frequency protective relays have been set in accordance with Requirement R1, such as dated setting sheets, calibration sheets, calculations, or other documentation.
- R2.** Each Generator Owner or Transmission Owner that has generator voltage protective ~~relaying¹ activated to trip its applicable generating unit(s)~~ shall set its protective relaying applicable voltage protection such that the generator voltage protective relaying generating resource does not trip or enter momentary cessation within the “no trip zone” of PRC-024 Attachment 2 the applicable generating unit(s) as a result of a during a voltage excursion at the high side of the GSU or collector transformer, subject to the following exceptions: [Violation Risk Factor: Medium] [Time Horizon: Long-term Planning] (at the point of interconnection³) caused by an event on the

¹Each Generator Owner is not required to have frequency or voltage protective relaying (including but not limited to frequency and voltage protective functions for discrete relays, volts per hertz relays evaluated at nominal frequency, multi-function protective devices or protective functions within control systems that directly trip or provide tripping signals to the generator based on frequency or voltage inputs) installed or activated on its unit.

²For frequency protective relays associated with dispersed power producing resources identified through Inclusion I4 of the Bulk Electric System definition, this requirement applies to frequency protective relays applied on the individual generating unit of the dispersed power producing resources, as well as frequency protective relays applied on equipment from the individual generating unit of the dispersed power producing resource up to the point of interconnection.

~~transmission system external to the generating plant that remains within the “no trip zone” of PRC-024 Attachment 2.⁴~~

- If the Transmission Planner allows less stringent voltage relay protection settings than those required to meet PRC-024 Attachment 2, then the Generator Owner or Transmission Owner may shall set its protection protective relaying within the voltage recovery characteristics of a location-specific Transmission Planner’s study. ~~Requirement R2 is subject to the following exceptions: [Violation Risk Factor: Medium] [Time Horizon: Long term Planning]~~
- ~~Generating unit(s) may trip in accordance with a Special Protection System (SPS) or Remedial Action Scheme (RAS).~~
- ~~Generating unit(s) may trip if clearing a system fault necessitates disconnecting (a) generating unit(s).~~
- ~~Generating unit(s) may trip by action of protective functions (such as out-of-step functions or loss-of-field functions) that operate due to an impending or actual loss of synchronism or, for asynchronous generating units, due to instability in power conversion control equipment.~~
- Generating resource(s) unit(s) may trip or enter momentary cessation within a portion of the “no trip zone” of PRC-024 Attachment 2 for documented and communicated regulatory or equipment limitations in accordance with Requirement R3.

M2. Each Generator Owner or Transmission Owner shall have evidence that applicable generator voltage protection has~~protective relays have~~ been set in accordance with Requirement R2, such as dated setting sheets, voltage-time boundaries, calibration sheets, coordination plots, dynamic simulation studies, calculations, or other documentation.

R3. Each Generator Owner or Transmission Owner shall document each known regulatory or equipment limitation⁵ that prevents an applicable generating resource(s) unit with generator frequency or voltage protective relaysprotection from meeting the relay protection setting criteria in Requirements R1 or R2, including (but not limited to)

³For the purposes of this standard, point of interconnection means the transmission (high voltage) side of the generator step-up or collector transformer.

⁴For voltage protective relays associated with dispersed power producing resources identified through Inclusion I4 of the Bulk Electric System definition, this requirement applies to voltage protective relays applied on the individual generating unit of the dispersed power producing resources, as well as voltage protective relays applied on equipment from the individual generating unit of the dispersed power producing resource up to the point of interconnection.

⁵ Excludes limitations that are caused by the setting capability of the generator frequency and voltage protection protective relays themselves itself but does not exclude limitations originating in the equipment that they it protects.

study results, experience from an actual event, or manufacturer's advice. *[Violation Risk Factor: Lower] [Time Horizon: Long-term Planning]*

- 3.1.** The Generator Owner or Transmission Owner shall communicate the documented regulatory or equipment limitation, or the removal of a previously documented regulatory or equipment limitation, to its Planning Coordinator and Transmission Planner within 30 calendar days of any of the following:
- Identification of a regulatory or equipment limitation.
 - Repair of the equipment causing the limitation that removes the limitation.
 - Replacement of the equipment causing the limitation with equipment that removes the limitation.
 - Creation or adjustment of an equipment limitation caused by consumption of the cumulative turbine life-time frequency excursion allowance.
- M3.** Each Generator Owner or Transmission Owner shall have evidence that it has documented and communicated any known regulatory or equipment limitations ~~(excluding limitations noted in footnote 3)~~ that resulted in an exception to Requirements R1 or R2 in accordance with Requirement R3, such as a dated email or letter that contains such documentation as study results, experience from an actual event, or manufacturer's advice.
- R4.** Each Generator Owner or Transmission Owner shall provide its applicable generator protection ~~trip~~-settings associated with Requirements R1 and R2 to the Planning Coordinator or Transmission Planner that models the associated generating resource(s) unit within 60 calendar days of receipt of a written request for the data and within 60 calendar days of any change to those previously requested ~~trip~~-settings unless directed by the requesting Planning Coordinator or Transmission Planner that the reporting of relay-protection setting changes is not required. *[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]*
- M4.** Each Generator Owner or Transmission Owner shall have evidence that it communicated applicable generator ~~protective-relay trip-protection~~ settings in accordance with Requirement R4, such as dated e-mails, correspondence or other evidence and copies of any requests it has received for that information.

C. Compliance

1. Compliance Monitoring Process

- 1.1. Compliance Enforcement Authority:** "Compliance Enforcement Authority" means NERC or the Regional Entity, or any entity as otherwise designated by an Applicable Governmental Authority, in their respective roles of monitoring and/or enforcing compliance with mandatory and enforceable Reliability Standards in their respective jurisdictions.

- 1.2. Evidence Retention:** The following evidence retention period(s) identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full-time period since the last audit.

The applicable entity shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation.

- The Generator Owner or Transmission Owner shall keep data or evidence of Requirements R1 through R4 for 3 years or until the next audit, whichever is longer.
- If a Generator Owner or Transmission Owner is found non-compliant, the Generator Owner or Transmission Owner shall keep information related to the non-compliance until mitigation is complete and approved for the time period specified above, whichever is longer.

- 1.3. Compliance Monitoring and Enforcement Program:** As defined in the NERC Rules of Procedure, “Compliance Monitoring and Enforcement Program” refers to the identification of the processes that will be used to evaluate data or information for the purpose of assessing performance or outcomes with the associated Reliability Standard.

Violation Severity Levels

R #	Violation Severity Levels			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
R1.	N/A	N/A	N/A	The Generator Owner <u>or</u> Transmission Owner that has frequency protection activated to trip a generating unit, failed to set its <u>applicable generator frequency protection protective relaying</u> so that it does not trip <u>or enter momentary cessation</u> within the criteria listed in <u>according to Requirement R1,</u> unless there is a documented and communicated regulatory or equipment limitation per Requirement R3.
R2.	N/A	N/A	N/A	The Generator Owner <u>or</u> Transmission Owner with voltage protective relaying activated to trip a generating unit, failed to set its <u>applicable voltage protection protective relaying</u> so that it does not trip <u>or enter momentary cessation</u> as a result of a voltage excursion

R #	Violation Severity Levels			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
				at the point of interconnection, caused by an event external to the plant per the criteria specified in according to Requirement R2. unless there is a documented and communicated regulatory or equipment limitation per Requirement R3.
R3.	The Generator Owner <u>or</u> <u>Transmission Owner</u> documented the known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2 and communicated the documented limitation to its Planning Coordinator and Transmission Planner more than 30 calendar days but less than or equal to 60 calendar days of identifying the limitation.	The Generator Owner <u>or</u> <u>Transmission Owner</u> documented the known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2 and communicated the documented limitation to its Planning Coordinator and Transmission Planner more than 60 calendar days but less than or equal to 90 calendar days of identifying the limitation.	The Generator Owner <u>or</u> <u>Transmission Owner</u> documented the known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2 and communicated the documented limitation to its Planning Coordinator and Transmission Planner more than 90 calendar days but less than or equal to 120 calendar days of identifying the limitation.	The Generator Owner <u>or</u> <u>Transmission Owner</u> failed to document any known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2. OR The Generator Owner <u>or</u> <u>Transmission Owner</u> failed to communicate the documented limitation to its Planning Coordinator and

R #	Violation Severity Levels			
	Lower VSL	Moderate VSL	High VSL	Severe VSL
				Transmission Planner within 120 calendar days of identifying the limitation.
R4.	<p>The Generator Owner <u>or</u> <u>Transmission Owner</u> provided its generator protection settings more than 60 calendar days but less than or equal to 90 calendar days of any change to those settings.</p> <p>OR</p> <p>The Generator Owner <u>or</u> <u>Transmission Owner</u> provided generator protection settings more than 60 calendar days but less than or equal to 90 calendar days of a written request.</p>	<p>The Generator Owner <u>or</u> <u>Transmission Owner</u> provided its generator protection settings more than 90 calendar days but less than or equal to 120 calendar days of any change to those settings.</p> <p>OR</p> <p>The Generator Owner <u>or</u> <u>Transmission Owner</u> provided generator protection settings more than 90 calendar days but less than or equal to 120 calendar days of a written request.</p>	<p>The Generator Owner <u>or</u> <u>Transmission Owner</u> provided its generator protection settings more than 120 calendar days but less than or equal to 150 calendar days of any change to those settings.</p> <p>OR</p> <p>The Generator Owner <u>or</u> <u>Transmission Owner</u> provided generator protection settings more than 120 calendar days but less than or equal to 150 calendar days of a written request.</p>	<p>The Generator Owner failed to provide its generator protection settings within 150 calendar days of any change to those settings.</p> <p>OR</p> <p>The Generator Owner or <u>Transmission Owner</u> failed to provide generator protection settings within 150 calendar days of a written request.</p>

R #	Violation Severity Levels			
	Lower VSL	Moderate VSL	High VSL	Severe VSL

D. Regional Variances

D.A. Variance for the Quebec Interconnection

This Interconnection-wide Variance shall be applicable in the Quebec Interconnection and replaces-, in its entirety, continent-wide Requirement R2 with the following:

D.A.2. Each Generator Owner or Transmission Owner shall set its applicable voltage protection such that the generating resource does not trip or enter momentary cessation within the “no trip zone” of PRC-024 Attachment 2a during a voltage excursion at the high side of the GSU or collector transformer, subject to the following exceptions:
[Violation Risk Factor: Medium] [Time Horizon: Long-term Planning]

- If the Transmission Planner allows less stringent voltage protection settings than those required to meet PRC-024 Attachment 2a, then the Generator Owner or Transmission Owner may set its protection- within the voltage recovery characteristics of a location-specific Transmission Planner’s study.
- Generating resource(s) may trip or enter momentary cessation within a portion of the “no trip zone” of PRC-024 Attachment 2a for documented and communicated regulatory or equipment limitations in accordance with Requirement R3.
- Inverter-based resources voltage protection settings may be set to enter momentary cessation within the “no trip zone” of PRC-024 Attachment 2a during a voltage excursion at the high side of the MPT under the following conditions:
 - After a minimum delay of 0.022 s, when the positive-sequence voltage exceeds 1.25 per unit (p.u.) Normal operation must resume once the voltage drops back below 1.25 p.u.
 - After a minimum delay of 0.022 s, when the phase-to-ground RMS voltages exceeds 1.4p.u., as measured at generator terminals, on one or multiple phases. Normal operation must resume once the voltage drops back below the 1.25 p.u.

M.D.A.2. Each Generator Owner or Transmission Owner shall have evidence that applicable voltage protection has been set in accordance with Requirement R2 such as dated setting sheets, voltage-time boundaries, calibration sheets, coordination plots, dynamic simulation studies, calculations, or other documentation.

D.E. Associated Documents

Implementation Plan

Industry Recommendation I – Loss of Solar Resources during Transmission Disturbances Due to Inverter Settings

Industry Recommendation II – Loss of Solar Resources during Transmission Disturbances due to Inverter Settings

Blue Cut Fire Disturbance

Canyon 2 Fire Disturbance

“Protective Relaying For Power Generation Systems”, Boca Raton, FL, Taylor & Francis, 2006, Reimert, Donald

“IEEE C37.102 IEEE Guide for AC Generator Protection”

“IEEE C50.13 IEEE Standard for Cylindrical-Rotor 50 Hz and 60 Hz Synchronous Generators Rated 10 MVA and Above”


“IEEE C37.106 IEEE Guide for Abnormal Frequency Protection for Power Generating Plants”

Version History

Version	Date	Action	Change Tracking
1	May 9, 2013	Adopted by the NERC Board of Trustees	
1	March 20, 2014	FERC Order issued approving PRC-024-1. (Order becomes effective on 7/1/16.)	
2	February 12, 2015	Adopted by the NERC Board of Trustees	Standard revised in Project 2014-01: Applicability revised to clarify application of requirements to BES dispersed power producing resources
2	May 29, 2015	FERC Letter Order in Docket No. RD15-3-000 approving PRC-024-2	Modifications to adjust the applicability to owners of dispersed generation resources.

PRC-024 — Attachment 1

~~OFF NOMINAL FREQUENCY CAPABILITY CURVE~~



Attachment 1
OFF-NOMINAL FREQUENCY CAPABILITY CURVE
(Frequency No Trip Boundary by Interconnection)




Figure 1

Curve-Frequency Boundary Data Points – Eastern Interconnection

High Frequency Duration		Low Frequency Duration	
Frequency (Hz)	<u>Minimum</u> Time (Sec)	Frequency (Hz)	<u>Minimum</u> Time (sec)
≥61.8	<u>0.10</u> Instantaneous trip	≤57.8	<u>0.10</u> Instantaneous trip
≥60.5	$10^{(90.935-1.45713*f)}$	≤59.5	$10^{(1.7373*f-100.116)}$
<60.5	Continuous operation	> 59.5	Continuous operation

Table 1




Figure 2

Curve Frequency- Boundary Data Points – Western Interconnection

High Frequency Duration		Low Frequency Duration	
Frequency (Hz)	<u>Minimum</u> Time (Sec)	Frequency (Hz)	<u>Minimum</u> Time (sec)
≥61.7	<u>0.10</u> Instantaneous trip	≤57.0	<u>0.10</u> Instantaneous trip
≥61.6	30	≤57.3	0.75
≥60.6	180	≤57.8	7.5
<60.6	Continuous operation	≤58.4	30
		≤59.4	180
		>59.4	Continuous operation

Table 3




Figure 4

Curve-Frequency Boundary Data Points – Quebec Interconnection

High Frequency Duration		Low Frequency Duration	
Frequency (Hz)	<u>Minimum</u> Time (Sec)	Frequency (Hz)	<u>Minimum</u> Time (Sec)
>66.0	<u>0.10</u> Instantaneous trip	<55.5	<u>0.10</u> Instantaneous trip
≥63.0	5	≤56.5	0.35
≥61.5	90	≤57.0	2
≥60.6	660	≤57.5	10
<60.6	Continuous operation	≤58.5	90
		≤59.4	660
		>59.4	Continuous operation

Table 2




Figure 5


Curve Frequency -Boundary Data Points – ERCOT Interconnection

High Frequency Duration		Low Frequency Duration	
Frequency (Hz)	<u>Minimum</u> Time (Sec)	Frequency (Hz)	<u>Minimum</u> Time (sec)
≥61.8	<u>0.10</u> Instantaneous trip	≤57.5	<u>0.10</u> Instantaneous trip
≥61.6	30	≤58.0	2
≥60.6	540	≤58.4	30
<60.6	Continuous operation	≤59.4	540
		>59.4	Continuous operation

Table 3

PRC-024— Attachment 2

(Voltage No-Trip Boundary – Eastern, Western, and ERCOT Interconnections)



6

Figure 1

Voltage Boundary Data Points Ride Through Duration:

High Voltage Ride-Through Duration		Low Voltage Ride-Through Duration	
Voltage (pu)	Minimum Time (sec)	Voltage (pu)	Minimum Time (sec)
≥1.200	Instantaneous trip 0.00	<0.45	0.15
≥1.175	0.20	<0.65	0.30
≥1.15	0.50	<0.75	2.00
≥1.10	1.00	<0.90	3.00

*Voltage at the high-side of the GSU or collector transformer.

<u><1.10</u>	<u>4.00</u>	<u>≥ 0.90</u>	<u>4.00</u>
-----------------	-------------	---------------	-------------

Table 1

Voltage at the high-side of the GSU or collector transformer.

Voltage Boundary Clarifications – Eastern, Western, and ERCOT Interconnections

Boundary Details:

1. The per unit voltage base for these ~~boundaries~~~~curves~~ is the nominal operating voltage (e.g., 115 kV, 138 kV, 230 kV, 345 kV, 500 kV, etc.) ~~specified by the Transmission Planner in the analysis of the reliability of the Interconnected Transmission Systems at the point of interconnection to the Bulk Electric System (BES).~~
2. ~~The curves depicted were derived based on three-phase transmission system zone 1 faults with Normal Clearing not exceeding 9 cycles.~~ The boundaries apply to voltage excursions regardless of the type of initiating event.
3. The ~~values in the table represent the minimum time durations allowed for specified voltage excursion thresholds.~~ ~~envelope within the curves represents the cumulative voltage duration at the point of interconnection with the BES.~~ For example, if the voltage first exceeds 1.15 pu at 0.3 seconds after a fault, does not exceed 1.2 pu voltage, and returns below 1.15 pu at 0.4 seconds, then ~~the cumulative time the voltage is above 1.15 pu voltage is 0.1 seconds and is within the no trip zone of the curve.~~
4. The ~~boundaries~~ ~~curves~~ depicted assume a system frequency is of 60 Hertz. When evaluating ~~volts per hertz~~ Volts/Hertz protection, ~~you may adjust the~~ magnitude of the high voltage ~~curve~~ ~~boundary can be adjusted~~ in proportion to deviations of frequency below 60 Hertz.
5. Voltages in the ~~curve~~ ~~boundaries~~ assume RMS minimum fundamental frequency phase-to-ground or phase-to-phase voltage, ~~for the low voltage duration curve and the greater of maximum RMS or crest phase-to-phase voltage for the high voltage duration curve~~
- 5-6. ~~The “no trip zone” ends at 4 seconds.~~

Evaluating ~~Protection~~ Protective Relay Settings:

1. Use either the following assumptions or loading conditions that are believed to be the most probable for the unit under study to evaluate voltage protection ~~relay~~ setting calculations on the static case for steady state initial conditions:
 - a. All of the units connected to the same transformer are online and operating.
 - b. All of the units are at full nameplate real-power output.
 - c. Power factor is 0.95 lagging (i.e. supplying reactive power to the system) as measured at the generator terminals.
 - d. The automatic voltage regulator is in automatic voltage control mode.
2. ~~Evaluate voltage protection~~ ~~relay~~ settings assuming that additional installed generating plant reactive support equipment (such as static VAR compensators, synchronous condensers, or capacitors) is available and operating normally.
3. ~~Evaluate voltage protection~~ ~~relay~~ settings accounting for the actual tap settings of transformers between the generator terminals and the ~~point of interconnection~~ high

side of the GSU or collection transformer.

PRC-024— Attachment 2a (Voltage No Trip Boundaries – Quebec Interconnection)




Figure 1a

Voltage Boundary Data Points – Quebec Interconnection

<u>High Voltage Duration for all Power Plants</u>		<u>High Voltage Duration for strategic¹ Power Plants</u>	
<u>Voltage (pu)</u>	<u>Minimum Time (sec)</u>	<u>Voltage (pu)</u>	<u>Minimum Time (sec)</u>
<u>---</u>	<u>---</u>	<u>>1.50</u>	<u>0.033</u>
<u>>1.40</u>	<u>0.033</u>	<u>>1.40</u>	<u>0.10</u>
<u>>1.25</u>	<u>0.10</u>	<u>>1.25</u>	<u>2.50</u>
<u>>1.20</u>	<u>2.00</u>	<u>>1.20</u>	<u>5.00</u>
<u>>1.15</u>	<u>30</u>	<u>>1.15</u>	<u>30</u>
<u>>1.10</u>	<u>300</u>	<u>>1.10</u>	<u>300</u>
<u>≤1.10</u>	<u>continuous</u>	<u>≤1.10</u>	<u>continuous</u>

Table 1a

Voltage Boundary Data Points – Quebec Interconnection

<u>Low Voltage Duration for all Power Plants</u>		<u>Low Voltage Duration for Inverter-Based Resources</u>	
<u>Voltage (pu)</u>	<u>Minimum Time (sec)</u>	<u>Voltage (pu)</u>	<u>Minimum Time (sec)</u>
<u><0.25</u>	<u>0.15</u>	<u><0.25</u>	<u>3.4*V(pu)+0.15</u>
<u><0.75</u>	<u>1.00</u>	<u><0.75</u>	<u>1.00</u>
<u><0.85</u>	<u>2.00</u>	<u><0.85</u>	<u>2.00</u>
<u><0.90</u>	<u>30</u>	<u><0.90</u>	<u>30</u>
<u>≥0.90</u>	<u>continuous</u>	<u>≥0.90</u>	<u>continuous</u>

Table 2a

¹ Power Plants designated by the Transmission Planner for protecting the integrity of Transmission System equipment.

Voltage Boundary Clarifications – Quebec Interconnection

Boundary Details:

1. The per unit voltage base for these boundaries is the nominal operating voltage (e.g., 115 kV, 138 kV, 230 kV, 345 kV, 500 kV, etc.).
2. The boundaries apply to voltage excursions regardless of the type of initiating event.
3. The values in the table represent the minimum time durations allowed for specified voltage excursion thresholds.
4. The boundaries assume a system frequency of 60 Hertz. When evaluating volts per hertz protection, magnitude of the high voltage boundary can be adjusted in proportion to deviations of frequency below 60 Hertz.
5. Voltages in the boundaries assume positive-sequence values.

Evaluating Protection Settings:

1. Use either the following assumptions or loading conditions that are believed to be the most probable for the unit under study to evaluate voltage protection setting calculations on the static case for steady state initial conditions:
 - a. All of the units connected to the same transformer are online and operating.
 - b. All of the units are at full nameplate real-power output.
 - c. Power factor is 0.95 lagging (i.e. supplying reactive power to the system) as measured at the generator terminals.
 - d. The automatic voltage regulator is in automatic voltage control mode.
2. Evaluate voltage protection settings assuming that additional installed generating plant reactive support equipment (such as static VAr compensators, synchronous condensers, or capacitors) is available and operating normally.
3. Evaluate voltage protection settings accounting for the actual tap settings of transformers between the generator terminals and the high side of the GSU or collector transformer.