

Implementation Plan

Project 2015-10 Single Points of Failure Reliability Standard TPL-001-5

Applicable Standard(s)

- TPL-001-5 – Transmission System Planning Performance Requirements

Requested Retirement(s)

- TPL-001-4 – Transmission System Planning Performance Requirements

Prerequisite Standard(s)

- None

Applicable Entities

- Planning Coordinator
- Transmission Planner

Background

Reliability Standard TPL-001-5 revises the prior version of the TPL-001 standard in three key respects:

- To address reliability issues concerning the study of single points of failure on Protection Systems, as identified in Federal Energy Regulatory Commission (FERC) Order No. 754 issued September 15, 2011, and the NERC Planning Committee System Protection and Control Subcommittee and System Analysis and Modeling Subcommittee September 2015 report titled *Assessment of Protection System Single Points of Failure Based on the Section 1600 Data Request*;
- To address directives from FERC Order No. 786 issued October 17, 2013, in which FERC approved Reliability Standard TPL-001-4; and
- To replace references to the MOD-010 and MOD-012 standards, which have been superseded by the MOD-032 Reliability Standard.

General Considerations

The 36-month implementation period for TPL-001-5 provides Planning Coordinators and Transmission Planners with time to update their annual Planning Assessments to include the new System models and studies required by the standard. This implementation period reflects consideration that Planning Coordinators and Transmission Planners will need time to develop, among other things:

- A process for coordinating with the Reliability Coordinator which known outages of generation of Transmission Facilities of less than six months shall be represented in planning studies;
- A process for establishing coordination with protection engineers to obtain the necessary data to perform the single points of failure analysis required by the standard; and
- Additional base case models and analysis.

In addition, the implementation plan includes an additional 24 month period for the development of Corrective Action Plans under TPL-001-5 to address newly-added studies involving single points of failure on Protection Systems. This implementation period reflects consideration that Planning Coordinators and Transmission Planners will need time beyond that provided to conduct the new studies and analysis to develop processes for coordination with asset owners and protection engineers to identify appropriate Corrective Action Plan actions and establish the associated timetables for completion. This includes:

- ~~Any necessary Corrective Action Plans to address Cascading caused by the occurrence of Table 1 extreme events listed in the stability column for events 2e-2h required by TPL-001-5 Requirement R4 Part 4.6; and~~

Any necessary Corrective Action Plans to address System performance issues for studies involving Table 1 Category P5 Multiple Contingency (Fault plus non-redundant component of a Protection System failure to operate) required by TPL-001-5 Requirement R2 Part 2.7 for the following non-redundant components of a Protection System identified in TPL-001-5 Table 1 Footnote 13, items 2-4:

- A single communications system, necessary for correct operation of protective functions a communication-aided protection scheme required for Normal Clearing, which is not monitored or not reported;
- A single dc supply associated with protective functions, and that single station dc supply is not monitored or not reported for both low voltage and open circuit;
- A single control circuitry associated with protective functions through including the trip coil(s) of the circuit breakers or other interrupting devices.

Lastly, the provisions related to Corrective Action Plans including Non-Consequential Load Loss and curtailment of Firm Transmission Service (in accordance with Requirement R2, Part 2.7.3) are carried forward from the TPL-001-4 implementation plan.

Effective Date

TPL-001-5 – Transmission System Planning Performance Requirements

Where approval by an applicable governmental authority is required, the standard shall become effective on the first day of the first calendar quarter that is 36 months after the effective date of the applicable governmental authority's order approving the standard, or as otherwise provided by the applicable governmental authority.

Where approval by an applicable governmental authority is not required, the standard shall become effective on the first day of the first calendar quarter that is 36 months after the date the standard is adopted by the NERC Board of Trustees, or as otherwise provided for in that jurisdiction.

Compliance Date for TPL-001-5 Requirement ~~R4, Part 4.6 and Requirement 2, Part 2.7~~ associated with Table 1 Category P5 Footnote 13 items 2, 3, and 4

~~Entities shall not be required to comply with Requirement R4, Part 4.6 until 24 months after the effective date of Reliability Standard TPL-001-5.~~

Entities shall not be required to comply with Requirement R2, Part 2.7 for the Table 1 Category P5 planning event for the non-redundant components of a Protection System identified in footnote 13 items 2, 3, and 4 until 24 months after the effective date of Reliability Standard TPL-001-5.

Note Regarding Corrective Action Plans

For 84 calendar months beginning the first day of the first calendar quarter following applicable regulatory approval of TPL-001-4, or in those jurisdictions where regulatory approval is not required on the first day of the first calendar quarter 84 months after Board of Trustees adoption or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities, Corrective Action Plans applying to the following categories of Contingencies and events identified in TPL-001-5, Table 1 are allowed to include Non-Consequential Load Loss and curtailment of Firm Transmission Service (in accordance with Requirement R2, Part 2.7.3.) that would not otherwise be permitted by the requirements of TPL-001-5:

- P1-2 (for controlled interruption of electric supply to local network customers connected to or supplied by the Faulted element)
- P1-3 (for controlled interruption of electric supply to local network customers connected to or supplied by the Faulted element)
- P2-1
- P2-2 (above 300 kV)
- P2-3 (above 300 kV)
- P3-1 through P3-5
- P4-1 through P4-5 (above 300 kV)
- P5 (above 300 kV)

Initial Performance of Periodic Requirements

Each responsible entity shall complete the first annual Planning Assessment in accordance with TPL-001-5 by the effective date of the standard.

Each responsible entity shall complete any required Corrective Action Plans under Requirement ~~R4, Part 4.6 and Requirement~~ R2, Part 2.7 associated with the non-redundant components of a

Protection System identified in Table 1 Category P5 Footnote 13 items 2, 3, and 4 by 24 months after the effective date of Reliability Standard TPL-001-5.

Retirement Date

TPL-001-4 – Transmission System Planning Performance Requirements

Reliability Standard TPL-001-4 shall be retired immediately prior to the effective date of TPL-001-5 in the particular jurisdiction in which the revised standard is becoming effective.