

## Description of Current Draft

This is the second draft of the proposed Glossary Terms posted for a 45-day formal comment period and additional ballot.

Completed Actions	Date
Standards Committee approved Standards Authorization Request (SAR)	September 24, 2020
SAR posted for comment	December 16, 2020 – January 14, 2021
45-day formal comment period with initial ballot	November 16, 2023 – January 9, 2024

Anticipated Actions	Date
45-day formal comment period with additional ballot	February 22 – April 8, 2024
10-day final ballot	April 2024
NERC Board adoption	May 2024

## New or Modified Term(s) Used in NERC Reliability Standards

### Background:

This section includes all new or modified terms used in the proposed standard that will be included in the *Glossary of Terms Used in NERC Reliability Standards* upon applicable regulatory approval. The terms proposed below are intended to be used in MOD-026-2 and other inverter-based resource related standards.

### Term(s):

**Inverter-Based Resource (IBR):** A plant/facility that is connected to the electric system, consisting of one or more IBR Unit(s) operated as a single resource at a common point of interconnection. IBRs include, but are not limited to, solar photovoltaic (PV), Type 3 and Type 4 wind, battery energy storage system (BESS), and fuel cell.

**Inverter-Based Resource Unit (IBR Unit):** An individual device that uses a power electronic interface, such as an inverter or converter, capable of exporting Real Power from a primary energy source or energy storage system, and that connects at a single point on the collector system; or a grouping of multiple devices that uses a power electronic interface(s), such as an inverter or converter, capable of exporting Real Power from a primary energy source or energy storage system, and that connect together at a single point on the collector system.