

A. Introduction

- 1. Title:** **Emergency Operations Planning**
- 2. Number:** EOP-001-0b
- 3. Purpose:** Each Transmission Operator and Balancing Authority needs to develop, maintain, and implement a set of plans to mitigate operating emergencies. These plans need to be coordinated with other Transmission Operators and Balancing Authorities, and the Reliability Coordinator.
- 4. Applicability**
 - 4.1.** Balancing Authorities.
 - 4.2.** Transmission Operators.
- 5. Effective Date:** April 1, 2005

B. Requirements

- R1.** Balancing Authorities shall have operating agreements with adjacent Balancing Authorities that shall, at a minimum, contain provisions for emergency assistance, including provisions to obtain emergency assistance from remote Balancing Authorities.
- R2.** The Transmission Operator shall have an emergency load reduction plan for all identified IROLs. The plan shall include the details on how the Transmission Operator will implement load reduction in sufficient amount and time to mitigate the IROL violation before system separation or collapse would occur. The load reduction plan must be capable of being implemented within 30 minutes.
- R3.** Each Transmission Operator and Balancing Authority shall:
 - R3.1.** Develop, maintain, and implement a set of plans to mitigate operating emergencies for insufficient generating capacity.
 - R3.2.** Develop, maintain, and implement a set of plans to mitigate operating emergencies on the transmission system.
 - R3.3.** Develop, maintain, and implement a set of plans for load shedding.
 - R3.4.** Develop, maintain, and implement a set of plans for system restoration.
- R4.** Each Transmission Operator and Balancing Authority shall have emergency plans that will enable it to mitigate operating emergencies. At a minimum, Transmission Operator and Balancing Authority emergency plans shall include:
 - R4.1.** Communications protocols to be used during emergencies.
 - R4.2.** A list of controlling actions to resolve the emergency. Load reduction, in sufficient quantity to resolve the emergency within NERC-established timelines, shall be one of the controlling actions.
 - R4.3.** The tasks to be coordinated with and among adjacent Transmission Operators and Balancing Authorities.
 - R4.4.** Staffing levels for the emergency.
- R5.** Each Transmission Operator and Balancing Authority shall include the applicable elements in Attachment 1-EOP-001-0b when developing an emergency plan.

- R6.** The Transmission Operator and Balancing Authority shall annually review and update each emergency plan. The Transmission Operator and Balancing Authority shall provide a copy of its updated emergency plans to its Reliability Coordinator and to neighboring Transmission Operators and Balancing Authorities.
- R7.** The Transmission Operator and Balancing Authority shall coordinate its emergency plans with other Transmission Operators and Balancing Authorities as appropriate. This coordination includes the following steps, as applicable:
 - R7.1.** The Transmission Operator and Balancing Authority shall establish and maintain reliable communications between interconnected systems.
 - R7.2.** The Transmission Operator and Balancing Authority shall arrange new interchange agreements to provide for emergency capacity or energy transfers if existing agreements cannot be used.
 - R7.3.** The Transmission Operator and Balancing Authority shall coordinate transmission and generator maintenance schedules to maximize capacity or conserve the fuel in short supply. (This includes water for hydro generators.)
 - R7.4.** The Transmission Operator and Balancing Authority shall arrange deliveries of electrical energy or fuel from remote systems through normal operating channels.

C. Measures

- M1.** The Transmission Operator and Balancing Authority shall have its emergency plans available for review by the Regional Reliability Organization at all times.
- M2.** The Transmission Operator and Balancing Authority shall have its two most recent annual self-assessments available for review by the Regional Reliability Organization at all times.

D. Compliance

1. Compliance Monitoring Process

1.1. Compliance Monitoring Responsibility

Regional Reliability Organization.

1.2. Compliance Monitoring Period and Reset Timeframes

The Regional Reliability Organization shall review and evaluate emergency plans every three years to ensure that the plans consider the applicable elements of Attachment 1-EOP-001-0b.

The Regional Reliability Organization may elect to request self-certification of the Transmission Operator and Balancing Authority in years that the full review is not done.

Reset: one calendar year.

1.3. Data Retention

Current plan available at all times.

1.4. Additional Compliance Information

Not specified.

2. Levels of Non-Compliance

- 2.1. Level 1:** One of the applicable elements of Attachment 1-EOP-001-0b has not been addressed in the emergency plans.

- 2.2. Level 2:** Two of the applicable elements of Attachment 1-EOP-001-0b have not been addressed in the emergency plans.
- 2.3. Level 3:** Three of the applicable elements of Attachment 1-EOP-001-0b have not been addressed in the emergency plans.
- 2.4. Level 4:** Four or more of the applicable elements of Attachment 1-EOP-001-0b have not been addressed in the emergency plans or a plan does not exist.

E. Regional Differences

None identified.

Version History

| Version | Date | Action | Change Tracking |
|----------------|-------------------|---|---|
| 0 | February 8, 2005 | Adopted by the Board of Trustees | New |
| 0 | April 1, 2005 | Effective Date | New |
| 0 | August 8, 2005 | Removed “Proposed” from Effective Date | Errata |
| 0b | November 4, 2010 | Adopted by the Board of Trustees | Project 2008-09 - Interpretation of Requirement R1 |
| 0b | November 4, 2010 | Adopted by the Board of Trustees | Project 2009-28 - Interpretation of Requirement R2.2 (R3.2 in EOP-001-0) |
| 0b | December 15, 2011 | FERC Order issued approving Interpretation of R1 and R3.2 (Order effective December 15, 2011) | Project 2008-09 - Interpretation of Requirement R1 and Project 2009-28 - Interpretation of Requirement R2.2 (R3.2 in EOP-001-0) |

Attachment 1-EOP-001-0b

Elements for Consideration in Development of Emergency Plans

1. Fuel supply and inventory — An adequate fuel supply and inventory plan that recognizes reasonable delays or problems in the delivery or production of fuel.
2. Fuel switching — Fuel switching plans for units for which fuel supply shortages may occur, e.g., gas and light oil.
3. Environmental constraints — Plans to seek removal of environmental constraints for generating units and plants.
4. System energy use — The reduction of the system’s own energy use to a minimum.
5. Public appeals — Appeals to the public through all media for voluntary load reductions and energy conservation including educational messages on how to accomplish such load reduction and conservation.
6. Load management — Implementation of load management and voltage reductions, if appropriate.
7. Optimize fuel supply — The operation of all generating sources to optimize the availability.
8. Appeals to customers to use alternate fuels — In a fuel emergency, appeals to large industrial and commercial customers to reduce non-essential energy use and maximize the use of customer-owned generation that rely on fuels other than the one in short supply.
9. Interruptible and curtailable loads — Use of interruptible and curtailable customer load to reduce capacity requirements or to conserve the fuel in short supply.
10. Maximizing generator output and availability — The operation of all generating sources to maximize output and availability. This should include plans to winterize units and plants during extreme cold weather.
11. Notifying IPPs — Notification of cogeneration and independent power producers to maximize output and availability.
12. Requests of government — Requests to appropriate government agencies to implement programs to achieve necessary energy reductions.
13. Load curtailment — A mandatory load curtailment plan to use as a last resort. This plan should address the needs of critical loads essential to the health, safety, and welfare of the community. Address firm load curtailment.
14. Notification of government agencies — Notification of appropriate government agencies as the various steps of the emergency plan are implemented.
15. Notifications to operating entities — Notifications to other operating entities as steps in emergency plan are implemented.

Appendix 1

| Requirement Number and Text of Requirement | |
|---|---|
| R1. | Balancing Authorities shall have operating agreements with adjacent Balancing Authorities that shall, at a minimum, contain provisions for emergency assistance, including provisions to obtain emergency assistance from remote Balancing Authorities. |
| Questions: | |
| 1. | What is the definition of emergency assistance in the context of this standard? What scope and time horizons, if any, are considered necessary in this definition? |
| 2. | What was intended by using the adjective “adjacent” in Requirement 1? Does “adjacent Balancing Authorities” mean “All” or something else? Is there qualifying criteria to determine if a very small adjacent Balancing Authority area has enough capacity to offer emergency assistance? |
| 3. | What is the definition of the word “remote” as stated in the last phrase of Requirement 1? Does remote mean every Balancing Authority who’s area does not physically touch the Balancing Authority attempting to comply with this Requirement? |
| 4. | Would a Balancing Authority that participates in a Reserve Sharing Group Agreement, which meets the requirements of Reliability Standard BAL-002-0, Requirement 2, have to establish additional operating agreements to achieve compliance with Reliability Standard EOP-001-0, Requirement 1? |
| Responses: | |
| 1. | In the context of this standard, emergency assistance is emergency energy. Emergency energy would normally be arranged for during the current operating day. The agreement should describe the conditions under which the emergency energy will be delivered to the responsible Balancing Authority. |
| 2. | The intent is that all Balancing Authorities, interconnected by AC ties or DC (asynchronous) ties within the same Interconnection, have emergency energy assistance agreements with at least one Adjacent Balancing Authority and have sufficient emergency energy assistance agreements to mitigate reasonably anticipated energy emergencies. However, the standard does not require emergency energy assistance agreements with all Adjacent Balancing Authorities, nor does it preclude having an emergency assistance agreement across Interconnections. |
| 3. | A remote Balancing Authority is a Balancing Authority other than an Adjacent Balancing Authority. A Balancing Authority is not required to have arrangements in place to obtain emergency energy assistance with any remote Balancing Authorities. A Balancing Authority’s agreement(s) with Adjacent Balancing Authorities does (do) not preclude the Adjacent Balancing Authority from purchasing emergency energy from remote Balancing Authorities. |
| 4. | A Reserve Sharing Group agreement that contains provisions for emergency assistance may be used to meet Requirement R1 of EOP-001-0. |

Appendix 2

| Requirement Number and Text of Requirement |
|---|
| R2.2. Develop, maintain, and implement a set of plans to mitigate operating emergencies on the transmission system. |
| Questions: |
| Does the BA need to develop a plan to maintain a load-interchange-generation balance during operating emergencies and follow the directives of the TOP? |
| Questions: |
| The answer to both parts of the question is yes. The Balancing Authority is required by the standard to develop, maintain, and implement a plan. The plan must consider the relationships and coordination with the Transmission Operator for actions directly taken by the Balancing Authority. The Balancing Authority must take actions either as directed by the Transmission Operator or the Reliability Coordinator (reference TOP-001-1, Requirement R3), or as previously agreed to with the Transmission Operator or the Reliability Coordinator to mitigate transmission emergencies. As stated in Requirement R4, the emergency plan shall include the applicable elements in “Attachment 1 –EOP-001-0.” |