

NERC

NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

CEI Webinar

Find, Fix, Track and Report (FFT) Update

February 2, 2012

RELIABILITY | ACCOUNTABILITY



- 1) Purpose of CEI and overview of FFT
- 2) Implementation of FFT to date
- 3) Preparation for 6-month filing with FERC
- 4) Timeline for phased implementation
- 5) Discussion of specific FFT Remediated Issues

- Refocus efforts on reliability excellence
 - Differentiate issues of noncompliance based on the level of risk to the reliability of the bulk power system
 - Continue to identify, correct and report all instances of noncompliance
- Eliminate undue regulatory burdens
- Streamline paperwork and filing requirements
- Encourage continued timely and thorough self-reporting and mitigation
- Improve caseload processing

- A Registered Entity may opt out of FFT processing
- Upon correction and submittal of FFT filing, the Possible Violation becomes a Remediated Issue
 - No penalty or sanction is assigned
 - Formal Mitigation Plans will not be required
 - Mitigating activity completion may be verified anytime
- Remediated Issues become part of a Registered Entity's compliance history

- On September 30, 2011, NERC filed several components of the Compliance Enforcement Initiative
 - Petition for Approval of New Enforcement Mechanisms
 - Reports due to industry at six months and one year
 - 117 FFT Remediated Issues
 - 75 Spreadsheet NOPs
 - 27 Full NOPs
- On October 28, 2011, FERC issued notice of no further review of the Spreadsheet NOPs and the Full NOPs

- On October 31, 2011, NERC filed the second group
 - 82 FFT Remediated Issues
 - 46 Spreadsheet NOPs
 - 31 Full NOPs
- On November 30, 2011, FERC issued notice of no further review of the Spreadsheet NOPs and the Full NOPs

- On November 30, 2011, NERC filed the third group
 - 50 FFT Remediated Issues
 - 60 Spreadsheet NOPs
 - 21 Full NOPs
- On December 30, 2011, FERC issued notice of no further review of the Spreadsheet NOPs and the Full NOPs

- On December 30, 2011, NERC filed the fourth group
 - 76 FFT Remediated Issues
 - 54 Spreadsheet NOPs
 - 15 Full CIP NOPs
- On January 27, 2012, FERC issued notice of no further review of the Spreadsheet NOPs and the Full NOPs

- On January 31, 2012, NERC filed the fifth group
 - 57 FFT Remediated Issues
 - 51 Spreadsheet NOPs
 - 21 Full CIP NOPs
- FERC order pending

- FRCC 77
- MRO 68
- NPCC 13
- RFC 77
- SERC 30
- SPP RE 43
- TRE 37
- WECC 17

• CIP	234 (62 TFEs)	• PER	6
• PRC	40	• MOD	3
• FAC	36	• TPL	3
• EOP	25	• COM	3
• VAR	14	• INT	2
• TOP	7	• IRO	2
• BAL	6	• NUC	0

- NERC committed to submit six-month and one-year informational filings with FERC
 - On or about March 30, 2012
 - On or about September 28, 2012
- NERC is working with Regional Entities
- NERC is soliciting Registered Entity feedback
 - February MRC meeting
 - Registered Entity responses to survey were due February 1, 2012
 - Written comments may be submitted by e-mail on or before February 23, 2012

- Guidelines
- Data and Trends
- Benefits
- Implementation and Transition Challenges
- Potential Improvements
- Training Schedule

**Phase I –
September 2011**

Possible
Violations
identified in all
compliance
monitoring
methods qualify
for FFT Report
consideration

**Phase II –
September 2012 or
later**

CEA auditors make
determinations in
the field on
disposition tracks;
CEA Enforcement
staff make
determinations on
other monitoring
methods

**Phase III –
2013 or later**

Future options
could include
aggregated
reporting of
Remediated
Issues to CEA,
NERC and FERC

NERC

NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

Specific FFT Remediated Issues Issues, Risk and Mitigation

RELIABILITY | ACCOUNTABILITY



- To date, 382 FFTs filed
 - They include minimal to moderate risk issues
 - They include documentation and operational issues
 - 1 was moved to Spreadsheet NOP
- Of these, 61 were late-filed TFEs
 - 50 were CIP-007
 - 7 were CIP-005
 - 4 were CIP-006

- This presentation provides a high level summary of some FFT remediated issues. For further details on individual FFTs filed with FERC as of January 31, 2012, please refer to the searchable FFT spreadsheet, available at :

<http://www.nerc.com/filez/enforcement/index.html>

- For a complete set of NERC-approved mandatory Reliability Standards, please refer to:

<http://www.nerc.com/page.php?cid=2|20>

Issue

Risk

Mitigation

R2: Fixed Frequency Bias

Minimal: Bias setting used single most severe disturbance to determine Frequency Bias rather than averaging several

Revise procedure to ensure several disturbances used

R3: AGC Settings

Minimal: EMS was continuously monitored, issue occurred during minimal usage period, no deviation in system frequency

Update cyber security change control protocols

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R11: Ramp Rates	Minimal: Impact was increase in inadvertent energy during ramp times	Update procedures for e-tag review and approval
R6: AGC Mode	Minimal: AGC mode has little impact to system frequency deviations, system frequency was monitored	Update cyber security change control protocols
R8: RTU Scan Rate	Minimal: Limited # scan rates and longer scan rate than minimum	Change scan rates and updated data acquisition procedure

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: Sabotage Awareness Procedures	Minimal: Little or no BES facilities; relied on third party process; security policy	Adopt procedure addressing sabotage
R2: Sabotage Communication Procedures	Minimal: Little or no Critical Assets, Critical Cyber Assets or BES facilities	Adopt procedure or include language on sabotage reporting
R3: Sabotage Guidelines for personnel	Minimal: Little or no Critical Assets, Critical Cyber Assets or BES facilities	Adopt and disseminate procedure or include language on sabotage reporting
R4: Contact FBI on sabotage events	Minimal: Little or no Critical Assets, Critical Cyber Assets or BES facilities	Adopt procedure to contact FBI for sabotage

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: Communicating sabotage events to personnel	Minimal: Personnel trained on sabotage and list of local authorities contact info maintained on site	Adopt procedure to increase awareness of personnel
R2: Communicating sabotage events to other entities	Minimal: Personnel trained on sabotage and list of neighboring entities contact info maintained on site	Adopt procedure to recognize and report sabotage events
R3: Communicating sabotage to law enforcement	Minimal: Little or no Critical Assets, Critical Cyber Assets or BES facilities	Adopt procedure to recognize and report sabotage events

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: Risk based assessment methodology	Minimal: No CAs that could impact the BPS, size of entity	Adopt appropriate methodology and implement
R2: Failure to identify all cyber assets in methodology	Minimal/Moderate: No CAs, CCAs on system or minimal delay in identification	Correct misidentification of assets and develop accurate list
R3: Develop list of all critical cyber assets (CCA)	Minimal: Assets incorrectly identified as CCAs or omitted but did not leave assets unprotected	Correct misidentification of assets and develop accurate list
R4: Review and approve the list of CCAs annually	Minimal: No CCAs identified or minimal delay in developing initial list	Establish procedure to document status of CCAs and approve annually

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: Risk based assessment methodology: omission of evaluation criteria	Minimal: Entities did correctly evaluate assets using studies	Adopt appropriate methodology and implement
R3: Develop list of all critical cyber assets (CCA)	Minimal: Assets incorrectly identified as CCAs and added to list	Correct misidentification of assets and develop accurate list
R4: Review and approve the list of CCAs annually	Minimal: No CAs or CCAs identified or minimal delay in developing initial list; no senior manager signed and dated record of approval	Establish procedure to document status of CCAs and approve annually

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: Risk based assessment methodology: third parties	Minimal: Third party assets were not considered; communications could not directly control assets	Amend procedure to include review of third parties
R2: Develop list of all critical cyber assets (CCA)	Minimal: No CAs and CCAs identified for entity involved	Adopt procedure to review annually
R3: Review and approve the list of CCAs annually	Minimal: No CAs and CCAs identified for entity involved	Adopt procedure to document status of CCAs and approve annually
R4: Review and approve CCA Methodology annually	Minimal: Approved its RBAM in the previous and following years	Adopt procedure to review methodology and approve annually

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: Cyber Security Policy	Minimal/Moderate: Policies in place but documentation inconsistencies	Revise CSP to comply with requirements of standard
R2: Senior manager responsibility for CIP	Minimal: No or minimal CCAs identified for entities involved/documentation error	Assign senior manager responsibility and document
R3: Exceptions to cyber policy	Minimal: Third parties preparing compliance with CIP Standards; gap in compliance	Adopt procedure to address exception reporting
R4: Information Protection	Minimal: Misabeled information related to CCAs	Reviewed all related information and corrected deficiencies.
R6: Change Control for CCAs	Minimal: Had a non-documented process to track changes	Document change related to control process

Issue

R2: Senior manager responsibility for CIP

Risk

Minimal: Documentation issues with updating personnel changes due to turnover, no gap in Compliance

Mitigation

Modified procedures, documented the personnel with CIP accountability

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R2: Cyber security training programs	Minimal: Contractors and internal personnel were not given CIP training prior to access to CCAs	Training for personnel granting access enhanced and tracking of personnel with access implemented. Automatic revocation of access if not trained
R3: Personnel assessment for all with access to CCAs	Minimal: Involved long-time employees/contractors	Audited personnel records and performed required PRAs; verified third parties performed and provided PRAs
R4: Unescorted access to CCAs: changes	Vendor/Contactor lists were not reviewed quarterly but annually in most cases; physical access devices were taken upon employment status changes	Develop improved tracking process to track vendor updates and personnel status changes

Issue

Risk

Mitigation

R1: Cyber assets within the Electronic Security Perimeter

Minimal: Unidentified assets were used to monitor network traffic

Updated training on how to identify CCAs and updated network topology correctly

R3: Monitoring electronic access; documentation

Minimal: review and logging process not properly documented

Document logging processes and publish appropriately

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: Physical security plans and access controls; CCAs	Minimal: Facilities monitored electronically 24/7 and access was limited	Physical issues were addressed with barriers; enhanced CIP training regarding visitor access inside Physical Security Perimeter(PSP)
R4: Physical access controls; logging visitor access	Minimal: All admitted inside PSP has been trained and approved	Communicate to staff and enhance training on visitor logging
R7: Access logs: retention	Minimal: All controls were in place when logging software was inoperative	System reconfigured to prevent recurrence of error

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: Test procedures; new or significantly changed CCAs	Minimal: Documentation of compatibility with existing CCAs	Additional testing completed and documented.
R2: Ports and services	Minimal: Unnecessary ports and services not open on CCAs	Disabled ports and services on devices
R5: Account Management: passwords	Minimal: Physical security and access to CCAs was maintained and persons with access were properly trained and screened	Upgraded technology and procedures to accurately track access and flag for update as necessary
R6: Security status monitoring: logs	Minimal: Continuous monitoring within the ESP was uninterrupted	Implement procedure to ensure regular security log review

Issue

R1: Cyber Security Incident Response Plan: Maintaining and updating plans

Risk

Minimal: Documentation errors were corrected promptly and measures were in place through other procedures at the organization to ensure compliance.

Mitigation

Correct deficiencies and update plans to require updates that meet the requirements of the Standard.

Issue

R1: Recovery plans for CCAs:
Cyber assets included and
activation criteria

Risk

Minimal: Plans included
necessary steps but not
activation criteria

Mitigation

Updated plans to include
varying activation based on
duration and severity level

Issue

Risk

Mitigation

R2: Three part communication

Minimal: Directives were not repeated back to ensure accuracy during a voltage adjustment event

Additional training to staff involved in issuing and receiving directives was provided.

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R3: Development and maintenance of plans for emergency situations	Minimal: SCADA included a load reduction schedule all operators were trained to use the system	Plans for load shedding and system restoration were developed and implemented
R4: Communication protocols for emergencies	Minimal: Other company documents outlined procedures	Plans for emergency communication protocols were implemented
R5: Incomplete emergency plan: Attachment 1	Minimal: Entity had all other elements in its plan	Created an emergency plan that incorporated all elements
R6: Emergency plans	Restoration plans were in place but not communicated to neighboring entities	Plans shared with appropriate entities
R7: Coordinating emergency plans	Minimal: Operators had tools in place to communicate	Update communication protocols and procedures

Issue

R8: Lack of load shedding plans for real-time emergencies

Risk

Minimal: Other company documents gave operators the authority to shed load during emergencies

Mitigation

A load shedding plan that met the requirements of the Standard was created

Issue

R3: Reporting a reportable incident: 24 hour limit

Risk

Minimal: Entities reported these storm related events on a delayed basis (within 4 days) after addressing the root causes and attempting repairs

Mitigation

Procedures were amended to ensure NERC reporting according to the Standard was completed within 24 hours

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: System Restoration Plans: Attachment 1 elements	Minimal: Entities demonstrated they could implement the plans	Plans were revised to include missing elements
R4: Coordinating restoration plans	Minimal: Plans were in place and operators trained on them	Plans were communicated to neighboring entities
R6: Restoration plans: training annually	Minimal: Employee lacking training was a 12 year veteran	Operator completed training and plan updated to include annual simulations
R7: Restoration Procedure: actual testing/simulations	Minimal: Documented procedure existed and was used in training	Consultant retained to validate procedure using simulations

Issue

R1: Control Center loss planning: annual tests and updates

Risk

Minimal: Plans were missing various components and, in most cases, were being tested annually. Plans that were not being tested and updated annually were in situations where no material changes had occurred

Mitigation

Plans were updated to address missing elements and processes put in place to ensure an annual test and complete review of the existing plans

Issue

Risk

Mitigation

R1: Facility connection requirements

Minimal: All applicable sub-requirements would have been discussed during the engineering studies related to an Interconnection

Facility connections requirement procedures were created

R2: Facilities connection document: requirements

Minimal: Requirements were discussed during the interconnection process in all cases

Missing elements were included in the procedure

Issue

R1: Vegetation management program

Risk

Minimal: Lacked procedures for immediate communication of imminent threats by vegetation; long vegetation growing times; periodic ground inspections

Mitigation

Revised document to include procedure for communication of vegetation creating an imminent threat

Issue

R1: Facilities rating methodology: not including all requirements

Risk

Minimal: Entities operated the equipment according to manufacturer's specification even though the omitted facility ratings for some devices or failed to include required items in their facilities ratings methodology

Mitigation

All entities revised their documents to include information missing from its facility rating methodology

Issue

R1: Facility ratings based on facility ratings methodology: implementation

Risk

Minimal: Entities did not include all elements in their methodology, at times the most limiting element, but operated the equipment within manufacturer's design specifications

Mitigation

All entities revised their facility rating methodology documents to include missing devices and established updated facilities ratings

Issue

R1: System Operating
Limit(SOL) Methodology

Risk

Minimal: Entity involved is small
with only a single connection to
another Transmission Operator

Mitigation

A SOL methodology was
developed and implemented

Issue

R5: Providing SOLs to other entities

Risk

Minimal: The SOL affected only the entity and did not have an impact outside of its footprint

Mitigation

The SOL was provided to the necessary entity

Issue

R1: On-time request for interchange (RFI) responses

Risk

Minimal: Delays averaged only minutes and had an economic impact only on limited RFI transactions

Mitigation

A formal practice for responding to RFIs was developed and staff trained

Issue

R4: Providing information to Reliability Coordinators

Risk

Minimal: In one case, the generator was not an available resource to the RC and in the other it was a one-time occurrence mitigated in real-time

Mitigation

Communications protocols were developed and existing protocols enhanced to include verifications

Issue

R8: Re-calculating Available Transfer Capacity within required timeframes

Risk

Minimal: The entity operated its system with an accurate ATC and did recalculate within 16 days of the mandatory timeframe

Mitigation

The ATC was recalculated prior to the planned outage

Issue

R1: Correctly reporting forecasts of interruptible demand and DCLM

Risk

Minimal: The data is used for long term forecasting and only one year was reported inaccurately

Mitigation

Require additional review of form EIA-411 before submittal in a written procedure

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: Adequately staffed with properly trained operating personnel	Minimal: Personnel NERC certified, met required emergency ops training	Added training personnel and completed required course training for operators
R3: Demonstrate competent training staff and program	Minimal/Moderate: Training staff had operational experience but lacked training expertise	Hired vendors or hired personnel with proper training credentials
R4: Cannot demonstrate that other training requirements met	Minimal: Personnel all NERC certified, met required emergency ops training but lacked additional training	Added training personnel and completed required course training for operators

Issue

Risk

Mitigation

R1: Personnel performing BES related duties were not NERC certified

Minimal/Moderate: Entities were in the process of obtaining NERC certification and only a small percentage were not certified

Entities completed NERC certification process within timeframes allotted

Issue

Risk

Mitigation

R3: Protection system changes made without informing neighboring TOPs and BAs

Minimal: Changes actually enhanced reliability but lacked evidence of coordination

Procedure modified to ensure proper communication. TOPs and BAs received new settings

R4: Protection system changes on transmission lines made coordinating with neighbors

Minimal: Changes only affected internal footprint and not neighboring TOPs or BAs

Changes communicated to neighbors. Procedure put in place to ensure future coordination

R5: Protection system on 345kV tie line disabled without notification to neighbors

Minimal: TOP was notified 4 minutes after disabling of protection system

All field technicians retrained on proper notification procedures

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: Protection system misoperations: corrective action plans (transmission)	Minimal/Moderate: Not all misoperations were being analyzed and addressed	Procedure now clearly identifies steps in analyzing misoperations and when an action plan is appropriate
R2: Protection system misoperations: corrective action plans (generation)	Minimal/Moderate: Procedures for analyzing and mitigating misoperations were deficient	Procedure now clearly identifies steps in analyzing misoperations and when an action plan is appropriate
R3: Protection system misoperations: reporting	Minimal: While not reported, the misoperation was mitigated and a plan developed	Procedure modified to monitor misoperations and ensure appropriate reporting

Issue

Risk

Mitigation

R1: Protection system maintenance and testing: requirements

Minimal: Most devices were tested and, in some cases, devices were tested to manufacturers specs rather than to procedure

Procedures updated to include missing requirements and all devices tested according to procedure within time allotted

R2: Protection system maintenance and testing: documentation of implementation

Minimal: Documentation not available to show all devices tested, only most devices

Testing completed on all devices and tracking procedure updated to ensure testing completed to schedule

Issue

Risk

Mitigation

R1: Under frequency load shedding(UFLS): testing and maintenance program

Minimal: maintenance and testing performed but records not available. Entities in question also very small

Created separate UFLS maintenance and testing program document that included record keeping

R2: UFLS: program results

Minimal: Little load at risk due to small size of entities

Established procedures for identifying, maintaining and testing UFLS devices and tested the devices according to program

Issue

R1: Phase protective relay settings: settings

Risk

Minimal: only one of fifty-nine relays settings not appropriate, it was an overreaching relay that would have tripped

Mitigation

Recomputed, coordinated and reset relay to appropriate value

Issue

Risk

Mitigation

R3: Coordination of operations

Minimal: One weekend message failed to be transmitted to the appropriate parties

Updated procedure to eliminate communication issues with transmission of reports and retrained operators

R14: Communicating changes/reduction in capabilities due to fuel

Minimal: Actual reduction in capability was minimal and of short duration

Develop document on reportable events for operators and train operators on same

Issue

R1: Planned outages:
communication and
coordination

Risk

Minimal: One weekend message
failed to be transmitted to the
appropriate parties and another
entity had no procedure but also
no outages

Mitigation

Updated procedure to
eliminate communication
issues with transmission of
reports and retrained operators

Issue

R1: Automatic voltage regulator(AVR) reporting

Risk

Minimal: Entity was aware of lack of AVR and was maintaining voltage manually

Mitigation

A new procedure for AVR status change tracking was developed and operators trained

Issue

R1: Status of resources:
communication

Risk

Minimal: One weekend message failed to be transmitted to the appropriate parties and another entity had no procedure but also no outages

Mitigation

Updated procedure to eliminate communication issues with transmission of reports and retrained operators

Issue

R1: Transmission planning:
annual assessment

Risk

Minimal: Stability assessment
was developed and procedures in
place to deal with issues but
results not documented,
procedure coordinated with the
RC

Mitigation

Results documented showing
requirements met

Issue

Risk

Mitigation

R1: System performance after loss of single BES element

Minimal: Stability assessment was developed and procedures in place to deal with issues but results not documented; procedure coordinated with the RC

Results documented showing requirements met

Issue

Risk

Mitigation

R1: System performance after loss of two or more BES element

Minimal: Stability assessment was developed and procedures in place to deal with issues but results not documented; procedure coordinated with the RC

Results documented showing requirements met

Issue

R6: Loss of AVR:
communications

Risk

Minimal: The TOP was aware of
the unavailability of AVR and was
regulating voltage manually

Mitigation

A new procedure for AVR
status change tracking was
developed and operators
trained

Issue

R1: AVR mode:
communication

Risk

Minimal: Voltage support was maintained without the use of AVR on a small unit during the period in question

Mitigation

Modified control panel/system alerts and trained the operators on new displays/alerts and AVR requirements

<u>Issue</u>	<u>Risk</u>	<u>Mitigation</u>
R1: AVR mode: communication	Minimal: Voltage support was maintained without the use of AVR during the period in question	Modified control panel/system alerts and trained the operators on new displays/alerts and AVR requirements
R2: Maintaining voltage as directed	Minimal: Entity continued to contribute VARs to the BPA, just in a narrow bandwidth	Worked with Transmission operator to modify load schedule and updated manuals on issue
R3: Status or capability changes: 30 minute notification	Minimal: In most cases, notification was in minutes past the deadline	Reviewed procedures regarding VAR changes and added functionality to monitor VAR settings (for example, alarms)

Issue

R1: AVR requirement: 98% of the time

Risk

Minimal: Only one turbine was not operating in AVR mode bringing the total to 95% for the operator for the period

Mitigation

The entity place the unit back in AVR mode as requested



Questions?