

NORTH AMERICAN ELECTRIC RELIABILITY CORPORATION

BES Protection System Misoperation Reduction Workshop

October 1-2, 2024



NORTH AMERICAN ELECTRIC RELIABILITY CORPORATION

MIDAS Misoperations Breakdown

Jack Norris, Engineer II Misoperation Reduction Workshop October 1, 2024



Annual Regional Misoperation Rate



NERC

Misoperation Causes Breakdown

100% 6.85% 7.17% 7.95% 8.63% 8.97% 11.96% 90% 17.56% 18.19% 15.79% 17.77% 17.01% 15.14% 80% 8.04% 7.17% 8.97% 70% 9.11% 10.74% 10.47% 3.59% 3.65% 3.97% 3.84% 3.72% 3.18% 60% 24.40% 21.66% 25.02% 21.70% 50% 22.25% 27.29% 40% 4.23% 4.24% 4.82% 4.36% 4.48% 3.97% 3.87% 3.66% 3.67% 3.64% 2.80% 30% 3.93% 11.04% 9.52% 9.73% 9.48% 8.46% 7.85% 20% 9.82% 9.05% 9.66% 10.27% 11.61% 7.48% 10% 12.05% 12.01% 11.73% 11.16% 9.91% 9.74%

2021

As-left personnel error

Incorrect settings

2022

Communication failures

Logic errors

2024

2023

DC system

Other/Explainable

0%

2019

AC system

Design errors

2020

Relay failures/malfunctions Unknown/unexplainable



Misoperation Causes Counts

	Cause Code	2019	2020	2021	2022	2023	Grand Total
	Incorrect settings	328	293	263	251	243	1378
	Relay failures/malfunctions	236	213	201	183	199	1032
350	As-left personnel error	132	136	107	112	115	602
	Unknown/unexplainable	92	84	102	104	89	471
300 –	AC system	162	114	142	136	125	679
	Communication failures	128	111	100	128	109	576
250	DC system	52	43	43	46	41	225
250	Design errors	57	51	53	49	54	264
	Logic errors	49	42	44	46	43	224
200	Other/Explainable	108	84	127	104	102	525
	Grand Total	1344	1171	1182	1159	1120	5976
150 100 50 0 Incorrect settings Incorrect settings As-left personnel error Unknown/unexplain Unknown/unexplain	able AC system Communication failures	DC system Design	errors	ogic 6	errors ther/E	xplain	able
■ 2019 ■ 2020 ■ 2021 ■ 2023							



Breakdown by Technology



Note: without inventory quantitative comparison between different technologies should be limited





Based on MIDAS data, which manufacturer do you think has had the most Misoperations since 2018?

All together now!









Breakdown by Manufacturer



Note: without inventory quantitative comparison between different manufacturers should be limited
8
RELIABILITY | RESILIENCE | SECURITY



Questions and Answers

NERC

Event Analysis Reporting

Protection System Misoperation Snapshot

Wei Qiu, Lead Engineer of Event Analysis, NERC BES Protection System Misoperation Reduction Workshop October 01, 2024







- Difference between MIDAS and Misop-related Events in EA
- Trend and Analysis
 - Event Analysis Process (EAP)
 - Cause Code Assignment Process (CCAP)
- Conclusion



MIDAS vs. Misop in Event Analysis





NERC Rules of Procedure (Section 800 and Appendix 8)

- Flexible discretionary risk and/or impact analysis authorities
- Major event response

ERO Event Analysis Process (EAP)

- System operating criterion-based risk and/or impact monitoring
- Off-normal to major system event spectrum

ERO Cause Code Assignment Process (CCAP)

• System risk and/or impact trending

NERC

Trending Risk through Off-Normal Events





Trending of Qualified Events









Trending of Category 1 Events (Cont'd)







Category 1a: An unexpected outage, that is contrary to design, of three or more BES facilities caused by a common disturbance...



Misoperation Snapshot



- Gold: incorrect settings
- Silver: relay failures
- Seeking better understanding of mitigation impacts

Total Events (2019-present)	672	Percentage of Total Events (2019-present)
Misops-related Events (2019-present)	198	29%
Reasons		Percentage of Misops-related Events
Incorrect Settings	78	39.4%
Relay Failure	26	13.1%
Other	94	47.5%

NERC

Trending Risk through Off-Normal Events







- A root cause is the fundamental reason for the occurrence of a problem or event - remove the root and no event. A root cause is not always identifiable.
- A **contributing cause** is not a single factor, **but one of many** that can influence an event.







* LTA: Less than Adequate. LTA does not imply any negligence or fault for the entity; it is solely intended to say that the situation to which the "LTA" is assigned was not sufficient to prevent the undesired situation from occurring.



TOP 5 Contributing Codes in Misop Events





System Operating Risk	Risk Contributors	Corrective Actions
Loss of 3 or more BES Facilities - Misoperation	Incorrect Setting	 Start-up testing Communication between groups Coordination with neighbors Peer review Training - Individual human error
	Relay Failure	 Maintenance Inspection Asset management – aging Vendor support









- The number of Misop-Related Events is decreasing in 2024
- Top 2 Reasons EAP
 - Gold: incorrect settings
 - Silver: relay failures
- Top 2 Root Causes CCAP
 - Gold: Design output scope LTA
 - Silver: Desing output not correct
- Individual Human Performance is not a main risk contributor.



Questions and Answers







- Event Analysis Program
- ERO Event Analysis Process Document Version 5.0
- <u>Cause Code Quick Reference Guide</u>
- <u>Cause Code Assignment Process</u>
- <u>Event Reports</u>
- Lessons Learned



EAP Category 5.0

Category 1: An Event that Results in One or More of the Following:

- a. An outage, contrary to design, of three or more BES Facilities caused by an event:
 - i. The outage of a combination of three or more BES Facilities (excluding successful automatic reclosing)
 - ii. The outage of an entire generation station of three or more generators (aggregate generation of 500 MW to 1,999 MW)⁴; each combined-cycle unit is counted as one generator.
- Intended and controlled system separation by the proper operation of a remedial action scheme (RAS) in New Brunswick or Florida from the Eastern Interconnection Retired on January 1, 2024
- c. Failure or misoperation of a BES Remedial Action Scheme (RAS)
- d. System wide voltage reduction of 3% or more that lasts more than 15 continuous minutes due to a BES Emergency Retired on January 1, 2024
- e. BES system separation contrary to design results in an island of 100 MW to 999 MW. This excludes BES radial connections and non-BES (distribution) level islanding.
- f. Unplanned evacuation from a control center facility with BPS SCADA functionality for 30 minutes or more. Retired on January 1, 2016
- g. In ERCOT, loss of generation of 1,400 MW to 1,999 MW

NERC | ERO Event Analysis Process – Version 5.0 | January 2024

 ³ ERO Enterprise Guide for the <u>Multi-Region Registered Entity Coordinated Oversight Program</u>, March 2018, Section IX: System Events
 ⁴ Gross MW output of the generators at the time of the outage.



EAP Category 5.0 (cont'd)

h. Loss of monitoring⁵ and/or control⁶ at a Control Center such that it degrades⁷ the entity's ability to make Real-time operating decisions that are necessary to maintain reliability of the BES in the entity's footprint for 30 continuous minutes or more.

Some examples that should be considered for EA reporting include but are not limited to the following. Additional cases are provided in the Addendum for Category 1h Events found under reference materials for event analysis on the EA Program website.⁸

- i. Loss of operator ability to remotely monitor or control BES elements
- ii. Loss of communications from SCADA remote terminal units (RTU)
- iii. Unavailability of ICCP links, which reduces BES visibility
- iv. Loss of the ability to remotely monitor and control generating units via automatic generation control (AGC)
- v. Unacceptable state estimator or real time contingency analysis solutions
- A non-consequential interruption⁹ of inverter type resources¹⁰ aggregated to 500MW or more not caused by a fault on its inverters, or its ac terminal equipment.
- A non-consequential interruption¹¹ of a DC tie(s), between two separate asynchronous systems, loaded at 500 MW or more, when the outage is not caused by a fault on the dc tie, its inverters, or its ac terminal equipment.

Category 2: An Event that Results in One or More of the Following:

- Complete loss of interpersonal communication and alternative interpersonal communication capability
 affecting its staffed BES control center for 30 continuous minutes or more.
- b. Complete loss of SCADA, control or monitoring functionality for 30 minutes or more. Retired on January 01, 2016 refer to Category 1h
- c. BES Emergency resulting in a voltage deviation of ≥ 10% difference of nominal voltage sustained for ≥ 15 continuous minutes.
- Complete loss of off-site power (LOOP) to a nuclear generating station per the Nuclear Plant Interface Requirement
- e. System separation contrary to design, that results in an island of 1,000 MW to 4,999 MW
- f. Simultaneous loss of 300 MW or more of firm load due to a BES event, contrary to design, for more than 15 minutes

⁵ The ability to accurately receive relevant information about the BES in Real Time and evaluate system conditions using Real-time data to assess existing (pre-Contingency) and potential (post-Contingency) operating conditions to maintain reliability of the BES.

⁷ For purposes of 1h categorization "degrades" means less-than required functioning of any monitoring/control component, process, or capability.

⁸ <u>https://www.nerc.com/pa/rrm/ea/Pages/EA-Program.aspx</u>

⁹ Interruption of resources caused by action of control systems on the resources in response to perturbations in voltage and/or frequency on the Interconnection, not including the control actions of a RAS.

¹⁰ In most cases, inverter-based generating resources refer to Type 3 and Type 4 wind power plants, and solar photovoltaic (PV) resources. Battery energy storage is also considered an inverter-based resource. Many transmission-connected reactive devices such as STATCOMs and SVCs are also inverter-based. Similarly, HVDC circuits also interface with the AC network though converters.

¹¹ Interruption of resources caused by action of control systems on the resources in response to perturbations in voltage and/or frequency on the Interconnection, not including the control actions of a RAS.

NERC | ERO Event Analysis Process - Version 5.0 | January 2024

g. Interconnection Reliability Operating Limit (IROL) exceedance for greater than 30 minutes

Category 3: An Event That Results in One or More of the Following:

- a. Loss of firm load, contrary to design, of 2,000 MW or more.
- b. System separation contrary to design, that results in an island of 5,000 MW or more
- c. System separation (without load loss) contrary to design, that islands Florida from the Eastern Interconnection
- d. Loss of 2,000 MW or more provided by DC tie(s) connected to asynchronous resources
- Loss of generation (including inverter-based resources) of 2,000 MW or more. This excludes RAS action that
 performed as designed.

RELIABILITY | RESILIENCE | SECURITY

21

⁶ The ability to take and/or direct actions to maintain the reliability of the BES in Real Time via entity actions or by issuing Operating Instructions.



Cause Code Reference





TCIPI

(Transmission Continuous Improvement Program Implementation)

Human Initiated Reliability Event Reporting



TCIPI – Table of Content

- Program Creation & Organization
- The Policy
 - Reportable Events
- Program Execution
- Risk Based Evaluation Process
- Metrics
 - Inadvertent Dashboard
 - Other Utilities Dashboard
 - Data Driven Decisions
 - Corrective Action Dashboard
 - Lessons Learned / Corrective Action Program
 - Example SEL BFR Actions taken
- Summary

Kammy's Bio

- Current Role
 - Supervisor in Organization Performance &
 Delivery System Operations
 - TCIPI Program, Operational Reporting, Reliability Compliance, Project Management
- BPA History:
 - Started at BPA in 1990 in the Safety Office
 - First Federal job was in Power
 - Worked in Power Services, Finance, Corporate, and Transmission
 - Have been with System Operations for 8 years

Brian's Bio

- Current Role
 - Lead Management and Program Analyst in the Transmission Continuous Improvement Program Implementation (TCIPI)
- BPA History:
 - Started at BPA in 2019 in TCIPI
- Prior to BPA:
 - Project Manager for Aerospace Manufacturing Co
 - Retired Air Force 30 years, Air Traffic Controller,
 - Experience in Human Organizational
 Performance, Human Factors in Aviation Safety,
 Adjunct College Educator
 - More...

TCIPI – Origins and Background - 2017

Problem Statement: BPA (Transmission) does not currently have a comprehensive program to track, analyze, and provide systemic fixes to Reliability incidents including Inadvertents, mis-operations and equipment on the BPA grid.

Strategic Alignment:

Strategic Objective 2b: "Modernize federal power and transmission system operations and supporting technology." This effort is also a subcomponent of the Transmission Business Model (TBM) section relating to Continuous Improvement.

Scope:

Develop for implementation an operational continuous-improvement program that identifies a centralized process for Reliability event-analysis, lessons learned, and corrective-action plans across Transmission. This program will promote transmission excellence by incorporating human performance evaluation into the analysis of incidents or events and sharing operating experience.
TCIPI – The Policy

BPA Transmission Senior Vice President and TCIPI Leadership announced a new *Human Initiated Reliability Event Reporting Policy* in 2019.

- Policy replaced the 2008 Memorandum entitled, "Reportable Event Notification & Reporting Process."
- Developed by a cross functional group of Tier 3 and 4 managers from Engineering, Field Services, System Operations, and Planning.
- Transferred responsibility for collecting inadvertent and misoperations from System Operations to the Transmission Continuous Improvement Program Implementation (TCIPI).

	BPA Transmission
	Human Caused Reliability Event Reporting Policy
Purpo	se
This p Augus Robin the fo	olicy establishes reporting requirements replacing those identified in the memorandum dated t7, 2008 titled "Reporting of Inadvertent Operations of Power System Equipment" signed by Furrer, Hardev Juj, and Larry Bekkedahl. The August 7, 2008 memo is rescinded and replaced with llowing requirements established by this policy.
The no impac equipr	ntification and reporting requirement formalizes the process to fully identify potential negative ts to the power system, reduce the risk to the reliability of the power system and associated ment. It also provides for expanded learning opportunities and sharing of information.
This re Imple faciliti incide	equirement will be administered through the Transmission Continuous Improvement Program mentation (TCIPI). TCIPI is a comprehensive program created by Transmission Operations (TO) to ate and support business unit? tracking, analyzing and proposing systematic fixes to reliability nts as indicated by BPA's mission for <i>Reliable, Efficient & Fiexible Operations</i> .
This p	olicy and associated process is not for reporting safety concerns or events.
Repor	table Events
<i>Humo</i> identi	on Caused Reporting Requirement: Reporting is required of any human caused event as fied in the definition of a reportable event.
Defini •	tion: Any event that resulted in, but not limited to: Loss of generation or load.
•	Loss of control and protection, including: relays, control circuits, and communications elements affecting control and protection.
•	Damaged equipment, including: high voltage equipment; low voltage control and protection equipment; communications equipment affecting control and protection.
•	Disturbance or schedule curtailments.
•	I he unplanned (inadvertent) operation of power system equipment that did not result in a loss of generation or load, result in a disturbance or curtailment, or result in damaged equipment.
Roles	and Responsibilities
Individ	luals Involved in a Reportable Event Shall:
Notify Notifi	their supervisor as soon as possible following the event, but prior to going off duty for the day. cations may be hand written and submitted within PII guidelines.

TCIPI - Reportable Events

Human Initiated Reporting Requirement: Reporting is required for any human Initiated event as identified in the definition below.

Definition of Reportable Event: Any event that resulted in, but not limited to:

- Loss of generation or load
- Loss of control and protection, including relays, control circuits, and communications elements affecting control and protection
- Damaged equipment, including high voltage equipment; low voltage control and protection equipment; communications equipment affecting control and protection
- Disturbance* or schedule curtailments
- The unplanned (inadvertent) operation of power system equipment that did not result in a loss of generation or load, result in a disturbance or curtailment, or result in damaged equipment

* NERC Disturbance definition:

- 1. An unplanned event that produces an abnormal system condition.
- 2. Any perturbation to the electric system.
- 3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

TCIPI - Program Execution

TCIPI Program functions on 3 key levels, leading into the support, development, and execution of actions to mitigate current and future risk:

- 1. TIRT (Transmission Incident Review Team)
- 2. TCIPI Steering Team
- 3. TCIPI Executive Management Team

Outcomes:

- Three key decision points are used to assess "value". They are centered upon risk-based prioritization and impact (actual and projected) to the system, based upon the event.
- Quality analysis leading into management decisions to act. Defining the BEST Decision.
- S.M.A.R.T. outcomes defined in individual Corrective Actions
- Management support/authorization to enact changes (i.e., completing the Corrective Actions) with clarity /understanding of "value" based upon risk and impact (actual and projected) to the system

Benefits:

- 360-degree view of event "Balcony view"
- Predictive analysis component / trending
- Risk-based recommendations derived from analysis
- Shared collaboration and development of corrective measures
- Distribution of a Supervisor View for shared learning opportunities for Transmission personnel

SMART: Specific-Measurable-Achievable-Relevant-Timely

Metrics

- Inadvertent Dashboard
- Other Utilities Dashboard
- Data Driven Decisions
- Corrective Action Dashboard
- Lessons Learned / Corrective Action Program
- Example SEL BFR Actions taken

Human Initiated Reliability Event Reporting: FY2024

TCIPI Dashboard

PRL = Pandemic Response Level



Current as of 9/17/2024 3:15 PM

Historical

TCIPI Metrics – Inadvertent Summary Dashboard

All Fiscal Years (FY)



10

9 8

7

6

2019 2019

April June August October

December | February |

October

020

December February April June August

2020

202

October

Jecember February April June August 2023

April June August

202

February |

ecember

202

February

December

October

April June August October 2023

202

August

February 01 April

December

Octobe



В E R R Ο Ε Ρ 0 Е Μ Ν S А Ο Ν Ν D

Other Utilities - Human Initiated Disturbance Event Reporting: FY2024



Data provided by TOOC Disturbance Event Tracking

Human Initiated Reliability Event Learning Team Candidate

9/17/2024

Data Driven Decisions

Using Data to Make Decisions

- After Action Review (AAR) Team Recommendation
- Learning Team (LT) Recommendation
- Facilitated Learning Team (LT) Recommendation
- Management Specials

TCIPI Report Summary

20230505 BFR Location
Installation Activities
Equipment unavailable or protective scheme compromised
No
While in an outage to replace the line relays, the main trip bus feed was landed in the rack that the crew was removing before it went to the overhead aux bus. A meeting was held about potential dangers. Crew was pushing a cable down the rack to demo it out when the trip bus cable slid out of the terminal block. This powered down the trip bus to the entire station. The cable was barely tightened down causing it to slide out easily. Workers checked the close cable (feeding entire station) and it was also landed in the rack, very loose, so they tightened it. In the process, the SEL-121B's on two lines at substation would not turn back on. Currently working on plan to do emergency relay replacement.
T&E - Commissioning & Testing
System Protection & Control (SPC)

Trended Summary

Activity Type	Cable - Installation, Cutting, Pulling or Removal
TIRT Disposition	Reliability Management Review
Trending Type	Relay Maintenance
Trending Specifics	SEL-100/BFR Failures
NCC - Level A	A3: Individual Human Performance LTA
NCC - Level B	
NCC - Level C	
Number of times TIRT Trended	0
Number of times	2
Type of Event, Activity Type and	
Primary Craft are same	
Number of times	0
Type of event, Activity Type and	
Trending Type were the same	

Recommendation

Number of times TIRT Trended	0	> 3 Take Some Action
TCIPI Report Data Score	35	> 65 Normally means AAR

Recommend TIRT Evaluation

TCIPI - Lessons Learned / Corrective Action Program

- Learning Teams
- Sponsor Engagement
- Corrective Action Details / Summary
- Status / Disposition

Learning Team Names	# Corrective Actions
20170929 Learning Team 1	4
20180124 Learning Team 2	5
20180313 Learning Team 3	6
20180805 Learning Team 4	9
20181107 Learning Team 5	12
20190422 Learning Team 6	5
20190805 After Action Review (AAR) 1	9
20191210 After Action Review (AAR) 2	2
20200814 After Action Review (AAR) 3	12
20201004 Learning Team 7	12
03252021 After Action Review (AAR) 4	7
20220521 After Action Review (AAR) 5	7
20211115 After Action Review (AAR) 6	2
FY22 Increased Inadvertents - Management Special 1	4
20220621 After Action Review (AAR) 7	3
20230531 After Action Review (AAR) 8	11
20240124 After Action Review (AAR) 9	8
Grand Total	118



- **Not Started** CA has been approved for action but has not formally started work on corrective measures.
- <u>Complete</u> CA has completed implementation and has been reviewed and accepted as done by responsible manager/process owner
- <u>In Progress</u> CA has started and is being tracked based upon agreed upon schedule or delivery due date
- <u>On Hold</u> CA has been deferred/delayed to a future date based upon priority or dependency or other action to complete first.
- <u>Closed</u> CA has been halted before defined/scheduled completion due to management decision.

Ν Ε Ε Ρ Ο W Ε R Μ Ν S R А \mathbf{O} Ο А D **Elimination** -Substitution -**Engineering Controls -**Administrative Administrative Controls Administrative Controls Administrative Controls **PPE -** Protect the worker with **Hierarchy of** Physically remove the hazard **Personal Protective Equipment** Replace the hazard Isolate people from the hazard Controls - Change the way people work Control Least Effective Most Effective Effectiveness Administrative Barriers **Administrative Barriers Administrative Barriers** Administrative Barriers Elimination Engineered / Physical Barriers Individual Control Barriers - Design Features **Tool and Equipment Training and Coaching** Written Communications Table Permanent elimination of the activity / function /hazard **New Effectiveness Table** 10 that introduced risk during the incident (e.g., cease using hazardous chemicals) Passive design features that reduce incident probability, with no human action required (e.g., pipe Most Effective replaced with one made from corrosion-resistant 9 alloys) Active design features that automatically actuate to reduce incident probability, with no human action 8 required (e.g., preventative interlocks) Passive design features that reduce incident consequences, with no human action required (e.g., 7 guard rails) Active design features that automatically actuate to reduce incident consequences, with no human action 6 required (e.g., fire suppression system) Passive design features that, if manually enabled, 5 reduce incident risk (e.g., reinforced cockpit door) Active design features that, Procedures or controlled work Tools / equipment that reduce Use of proven human errorincident probability (e.g., reduction tools by front-line if manually enabled, reduce instructions that are used "in-4 incident risk (e.g., front hand" during task performance temporary lock or block that workers during task performance passenger seat air bag) (e.g., checklists) prevents component operation) Design feature that Procedures or controlled work Fools / equipment that reduce Training or coaching that is Over checks by individuals using automatically warn workers instructions that are not used "inncident consequences (e.g., recurring, and validates proven error-reduction tools, of 3 that a problem requiring hand" during task performance Personal Protective Equipment) learning has occurred tasks completed by front-line action exists (e.g., low oil workers pressure alarm) Design feature that, if Written policies; posted warning Training or coaching that Over checks by individuals who are manually actuated, warn signs validates learning has not using proven error-reduction Least Effective 2 workers that a problem occurred, but isn't recurring tools, of tasks completed by frontrequiring action exists (e.g. and/or mandatory line workers fire alarm pull station) Information written Training or coaching that does Increased awareness / diligence by not validate learning has front-line workers during task communications (e.g., emails, 1 14 safety alerts) occurred (e.g., lessons learned performance meetings)

В

Ν

Corrective Action Effectiveness

Presenting all 118 Corrective Actions to Date

Hierarchy Control	of	Elimination - Physically remove the hazard	Substitution Replace the hazard	- Engineering Controls - Isolate people from the hazard	Administrative Controls - Change the way people work	Administrative Controls	Administrative Controls	Administrative Controls	PPE - Protect the worker with Personal Protective Equipment
		Most Effective						Least Effective	
Effectivene Table	ss	Elimination	Engineered /	Physical Barriers	Administrative Barriers - Design Features	Administrative Barriers - Written Communications	Administrative Barriers - Tool and Equipment	Administrative Barriers - Training and Coaching	Individual Control Barriers
Most Effective	10								
	9			1					
- T -	8			6					
	7								
	6								
	5				2				
	4				3	6	4		1
	3				3	44	2	3	2
Least Effective	2				2	6		3	
	1					23		6	
	<u> </u>								© Fisher IT, Inc. 8 Compass PL LLC

Example: SEL - BFR

Problem

• Over the last several months and years, we've noticed an uptick of mis-operations with SEL-100 series relays and SEL-BFRs on our system. Most recent we had an event in May 2023, again at a different site in July 2023, then looking back historically to July 2021 at another location. As these mis-operations were trending upward, we had SMEs from various organizations to review the data.

Analysis

- From the data, we believed the SEL-BFRs to be the highest risk of the two and would require the most work to replace due to configuration changes necessary to fit a replacement.
- TCIPI represented these BPA SME's who had asked that Engineering / Program Management consider making these replacements a priority on our system.
- The substation list was narrowed down to 8 due to their risk level based on our Agency's 5-level Risk Assessment Scale (Reliability) and asked for all to be prioritized by our Asset Management Team.

Actions Taken

 As a result of this analysis, risk assessments, corrective measure development and more; BPA is now able to get these BFR replacements completed under an emergency capital work order for each identified site. Work has already begun.

BPA Agency-Level Consequence Scales*

Consequence Type Score	Financial -BPA Impact- (PV) ¹	Environmental Stewardship ⁴ -Societal Impact- (Air, Land, Water, F&W Resources)	Safety -Societal Impact-	Legal/Regulatory ⁴	Regional Accountability - Societal Impact - (Reputation; customer & constituent satisfaction)	Reliability -MWs- (TBL)	Reliability -MWHs- (PBL)
5 = Extreme	>\$100 M	Substantial, extensive and lasting damage or impact to ecosystems, environmental resources, natural resources and/or valued species. Widespread and long-term corrective action, e.g. remediation or mitigation required.	Fatality or multiple severe irreversible disabilities	Violation or non-compliance with a fundamental statute, regulatory principle or standard leads to severe observable impacts and orders for substantial corrective action, including major mandatory changes in BPA operations or administration.	Extreme negative national and ongoing media, Fed, customer and constituent attention and criticism; extreme damage control.	Violations resulting from multiple contingencies even after load shedding over 300 MW has been applied	Cumulative loss of over 3 million MWHs net generation deliveries or conservation resource acquisition
4 = Major	\$10M - \$100M	Major damage or impact to ecosystems, environmental resources, natural resources and/or valued species. Major corrective action, e.g. remediation or mitigation required.	Severe disability	Violation or non-compliance leads to observable impacts and orders for corrective action, including some mandatory changes in BPA operations or administration.	National spike or ongoing regional media, Federal, customer or constituent attention; Major damage control	Violations resulting from multiple contingencies even after load shedding of 100 MW to 300 MW have been applied	Cumulative loss of 1 million to 3 million MWHs net generation deliveries or conservation resource acquisition
3 = Moderate	\$1M - \$10M	Some observable damage or impact to specific localized environmental or natural resources. Impact on wildlife uncertain. Some localized corrective action, e.g. remediation or mitigation required.	Serious injury, immediate medical treatment needed	Violation or non-compliance causes BPA to adopt modest changes in BPA operations, policies or procedures.	Regional spike or ongoing local local media, Federal, customer or constituent attention and criticism; moderate damage control	Load loss of 50 to 100 MW	Failure of critical generation equipment, leading to serious workarounds; zero up to 1 million MWHs cumulative loss of generation deliveries or conservation resource acquisition.
2 = Minor	\$100K - \$1M	Minor observable effects. No mortality. Corrective or mitigative action uncertain.	Injury requiring first aid, delayed medical treatment OK	Minor change in operations or administrative flexibility	Spike of local media attention and/or internal complaints only (e.g. AEs or other)	Load loss of up to 50 MW	Reduced operating margins elevate risk, but no externally observable impact on service.
1 = Insignificant	<\$100K	No or small transitory effects, no corrective or mitigative action required.	No or minor injury, first aid only	No or Insignificant effect on operations or administrative flexibility	No impact or Isolated internal complaints	Momentary interruption with automatic restoration; no customer loss of load	Failure of non-critical assets but minimal risk or observable impact on service

*Consequences are not comparable across columns and shall not be used to infer comparability between categories of impact.

1 - PV Costs for map of risks incurred from doing project; PV Avoided Risks (or Benefits) for map of risks avoided from doing project; Scale will depend on CAB-Approved thresholds.

2 - MWHs can mean one event or multiple aggregated events.

Financial is a "natural scale," Legal/Regulatory is a "constructed" scale and Regional Accountability is a "proxy" scale.

For question about Risk Chart Contact: BPA Enterprise Risk Manager via email jcshea@bpa.gov

TCIPI – Other Achievements

Overall Achievements since 2018

- 275 events evaluated by the Disturbance Team to date.
- 221 Human Initiated Reliability Events (TCIPI reports) submitted / analyzed across Transmission to date
- Completion of 17 "Lessons Learned Root Cause Analysis"
- 118 Corrective Actions approved for implementation by Management

Ongoing cooperation with Safety:

- Integration with Safety to form a unified front for our personnel, showing a tangible sign of partnership.
- Occasionally when a Safety Event occurs there is also a Human Initiated Reliability Event associated. We
 assess these events against our reportable criteria and evaluate them for reliability continuous
 improvement.
- TCIPI resource engagement on Safety Incident Assessment Teams (IAT). Supporting team facilitation, documentation of findings, management of Corrective Action reviews and approvals.
- Leading development of Agency Decision Framework effort resulting from recently completed Safety IAT
- Development of process to collaboratively review Safety and TCIPI "Near Hits" in a secured environment

TCIPI – Summary

We are

- Learning-driven
- Cross-Transmission in nature and intent
- Transparent in execution to build trust
- We focus on the "What" and not the "Who"
- Collaborative by design
- Forward looking to apply predictive value to business decisions
- Adaptive to the changing environment



Questions

Thank you for your interest in TCIPI



Human Performance Improvement & Substation Operations

Gary Riibe Jr.

Substation Operations Manager-West









820,000 Electric Customers 3,100





GENERATION CAPACITY 2023



About Me

- Electrical Engineer (PE)
- 21+ Years Substation
- Married 20+ Years
- Father of 4 Active Kiddos
- Red Sox Fan (married into it)
- Volunteer Youth Sports Coach
- Lover of BBQ and Ice Cream
- Green Thumb
- Enjoys the Great Outdoors



My Background

- From Sioux City, Intern with MEC (Sub Ops, Thermal Gen)
- Graduated U of Neb-Lincoln in Electrical Engineering, Dec 2002
- Started w/ MEC at Davenport in Substation Engineering, Jan 03' – Played <u>fantasy</u> football 2003-2005 and met many MEC employees
- Transferred to Substation Operations 2006 at Council Bluffs
 - Supervisor of a <u>real</u> team of substation electricians and techs to complete compliance tasks, projects and job packages in SW Iowa
 - (like a fantasy roster, who are the "sleepers", "must starts" and PUPs each week)
- Transferred to Sioux City, Sub Ops in 2011
 - Back to engineer for a bit, 2014 the manager of NW an SW lowa
 - Met a new team in SC, they were somewhat the same but different than the team in Council Bluffs

Understanding People and Their Differences

- Around this time of moving around, I thought that <u>parts</u> of people are the same
 - These parts come together to make up who they are, their personality
 - Different parts, make a different person...and different personalities
 - Part of Person A + part of Person B + part of Person C = Person Z
 - Could be a totally different person than any of persons A or B or C







Clifton Strengths (34 of them)





- If the number is low, give more details or be more interesting...if possible
- If the number is high, they understand or care
- If the <u>listener</u> sees that the <u>speaker's</u> number is high, they'd know when to listen or pretend to care about what the speaker is saying

Evolution of Human Performance

- 3/3/1979, I was born on my dad's birthday and named after him
 - Identity theft was created that same day (needs verified)
- 3/16/1979, <u>movie</u> about a core meltdown "The China Syndrome" that occurs at a power plant in California
 - China Syndrome: a nuclear meltdown scenario, so pamod for idea that there would be nothing to stop the r the other side of the world (China)
- 3/28/1979, <u>Three Mile Island</u> in Middleto meltdown of Unit 2 (TMI-2) reactor due to
 - The most significant accident in US commerce
 - By 12/1979, Institute of Nuclear Power Operations (INPO) was formed

CHI

artial

r history

Evolution of Human Performance

- DOE Human Performance Improvement Handbook June 2009
- It's 300+ Pages, 2 Vol
 - DOE was created in 1977, po
- 5 Principles of Human Perfc
 - 1. Error is normal. Even the be
 - 2. Blame fixes nothing.
 - 3. Learning and Improving is v
 - 4. Context influences behavior
 - 5. How you respond to failure counts.
- 2016 no PD Logs, 2017 sinç



Evolution of Human Performance at MidAmerican



2019-2020 Workshop Pays Off



Workshop Photos







Return Relay to Service

- O Acture the relay settings to normal + compare the "As Left" settings in the relay to the file that you read out of the relay before starting.
- Clear event history
 Return AC imputs, currents/Potentials to The kelony
 (1) Verify that NO "Trip" outputs/BFI,
- LOCAL OR ALMOST (COMA assister) are assorted use (DVOM) across output contacts (MB Tester) on serial comm
 - Ac Selentur software HMI TO Check for targets. (Relay LCD target status)
- () IF NO TIP outputs / Return OC/Imputs to NOTMAL () RECONNECT COMM ASSISTED Trip
- O Clear COMM & Notity DMCC







Work Smarter Not Harder

• Developed MEC HP Playbook, Work Zone, and Culture!



Learn From Others-NATF



14

• Participate in Practice Groups and Forums

North America	North American FOR About - Ex	Transmission Transmission Recutive Center -	SPort	Fools & Product	Congratulations to the new Certified Human Performance Professionals! Kent Peterson, Eric DiLandro, Holly Copeland, John Baumert, Vincent Vincek, Dave Gaul, Timm Maynard,
Mission	Metrics & Analytics	Practices Groups			Stacey Pasztor, Sam Reno, LaRhonda Julien and Adeel
excellence in the safe, relia	Risk, Controls and	Collaboration	/ Practices Groups / Human Per	formance Improveme	Laeeq.
resilient operation of the el transmission system.	Compliance	2022 HI	PI Workshop		2024 Graduating Class Practice Group Certificate #
Vision The NATF envisions continu	EPM Asset Management		Human Performar	nce Improv	Hit Precident Consum Kert Reterna Kert Innergi Kert Reterna Reterna Kert Reterna Reterna Holly Coulted America Holly Coulted America KM2 (Reterna KM2 (Reterna
reliability and resiliency, wi the safety of utility personr	EPM Lines Equipment	 ✓ 08/23/20 Event Time 	22 - 08/25/2022 e: All Day		Den Konsten Saczy Inferer Veze Veze Veze Veze Dar Guid Dar Guid Enter Ferer Dar Guid Enter Ferer Dar Guid Enter Ferer Enter
Approach We aggressively pursue relivesiliency, security, and per	EPM Substations Equipment	 Location: V 	Vestminster, CO		Store Parka Store Parka Sam Rea Benchare Hatbarry (hergy Laseback Hatbarr George Traumission
excellence by fostering con challenge to improve and b	EPM Trans-NPP	✓			
sharing timely, detailed, an information, including lesso and superior practices.	Human Performance Improvement	e Tri-State G 1100 West Westminst	eneration and Transmission A 116th Avenue er, CO 80234	Association Headq	
NATF Members Investor-Owned 	HP Core Team	Workshop	Dates:		
 State/Municipal Cooperative Federal/Provincial ISO/RTO 	HP Roadmap	August 23: August 24: August 25:	8:00 a.m 5:00 p.m. 8:00 a.m 12:00 noon		

Substation Engineering

- Substation Engineering Presented on use of HPI Tools in NATF HPI Workshop.
- Presentation was over
 - the HPI involved in the design

HPI TOOLS CAN HELP

- VALIDATE ASSUMPTIONS Perform a site visit early in design to verify existing conditions
- **PRE-JOB BRIEF** Hold a planning review meeting with main stakeholders to outline project scope
- SELF-CHECK Design Engineer performs full point-to-point check on their drawings prior to third-party quality assurance (QA) review
- PEER REVIEW QA review conducted by third party

30/60/90 REVIEW – Formal third-party QA reviews held at 30%, 60% and 90% design milestones

JOB SPECIFIC CHECKLIST – QA review checklist used to ensure all required review points are complete

POST-JOB REVIEW – As-built drawing markups are reviewed by Design Engineer

ing and schematics



THE DRAWING PROCESS

ERROR PRECURSORS

- Task Demands: time pressure, heavy workload, simultaneous tasks
- Work Environment: distractions, unexpected equipment conditions
- Human Nature: assumptions, limited short-term memory

Substation Operations

- Sub Ops followed up the presentation by Sub Eng
- Showed our HPI eBook and (AR) Augmented Reality Apps
 - Used to aid in training apprentices, engineers
 - Supervisors, journeymen, and even contractors
- Talked about how we work with Sub Eng
 - Take their design package to successful outcomes
 - Could have errors (noted on previous presentation)
 - Apply our HPI tools, different 30/60/90 milestones
- Sub Ops follow T/C contractors
 - They must do the same HPI tasks as MEC



Augmented Reality



- Forget about hover boards, we need "Free Guy" glasses
 - Overlay important details "virtually" to the real world (Augmented Reality)
 - Would allow us to "see" error precursors, increasing human performance
 - We'd have "AI" awareness, brought to our human attention in real-time
 - "Personal Importance Levels" are displayed in conversations!







eBooks Operations

MIDAMERICAN ENERGY COMPANY ENERGY COMPANY	Substation Apprenticeship
 Electric Meter Apprenticeship Line Mechanic Apprenticeship Substation Apprenticeship Electric Non- Apprenticeship Substation Engineering 	<text><text><text><text><text><text><text><text><text></text></text></text></text></text></text></text></text></text>
Main Menu	Image: static and apprendicable Updated: Updated: <tdu< th=""></tdu<>

eBooks for Office

Ab

ACCOUNTS PAYABLE

TABLE OF CONTENTS

Click the chapter or section header to navigate to that page.

Chapter 1: Introduction

Section 1: Training Objectives (2) Section 2: Our Core Principles (4) Section 3: Human Performance Improvement (5)

Chapter 2: Overview of Accounts Payable

Section 1: Accounts Payable Overview (7) Section 2: Proper Accounting Methods (9) Section 3: Code Block Validation (11) Section 4: Cost Classification (15) Section 5: Knowledge Check (18)

Chapter 3: Employee Expenses

Section 1: Employee Expense Reimbursement (18) Section 2: Employee Expense Advances (21) Section 3: P-Cards (23) Section 4: Knowledge Check (25)

Chapter 4: Purchasing

Section 1: Purchase Order Related Transactions (27) Section 2: Non-PO Transactions (30) Section 3: Invoices (33) Section 4: Accrual Procedures, Goods and Services (37) Section 5: Knowledge Check (40)

Chapter 5: Vendor Request

Section 1: Accounts Payable Vendor Request Form (42) Section 2: Exceptions to Vendor Request Form (44) Section 3: Knowledge Check (45)

Chapter 6: Voucher Reclasses

Section 1: Standard Voucher Reclass (47) Section 2: Non-Standard Voucher Reclass (49) Section 3: Knowledge Check (50)

Chapter 7: Final Review Section 1: Final Review (52)

Glossary

Accounts Payable - Table of Contents - Updated: Apr. 2021
eBooks for Specific Procedures



Quick Tip: Explore the book by clicking Preview or click Download to enjoy the book's full functionality.



3 eBook(s) Available for Windows (for viewing on desktop or laptop). Click the 'Main Menu' button to return to the home page or Click the 'Switch to iOS' button if you are on an iPad or iPhone.



RELAY TESTING AND COMMISSIONING DIGITAL TRAINING MATERIAL

Relay Testing and Commissioning Substation Operations



ngital training materia

O Preview

Residential Underground Electric Design Electric Delivery

↓ Download



WMIS: THE WORK MANAGEMENT SYSTEM

DIGHAL KAINING MAHERIAL

↓ Download

WMIS The Work Management System Gas and Electric Delivery

Preview

Main Menu

Switch to iOS

Human Performance Resources

ectric D

Gas Del

format

legal an Office Se

- HPI is available to and used by all the groups at MEC (2015->2024)
- New HPI Champions are made each year (2 sessions per year)
- You start to hear "HPI speak" on meetings (that was awesome!)
- Part of the onboarding and overall culture, share best practices/expectations/etc. (no hard knocks)

	Document Library
ations	
6	To help you be successful in using the HPI resources available to you, instructional videos are
nd Business	available as guidance. Find these videos through Microsoft Stream.
tal	
	ebook
5	• <u>HPI eBook</u>
	Podcasts
	• Electric Operations - Dallas County
	<u>Service Dispatch and Safety</u>
	Louisa Generating Station
y (IT)	Business and Community Development
Compliance	Templates
11	Error Precursor Template
nt and	HP Project Preview Template
	<u>30/60/90 Check and Review Template</u>
9	HPI Tool Plans
	Layers of Defense Analysis Template

Journey to Excellence

HPI Resources

HPI References

Overview
 HPLTools
 Documents Library
 HPLEvent Reviews

HP Metrics
 HP Tool Flipbook

HP Tool Playbook

 Human Performance Champions Find the latest news from Berkshire Hathaway Energy businesses, as well as information about cybersecurity, sustainability and more on the Journey to Excellence home page. Learn more



22

Final Thoughts



- 5 Principles of Human Performance
 - 1. Even Superman has a bad day

Create HP Champions, Understand what it is to be human, Clifton Strengths

2. Blame fixes nothing

Commitment to Excellence Senior Management need to support the effort

- 3. Learning and Improving is vital. Learning is deliberate. eBooks, build your library of knowledge and preserve it, share it
- 4. Context influences behavior. Systems drive outcomes. Build that culture! Fix the procedure. Find those error likely situations. It all influences us.
- 5. How you and leaders respond to failure matters.

People achieve high levels of performance because of the encouragement and reinforcement received from their leaders and peers.

Questions?



HP Project Preview or Learning Team

This activity involves participating or attending an HP Project Preview or Learning Team.

This activity is worth 2 points.

For information on how to complete this activity, refer to <u>Chapter 9, Section 3</u>, which contains a complete list of instructional guides for HP Champion certification.

Learning Team Activity

This activity involves facilitating or attending an Event Learning Team.

This activity is worth 4 points.

For information on how to complete this activity, refer to Chapter 9, Section 3.



An HP Champion showing the HP Project Preview tool from the HPI Flipbook.



HPI at MidAmerican - HP Reviews - Updated: Aug. 2021



NERC

Human and Organizational

Performance

An Event Causal Assignment Analysis

Ed Ruck, Senior Engineer of Event Analysis, NERC BES Protection System Misoperation Reduction Workshop October 1, 2024











Data Source

- Electric Reliability Organization
 Event Analysis Program
 - A program that includes reviewing off-normal events occurring on the bulk power system.
 - Requires industry participation and support to be effective.
 - Used to identify and publish lessons learned (NERC website) and support system reliability.
 - Event reporting supports identifying trends, identifying themes of occurrence, studying impact-risk relationships, and improving operating culture.







- Trends are identified by cause codes that include the following:
 - Engineering and Design Human Performance Communication
 - Other
 - No cause found

Equipment and Material Management and Organization Training Overall Configuration Information to determine cause LTA



Event Numbers





- Root cause identification continues to improve
- Overall average is 55.4%
- 2018–2022 (rolling average of last 5 completed years) is 65.9%



*AZ Codes represent when a specific correctable/actionable root cause cannot be determined for an event 5 RELIABILITY | RESILIENCE | SECURITY



- Human Performance refers to individual human performance
 - Refers to when a person makes a decision as an individual, not as part of a team
 - A substitution test would show different results, excluding the operating environment from influencing individual action
- Organizational Performance refers to practices, policies, procedures, management decisions, etc.
 - This would include work that is done as part of a team effort
 - Substitution test would show similar result indicting the operating environment leading the individual to action



Types of Human Error*

- Skill-Based Mode
- Rule-Based Mode
- Knowledge-Based mode
- Work Practices Error** (This is when a person can't perform the task or deliberately causes an error.)
- * Based on Rasmussen's model
- ** Not Based on Rasmussen's model



Skill-Based Mode—associated with highly practiced actions in a familiar situation

ABCDEFG
HIJKLMNOPQR
STUVWXYZ

- Main error driver–Distraction
- Error Rate 1:10,000



 Rule Based Mode – based on the selection of stored rules derived from one's recognition of the situation

ZYXWVUIT
SRQPONMLKJI
HGFEDCBA

- Main error driver Incorrectly identified the problem
- Error Rate 1:1,000



• Knowledge-Based Mode–Behavior based on unfamiliarity, so individuals must rely on experience, perceptions, and perspectives



- Main Error Driver–Lack of a good mental model
- Error Rate 1:2



Human Performance Issues

- Human Performance has been identified as either a root cause or a contributing factor 329 times since 2010
- Average of ~26.2 events per year
- So more than once every other week, someone is making a mistake with consequences for the grid





Where are the problems

- Skill-Based Error (182 times)
- Rule-Based Error (70 times)
- Knowledge-Based Error (41 times)
- Unknown mode (33 times)
- Work Practices Error (3 times)





Out of 329 times a human performance code was identified, the top five codes were:

- Check of work Less than Adequate (LTA) (71 times, skill based)
- Individual Human Performance (33 times, unknown mode)
- Incorrect performance due to mental lapse (27 times, skill based)
- Situation incorrectly identified or represented resulting in wrong rule used (27 times, Rule based)
- General Skill Based Error (25 times)



So is it just the Human?





What do others see?



The PII Performance Pyramid TM



- Organizational Performance has been identified as a root or contributing factor 1,116 times
- Average of ~89 events per year
- This is over 3x the rate of Individual Human Performance issues





Out of the 1,116 times organization performance has been indicated as factor, the top five are the following:

- Job scoping did not identify special circumstances and/or conditions (135 times)
- Corrective action responses to a known or repetitive problem was untimely (99 times)
- System interactions not considered or identified (97 times)
- Risks/consequences associated with change not adequately reviewed/assessed (74 times)
- Previous industry or in-house experience was not effectively used to prevent recurrence (62 times)



Design/Engineering Issues

- Design/Engineering has been identified as a root or contributing factor 1,210 times
- Average of ~95 events per year
- This is over 3x the rate of Individual Human Performance issues





Out of the 1,210 times Design and Engineering has been indicated as factor, the top five are the following:

- Design output scope LTA (528 times)
- Errors not detectable (134 times)
- Independent review of design/documentation LTA aka, peer checking (126 times)
- Design output not correct (111 times)
- Testing of design/installation LTA (70 times)



Human Perfomance vs All Other Root Causes



 Only 3.6% of identified event root causes indicate that the event is due to an Individual Human Performance issue



- 41.0% Organizational Performance (45.9% past 5 years)
- 26.4% Design and Engineering (26.5% past 5 years)
- 3.6% Human Performance (3.5% past 5 years)





Human Performance vs. Organization Performance

- Human performance remains fairly constant at a very low level
- Engineering has decreased over the past few years
- Organizational Performance issues remain a major driver of Categorized events





Top HP/OP Event Root Causes

Org. Performance – Job scoping did not identify special circumstances and/or conditions (67 times)

Org. Performance – System interactions not considered or identified (40 times) Eng. Design Output Scope LTA (184 times) Org. Performance – Risks / consequences associated with change not adequately reviewed / assessed (31 times)

Org. Performance – Management policy guidance or expectations not well-defined, understood, or enforced (29 times)

RELIABILITY | SECURITY



Conclusions





- "Human Performance issues" are usually a symptom of larger challenges within a company.
- Best ways to reduce events are by performing the following:
 - Working to improve engineering, especially improving the understanding of all the ways a design could fail and ensure you have a robust peer review process
 - Working with supervisors and crews to improve job scoping and understanding of how systems interact with each other
 - Ensuring that all potential impacts or dependencies are identified, reviewed, and (if needed) modified to accommodate changes when they are made
 - Ensure that policies and expectations are well defined and understood by your employees and contractors





- Doing what is easy vs doing what is hard
 - It is easy to blame the individual human, a failed component, or weather
 - It is harder to admit our processes, procedures, and policies need improvement
- Yet, It is by identifying and doing what is hard that results in significant improvement for a more Reliable, Resilient, and Secure industry.

"We choose to go to the Moon in this decade and do the other things, not because they are easy, but because they are hard." – President John F. Kennedy







- ERO Event Analysis Program Website
- ERO Event Analysis Process Document
- ERO Cause Code Assignment Process
- Lessons Learned Website



Questions and Answers



Contact: Ed Ruck Senior Engineer of Event Analysis <u>ed.ruck@nerc.net</u>





Q U A N T A T E C H N O L O G Y



OCTOBER 2024

BES Protection System Misoperation Reduction Workshop

Wildfire Risks and Mitigation Strategies on Transmission and Distribution Systems

Jonathan Sykes, Ali Arabnya – Quanta Technology Scott Hayes – PG&E





Economics of Protection Methods for Wildfire Risk Management in T&D Systems

2

IEEE D45 Technical Report

3

Discussion about Regulatory Environment in Australia and U.S.

4

Questions and Answers

5

Introduction



3

The impact of fires is made worse by the increased development in Wildland Urban Interface areas.

frequent and more damaging in recent years.

Wildfires (bush fires or forest fires) have become more

Electrical equipment is not the largest cause of wildfires but the fires that they cause tend to become larger and more damaging due to their relationship to the environmental conditions at the time of ignition (i.e., high temperatures, dry fuel, and high wind conditions).
Introduction



Location	<u>Victoria</u> , Australia	
	Statistics	
Date(s)	7 February – 14 March 2009 <mark>Multiple Fires</mark>	
Burned area	450,000 hectares (1,100,000 acres) ^[1]	
Cause	Various confirmed sources including: Power lines^[2] <u>Arson^[3]</u> <u>Lightning^[4]</u> Machinery^[5] 	
Land use	Urban/rural fringe areas, farmland, and forest reserves/national parks	
Buildings destroyed	3,500+ (2,029 houses) With costs approaching \$100 billi	<mark>ion</mark> , t
Deaths	173 ^{[6][7][8]} fires are Australia's costliest	
Non-fatal injuries	414 ¹⁹ natural disaster. January 16, 2020	

he

Introduction – Distribution Risk vs. Transmission Risk

Camp Fire 115 kV Phase-to-Tower Fault



Introduction – Wildfires and Their Impacts are Increasing

The New York Times

Pleads Guilty to 84 Counts of aughter in Camp Fire Case

ia utility's transmission line started the 2018 fire tha s and destroyed the town of Paradise.



Judge approves [Utility's] bankruptcy exit

- A federal judge has approved [Utility's] plan to exit bankruptcy, to compensate victims of a series of wildfires in the state that left more than 100 people dead in 2017 and 2018.
- The action authorized \$13.5 billion in compensation for more than 70,000 businesses and homeowners for losses sustained during the fires, which officials said were started by [Utility's] equipment.
 The company will emerge from bankruptcy with about \$40 billion in debt, after agreeing to settle claims from people, insurers, and local government agencies for \$25.5 billion.

Introduction – Distribution Risk vs. Transmission Risk

Kincade Fire 230kV Phase-to-Tower Fault



- **374** structures destroyed.
- 185,000+ people evacuated
- \$385 Million estimated property damage.



Introduction – WECC Weekly (Wildfire) Update

Weekly Update

https://www.wecc.org/wecc-document/14941

Weekly Wildfire Update (PDF)

Western Interconnection Wildfire Assessment_Sept18_Final.pdf (wecc.org)





Weekly Wildfire Update WECCSA September 18, 2024

Western Interconnection Wildfire Assessment

This is a high-level summary of the wildfire risk to the bulk power system. The information is for general purposes only and should not be relied on as accurate, because fires are dynamic, and circumstances may change quickly.

Active Wildfires (U.S. and Canada)

In the Western U.S., the National Interagency Fire Center (NIFC) reports 75 large (>1,000 acres) wildfires burning in eight states. Alberta has zero and BC has 25 wildfires listed as *out of control*. Overall, the interconnection had an increase of 19 wildfires in the past week.

Active fires in the Western Interconnection-September 18, 2024



Introduction – WECC Weekly (Wildfire) Update

Latest Wildland Fire Outlook (NWS)

WECC Wildfire Dashboard

https://www.weather.gov/fire/



https://experience.arcgis.com/experience/87cda22dccde4a35af250469ae12f40e/



The Economics of Protection Methods for Wildfire Risk Management in Transmission and Distribution Systems

Ali Arabnya – Quanta Technology

Wildfire Risk Management Strategy: Deep Defense



Picture Credit: Mike Eliason, Santa Barbara County Fire Department, AP / IEEE Spectrum

The deep defense (or defense-in-depth) approach in risk management is a paradigm that has its origins in ancient military strategy, which relies on multiple lines of defense rather than a single frontline.

An effective wildfire risk management should achieve following objectives:

- Operational resilience
- Financial resilience.

Three Lines of Defense for Wildfire Risk Management

A three-lines-of-defense (3LD) framework for end-to-end wildfire risk management can facilitate an optimal resource allocation for wildfire resilience building by utilities.



Counterfactual Risk Analysis



A data-driven counterfactual risk analysis can provide crucial input to measuring the success metrics of protection methods used for wildfire risk reduction.

Incremental (marginal) cost analysis of wildfire mitigation strategies (including protection methods) can determine the true cost difference between various alternatives.

Picture credit: Cody Warner et al., Risk-Cost Tradeoffs in Power Sector Wildfire Prevention. The Energy Institute at Haas, 2024.



The Economics of Protection Methods – Fast-Trip Settings

Fast-trip settings should be co-optimized with other mitigation strategies using a riskbased approach:

Minimize:

 $\sum_{i}^{n} Pr(ignition)_{i} x (consequence)_{i}$

Subject to:

- Undergrounding cost ≤ C_{UG}
- Vegetation management cost $\leq C_{VM}$
- (Hours of fast trip outages) x (value of lost load) $\leq C_{FT}$



Industry Perspective – Emerging Trends

Some of the recent challenges and wildfire risk management objectives set by utility executives are, as follows:

How to reduce the financial exposure from wildfire events by 90%, asked an electric utility CFO? What's the price tag to achieve that goal?

How can Probabilistic Risk Assessment (PRA) methods from nuclear safety codes be leveraged to reduce wildfire ignition risk in an electric utility by x percent? How a utility can reach its wildfire risk reduction goals using PSPS without compromising SAIDI and SAIFI reliability metrics?

Achieving these multi-objective goals require protection methods to work in sync with other risk reduction methods considering their microeconomic dynamics in utility businesses.





IEEE PRSC D45 WG, Technical Report Document Protection Methods Used to Reduce Wildfire Risks Due to Transmission and Distribution Lines

Jonathan Sykes, PE, IEEE Fellow, Quanta Technology Scott Hayes, PE, Principal Engineer, PG&E

> October 01, 2024 NERC Salt Lake City, Utah



Overview



D45: Prepare a technical report to the line protection subcommittee to "document protection methods used to reduce wildfire risks due to transmission and distribution lines."

Chair: Jonathan Sykes Vice Chair: Scott Hayes Output: Technical paper approximately January 2025 Team: Utilities, Consultants, Academia, and Manufactures



Members and Contributors

- Galina Antonova
- Hugh Borland
- Ritwik Chowdhury
- Normann Fischer
- Matt Garver
- Wayne Hartmann
- Scott Hayes
- Daqing Hou
- Robbie James
- Bogdan Kasztenny
- Deepak Maragal
- Boris Marendic
- Tony Marxsen
- Nirmal Nair

- Russ Patterson
- Henry Quin
- Farnoosh Rahmatian
- Dan Ransom
- Jesse Rorabaugh
- Andrew Swisher
- Jonathan Sykes
- Douglas Taylor
- Eric Udren
- Joe Xavier
- Yujie Yin
- Amin Zamani



Table of Contents (Abbreviated)

- Fault Behavior and Ignition Risks
- Fault Responsive Relay Applications
- High Impedance Fault Detection
- Incipient Fault Detection
- Impact of Fuses on Fire Risk
- Neutral Grounding Practices
- Compensated Neutral Schemes



Fault Behavior and Ignition Risk



- The capacity of electricity to start wildfire is as old as lightning, and the fire ignition risks associated with modern electrical equipment led to the creation of the National Electrical Code (NEC), produced by the National Fire Protection Association (NFPA) beginning in 1897.
- At a fundamental level, fire ignition risk increases with an increase in fault energy.
- Fault energy is a function of the magnitude of fault current and the duration of the fault, but the variety of fault conditions that occur on the power system factored in with fuel bed and climate conditions make for a much more complicated picture.



Fault Behavior and Ignition Risk

- There are to many variables to determine the exact risk.
- The electrical grid extends thousands of miles throughout the forest and has millions of arc possibilities.
- Each point of the arc can present very different risk characteristics.
- For over 100 years the grid has used overcurrent and impedance-based detection methods to detect and isolate the fault on the line.
- The protection of the electrical grid focused on the isolation of the fault with as little interruption to the rest of grid as possible.
- Relays were coordinated with intentional time delays to allow coordination between zones of protection.
- Some faults were cleared with an intentional time delay.

The longer the fault or arc lasts the more heat energy is present and the greater risk of a wildfire.



Fault Responsive Relay Applications

- Distributed Energy Resources (DER) on the distribution system
- Relay setting change methods:
 - Increase fault detection, selectivity, sensitivity, and lower relay operation time
 - Automatic and Dynamic Reclosing
- Communication-aided protection methods:
 - Step distance-based communication systems
 - Transmission Line-Current Differential (LCD)
 - Time-domain and traveling wave protection
 - Distribution Line Differential (DLD)
 - Sensor-based methods.







Figure 4.3.2 . Line Current Differential.

Risk-Cost Tradeoffs in Power Sector Wildfire Prevention, Energy Institute at HAAS, WP 347, Cody Warner, Duncan Callaway, and Meredith Fowlie February 2024; <u>https://haas.berkeley.edu/wp-content/uploads/WP347.pdf</u>



Fault Responsive Relay Applications

Time-domain and travelling wave protection:

• Transmission application is simpler.



TW for Complex Line Topologies



• Positive detection and location of downed conductors.







Fault Responsive Relay Applications



Passive Distributed Measurements



M. Mohemmed, P. Orr, S. Blair, N. Gordon, I. Mckeeman, A. Mohamed, and A. Bonetti, "Differential Protection of Multi-Ended Transmission Circuits Using Passive, Time-Synchronised Distributed Sensors," proceedings of the PAC World Conference, Prague, Czech Republic, 2022.



High-Impedance Fault Detection and Pulse Counting

Arcing produces a wide spectrum of even-, odd-, and inter-harmonic energy along the power line that extend into the megahertz range.

Detection Strategies:

- Derive the high-frequency signal component including even and odd harmonics in the range of sub-harmonic to 1 MHz.
- Tune the response of the detection algorithms.
- Logic to differentiate an HIF condition from switching operations and noisy loads.
- Detect intermittent arcing (i.e. Pulse Counting)



Diagram 5.1 Example of time-varying, intermittent, and harmonic-rich HIF current waveform



Incipient Fault Detection

- Technologies, trials, and solutions being developed or applied for incipient or "emergent" fault detection that are potential pre-cursors to fire ignition risks.
- The gold standard sought by the industry are methods to detect incipient faults with enough time to take action before high-current faults occur.
- Principles used for the technologies and solutions for incipient fault detection can be classified under the following categories:
 - Pattern recognition
 - Corona discharge detection / partial discharge analysis
 - Remote sensing and LiDAR-based
 - Video monitoring based
 - Fiber-based line monitoring methods.



Incipient Fault Detection – Falling Conductor Detection (FCP), Broken Conductor, Open Phase Methods



- Falling Conductor Protection (FCP) systems, developed around 2014, detects the electrical signature of circuit voltage and/or current changes
- There is adequate time to deenergize the circuit well before the conductors reach the ground
 - A distribution conductor 33 feet in the air takes about 1.4 seconds to reach the ground.
- Voltage sensing is commonly used for distribution and current sensing for transmission.

IEEE PES PSRC Working Group D45 Impact of Fuses on Fire Risk

Fuses are typically the most common protective device installed in overhead distribution systems.

Various types include:

- Single-phase devices
- Expulsion fuses
- Non-expulsion fuses
- Current-limiting fuses
- Electronic interrupters.

Back Feed Issue: If three-phase or phaseto-phase transformers are connected on the load side of the blown fuse, it can result in low-level currents flowing that have been known to ignite fires. This is sometimes called a back fed fault.



Single-Phase Fuse Operation

IEEE



Neutral Grounding Practices

- Neutral grounding methods can significantly reduce ground faultcurrent levels and fire ignition risk.
- Neutral grounding methods can result in ground fault currents ranging from tens of thousands of amps to milliamps.
- When applying delta or high impedance grounding methods the effects of temporary overvoltages on equipment and the impact on detecting ground faults must be considered.



Neutral Grounding Practices

Multipoint Grounded Wye

- Multipoint grounded Wye or 4-wire systems are prevalent for mediumvoltage circuits in North America.
- Supports phase-to-phase and phase-toground connected loads. This can reduce equipment costs but typically results in high levels of ground fault current.
- High-impedance grounding is usually not applied. Load unbalance is often high, requiring ground relays with high minimum trip.
- This results in less sensitivity for highimpedance ground faults .

Uni Grounded Wye

- Uni-grounded Wye or 3-wire systems are common at medium- voltage installations internationally.
- This method supports phase-to-phase connected loads without an insulated neutral conductor being brought to the load.
- These systems can accommodate different grounding methods to reduce ground faultcurrent levels by applying neutral grounding resistors, reactors, or compensated neutral schemes.
- Unbalanced loads do not flow in ground relays allowing sensitive ground time-overcurrent settings.



Neutral Grounding Methods

Multipoint grounded Wye

Uni-grounded Wye

Delta/ungrounded

Delta/grounded

High-impedance grounding for Wye grounded systems.



PES

Power & Energy Society

High-resistance/reactance/compensated ground



Compensated Neutral Schemes



Note: Compensated neutral schemes also referred to as Petersen Coils were first developed in Germany by Waldemar Petersen in the early 1900's and appear in AIEE papers beginning in 1922.



Compensated Neutral Schemes

Resonant Grounding – How Does GFN Work?

- The ASC across the neutral, that is tuned to the network capacitance, will neutralize the unbalanced capacitive current resulted from phase-to-ground voltage on the two healthy phases.
- A residual current due to resistive (residual) losses still exists of between 10-20 amperes typically. This current is then reduced to almost zero by the RCC.

- 12 kV phase-to-ground on the two un-faulted phases
- 0 kV phase-to-ground on the faulted phase,
 7.2 kV neutral-to-ground





Compensated Neutral Schemes

Rapid Earth Fault Current Limiter (REFCL)

REFCLs come in two main types:

- 1) Arc Suppression Coils with no power electronic components
- 2) Ground fault neutralizers with active residual current compensation using power electronics

Other Methods (Outside North America)

- Isolated Neutral
- Directional Residual Overcurrent Methods
- Fault Inception Transient Methods
- qu (Charge Voltage) Method
- Transient Reactive Power Method
- Admittance Methods
- Multi-frequency Admittance Method

- Change in Admittance Method
- Change in Negative-Sequence Current (Δ3* I2) Methods
- Harmonics
- Concurrent Algorithm
- Network protection
- System Wide Ground Fault Protection

Regulatory Environment in Australia and U.S.

Scott Hayes – PG&E

Australian Regulation

- In 2016, the State of Victoria, Australia passed regulation 32/2016 to reduce bushfire risk.
- The regulations are prescriptive and includes 45 substations – listed by name and latitude/longitude.
- Performance requirements are part of the regulation
- In 2016, only one vendor could meet the performance requirement.



Australian Regulation

Performance requirement must be validated by testing every year.

In the event of a phase-to-ground fault on a polyphase electric line, the ability:

- (a) to reduce the voltage on the faulted conductor in relation to the station earth when measured at the corresponding zone substation for high impedance faults to 250 volts within 2 seconds; and
- (b) to reduce the voltage on the faulted conductor in relation to the station earth when measured at the corresponding zone substation for low impedance faults to
 - (i) 1900 volts within 85 milliseconds; and
 - (ii) 750 volts within 500 milliseconds; and
 - (iii) 250 volts within 2 seconds; and
- (c) during diagnostic tests for high impedance faults, to limit
 - (i) fault current to 0.5 amps or less; and
 - (ii) the thermal energy on the electric line to a maximum I2t value of 0.10;



Regulatory Framework in the U.S.



California Utilities:

- Are not allowed to cut healthy trees outside of right of way.
- Some right of ways are 30 feet wide with 100- to 300-foot-tall trees.



California:

- Has GO 95, which applies to hardware failures and vegetation contacts.
- Faults are generally considered a violation due to Utility "Failing to Maintain its Facilities Safely..."





Ignition Risk Formulas

Scott Hayes, PE, Principal Engineer, PG&E

Jonathan Sykes, PE, IEEE Fellow, Quanta Technology


Basic research to develop risk equations

- There are no standard industry equations for ignition risk vs fault current or clearing times. Initial assumptions that fault energy predicted by I²T have been found overly simplistic and not a good model of ignition risk. The lack of industry wide ignition risk formulas are a result of the chaotic nature of electrical arcs, many construction and hardware variables, and large numbers of environmental variables.
- Australian testing and PG&E testing have developed some formulas that are not consistent or adequate
- Suggest pursuing collaborative funding/testing through an industry group.



Proposed Fault Types to test

- Wire on Ground Low Z/High Z
- Vegetation on wire(s)
- Overhead arcing fault (Phase to Phase or Phase to Ground)
- Fault height above ground.
- Conductor types and configurations
- Vary fault current and clearing time

Ignore environmental variables (wind speed, temperature, humidity)



Fire Ignition Risk ~ Fault Energy

Fault Energy = f(Fault Current and Clearing Time)

THERE ARE NO EXACT FORMULAS

I² T R Where R is resistance at fault point

 $\mathbf{P}_{\mathbf{I}} = \frac{1}{1 + e^{-(-7.85 + 0.129t)}}$

PG&E Testing: Constants vary with fault current and environmental factors

$$P_{397Al}(I, f, t) = (0.006842 I)^4 f^2 \exp((0.79 f - 3.845)t)$$

Fault Behavior and Ignition Risk



Figure 1. Ignition probability against arc duration for 4.2, 50 and 200 amp arcs at 45°C and 10 kph wind speed for hay/straw at 5% moisture

https://www.researchgate.net/publication/283486798_Probability_o f_Bushfire_Ignition_from_Electric_Arc_Faults

Particle Counts PG&E tests – Overhead arcing faults

IEEE

Power & Energy Society*



Figure 11. Particle Count vs. Fall Time (seconds) for the Cage and Lift tests combined, 0.1 second fault time, for #4 ACSR, Pigtail Configuration.

Assessment of Hot and Flaming Particles and Fire Risk from High Current Faults, Western Protective Relaying Conference 2022

Questions or Comments?





Accelerate Successful Outcomes for Your Projects



919-334-3000

in

<u>quanta-technology.com</u>

info@quanta-technology.com

linkedin.com/company/quanta-technology/

twitter.com/quantatech

Contact us and follow us today





Automated Solutions and Remote Settings Changes - AEP's Approach to Implementing PRC-027-1

Jeff Iler, Nelson Doe, and Manish Thakur

American Electric Power



Automated Solutions and Remote Settings Changes - AEP's Approach to Implementing PRC-027-1

2024 ERO Misoperation Reduction Workshop Agenda:

- AEP Background
- PRC-027-1 Requirement 2
- What is a Protection System Coordination Study
- AEP's Initial 765kV Area Study
- Lessons Learned
- Coordination Study Progress



AEP Serves 5.5 million Customers in 11 States



AEP's PRC-027 Applicable Lines

Voltage (kV)	Transmission Lines	Total Line Terminals	Interconnected Terminals
765	36	68	6
500	8	8	8
345	336	506	177
230	9	11	7
161	41	68	20
138	1601	2952	346
115	5	8	2
Totals	2036	3621	566

NERC Standard PRC-027-1

Purpose: To maintain the coordination of Protection Systems installed to detect and isolate Faults on Bulk Electric System (BES) Elements, such that those Protection Systems operate in the intended sequence during Faults.

Requirement R2 Each Transmission Owner, Generator Owner, and Distribution Provider shall, for each BES Element with Protection System function identified in Attachment A:

- **Option 1**: Perform a Protection System Coordination Study in a time interval not to exceed six-calendar years (4/1/2027) ; or
- Option 2: Compare present Fault current values to an established Fault current baseline and perform a Protection System Coordination Study when the comparison identifies a 15 percent or greater deviation in Fault current values (either three phase or phase to ground) at a bus to which the BES Element is connected, all in a time interval not to exceed six-calendar years; or,
- **Option 3**: Use a combination of the above.

PRC-027 Attachment A

Attachment A

The following Protection System functions are applicable to Requirement R2 if: (1) available Fault current levels are used to develop the settings for those Protection System functions; and (2) those Protection System functions require coordination with other Protection Systems.

- 21 Distance if:
- infeed is used in determining reach (phase and ground distance), or
- zero-sequence mutual coupling is used in determining reach (ground distance).
- 50 Instantaneous overcurrent
- 51 AC inverse time overcurrent

67 – AC directional overcurrent if used in a non-communicationaided protection scheme

Option 1 or Option 2?

Option 1:

- Ensures that Protection Systems are coordinated
- Potentially reduces misoperations caused by incorrect relay settings
- May be more costly and time consuming than Option 2

Option 2:

- Protection Systems must be coordinated before setting a baseline
- May be less resource intensive than Option 1

What is a Protection System Coordination Study?

An analysis to determine whether Protection Systems operate in the intended sequence during Faults.



The standard does not prescribe reach margins, pickup margins, or coordination time intervals; it allows Transmission Owners to define coordination criteria based on their own philosophy

AEP's Coordination Study

<u>21 – Distance</u>

- Zone 1 reach < maximum value
- Zone 2 reach > minimum value
- Zone 2 reach coordinates with Zone 1 relays on downstream lines
- Zone 3 reach coordinates with Zone 2 relays on downstream lines

50 – Instantaneous overcurrent

 Instantaneous Elements have adequate margin for remote bus fault

51/67 – AC overcurrent

- Minimum pickup for line end fault
- Minimum pickup for line end fault with single contingency source outage

AEP's Coordination Study

- Coordination checked at the end of the instantaneous zone to determine coordination time interval (CTI)
- Distance and overcurrent checked together CTI is based on fastest relay function
- Additional check using Aspen OneLiner Relay Operations Using Stepped Events



Initial 765kV Area Study

In 2019 AEP Studied our 765 KV System

- 34 lines, 66 line terminals studied
- ASPEN OneLiner coordination Checking Tools were used
- **Coordination Errors Identified:**
- 9 issues that could result in a misoperation (Instantaneous Overcurrent)
- 32 other issues outside AEP's setting criteria

Initial 765kV Area Study

- Reviewed and updated all 765kV line settings (not just attachment A)
- Opportunity taken to update settings up to AEP's latest guidance
 - Directional elements
 - Add a time delay to the DCB ground overcurrent function
 - Disabling phase instantaneous overcurrent elements
- Setting revised for 56 line terminals (112 digital relays)

Why AEP Selected Option 1?

Based on 765kV study results Option 1 was selected

- Achieve reliable system protection by ensuring all relays are properly coordinated
- Significantly reduce, and potentially eliminate, misoperations caused by outdated and incorrect settings
- Provides opportunity to go above PRC-027 R2 requirements and review and update all protective functions

Lessons Learned from Initial 765KV Study

- 1. Updated the philosophy for setting ground overcurrent backup protection
- 2. Automated the development of relay settings
- 3. Adjusted criteria for Protection System Coordination Studies
- 4. Automated the execution of Area Protection System Coordination Studies
- 5. Began remotely applying relay settings

Updated the Philosophy for Setting Ground Overcurrent Backup Protection

Initial study identified GOC settings as leading cause of coordination errors

- Disable ground instantaneous function
- Slow down time overcurrent function
- Allow ground distance to operate first
- GTOC expected to operate for high impedance faults when pilot system it out of service



Automated Relay Setting Development

- Automated Relay Settings (ARS) developed by Utility Automation Solutions (UAS)
- ARS was initially used for the 765kV PRC-027 settings 56 line terminals

Automated Relay Settings 1.0.5.6	- O X
File Checks Tools Help	
🛛 💐 Preference 🛛 😪 Check Line Protection 🛛 💇 C	Check Xfmr Backup Protection ا 🗃 Update Setting Files 🛛 🔣 Update Oneliner File 🛛 🙆 Compare Setting Files
Line	Settings for 2-Terminal Line Protection Using DCB
DCB POTT	ASPEN Oneliner File: C:\Users\o437315\Desktop\WPRC\AEP_MASTER.OLR Browse Open Dir
Step Distance DCB & Step Distance DCB & 871	Local Bus Name: OHIO Remote Bus Name: Tap Bus Name: Circuit ID: 1
- 87L & Step Distance - 87L & POTT	Line Voltage (kV): 765 Winter Emergency Load (MVA): 4961 Line Conductor Rating (MVA): 7897 Doth Terminals Have Polarizing CT's?
	CT Ratio: 400 :1 CT Primary (A): 2000 CT Secondary (A): 5 Local Polarizing CT Ratio: 600
Distribution T-Transformer	PT Ratio: 6250 :1 PT Primary (Ph-Ph, kV): 765 PT Secondary (Ph-Ph,V): 122.4 Use Bus PT ?
⊕-Capacitor Bank	Remote CT Ratio: 400 :1 Remote PT Ratio: 6250 :1 🥑 Use Automated Settings for Remote Terminal DCB Scheme?
	Type AEP Version Scheme Relay System 1: L90 Gen3.1 DCB CB Relay System 2: 411L Gen3.1 DCB It is interconnection that requires information exchange process per PRC-027?
	Generate Setting Document

ARS Calculation Sheet

3.4 Phase Distance Zone 2								
Phase Distance Zone 2 (72P) Function is Enabled								
125%Z1L=	1.91 Ω	secondary	150%Z1L=	2.29 Ω	secondary			
The 72D res	ach is sat at					2 29 0	secondary	1 92 0
THE ZZF TEG	ich is set at					2.25 11	secondary	1.52 1/
Expressed	in primary o	ohms, the Z2	Preach settin	ig is		35.78 Ω	primary	
The 72D rev	ch in norce	ntago of the	line positivo		impodonoo (711) is	150%		
The ZZP rea	ach in perce	intage of the	ine positive	sequence	impedance (ZIL) is	150%		
The Z2P tin	ne delay is t	ypically 0.33	s - 0.4s, or lor	nger for co	ordination	0.333 s		
The Curren	t Supervisio	on of Z2P is se	et at			0.100 pu		
The adjace	nt line sele	cted for Z2P	checking has	the follo	wing information:			
The line is	"242513 TEX	(AS 765.kV - 2	42508 OKLAH	IOMA 765	.kV 1 L". The check r	elay is		
"TEXAS_OK	LAHOMA_C	060_PDS", of	which the Z1	P reach is	0.42 ohms (6.6 prima	ary ohms, 79.5%	6 line	
impedance	.).							
The appare	nt impedar	ice from the	3LG fault (LEC	D) at the c	heck point is	38.98 Ω	primary	
Based on this and using 0.8 as margin factor, the Z2P check impedance is 2.00Ω secondary								
The result of the Z2P coordination check is Invalid								
Comment:	CHANGED	REACH TO 15	0%					
	ARS CALCU	ILATED Was 1	.92					
	2.00 OHMS IS THE MAXIMUM REACH BEFORE TIME COORDINATION IS REQUIRED							J

ARS UI for Updating Setting Files

	Update Line Relay Setting Files	Dual SEL Relays		
Setting Calc File (.xlsm)	C:\Users\o437315\Desktop\WPRC\Setting Calc_DCB_09042023_OHIO_TEXAS_765kV_Sys1L90	0DCBGen31_Sys2411LDCBGen31.xlsm	Browse	Open Dir
Sys1 Setting File (.xml):	C:\Users\o437315\Desktop\WPRC\L90_v82_DCB_G3_01.xml	E	Browse	Open Dir
Sys2 Setting File (.rdb)	C:\Users\o437315\Desktop\WPRC\SEL411L_R128_DCB_G3_01.rdb	E	Browse	Open Dir
SEL Architect File (.scd)	C:\Users\o437315\Desktop\WPRC\SEL411L_R128_DCB_S1DCB_G3_01.scd	E	Browse	Open Dir
Sys1 Base Template	L90-82x-DCB-G3.1	11L-R128-DCB-G3.1 ×		
	 Update SEL relay's Protection Logic per AEP Standards Update CB names in SEL setting template per AEP Standards Update UR relay's Digital Elements, FlexElements, FlexLogic or Flexlogic T Update CB names for Contact Inputs, Contact Outputs and Virtual Inputs p 	Timer per AEP Standards er AEP Standards for UR relays		UAA
	Update UR Relays GOOSE IDs, Relay Name and User Display Names			697
Note: 1. The setting file to be up please do not use this 2. The copy of the input s 3. A comparison report in 4. Please review the upd	Update Setting Files Per Calculation Sheet odated must be based on one of the standard templates. Please select the base template tool for settings update. etting file will be updated and there is no change to the input file. The two files can be comp pdf can be found in the same folder as the setting files. ated setting file thoroughly. It is recommended to verify the I/O settings against schematic d	e carefully. If you are not sure about the base pared to verify the updates. diagrams, regardless they need to be update	template, ed or not.	

Adjusted Criteria for Protection System Coordination Studies

	Element	AEP Setting	PRC-027
		Criteria	Criteria
	Zone 1 Phase Distance maximum reach	85%	86%
\geq	Zone 2 Phase Distance minimum reach	125%	120%
Ň	Zone 1 Ground Distance maximum reach	80%	85%
<u>í</u>	Zone 2 Ground Distance minimum reach	120%	110%
	Zone 2 Distance Z2/Zapp threshold	80%	85%
ц Г	Instantaneous overcurrent minimum margin	125%	120%
m m	Ground time overcurrent pickup margin	3.0x	2.5x
	Minimum Coordination Time Interval (CTI)	20 cycles	18 cycles
	Zone 1 Phase Distance maximum reach	85%	86%
$\mathbf{\mathbf{z}}$	Zone 2 Phase Distance minimum reach	125%	120%
0	Zone 1 Ground Distance maximum reach	80%	85%
Ϋ́	Zone 2 Ground Distance minimum reach	120%	110%
	Zone 2 Distance Z2/Zapp threshold	80%	85%
പ	Instantaneous overcurrent minimum margin	120%	115%
	Ground time overcurrent pickup margin	3.0x	2.5x
	Minimum Coordination Time Interval (CTI)	24 cycles	20 cycles

Automated the Execution of Area Studies

ARS has a module that will:

- 1. Automatically perform all coordination checks
- 2. Study multiple lines at one time
- 3. Output easily identifies where errors exists

	Check Line Relay Settings	Check Single Terminal		
ASPEN Oneliner File C:\Users\o437315\Desktop\WPR	VAEP_MASTER.OLR		Browse	Open Dir
Line Information File: C:\Users\o437315\Desktop\WPR	Ninecollection_2termxlsx		Browse	Open File
Folder For Result Files: C:\Users\o437315\Desktop\WPR	>		Browse	Open Dir
Check Options	Backup Check ? 🛛 🛛 Include C	Oneliner Function for Step Event Check ?		
	Check Settings			
Auxiliary Functions			E A	
Collect Line Information	s Names in Line Information File		\$	9

ARS - Check Line Protection

- List of lines to be studied is needed
- AEP system divided into 87 groups
- Each groups contains about 20-25 lines

2-Terminal Lines		Check From Seq. #	1	To Seq. #	8		
Seq.#	Line KV	Local Bus Name	Remote Bus Name	Tap Bus Name	Relay Modelled for Both Terminals? (Y/N)	Interconnection (Y/N) ?	Circuit ID
1	765	OHIO	TEXAS		Y		1
2	765	TEXAS	OHIO		Y		1
3	765	TEXAS	VIRGINIA		Y		1
4	765	VIRGINIA	TEXAS		Y		1
5	765	KENTUCKY	TEXAS		Y		1
6	765	TEXAS	KENTUCKY		Y		1
7	765	OKLAHOMA	TEXAS		Y		1
8	765	TEXAS	OKLAHOMA		Y		1

ARS - Check Line Protection

- A summary sheet is produced showing each terminal that was checked
- The results of each element checked is shown
- This make is easy to determine which terminals have issues

	S	ummary of	Settings Check	c For Mul	tiple Lir	ne Termin	als	
Oneliner	File:	C:\Users\o437	315\Desktop\WPRC\	AEP_MASTER	R.OLR			
Folder fo	r Check Files:	C:\Users\o437	315\Desktop\WPRC					
Local Ter	minal	OHIO		Remote Ter	minal	TEXAS		
Number	of terminals	2		Line Voltage	2	765 kV	Seq.#	1
Check Fil	e	OHIO TEXAS	765kV SettingsChee	ck 1 0904202	3.xlsm			
Туре	Relay ID		Elements			Check	Results	
21P	OHIO_TEXA	S_421_PDS	Z1P;Z4P;Z2P	b		Issue	Found	
21P	OHIO_TEXA	S_D60_PDS	Z1P;Z3P;Z2F	0		(ОК	
21G	OHIO_TEXA	S_421_GDS	Z1G;Z4G			(ОК	
21G	OHIO_TEXA	S_D60_GDS	Z1G;Z3G			(ОК	
51G	OHIO_TEXA	S_421_GOC	51G		O	K, but issue w	ith adjacent rela	у
51G	OHIO_TEXA	S_D60_GOC	51G		OK, but issue with adjacent relay			у
Coordina	tion With Dow	nstream Relays	For Adjacent Line Er	nd 1LG Fault	OK			
Coordina	tion With Upst	tream Relays Fo	r Adjacent Line End 1	LLG Fault	Issue Found			
Coordina	tion With Dow	nstream Relays	For Adjacent Line Er	nd 3LG Fault	OK			
Coordina	tion With Upst	tream Relays Fo	r Adjacent Line End 3	BLG Fault	ОК			
Relay Op	erations Check	CUsing Step Eve	ents			Issue	Found	
Local Ter	minal	TEXAS		Remote Ter	minal	OHIO		
Number	of terminals	2		Line Voltage	2	765 kV	Seq.#	2
Check Fil	e	TEXAS OHIO	765kV SettingsChee	ck 1 0904202	3.xlsm			
Туре	Relay ID		Elements			Check	Results	
21P	TEXAS_OHI	O_D60_PDS	Z1P;Z3P;Z2P	2		(ОК	
21P	TEXAS_OHI	O_421_PDS	Z1P;Z4P;Z2P	b		(ОК	
21G	TEXAS_OHI	O_D60_GDS Z1G;Z3G OK						
21G	TEXAS_OHI	D_421_GDS Z1G;Z4G			ОК			
51G	TEXAS_OHI	IO_D60_GOC 51G OK						
51G TEXAS_OHIO_421_GOC 51G					(ОК		
Coordina	tion With Dow	Instream Relays	For Adjacent Line Er	nd 1LG Fault		(ОК	
Coordina	tion With Upst	tream Relays Fo	r Adjacent Line End 1	LLG Fault	ОК			
Coordina	tion With Dow	nstream Relays	For Adjacent Line Er	nd 3LG Fault	ОК			
Coordina	tion With Upst	tream Relays Fo	r Adjacent Line End 3	BLG Fault		(ОК	
Relay Op	erations Check	Using Step Eve	ents			Issue	Found	

ARS - Check Line Protection

- Individual check sheet is created for each terminal
- Provides details for each check

4.2 Phase Distance Zone 2									
From Opeliner, the main settings of Phase Distance Zone 2 (720) relays are:								21P	Plots
Polay ID		Roach	Drimany O	% 711	Dolay	Leun	Chock	-	
		2 22 O		1500/	Delay	1_sup	CHECK		
OHIO_TEXAS_421_PDS(24P)	400/6250	2.29 Ω	35.78 Ω	150%	0.333 \$	-	EKK	Notes on C	heck Result
OHIO_TEXAS_D60_PDS(Z3P)	400 / 6250	1.92 Ω	30.00 Ω	126%	0.333 s	0.50 A	OK	Notes on e	neek kesut
Downstream adjacent Relay ID	Op Time (s)		Local Relay ID		Op Time (s)	Z2P/Zapp	Check		
TEXAS_KENTUCKY_D60_PDS	0.333	OHIO_TEXA	AS_421_PDS		9999.000	50%	OK	Plot	
TEXAS_KENTUCKY_D60_PDS	0.333	OHIO_TEXA	AS_D60_PDS		9999.000	42%	OK	Plot	
TEXAS_KENTUCKY_421_PDS	0.333	OHIO_TEXA	AS_421_PDS		9999.000	50%	OK	Plot	
TEXAS_KENTUCKY_421_PDS	0.333	OHIO_TEXA	AS_D60_PDS		9999.000	42%	OK	Plot	
TEXAS_VIRGINIA_D60_PDS	0.333	OHIO_TEXA	AS_421_PDS		9999.000	31%	OK	<u>Plot</u>	
TEXAS_VIRGINIA_D60_PDS	0.333	OHIO_TEXA	AS_D60_PDS		9999.000	26%	OK	Plot	
TEXAS_VIRGINIA_421_PDS	0.333	OHIO_TEXA	AS_421_PDS		9999.000	31%	OK	Plot	
TEXAS_VIRGINIA_421_PDS	0.333	OHIO_TEXA	AS_D60_PDS		9999.000	26%	OK	Plot	
TEXAS_OKLAHOMA_D60_PDS	0.333	OHIO_TEXA	AS_421_PDS		0.670	92%	ERR	<u>Plot</u>	
TEXAS_OKLAHOMA_D60_PDS	0.333	OHIO_TEXA	AS_D60_PDS		0.670	77%	OK	<u>Plot</u>	
TEXAS_OKLAHOMA_421_PDS	0.333	OHIO_TEXA	AS_421_PDS		0.670	92%	ERR	<u>Plot</u>	
TEXAS_OKLAHOMA_421_PDS	0.333	OHIO_TEXA	AS_D60_PDS		0.670	77%	OK	Plot	

Remote Application of Relay Settings

PRC-027 required a new approach to implement settings

- Procedure developed for remote application of settings
- Criteria created for settings than can be applied remotely
- Setting changes excluded are:
 - Critical interconnects; CT ratio, I/O, firmware, trip logic
- Procedure piloted on AEP's initial 765kV area study
- 55 settings were applied remotely without incident

Study Process



345kV Studies

Lines	Terminals	Interconnections
336	506	177

- 16 groups studied late 2021 thru 2022
- 399 revised settings, 107 did not need reset
- Lessons Learned from 345kV Studies
- Interconnects defer if possible
- Complete PRC-027 Settings as part of capital projects

161kV and 138kV Studies

Lines	Terminals	Interconnections
1642	3020	366

- 70 groups, planned to complete 1/3 each year 2023-2025 (15 months margin)
- Estimated 45% of these will be or have been completed on capital (20% for 345kV)

Line Terminals	PRC-027 Specific	Capital Project	% O&M	
Studied (7/31/2024)	Setting		Expense	
967	512	455	53	

- Plan revised based on 2023 progress
- Completion Q2 2026 (9 months margin)

Remote Application of Relay Settings

- 31% of settings meeting criteria have been applied remotely
- Percentage should increase as personnel become comfortable with process
- Estimated time saving 4 hours per relay, 8 hours per terminal

Settings Meet Criteria for Remote Application?	Settings Applied at Station	Settings Applied Remotely
No – 454	454	
Yes – 512	353	159
Total – 966	807	159

Challenges

- System is continually changing
 - List of line terminals must be kept up to date
 - Short circuit models must be kept up to date
 - Budgets and projects schedules constantly changing
- Process must be reviewed and adjusted



Conclusion

- The initial round of studies is costly and time consuming
- End-result:
 - Assures all line protection is coordinated
 - All line protection updated to latest guidance
 - Settings more resilient as system change
 - Misoperation caused by relay settings significantly reduced
- Process ensures system will remain coordinated in the future
- Future studies will be performed more frequently then 6 years
- Automated tools are essential to using Option 1!
Questions?







Test & Technical Services Back-to-Back Relay Testing: Step-by-Step Commissioning Process

Presented by:

Cleofas Rojas, P.E. Sanjay Mehta, P.E.

October 2, 2024



Introduction

This presentation highlights LADWP's typical commissioning methods to ensure the successful and smooth installation of protection systems on the Bulk Electric System (BES).

- Protection system design review process and coordination (PRC-027), installation coordination and commissioning tests.
- Back-to-Back relay testing.
- End-to-End relay testing.





LADWP PRC-027 Program Overview

- Review preliminary and final electrical design prints, relay schematic and wiring prints, etc.
- Exchange short-circuit model data, i.e., impedance parameters & fault data.
- Develop, exchange and review preliminary and final relay settings.
- Perform protection coordination study and notify entity about results.





LADWP PRC-027 Program Overview Cont'd...

- Coordinate the back-to-back relay test plan and schedule.
- Arrange for the relay panels to be shipped to the lab facility.
- Communicate and verify test equipment model & firmware to be used for back-to-back testing.
- Agree on the relay test routines to be used for testing.



LA DWP

Construction & Commissioning Groups

- Electrical Construction (EC)-Installs relay panels, secondary wiring and other electrical equipment as per the construction work package (CWP).
- Station Test (ST) Group– Leads the commissioning activities and provide support to back-to-back and end-to-end testing.
- System Protection & Controls

 (SP&C) Group– Leads back-to-back
 testing, end-to-end testing,
 SCADA/RTU commissioning and
 PRC-005 baseline testing.





Prepare Relay Panel for Back-to-Back Testing

- Relay panel point-to-point wiring verification "ring-out", "buzzing" (CWP wiring prints).
- Verify relay panel labels match design.
- Relay cut-off blades, test switches and lock out relays function properly.
- Any wiring issues found need to be resolved.
- Power up the relays.
- Relay firmware version verification & provide info & default settings file to settings engineer.
- Verify test equipment model and firmware version compatibility.
- Verify final relay settings match the approved relay settings write up and upload.





Prepare Relay Panel for Testing – Cont'd...

- Set-up antennas to time synchronize the test equipment (Fault Simulator) to the GPS clock.
- Relay metering test verification i.e., single phase and three phase voltage and current injection to verify CT & PT ratios and test the set-up connections.
- Perform "stand alone panel" schematic functional test down to the termination blocks and perform "Trip Test" using "dummy" breaker(s).

COMPONENT	MAGNITUDE / ANGLE	COLOR	ASSIGN TO	GRAPH	MAP PH		
SRC 1 (SRC 1)-Phasor la	199.631 A -179.0 deg		Phasor 5at 1	1	Salect Ph	dob P	
SRC 1 (SRC 1)-Phaser Ib	199.356 A - 299.0 deg	•	Phasor Set 1	2	Select Ph		
SRC 1 (SRC 1)-Phasor Ic	199.715 A -59.3 deg	-	Phasor Set 1	3	Select Ph		
SRC 1 (SRC 1)-Phasor Vag	132.962 kV 0.0 deg	-	Phasor Set 2	4	Select Ph		and a second
SRC 1 (SRC 1)-Phasor Vbg	132.866 kV -120.0 deg	•	Phasor Set 2	5	Select Ph		
SRC 1 (SRC 1)-Phasor Vcg	132.912 KV -240.1 deg	+	Phasor Set 2	6	Select Ph		
None							
None				8			
None		-				Phase C Real Power	-28.525 M
None		-				Three Phase Reactive Power	1.233 Myp
rephil				\sum	-	JAA BATTERY +	



Back-to-Back Test Activities

- Run fault simulation routines to verify protection schemes and logic function as designed, i.e., trips for all internal faults and time delay backups, and restraints for external faults.
- Resolve any settings test discrepancies with protection engineer(s).
- Secure the relay settings by setting relay passwords.
- Generate and review back-to-back relay test reports
- As-Left relay setting files are exchanged, reviewed, and approved
- Ship relay panels to the field for commissioning.

S2_231 Test Settings Characteristic Connection Table No Name TEST RESULT METER TEST NO FAULT @ HAS LINE FAULT-50% @ HAS A-8-C LINE FAULT-50% @ HAS B-C LINE FAULT-50% @ HAS B-C LINE FAULT-50% @ HAS B-C LINE FAULT-10% @ HAS B-C LINE FAULT-90% @ HAS B-C	Macro NOTEBK SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL	Comments MANUAL ENTRY OF TE TEST 1- METER TEST - TEST 2-Z1P 3-PH PICK TEST 3-Z1P PH-PH PIC TEST 4-Z1G SLG PICK TEST 5-HY8RPOTT PI TEST 6-HY8RPOTT SI TEST 7-HY8RPOTT PI	ST RESULTS NO 21 OP CKUP CKUP UP H-PH PICKUP LG PICKUP
Name TEST RESULT METER TEST NO FAULT @ HAS LINE FAULT-50% @ HAS A-8-C LINE FAULT-50% @ HAS B-C LINE FAULT-10% @ HAS A-G LINE FAULT-10% @ HAS A-G LINE FAULT-90% @ HAS A-G LINE FAULT-90% @ HAS A-G FAULT-90% @ HAS A-G FAULT-0N REB RUS R.C Web Relay FAULT-00 FAULT-00 FAULT-	Macro NDTEBK SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL	MANUAL ENTRY OF TE TEST 1- METER TEST - TEST 2 - Z1P 3-PH PICK TEST 3 - Z1P PH-PH PIC TEST 4 - Z1G SLG PICK TEST 5 - HYBRPOTT PI TEST 6 - HYBRPOTT SI TEST 7 - HYBRPOTT PI	ST RESULTS NO 21 OP KUP CKUP UP H-PH PICKUP LG PICKUP
METER TEST NO FAULT @ HAS METER TEST NO FAULT @ HAS LINE FAULT-50% @ HAS A-6 LINE FAULT-50% @ HAS B-C LINE FAULT-10% @ HAS B-C LINE FAULT-10% @ HAS B-C LINE FAULT-90% @ HAS B-C LINE FAULT-90% @ HAS B-C LINE FAULT-90% @ HAS A-6 FAULT-90% @ HAS A-6	NUTEBK SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL	MANUAL ENTRY OF TE TEST 1-METER TEST - TEST 2-Z1P 3-PH PICK TEST 3-Z1P PH-PH PIC TEST 4-Z1G SLG PICK TEST 5-HY8RPOTT PI TEST 5-HY8RPOTT SI TEST 7-HY8RPOTT PI	NO 21 OP (UP CKUP UP H-PH PICKUP LG PICKUP
	SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL	TEST 1-METER TEST TEST 2-Z1P 3-PH PICK TEST 3-Z1P PH-PH PI TEST 4-Z1G SLG PICK TEST 5-HYBRPOTT PI TEST 6-HYBRPOTT SI TEST 7-HYBRPOTT PI	NO 21 OP KUP CKUP IVP H-PH PICKUP LG PICKUP
LINE FAULT-50% @ HAS A-8-C LINE FAULT-50% @ HAS B-C LINE FAULT-50% @ HAS B-C LINE FAULT-10% @ HAS B-C LINE FAULT-10% @ HAS B-C LINE FAULT-90% @ HAS B-C LINE FAULT-90% @ HAS B-C FAULT-90% @ HAS A-G FAULT-90% @ HAS A-G	SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL	TEST 2 · Z1P 3·PH PIC TEST 3 · Z1P PH·PH PI TEST 4 · Z1G SLG PICK TEST 5 · HY8RPOTT PI TEST 6 · HY8RPOTT SI TEST 7 · HY8RPOTT PI	(UP CKUP IVP H-PH PICKUP LG PICKUP
LINE FAULT-50% @ HAS B-C LINE FAULT-50% @ HAS A-G LINE FAULT-10% @ HAS B-C LINE FAULT-10% @ HAS A-G LINE FAULT-90% @ HAS B-C LINE FAULT-90% @ HAS A-G FAULT-90% @ HAS A-G FAULT-0N REP RUS R.C FAULT-0N REP RUS R.C FAULT-0N REP RUS R.C FAULT-00 REP RUS R.C	SSIMUL SSIMUL SSIMUL SSIMUL SSIMUL	TEST 3 · Z1P PH·PH PI TEST 4 · Z1G SLG PICK TEST 5 · HYBRPOTT PI TEST 6 · HYBRPOTT SI TEST 7 · HYBRPOTT PI	CKUP JUP H-PH PICKUP LG PICKUP
LINE FAULT-50% @ HAS A-G LINE FAULT-10% @ HAS B-C LINE FAULT-10% @ HAS A-G LINE FAULT-90% @ HAS B-C LINE FAULT-90% @ HAS A-G FAULT-90% @ HAS A-G FAULT-90% @ HAS A-G FAULT-90% @ HAS A-G FAULT-90% @ HAS A-G	SSIMUL SSIMUL SSIMUL SSIMUL	TEST 4 · Z1G SLG PICK TEST 5 · HYBRPOTT PI TEST 6 · HYBRPOTT SI TEST 7 · HYBRPOTT PI	up H-PH Pickup Lg Pickup
LINE FAULT-10% @ HAS B-C LINE FAULT-10% @ HAS A-G LINE FAULT-90% @ HAS B-C LINE FAULT-90% @ HAS A-G FAULT-90% @ HAS A-G FAULT-0N REB BLIS B.C FAULT-0N REB BLIS B.C	SSIMUL SSIMUL SSIMUL	TEST 5 · HYBRPOTT P TEST 6 · HYBRPOTT SI TEST 7 · HYBRPOTT P	H-PH PICKUP LG PICKUP
LINE FAULT-10% @ HAS A-G LINE FAULT-90% @ HAS B-C LINE FAULT-90% @ HAS A-G FAULT ON REP RUS R.C F/ Web Relay	SSIMUL SSIMUL	TEST 6 · HYBRPOTT SI TEST 7 · HYBRPOTT PI	LG PICKUP
LINE FAULT-90% @ HAS B-C LINE FAULT-90% @ HAS A-G FAULT-90% @ HAS	SSIMUL	TEST 7 - HYBRPOTT P	U DU DICKUD
LINE FAULT-90% @ HAS A-G FAULT ON RER RUS R.C F/ Web Relay	COMU		H-FH FILKUF
FAILT ON BREALISE.C F/ Web Relay	SSIMUL	TEST 8 - HYBRPOTT SI	LG PICKUP
C F. Web Relay	ILIMI22	TEST 9 - REM RUS FAI	II T - NO OP
De			
	Web Rel	lay	
Гр Туре	(Disabled 🗸	
IP Address	[
User Name		*****	
Password	l		
Web	Relay Actio	on Setting	
Action ID Web Relay	Action	Web Relay Key	Web Relay Extension
Action ID 01			
Action ID 02			



Prepare Equipment for End-to-End Testing

- Communicate and coordinate with Electrical Substation Construction (EC) personnel for the demolition of existing equipment and wiring, as applicable.
- Communicate and coordinate with EC personnel for the installation and testing of new power system equipment (i.e., circuit breakers (CBs), transformers, voltage transformers (VTs), secondary wiring, etc.)
- Coordinate with EC for the installation of the relay panels
- Verify field point-to-point wiring "ring-out",
 "buzzing" (i.e. CTs, VTs, CBs, etc.).





Prepare Equipment for End-to-End Testing Cont'd...

- Verify CT taps ratio & polarity, i.e. non-polarity common or polarity common?
- Verify CT circuit grounding & wire insulation, check for "shorts and ground".
- Verify field-to-panel terminal blocks wiring, all links open, "ring-out" and conductor insulation test "Megger", i.e., 500 V - 1000 V dc.
- Verify field wiring diagram matches the relay schematic diagram (URELs), "field wiring vs schematic".
- Secondary current and voltage injection from furthest point i.e., CB terminal panel to verify wiring and metering values in the relay.





Prepare Equipment for End-to-End Testing Cont'd...

- Verify communication channels are working (i.e. Fiber Optic, Microwave, etc.), i.e. DIFF protection, POTT, etc.
- Perform schematic wiring functional test (i.e. DC control circuits, Trip CBs "Trip Test", etc.).
- Verify relay display and LEDs match the programmed settings.
- Perform Pre-Site Acceptance Testing (Pre-SAT) of RTU/SCADA mapped points to HMI (Human Machine Interface computer). (Local test first)
- Perform Site Acceptance Testing (SAT) of RTU/SCADA mapped points to the Energy Control Center (ECC).





End-to-End Testing

- Prepare the PRC-005 Baseline commissioning test document to record the test data
- Verify relay settings: As-Found vs Final Approved Settings File.
- Verify relay communication is normal.
- Agree with the remote end team at what time to start with the first test and so on, "going at...hh:mm:ss"
- Run fault simulation routines to verify protection schemes and logic function as programmed & designed, i.e., trips for all internal faults and time delay backups, and restraints for external faults.

PRC-005 TESTING

R3. Each Transmission Owner, Generator Owner, and Distribution Provider that utilizes time-based maintenance program(s) shall maintain its Protection System, Automatic Reclosing, and Sudden Pressure Relaying Components that are included within the time-based maintenance program in accordance with the minimum maintenance activities and maximum maintenance intervals prescribed within Tables 1-1 through 1-5, Table 2, Table 3, Table 4-1 through 4-3, and Table 5.

	TEST REPORT	DATE COMPLETED	INITIAL
1	PROTECTIVE RELAYS Table 1-1	04-09-2019	RU
2	COMMUNICATION SYSTEMS Table_1-2	04-09-2019	RU
3	VOLTAGE AND CURRENT SENSING DEVICES Table 1-3 (PENDING 87CS & TRS Block Contacts, CT Clear GND)	04-09-2019	RU
4	CONTROL CIRCUITRY Table 1-5	04-09-2019	RU
5	ALARMING PATHS AND MONITORING (PENDING) Table 2		
6	SUDDEN PRESSURE RELAY (NOT AVAILABLE) Table 5	N/A	N/A
7	DISTRIBUTED UFLS & UVLS SYS (NOT AVAILABLE) Table 3	N/A	N/A
8	BREAKER FAILURE (PENDING)		

PRC-005-6 Table 1-1 Protective Relay & Table 2 Alarming Paths

PROTECTIVE RELAY – SEL411L and GE-L90

 For non-microprocessor relays, verify settings through testing (minimum pickup) (N/A)

Relay	Relay Setting	Test Value	Relay Trip
SEL-411L	87LPP Diff	9.9A	Yes
SEL-411L	87LQP Diff	6.0A	Yes
SEL-411L	Phase TOC	15.4A, 125-cyc	Yes
SEL-411L	Neutral TOC	6.1A, 69-cyc	Yes
SEL-411L	SOTF	9.9A, 42V	Yes
GE-L90	Phase Diff	9.9A	Yes
GE-L90	GND Diff	6.0A	Yes
GE-L90	Phase TOC	15.4A, 125-cyc	Yes
GE-L90	Neutral TOC	6.1A, 69-cyc	Yes
GE-L90	SOTF	9.9A, 42V	Yes

Attach screen shot of relay metering test compared to Doble F8000 (attached at end of report)

Verify relay inputs and outputs that are part of trip testing ONLY – LIST I/O (PENDING 87CS and TRS Block Contacts)

87L1 (VAY, VBY, VCY)	A, B, C Voltage Inputs (metering screenshot)
87L1 (IAW, IBW, ICW)	A, B, C Current Inputs (metering screenshot)
87L2 (F5a, F5c, F6a, F6c, F7a, F7c)	A, B, C Voltage Inputs (metering screenshot)
87L2 (F1a, F1b, F2a, F2b, F3a, F3b)	A, B, C Current Inputs (metering screenshot)
87L1 DIFF E51, E52 TC2 (OUT201 & OUT202)	Observed TRIP, INST, 87L LEDs, SER Report
	and CB Open Status LED
87L1 TT E51, E52 TC2 (OUT203 & OUT204)	Observed TRIP, INST, 87L LEDs, SER Report,
	CB Open Status LED
87L2 DIFF E51, E52 TC1 (H1, H2)	Observed 87L TRIP LEDs, SER Report and CB
	Open Status LED



End-to-End Testing Cont'd...

- Resolve any end-to-end test discrepancies with protection engineer(s).
- Generate and review end-to-end relay test reports i.e., sequence of event record for each test.
- Develop PRC-005 Baseline Commissioning Test report for review and filing.

ent List	lests			2012002-0	020170518	
Macro	Eval	Last Tested	Comments	00.0537	ELEMENT HOT LINE	STATE Asserted
SSIMUL	Pass	6/5/2019 9:50:06AM	TEST 1	05.0452	TRIPLED	Asserted
SSIMUL	Pass	6/5/2019 9:54:05AM	TEST 2	05.0452	TRIP OUTPUT	Asserted
SSIMUL	Pass	6/5/2019 9:57:05AM	TEST 3	05.0452	B-Phase Diff.	Asserted
SSIMUL	Pass	6/5/2019 10:02:05AM	TEST 4	05.0452	C-Phase Diff.	Asserted
SSIMUL	Pass	6/5/2019 10:05:05AM	TEST 5	05.0452	Neg. Seq. Diff.	Asserted
SSIMUL	Op	6/5/2019 10:08:06AM	TEST 6	05.0452	F-31 DIFF TRIP	Asserted
SSIMUL	Pass	6/5/2019 10:11:05AM	TEST 7	05.0452	F-32 DIFF TRIP	Asserted
SSIMUL	Pass	6/5/2019 10:16:06AM	TEST 8	05.0452	F-31 BFI	Asserted
SSIMUL	Pass	6/5/2019 10:20:05AM	TEST 9	05.0452	F-32 BFI	Asserted
SSIMUT	Pass	6/5/2019 10:29:06AM	TEST 10	05.0472	DIFF TRIP	Asserted

	TEST REPORT	DATE COMPLETED	INITIAL
1	PROTECTIVE RELAYS (Part of Commissioning) Table 1-1	05-29-2019	SM
2	COMMUNICATION SYSTEMS (Part of Commissioning) Table 1-2	05-29-2019	SM
3	VOLTAGE AND CURRENT SENSING DEVICES Table 1-3 (Part of PRC-005)	05-29-2019	SM
4	CONTROL CIRCUITRY (Part of PRC-005) Table 1-5	06-03-2019	KV, BP
5	ALARMING PATHS AND MONITORING (Part of Commissioning) Table 2	06-03-2019	KV BP
6	SUDDEN PRESSURE RELAY (Not Applicable) Table 5	N/A	N/A
7	DISTRIBUTED UFLS & UVLS SYS (Not Applicable) Table 3	N/A	N/A
8	BREAKER FAILURE (Existing BF Relays-Verified only the BFIs to Breaker Failure Relays from Line Protection Relays.) (Part of PRC-005)	06-03-2019	SM, KV, BP



Declarations (Ok for Service) To ECC

- Ensures the NERC critical infrastructure protection (CIP) requirements for new cyber asset compliance documentation is completed.
- Upon successful completion of all tests, communicate with Electrical Construction to declare equipment, i.e. CBs, etc. "OK for Service" to the Energy Control Center (ECC) Load Dispatcher (LD)
- Commissioning Team declares protective relays "OK for Service" to ECC LD.





In-Service Test "Load Checks"

- Line charging current & voltage reads
- Verify phasing, rotation, load checks and meters are correct.
- Exchange load check data with the remote commissioning team
- Prepare & send load data report to setting engineers.
- File As-Built drawings and supporting documents.





Commissioning Story 1

- Inter-Tie 230kV Transmission line
- Dual Protection SEL-311C(Dev.21) & GE-L90(Dev.87L)
- Communication Channels: Digital MW & Fiber Optics
- Followed above commissioning methods & steps
- Results: No commissioning discrepancy found
- Transmission line commissioned
 successfully





Commissioning Story 2

- Inter-Tie 230kV short transmission line (approx. 6 miles)
- Dual Differential Protection SEL-411L(Dev.87L1+21 BU) & GE L90(Dev.87L2 + 21 BU)
- Communication Channels: Digital MW & Fiber Optics
- Followed above commissioning methods & steps
- Results: Commissioning discrepancy found during end-to-end testing





Commissioning Story 2 Cont'd...

- Zone 2 BU test FAILED during end-to-end testing.
- However, Zone 2 BU test PASSED during back-to-back testing.
- Findings: Settings changed at remote terminal prior to the start of end-to-end testing.
- Mitigation: Meeting with relay setting engineers to discuss the findings and a resolution was agreed upon.
- All end-to-end test passed after the resolution was implemented.
- Lesson Learned: Prior to the start of the end-to-end testing exchange final relay settings once again.





Conclusion

- In conclusion, LADWP approach to commissioning of the protection systems installation ensures new equipment to the power system is of the highest quality and meets FERC/NERC regulatory compliance.
- As can be seen in this presentation, the commissioning methods involve several steps, such as, preliminary design review, preliminary and final settings review, coordination of test plans, back-to-back test, end-to-end test, etc.
- The two commissioning stories presented here highlight the successes and lessons learned from each project.
- Thank you for the invitation to participate in this effort to promote best commissioning practices.





End of Presentation

Thank You!

Presented by: Los Angeles Department of Water and Power

Name:	Cleofas Rojas, P.E.
E-Mail:	<u>Cleo.Rojas@ladwp.com</u>
Phone:	(213) 367 - 7291

Name: Sanjay Mehta, P.E. E-Mail: <u>Sanjay.Mehta@ladwp.com</u> Phone: (213) 367 – 7294



UFLS PROGRAM CHALLENGES AND SOLUTIONS IN LOW INERTIA SYSTEMS

Kevin W. Jones, Consulting Engineer, System Protection Engineering Presented to NERC Mis-Op Reduction Workshop

October 2, 2024

OUTLINE OF PRESENTATION

- UFLS Challenges in Predominately Renewable GEN World Recap
- Need to Rethink Underfrequency Mitigation Strategies
- Solution #1: Replace Inertia with Synchronous Condensers
- Solution #2: Arrest Frequency Pre-UFLS with BESS
- Solution #3: Implement Patent Pending RoCoF UFLS Program
- Conclusions



What is Automatic UFLS? What is its Purpose?

Automatic UFLS is a *last-ditch*, first line of defense to prevent blackouts and generator steam turbine damage

Prevent Generator Turbine Damage

Frequency at	Minimum Time to
Full Load (Hz)	Damage (Min.)
59.4	
58.8	90
58.2	10
57.6	1

Time is CUMULATIVE over the life of the machine!!

Blackout Avoidance

	PRC-024-2 Allowable Low Frequency Tripping Time Delay (Sec.)				
	Eastern	Western	ERCOT		
Frequency (Hz)	Interconnection *	Interconnection	Interconnection		
> 59.5 Hz	Continuous	Continuous	Continuous		
≤ 59.5 Hz	1792	Continuous	Continuous		
> 59.4 Hz	1201	Continuous	Continuous		
≤ 59.4 Hz	1201	180	540		
≤ 59.0 Hz	242	180	540		
≤ 58.4 Hz	22	30	30		
≤ 58.0 Hz	4.44	30	2		
≤ 57.8 Hz	0	7.5	2		
≤ 57.5 Hz	0	7.5	0		
≤ 57.3 Hz	0	0.75	0		
≤ 57.0 Hz	0	0	0		

* EI tripping times follow the formula 10^(1.7373*f - 100.116) for frequency values >

57.8 Hz and \leq 59.5 Hz. This formula was applied to fill in El values in table at frequency shown.

Brief History of UFLS

- 1965 Northeast Blackout
- 2003 Northeast Blackout
- **2011 Arizona-Southern California Blackout**
- 2016 South Australia Blackout

Blackout	Load Lost (MW)	People Affected (Millions)	Interesting Facts
1965 NE	20,000	30	Min. UFLS; NERC ¹ formed 3 years later
2003 NE	62,000	50	26,000 MW UFLS; NERC ² Standards
2011 Arizona-SoCo	7,835	2.7	ALL UFLS tripped; –3 Hz/s ROCOF
2016 S. Australia	1,826	0.85	ALL UFLS tripped; -6 Hz/s ROCOF

¹ National Electric Reliability Council

² North American Electric Reliability Corporation



UFLS Regional Practices

SPP/Eastern Interconnect (EI) *

		Minimum Accumulated Load	Maximum Accumulated Load
		Relief as Percentage of	Relief as Percentage of
UFLS Step	Frequency (Hz)	Forecasted Peak Load (%)	Forecasted Peak Load (%)
1	59.3	10	25
2	59.0	20	35
3	58.7	30	45

ERCOT

2	58.9	An additional 10% of the ERCOT System Load (Total 15%)
3	58.5	An additional 10% of the ERCOT System Load (Total 25%)

WECC

Load Relief 5% of the ERCOT System Load (Total 5%)

* Table is SPP specific, but Eastern Interconnect general with regional variations	<u>IIE00</u>		
Table is SFF specific, but Eastern interconnect general with regional variations.	Percent of	Frequency	
Load Sheddin	g Balancing Authority	Set-Point	Tripping
59.3 Hz - 59.0 Hz $0.3 Hz$ Hz Block	Area Load Dropped	(Hz)	Time
EI MAX Design RoCoF = $\frac{1}{1}$	5.3	59.1	no more than 14 cycles
(6 cyc. ID + 4 cyc. CB) / 0.1667 sec. sec. 2	5.9	58.9	no more than 14 cycles
$/60\frac{cyc.}{3}$	6.5	58.7	no more than 14 cycles
4 <i>sec.</i> 4	6.7	58.5	no more than 14 cycles
$5 - 2 H_{-} = 5 - 0 H_{-} = - 5 - 5 - 5 - 5 - 5 - 5 - 5 - 5 - 5 -$	6.7	58.3	no more than 14 cycles
$ERCOT MAX Design RoCoF = \frac{59.3 Hz}{(C max TD + 4 max CD)} = \frac{0.4 Hz}{0.4 CT} = 2.4 \frac{Hz}{0.4 CT}$	matic load shedding to	correct under	frequency stalling
(6 CyC. ID + 4 CyC. CB) / 0.166/ sec. sec.	2.3	59.3	15 sec
$/60\frac{cyc}{c}$	1.7	59.5	30 sec
, sec.	2.0	59.5	1 min
WECC MAX Design RoCoF = $\frac{59.1 Hz - 58.9 Hz}{(6 cvc, TD + 4 cvc, CB)} = \frac{0.2 Hz}{0.1667 sec} = 1.2 \frac{Hz}{sec}$ Load automatic	ally restored from 59.1 1.1	Hz block to c 60.5	orrect frequency overshoot 30 sec
$(\circ \circ) \circ $	1.7	60.7	5 sec
$760\frac{5}{sec.}$	2.3	60.9	0.25 sec

UFLS Level Frequency (Hz)

1

59.3

© 2022 Xcel Energy

Need to Rethink Existing UFLS Program IEEE Power & Energy Society

- High penetrations of renewable resources are depleting system inertia
- Lower system inertia results in higher Rate-of-Changeof-Frequency (RoCoF)



PREPARED BY THE IEEE/NERC Task Force on Short-Circuit and System Performance Impact of Inverter Based Generation

3.2.9 UFLS Frequency Time Delay Settings

Under Frequency Load Shed (UFLS) is necessary to keep load and generation in an electrical island balanced and as close to the nominal system frequency (60 Hz for North America) as possible after the loss of significant amounts of generation or after the loss of significant power imports following a system separation event. The rapid influx of IBR has both offset and replaced conventional fossil generation resources. Because of this, lower levels of system inertia are available at any given time, which results in more rapid frequency decay following a loss of generation or power imports.

K. Jones, P. Pourbeik, Et. Al., "Impact of Inverter Based Generation on Bulk Power System Dynamics and Short Circuit Performance", July, 2018. Available: Impact of Inverter Based Generation on Bulk Power System Dynamics and Short-Circuit Performance (TR68) (ieee-pes.org)

TECHNICAL REPORT PES-TR68

July 2018

IFEE

Need to Rethink Existing UFLS Program

- Significant amounts of UFLS with extended time delays
- Higher ROCOF caused by increasing penetrations of renewable resources



Need to Rethink Existing UFLS Program

- Significant amounts of UFLS with extended time delays
- Higher ROCOF caused by increasing penetrations of renewable resources



- Electromagnetic Transient Software (EMTS) program model is used to test for UFLS relay mis-trip under transient or lost source conditions
 - Two commercially available EMTS programs were used and results were compared



Four 3-MVA induction motors

RLC loads (R=1.74 MW; L=C=1 MVAR)

■ Comparison of Time Delays – 6 cyc. vs. 30 cyc. (UV block = 67%):

Test#	RLC load connected	# of Motors connected	UFLS Levels 1, 2, 3 6 cycle delay	UFLS Levels 1, 2, 3 30 cycle delay
1	Resistor	4	Trip	No Op
2	Resistor	3	Trip	No Op
3	Resistor	2	Trip	No Op
4	Resistor	1	Trip	No Op
5	Capacitor	4	Trip	No Op
6	Capacitor	3	Trip	No Op
7	Capacitor	2	Trip	No Op
8	Capacitor	1	Trip	Trip
9	Inductor	4	Trip	No Op
10	Inductor	3	Trip	No Op
11	Inductor	2	Trip	No Op
12	Inductor	1	Trip	No Op
13	None	4	Trip	No Op
14	None	3	Trip	No Op
15	None	2	Trip	No Op
16	None	1	Trip	No Op

Test system details:



12

ALL Test Cases:



UFLS Solution for Motor Spin-Down

Use Supervision of Underfrequency Elements from IEEE C37.117

C37.117-2007 - IEEE Guide for the Application of Protective Relays Used for Abnormal Frequency Load Shedding and Restoration



UFLS Solution for Motor Spin-Down

ROCOF Supervision:



ROCOF supervision = $\frac{81D4P - 81D1P}{81D4D / 60} = \frac{59.7 - 59.3 \text{ Hz}}{2 / 60 \text{ s}} = 12 \text{ Hz/s}$

- The worst-case (lowest) ROCOF for motor bus de-energization was 34 Hz/s
- Frequency decay experienced in South Australia during the 2016 blackout was 6 Hz/s
UFLS Solution for Motor Spin-Down

Summary of Supervision Methods:

Test	RLC Load Connection	Number of Motors Connected	UFLS With Undervoltage Block = 67%	UFLS With Undervoltage Block = 80%	UFLS With Current Supervision	UFLS With ROCOF Supervision
1	Resistor	4	Trip	No Op	No Op	No Op
2	Resistor	3	Trip	No Op	No Op	No Op
3	Resistor	2	Trip	No Op	No Op	No Op
4	Resistor	1	Trip	No Op	No Op	No Op
5	Capacitor	4	Trip	No Op	No Op	No Op
6	Capacitor	3	Trip	Trip	No Op	No Op
7	Capacitor	2	Trip Trip		Trip	No Op
8	Capacitor	1	Trip	Trip	Trip	No Op
9	Inductor	4	Trip	No Op	No Op	No Op
10	Inductor	3	Trip	No Op	No Op	No Op
11	Inductor	2	Trip	No Op	No Op	No Op
12	Inductor	1	Trip	No Op	No Op	No Op
13	None	4	Trip	No Op	No Op	No Op
14	None	3	Trip	No Op	No Op	No Op
15	None	2	Trip	Trip	No Op	No Op
16	None	1	Trip	Trip	Trip	No Op

UFLS Solution Test for Motor Spin-Down – ALL delays 6-cyc.



50% Wind Generation Test



25% Wind Generation Test



66% Wind Generation Test



UFLS Solution Test for Motor Spin-Down Conclusions

- Verified that the 6-cycle UFLS time delay is too short to avoid UFLS relay mis-trips when source transmission line outages feeders with significant motor load
- Verified that the 30-cycle UFLS time delay prevents most UFLS misoperations due to motor spin-down
- Proved that the ROCOF supervisory scheme is the most secure of the three supervisory methods tested in preventing UFLS misoperations due to motor spindown
- Verified that implementation of ROCOF supervision of UFLS relays allowing use of 6cycle time delays results in higher frequency nadir, faster recovery to nominal frequency, and less load shed in some cases





UFLS Challenges Due to Excess Load Shedding

□ CAPE TS-Link example for trip of 490 MW Maple Unit 2

□ All three levels of UFLS operate tripping 600 MW of load



UFLS Challenges Due to Excess Load Shedding

- 10/13 (77%) cases studied would result in potential uncontrolled generator tripping due to over/under frequency per NERC PRC-024 Standard
- 5/13 (38%) cases studied would lead to uncontrolled, instantaneous tripping of generation, leading to a blackout

Eastern Interconnection

High Frequency Duration											
Frequency (Hz)	Time (Sec)										
≥61.8	Instantaneous trip										
≥60.5	10 ^(90.935-1.45713*f)										
<60.5	Continuous operation										
Low Frequ	ency Duration										
Low Freque	ency Duration Time (sec)										
Low Freque Frequency (Hz) ≤57.8	ency Duration Time (sec) Instantaneous trip										
Low Freque Frequency (Hz) ≤57.8 ≤59.5	ency Duration Time (sec) Instantaneous trip 10 ^(1.7373*f-100.116)										

			Existing	UFLS		
Generation	RoCoF	Total Load	Excess Amount of	Frequency	Overshoot	Final
Tripped (MW's)	(Hz/Sec.)	Shed (MW's)	Load Shed (MW's)	Nadir (Hz)	Freq. (Hz)	Freq. (Hz)
95	-0.54	200	105	59.23	61.23	60.92
140	-1.01	200	60	59.14	60.84	60.60
190 -1.24		200	10	59.10	60.21	60.13
235	-1.71	400	165	58.96	62.15	61.54
330	-2.53	400	70	58.71	61.74	61.18
375	-2.23	400	25	58.79	60.33	60.23
435	-3.35	600	165	58.46	64.04	62.52
490	-4.17	600	110	58.31	61.47	61.44
540	-4.54	600	60	58.17	60.86	60.85
600	-3.58	600	0	58.30	60.04	59.99
640	-5.44	600	-40	57.79	N/A	57.79
700	-4.05	600	-100	56.95	N/A	56.95
750	-4.27	600	-150	54.93	N/A	54.93
		TOTAL	770			

77.00

Ave. Difference

Solution #1: Replace Inertia with Synchronous Condensers

26 Maple_230_SC

13.2 k

1.05000 pu @-7.45 de

0.00 3.40

-3.40

0.00

												2.000 MW	Syste	m			23 Spruce_WTG
			ALL Synchro				66% Wind					_,	•) • ! •			©	-25.00
Generator	Nameplate	Generator Inertia	H@100 MVA	Generator	Nameplate	Generator Inertia	H@100 MVA					15 Elm	28 Elm - 23	L SC			-3.60 -3.60
Birch 111	150	6.22	933	Birch U1	150	6.22	9 33					230.0 kV	20 EIII_23	/		-	-25.0025.00
Oak U1	100	5.48	5.48	Oak U1	100	5.48	5.48				24 Elm_WTG 0.7 kV	0.02		0.00		6	-3.60 -3.60
Pine U1	300	3.33	9,99	Cherry WTG	600	0	0	29 Fir	230 SC	12 Fir	-75.00 -75.00	-29.33	30.00 1.04839 pu @-	-30.00 0.50 deg		~	-25.00 -25.00
Maple U1	100	5.48	5.48	Maple WTG	100	0	0	0.00	2 kV	230.0 kV	-10.00		premier -0.00	1-0.00		0	-3.60 -3.60
Maple U2	500	3.236	16.18	Maple U2	500	3.236	16.18	G-15.08		-14.89	-75.00 375.00	0.00 V	27 So	ruc 230 SC	16 Spruce	~	-25.00 -100.00
Elm	1000	3.959	39.59	Elm	200	3.959	7.918	1.05000 pu	@-5.54 deg	- 14005	9,0.00 = - 50.00 ×	0.00		13.2 kV	230.0 kV	0	-3.60 -3.60
Spruce	1000	3.959	39.59	Elm WTG	500	0	0	Population		50.00	-75.00 -75.00	-30.49	G-341	341	-340 -374.94		-100.00
TOTAL	3150	J	125.64	Spruce	100	3.959	3.959		-	0.00	9 <u>10.00</u>		1.05000	pu @1.23 deg	-19.55		32.40 -3.60 1.05000 pu @3.18 deg
				Spruce WTG	900	0	0			75.00	1.02939 pu @1.58 deg	-23.75	pqua		23.92		pgmis: 0.00 0.00
				TOTAL	3150		42.867		4	0.00	pqmis: 0.00 0.00	-27.54			-3.35		
		Inortio	doplata			Mind			4	75.00					151.02	8 Map	le
		mentia	uepiere	ubyiy		/viriu.				0.00	-245.69	249.20	•	G	-100.00 -23.70	-147.55	kV
	(12	25.64 – 4	2.867)/	125.64	* 100	= 65.88%	6		<u></u>	0.00	83.21	-68.23 161.60 1.02500 pu @-0.46 deg			50.00	21.98	
	(,,	0.0 .		00.007	0			-32.34	47.64	pqmis: -0.00 0.00			1.04734 pu @1.23 deg	-47.38	
			CC0/ Mind							-1.90	-27.45	6 Oak U1 5.0	Dak		pqmis: 0.00 0.00	13.13	0.00
	Namoniato	SYNC CON Inorth	66% Wind							1.03828 pu @-5.5	52 deg	13.2 kV 115.	.0 kV		14 Maple_U2		-32.91
Name	MVA	Constant (H)	Base							pqmis: -0.00 -0	0.00	00 <u>95.00</u> <u>94.81</u>	-21.44		24.0 kV -490.00 490.00	-489.47	~
Birch 115 S	150	6.00	9.00								-119	S4.54 -2.41	1530 0		© <u>-26.31</u> 26.31 26.31 26.31	-2.02	2
Cherry 230 S	C 150	6.00	9.00							11 Pine_TRT	34	9nis: 00-0.00 -11.98	2500		1.05000 pu @-4.61 deg	aple_TRT	_ 0.00 👝 🛛 0.
Elm 230 SC	150	6.00	9.00						10	13.2 kV	7 Pine -12.0	19 12.09 -51.95	03030		perma. and record	13.2 kV	-3.39 3.
Fir 230 SC	150	6.00	9.00						1.04	4004 pu (g-9.95 deg	THE OKV TOOL	9.76 50.00	3.19		1.04730 pu @-10.83 deg	T. I	1.00
Maple 230 S	C 150	6.00	9.00					21 Cherry_Wind 0.7 kV			4-000	0.00 3 Birch U1 1.04059 pu (@-12.67 deg	321	13.2 kV provise 0.00 0.00	000	_ 200.00
Maple 115 S	C 150	6.00	9.00				<u></u>	-100.00			0.00	13.2 kV pqmis: -	0.00 0.00 1 Birch	0.00	-0.00 + 0.0		0.00
Oak 115 SC	150	6.00	9.00					10.00 10.00		10 Pice		G-141.00 141.00	140.52	-4.2	4.29		200.00
Pine 250 50	150	6.00	9.00				<u> </u>	100.00		230.0 kV		3.98 - 3.98	10.77	1,0500	00 pu @-10.97 deg -1.63	116.73 	- 0.00
Spruce 230.5	C 150	6.00	9.00			20 CH	erry_Wind	10.00	1.95	5 152.32	+152.10	pqmis: 0.00 - 0.00		P4	50.00 _ 75.00	2/1	0.00
TOTAL	1500		90.00			3	94.5 kV		0.56	-7.49	19.87		0.27	4 Maple	•_WTG 0.00 0.00	Þ	200.00
					34.5 kV			-30.00	150.00	- ·	35.00		-0.90	0.7	kV 100.00	-32.35	0.00
ا مرا			المار		L	-592.61 599.66		-100.00	0.00	0	0.00 -0.27	00.00	0.27 32.22	-100.00 G_0.12		1.04736 pu @	-7.45 deg
ine		uded bac	кру			100.98 -86.87	-299.83	300.00	125.00) <	35.00	13.2 kV	-0.98 -3.80 25.00	1.05000 pu	@-5.23 deg	pqmis: -0.0	0.00
	SYN	IC CON				1.04550	43.43 ×	-30.00	0.00		0.00		0.00	pqmis: 0	<u>.00-0.00</u> -5.24		
						19 Ch pqmis	1.04428	pu @ 1.51.000-0.00	125.00	0	1.04598 cm /8, 10.12	5.16 -5.16	-2.67		-1.2/ 75.00		
(42.8	367 + 9	90.00)/1	25.64				9 9	17 Cherry	0.00	o-	pgmis: 0.00 0.00	pqmis: 0.00%/djirch_115_SC	0.00	100 Certer	0.00		
	* 100 -	- 105 75	0/				0 0 0	230.0 kV	0.00	2		132 kV		115.0 kV	1.04666 pu @-10.96 deg		
	100 -	= 105.75	70			296.30		296.14	-32.45	5	13 Pine_230_5	6C (G-116	-1.16	-2.50	101 Cedar		
						-23.59		36.73		0.00	0.00	1.05000 pu @-10.13 deg	-1.18	-0.02 2.50	13.2 kV 2.50		
						-53.80	69	-32.53	-000.03	-12.76	12.88	12.85 pqmis. 0.00 0.00		0.02	<u>0.00</u>		
					_	296.30		296.14	70.00		1.05000 pu @-5.5	1 deg		1.04896 pu @-10.25 deg pamis: 0.00.0.00	1.04874 pu @-10.67 deg pamis: 0.00.000		
					F.	-23.59		36.73			and a second second		1.04910 pu @-10.13 deg	perma. and a do	full contract of the		
					1.03726 pu @2. pamis: 0.00 (10 deg 1.00	8 8		25 Cherr 230 SC	32.54			pqmis: -0.00 0.00				
							9 6	0.00	13.2 kV	-23.50						-	
						22 Cł	terry_T2 1.04428	pu@-1.51	4 13	mis: © 00 -0.00							
		. –					ia.e.kv pqmis:	1:04134 pu @-0.42 deg	-11.13 1.05000 - @-0.43 dec								

pgmis: 0.00 0.00

pgmis: 0.00 - 0.00

Solution #1: Replace Inertia with Synchronous Condensers

		66% IBR
First 10 Case Study Stats	00% IBR Case	w/SYNC CON Case
Total Load Shed (MW's)	3400 🗸	3800
HIGH RoCoF (Hz/sec.)	1.08 🗸	1.33
AVE. RoCoF (Hz/sec.)	0.63 🗸	0.79
LOW RoCoF (Hz/sec.)	0.16 🗸	0.17
AVE Freq. Nadir (Hz)	59.03	58.98
AVE Freq. Overshoot (Hz)	60.16	60.43
AVE Final Freq. (Hz)	60.07 🗸	60.35



Solution #1: Replace Inertia with SYNC CON Conclusions

- Replacing inertia with synchronous condensers can achieve similar, but not quite as good response as 00% IBR case.
 - Synchronous condensers add inertia to the system, but can't provide MW injection like synchronous generation can.
- Synchronous condensers are not cheap (~\$25 million per 100 MVAR) and are maintenance intensive.

Test System SYNC CON Cost = 10 units $\cdot 1.5 \cdot \$25$ million (per 100 MVAR) = \$375 million

Solution #2: Arrest Frequency Pre-UFLS with BESS

Generator	Nameplate	Generator Inertia	ALL Synchro H@100 MVA	Generator	Nameplate
Name	MVA	Constant (H)	Base	Name	MVA
Birch U1	150	6.22	9.33	Birch U1	150
Oak U1	100	5.48	5.48	Oak U1	100
Pine U1	300	3.33	9.99	Cherry WTG	600
Maple U1	100	5.48	5.48	Maple WTG	100
Maple U2	500	3.236	16.18	Maple U2	500
Elm	1000	3.959	39.59	Elm	200
Spruce	1000	3.959	39.59	Elm WTG	500
TOTAL	3150		125.64	Spruce	100
				Spruce WTG	900

3.939	39.39		500	0	
	125.64	Spruce	100	3.959	3.
		Spruce WTG	900	0	
		TOTAL	3150		42
Inertia	deplete	ed by Typ	e IV \	Wind:	

(125.64 - 42.867) / 125.64 * 100 = 65.88%



Solution #2: Arrest Frequency Pre-UFLS with BESS

	66% IBR Case	66% IBR
First 10 Case Study Stats	6-Cyc. Delay	w/BESS Case
Total Load Shed (MW's)	4200	2000
HIGH RoCoF (Hz/sec.)	4.82	4.42
AVE. RoCoF (Hz/sec.)	2.59	2.38 🗸
LOW RoCoF (Hz/sec.)	0.54 🗸	0.57
AVE Freq. Nadir (Hz)	58.71	59.10 🗸
AVE Freq. Overshoot (Hz)	61.33	60.11 V
AVE Final Freq. (Hz)	60.79	<u>59.98</u>



Solution #2: Arrest Frequency with BESS Conclusions

- BESS fast frequency response MW injection/absorption using only 10% of system peak load (2,000 MW system) can provide significant improvement in conventional UFLS program performance.
 - BESS fast frequency response can reduce overall load shed by 50% or more.
 - BESS's are not cheap (~\$115 million per 100 MW 4-Hr. duration).

Test System BESS Cost = $2 \text{ Units}(100 \text{ MWeach}) \cdot \$115 \text{ million} (per 100 \text{ MW}) = \230 million

□ Trip <u>AT</u> the UF set point <u>IF</u> the RoCoF is greater than zero and less than 10 Hz/sec.



□ Minor "tweaks" to fine-tune performance

□ Raised under frequency detector to 59.8 Hz

□ Changed RoCoF bandwidths slightly





81D6P = 60.4 Hz

CAPE allows building custom logic, which was done for every logic element of this RoCoF UFLS scheme

			External Logic Inputs		Selected External Logic Input
			Logic Name	Type of Supervisor Relay Element	✓ Select Supervisor
			12Hz_Timer 5Hz Timer	Supervising Relay Element	
 SUBSTATION AREA ZONE OWNER RIGHT OF WAY 	 BUS LZOP SUM POINT AUX CT AUX VT NEUTRAL NODE 	PROTECTIVE DEVICE ARCHIVED DEVICE FUSE	UFLS_PU	Substation: Oak LZOP Name: Oak_115_Step1_UF_ Element: TIMER	Relay Name: 12Hz_Timer 2 Relay Tag: 208 1 Redirect input to differer
<unassigned></unassigned>	LINE Oak-Birch 115	RELAY 1 UF_STEP_1	Add Input Delete Input		
Birch Cedar	LINE Oak-Maple 115 LINE Oak-Pine 115	RELAY 2 UF_Timer RELAY 3 UF_Starter	AUX Elements		Selected AUX Element
Cherry Elm	MACHINE Unit_1_Protection MISC Oak_115_Step1_UF_1	RELAY 4 12Hz_Timer RELAY 5 5Hz_Timer	Designation	Target Designation	Contact Logic Code
Fir Maple	MISC Oak 115 Step1 UF 2 MISC Oak 115 Step2 UF	RELAY 6 3Hz_Timer RELAY 7 1 5Hz Timer		ANSI Number	Pickup Time 0
Oak Dine	MISC Oak_115_Step3_UF	RELAY 8 AND 1		Contact Status Normal	V Dropout Time 0
Spruce		RELAY 10 AND_3		Parent And/Or OR V	Pilot Flag Direct Trip CB ir
		RELAY 11 AND 4 RELAY 12 OR 1		Internal Logic Expression (library) = <b< td=""><td>lank></td></b<>	lank>
				External Logic Expression (system) Ele	ment Remarks
				Combine External Logic Inputs with AND	IOR UFLS_PU
	Internal Logic Expression (library))= <blank></blank>			
	External Logic Expression (system) Element Remarks			-
	Combine External Logic Inputs with AND_1 OR AND_2 OR AND_3 OR AND	h AND OR ND_4			

Trip more load in level 1, up to 25%, but minimum of 10%

□ Trip 10% in level 2 and level 3

				460	410	260	205						
				23.00%	20.50%	13.00%	10.25%						
				3 сус.	8 cyc.	12 cyc.	30 cyc.						
				AND_1	AND_2	AND_3	AND_4		Load	Load Restore			
Substation -	Load Label 💌	Load (MW's) 🔻	UFLS Level	RoCoF 3.75-10 Hz? 💌	RoCoF 2.5-3.75 Hz? 🔻	RoCoF 1.00-2.5 Hz? -	RoCoF 0-1.00 Hz?	Time Delay 🔻	Restore -	RoCoF 💌	-	f start 🔻	f restore 🔻
Birch	1-1	50	3	Y	Y	Υ	Ŷ	6	Ν				
Birch	1-2	25	1	Y	Y	Y	Y	6	1	>0.15 Hz/Sec.	80 cyc	60.1	60.3
Birch	1-3	25	1	Y	Y	Y	Ν	12	1	>0.25 Hz/Sec.	48 cyc	60.1	60.3
Fir	12-2	75	2	N	N	N	N	6	Ν				
Fir	12-3	50	1	Y	N	Y	N	30	Ν				
Maple	2-1	75	3	N	N	N	N	20	Ν				
Maple	2-2	75	3	Ν	N	N	N	20	Ν				
Maple	2-3	50	2	Y	Y	N	N	30	Ν				
Oak	5-1	75	1	Y	Y	Y	Ŷ	6	Ν				
Oak	5-2	75	2	Ν	Ν	Ν	N	20	Ν	Was 15 cyc.			
Oak	5-3	50	1	Ŷ	Ν	N	Ν	599940	Ν				
Oak	5-3	50	3	N	Ν	N	N	10	Ν				
Pine	7-1	35	1	Y	Y	Y	Ν	599940	Ν				
Pine	7-1	35	3	N	N	N	Ν	20	N				
Pine	7-2	20	1	Y	Y	Y	Ν	599940	1	>0.5 Hz/Sec.	24 cyc	60.1	60.3
Pine	7-2	20	3	N	Ν	N	Ν	20	1				
Pine	7-3	30	1	Y	Y	Y	Ν	20	1	>0.10 Hz/Sec.	120 сус	60.3	60.5
Pine	10-1	150	1	Y	Y	Ν	Ν	599940	Ν				
Pine	10-1	150	3	N	N	Ν	Ν	30	N				
TOTAL		2055											
Level 1 Total	460	MW's	23.00%	%									
Level 2 Total	200	MW's	10.00%	%									
Level 3 Total	200	MW's	10.00%	%									
Not Used Total	940	MW's	47.00%	%									

□ Trip 205 MW's (10.25%) of level 1 load when RoCoF is less than 1.0 Hz/sec.

				460	410	260	205						
				23.00%	20.50%	13.00%	10.25%						
				3 сус.	8 cyc.	12 cyc.	30 cyc.						
				AND_1	AND_2	AND_3	AND_4		Load	Load Restore			
Substation 💌	Load Label 🔻	Load (MW's) 🔻	UFLS Level	RoCoF 3.75-10 Hz? 💌	RoCoF 2.5-3.75 Hz? 🔻	RoCoF 1.00-2.5 Hz? -	RoCoF 0-1.00 Hz?	Time Delay 🔻	Restore -	RoCoF 💌	-	f start 🔻	f restore 🔻
Birch	1-1	50	3	Y	Y	Y	Y	6	Ν				
Birch	1-2	25	1	Y	Y	Y	Y	6	1	>0.15 Hz/Sec.	80 cyc	60.1	60.3
Birch	1-3	25	1	Y	Y	Y	N	12	1	>0.25 Hz/Sec.	48 cyc	60.1	60.3
Fir	12-2	75	2	N	N	N	N	6	Ν				
Fir	12-3	50	1	Y	N	Y	Ν	30	Ν				
Maple	2-1	75	3	Ν	N	N	Ν	20	Ν				
Maple	2-2	75	3	Ν	N	N	N	20	Ν				
Maple	2-3	50	2	Y	Y	N	N	30	N				
Oak	5-1	75	1	Y	Y	Y	Y	6	Ν				
Oak	5-2	75	2	N	N	N	N	20	Ν	Was 15 cyc.			
Oak	5-3	50	1	Ŷ	Ν	N	Ν	599940	N				
Oak	5-3	50	3	N	Ν	N	N	10	N				
Pine	7-1	35	1	Y	Y	Y	Ν	599940	N				
Pine	7-1	35	3	Ν	N	N	Ν	20	N				
Pine	7-2	20	1	Y	Y	Y	Ν	599940	1	>0.5 Hz/Sec.	24 сус	60.1	60.3
Pine	7-2	20	3	Ν	Ν	N	N	20	1				
Pine	7-3	30	1	Y	Y	Y	Ν	20	1	>0.10 Hz/Sec.	120 сус	60.3	60.5
Pine	10-1	150	1	Y	Y	N	Ν	599940	N				
Pine	10-1	150	3	Ν	N	N	Ν	30	Ν				
TOTAL		2055											
Level 1 Total	460	MW's	23.00%	%									
Level 2 Total	200	MW's	10.00%	%									
Level 3 Total	200	MW's	10.00%	%									
Not Used Total	940	MW's	47.00%	%									

□ Trip 260 MW's (13.00%) of level 1 load when RoCoF is between 1.0 Hz/sec. and 2.5 Hz/sec.

				460	410	260	205						
				23.00%	20.50%	13.00%	10.25%						
				3 cyc.	8 cyc.	12 сус.	30 cyc.						
				AND_1	AND_2	AND_3	AND_4		Load	Load Restore			
Substation 🔻	Load Label 💌	Load (MW's) 🔻	UFLS Level 🖅	RoCoF 3.75-10 Hz? 💌	RoCoF 2.5-3.75 Hz? 🔻	RoCoF 1.00-2.5 Hz? -	RoCoF 0-1.00 Hz?	Time Delay 🔻	Restore -	RoCoF 💌	-	f start 💌	f restore 💌
Birch	1-1	50	3	Y	Y	Y	Y	6	Ν				
Birch	1-2	25	1	Y	Y	Y	Y	6	1	>0.15 Hz/Sec.	80 cyc	60.1	60.3
Birch	1-3	25	1	Y	Y	Y	N	12	1	>0.25 Hz/Sec.	48 cyc	60.1	60.3
Fir	12-2	75	2	N	N	N	N	6	Ν				
Fir	12-3	50	1	Y	N	Y	N	30	Ν				
Maple	2-1	75	3	Ν	N	N	Ν	20	Ν				
Maple	2-2	75	3	Ν	Ν	Ν	N	20	Ν				
Maple	2-3	50	2	Y	Y	N	N	30	Ν				
Oak	5-1	75	1	Y	Y	Y	Y	6	Ν				
Oak	5-2	75	2	N	Ν	Ν	N	20	Ν	Was 15 cyc.			
Oak	5-3	50	1	Y	Ν	N	Ν	599940	Ν				
Oak	5-3	50	3	Ν	Ν	N	N	10	Ν				
Pine	7-1	35	1	Y	Y	Y	N	599940	Ν				
Pine	7-1	35	3	Ν	N	N	N	20	Ν				
Pine	7-2	20	1	Y	Y	Ý	N	599940	1	> 0.5 Hz/Sec.	24 cyc	60.1	60.3
Pine	7-2	20	3	Ν	Ν	N	N	20	1				
Pine	7-3	30	1	Y	Y	Y	N	20	1	>0.10 Hz/Sec.	120 cyc	60.3	60.5
Pine	10-1	150	1	Y	Y	N	N	599940	Ν				
Pine	10-1	150	3	N	Ν	N	N	30	Ν				
TOTAL		2055											
Level 1 Total	460	MW's	23.00%	%									
Level 2 Total	200	MW's	10.00%	%									
Level 3 Total	200	MW's	10.00%	%									
Not Used Total	940	MW's	47.00%	%									

□ Trip 410 MW's (20.50%) of level 1 load when RoCoF is between 2.5 Hz/sec. and 3.75 Hz/sec.

				460	410	260	205						
				23.00%	20.50%	13.00%	10.25%						
				3 сус.	8 cyc.	12 cyc.	30 cyc.						
				AND_1	AND_2	AND_3	AND_4		Load	Load Restore			
Substation 🔻	Load Label 💌	Load (MW's) 🔻	UFLS Level 🕶	RoCoF 3.75-10 Hz? 💌	RoCoF 2.5-3.75 Hz? 🔻	RoCoF 1.00-2.5 Hz? -	RoCoF 0-1.00 Hz? -	Time Delay 🔻	Restore -	RoCoF 💌	-	f start 💌	f restore 💌
Birch	1-1	50	3	Y	Y	Υ	Ŷ	6	N				
Birch	1-2	25	1	Y	Y	Y	Y	6	1	>0.15 Hz/Sec.	80 cyc	60.1	60.3
Birch	1-3	25	1	Y	Y	Y	N	12	1	>0.25 Hz/Sec.	48 cyc	60.1	60.3
Fir	12-2	75	2	N	N	N	N	6	Ν				
Fir	12-3	50	1	Y	N	Y	Ν	30	Ν				
Maple	2-1	75	3	Ν	N	Ν	N	20	N				
Maple	2-2	75	3	Ν	Ν	N	N	20	Ν				
Maple	2-3	50	2	Y	Y	N	N	30	Ν				
Oak	5-1	75	1	Y	Y	Y	Y	6	Ν				
Oak	5-2	75	2	Ν	Ν	N	N	20	Ν	Was 15 cyc.			
Oak	5-3	50	1	Y	Ν	N	Ν	599940	N				
Oak	5-3	50	3	N	N	N	N	10	N				
Pine	7-1	35	1	Y	Y	γ	Ν	599940	N				
Pine	7-1	35	3	N	N	N	N	20	N				
Pine	7-2	20	1	Y	Y	Y	Ν	599940	1	>0.5 Hz/Sec.	24 cyc	60.1	60.3
Pine	7-2	20	3	Ν	Ν	N	N	20	1				
Pine	7-3	30	1	Y	Y	Y	Ν	20	1	>0.10 Hz/Sec.	120 сус	60.3	60.5
Pine	10-1	150	1	Y	Y	Ν	Ν	599940	N				
Pine	10-1	150	3	Ν	N	N	N	30	N				
TOTAL		2055											
Level 1 Total	460	MW's	23.00%	%									
Level 2 Total	200	MW's	10.00%	%									
Level 3 Total	200	MW's	10.00%	%									
Not Used Total	940	MW's	47.00%	%									

Trip 460 MW's (23.00%) of level 1 load when RoCoF is between 3.75 Hz/sec. and 10 Hz/sec.

				460	410	260	205						
				23.00%	20.50%	13.00%	10.25%						
				3 cyc.	8 cyc.	12 cyc.	30 cyc.						
				AND_1	AND_2	AND_3	AND_4		Load	Load Restore			
Substation 🔻	Load Label 🔻	Load (MW's) 🔻	UFLS Level 🖵	RoCoF 3.75-10 Hz? 🔻	RoCoF 2.5-3.75 Hz? 🔻	RoCoF 1.00-2.5 Hz? -	RoCoF 0-1.00 Hz?	Time Delay 🔻	Restore -	RoCoF 🔻	-	f start 🔻	f restore 🔻
Birch	1-1	50	3	Y	Y	Υ	Ŷ	6	N				
Birch	1-2	25	1	Y	Y	Y	Y	6	1	>0.15 Hz/Sec.	80 cyc	60.1	60.3
Birch	1-3	25	1	Y	Y	Ŷ	N	12	1	>0.25 Hz/Sec.	48 cyc	60.1	60.3
Fir	12-2	75	2	N	N	N N	N	6	N				
Fir	12-3	50	1	Y	N	Ŷ	N	30	N				
Maple	2-1	75	3	Ν	N	Ν	N	20	N				
Maple	2-2	75	3	Ν	N	N	N	20	N				
Maple	2-3	50	2	Y	Y	N	N	30	N				
Oak	5-1	75	1	Y	Y	Y	Ŷ	6	N				
Oak	5-2	75	2	N	N	N	N	20	N	Was 15 cyc.			
Oak	5-3	50	1	Y	N	N	N	599940	N				
Oak	5-3	50	3	N	Ν	N	N	10	N				
Pine	7-1	35	1	Y	Y	Ŷ	Ν	599940	N				
Pine	7-1	35	3	N	N	N	Ν	20	N				
Pine	7-2	20	1	Y	Y	Y	Ν	599940	1	>0.5 Hz/Sec.	24 cyc	60.1	60.3
Pine	7-2	20	3	N	N	N	Ν	20	1				
Pine	7-3	30	1	Y	Y	Y	N	20	1	>0.10 Hz/Sec.	120 cyc	60.3	60.5
Pine	10-1	150	1	Y	Y	Ν	Ν	599940	N				
Pine	10-1	150	3	N	N	N	N	30	N				
TOTAL		2055											
Level 1 Total	460	MW's	23.00%	%									
Level 2 Total	200	MW's	10.00%	%									
Level 3 Total	200	MW's	10.00%	%									
Not Used Total	940	MW's	47.00%	%									

□ Trip up to 255 MW's of level 1 RoCoF only at level 3 with time delay

□ Allows extra load shed at level 3 (22.75%) for high inertia, low RoCoF situations

				460	410	260	205						
				23.00%	20.50%	13.00%	10.25%						
				3 cyc.	8 cyc.	12 cyc.	30 cyc.						
				AND_1	AND_2	AND_3	AND_4		Load	Load Restore			
Substation 🔻	Load Label 🔻	Load (MW's) 🔻	UFLS Level 🖵	RoCoF 3.75-10 Hz? 💌	RoCoF 2.5-3.75 Hz? 🔻	RoCoF 1.00-2.5 Hz? -	RoCoF 0-1.00 Hz?	Time Delay 🔻	Restore -	RoCoF 💌	-	f start 💌	f restore 🔻
Birch	1-1	50	3	Y	Y	Y	Ŷ	6	N				
Birch	1-2	25	1	Y	Y	Y	Y	6	1	>0.15 Hz/Sec.	80 cyc	60.1	60.3
Birch	1-3	25	1	Y	Y	Y	N	12	1	>0.25 Hz/Sec.	48 cyc	60.1	60.3
Fir	12-2	75	2	N	N	N	N	6	Ν				
Fir	12-3	50	1	Y	N	Y	N	30	N				
Maple	2-1	75	3	Ν	N	Ν	N	20	N				
Maple	2-2	75	3	Ν	Ν	N	N	20	N				
Maple	2-3	50	2	Y	Y	N	N	30	N				
Oak	5-1	75	1	Y	Y	Y	Y	6	N				
Oak	5-2	75	2	N	Ν	N	N	20	N	Was 15 cyc.			
Oak	5-3	50	1	Ŷ	Ν	Ν	N	599940	N				
Oak	5-3	50	3	N	Ν	N	N	10	N				
Pine	7-1	35	1	Ŷ	Y	Y	N	599940	N				
Pine	7-1	35	3	Ν	N	N	N	20	N				
Pine	7-2	20	1	Y	Y	Y	N	599940	1	>0.5 Hz/Sec.	24 cyc	60.1	60.3
Pine	7-2	20	3	Ν	Ν	N	N	20	1				
Pine	7-3	30	1	Y	Y	Y	N	20	1	>0.10 Hz/Sec.	120 сус	60.3	60.5
Pine	10-1	150	1	Y	Y	N	N	599940	N				
Pine	10-1	150	3	Ν	N	Ν	Ν	30	N				
TOTAL		2055											
Level 1 Total	460	MW's	23.00%	%									
Level 2 Total	200	MW's	10.00%	%									
Level 3 Total	200	MW's	10.00%	%									
Not Used Total	940	MW's	47.00%	%									

□ CAPE TS-Link example for trip of 490 MW Maple Unit 2

ONLY level 1 UFLS operates tripping 460 MW of load



- NONE of the cases studied would result in potential uncontrolled generator tripping due to over/under frequency per NERC PRC-024 Standard
- □ ALL final frequencies were within +/- 0.3 Hz of nominal

Eastern Interconnection

High Frequency Duration							
Frequency (Hz)	Time (Sec)						
≥61.8	Instantaneous trip						
≥60.5	10 ^(90.935-1.45713*f)						
<60.5	Continuous operation						
Low Frequency Duration							
Low Frequ	ency Duration						
Low Frequ Frequency (Hz)	ency Duration Time (sec)						
Low Frequ Frequency (Hz) ≤57.8	ency Duration Time (sec) Instantaneous trip						
Low Frequ Frequency (Hz) ≤57.8 ≤59.5	ency Duration Time (sec) Instantaneous trip 10 ^(1.7373*f-100.116)						

			RoCoF UFLS			
Generation	RoCoF	Total Load	Excess Amount of	Frequency	Overshoot	Final
Tripped (MW's)	(Hz/Sec.)	Shed (MW's) *	Load Shed (MW's)	Nadir (Hz)	Freq. (Hz)	Freq. (Hz)
95	-0.54	100	5	59.27	60.16	60.06
140	-1.02	160	20	59.23	60.53	60.17
190	-1.25	190	0	59.22	60.31	59.99
235	-1.73	235	0	59.18	60.30	59.97
330	-2.60	310	-20	59.03	60.51	59.88
375	-2.33	390	15	58.91	60.37	60.12
435	-3.47	410	-25	58.96	60.32	59.83
490	-4.37	460	-30	59.00	60.30	59.84
540	-4.82	505	-35	58.85	60.31	59.90
600	-3.72	610	10	58.69	60.31	60.00
640	-5.72	630	-10	58.67	60.34	60.16
700	-4.26	760	60	58.58	60.62	60.30
750	-4.51	790	40	58.44	60.45	60.19
		TOTAL	-60			
		Ave. Difference	16.00			

© 2022 Xcel Energy

* Includes Auto Load Restoration

□ ALL RoCoF UFLS Test System Study Results:

00% Existing UFLS vs. RoCoF UFLS

	00% IBR Case	66% IBR
First 10 Case Study Stats	6-Cyc. Delay	w/RoCoF Case
Total Load Shed (MW's)	3400	3160 🗸
HIGH RoCoF (Hz/sec.)	1.08	1.08
AVE. RoCoF (Hz/sec.)	0.63	0.63
LOW RoCoF (Hz/sec.)	0.16	0.16
AVE Freq. Nadir (Hz)	59.03 🗸	59.00
AVE Freq. Overshoot (Hz)	60.16	60.02 🗸
AVE Final Freq. (Hz)	60.07	59.95 🗸

50% Existing UFLS vs. RoCoF UFLS

	50% IBR Case	66% IBR
First 10 Case Study Stats	6-Cyc. Delay	w/RoCoF Case
Total Load Shed (MW's)	3800	3540 🗸
HIGH RoCoF (Hz/sec.)	2.91	2.91
AVE. RoCoF (Hz/sec.)	1.64	1.64
LOW RoCoF (Hz/sec.)	0.32	0.32
AVE Freq. Nadir (Hz)	58.90	58.98 🗸
AVE Freq. Overshoot (Hz)	60.53	60.25 🗸
AVE Final Freq. (Hz)	60.38	60.10 🗸

25% Existing UFLS vs. RoCoF UFLS

	25% IBR Case	66% IBR
First 10 Case Study Stats	6-Cyc. Delay	w/RoCoF Case
Total Load Shed (MW's)	3800	3490 🗸
HIGH RoCoF (Hz/sec.)	1.75	1.75
AVE. RoCoF (Hz/sec.)	1.01	1.01
LOW RoCoF (Hz/sec.)	0.19	0.19
AVE Freq. Nadir (Hz)	58.97	58.97
AVE Freq. Overshoot (Hz)	60.47	60.15 🗸
AVE Final Freq. (Hz)	60.38	60.09 🗸

66% Existing UFLS vs. RoCoF UFLS

	66% IBR Case	66% IBR
First 10 Case Study Stats	6-Cyc. Delay	w/RoCoF Case
Total Load Shed (MW's)	4200	3370 🗸
HIGH RoCoF (Hz/sec.)	5.72	5.72
AVE. RoCoF (Hz/sec.)	3.10	3.10
LOW RoCoF (Hz/sec.)	0.54	0.54
AVE Freq. Nadir (Hz)	58.71	59.03 🗸
AVE Freq. Overshoot (Hz)	61.33	60.34 🗸
AVE Final Freq. (Hz)	60.79	59.98 🗸

□ RoCoF UFLS vs. Synchronous Condenser and BESS:

	66% IBR	66% IBR	66% IBR
First 10 Case Study Stats	w/SYNC CON Case	w/BESS Case	w/RoCoF Case
Total Load Shed (MW's)	3800	2000 🗸	3370
HIGH RoCoF (Hz/sec.)	1.33 🗸	4.42	5.72
AVE. RoCoF (Hz/sec.)	0.79 🗸	2.38	3.10
LOW RoCoF (Hz/sec.)	0.17 🗸	0.57	0.54
AVE Freq. Nadir (Hz)	58.98	59.10 🗸	59.03
AVE Freq. Overshoot (Hz)	60.43	60.11	60.34
AVE Final Freq. (Hz)	60.35	59.98 V	59.98 V

Solution #3: Implement RoCoF UFLS Program Conclusions

- RoCoF UFLS program works well for inertia reductions up to 80%, resulting in final frequencies within +/- 0.5 Hz of nominal.
 - RoCoF UFLS program is easy/cost effective to implement.
- RoCoF UFLS program can be implemented at a fraction of the cost of synchronous condensers or BESS.

Xcel Energy NM/TX RoCoF Cost = \sim 135 Relays \cdot \$150k (per Relay) = \$20.25 million

Xcel Energy NM/TX SYNC CON Cost = 10 units $\cdot 1.5 \cdot \$25$ *million (per 100 MVAR)* $\cdot 3 = \$1,125$ *million*

Xcel Energy NM/TX BESS Cost = $2 \text{ Units}(100 \text{ MW's}) \cdot \$115 \text{ million} \cdot 3 = \690 million

Next Steps to Implement New Program

- Continue testing various IBR penetration levels on actual Xcel Energy New Mexico-Texas region (2025)
- Develop relay settings and test using COMTRADE file play-back in test lab
- Perform studies on actual system to determine optimum amount of BESS to provide inertial fast frequency response working in conjunction with RoCoF UFLS program to reduce amount of load shed when compared to existing UFLS program
- Write paper about RoCoF UFLS program with three co-authors and present at conferences
- Convince Xcel Energy Protection and Planning Departments that this is a necessary program to implement
- Convince Southwest Power Pool that this solution fits their PRC-006 mold and is worthy of implementation at SPS
- □ Implement program in the SPS region

Conclusions

- Underfrequency load shed programs across the industry are outdated and need to be modernized to operate successfully with systems that have high IBR penetrations and low system inertia that leads to high RoCoF
- □ If UFLS programs are left as-is, blackouts will become more common
- Implementing this new RoCoF UFLS scheme will better guarantee adequate load shed and blackout avoidance
- Implementing this new RoCoF UFLS scheme can potentially save millions of dollars in avoided costs of investment in synchronous condensers to replace depleted inertia and BESS to provide MW injection during UF events



Megger

Cloud-Based End-to-End Testing

BES Protection System Misoperation Reduction Workshop

> Dhanabal Mani Director Relay Software Development

THE REAL PROPERTY AND INCOMENTS

Agenda

- Pilot Schemes
- Line Differential Schemes
- End-to-End Testing Concepts
- Cloud-Based End-to-End Technology and Testing
 - Why, How and What
- Test Scenarios and Results
 - Traditional and Cloud-Based End-to-End
- Summary
- Conclusion



- PUTT schemes use both underreaching (Z1A and Z1B) and overreaching (Z2A and Z2B) elements.
- Each terminal will trip directly for its underreaching element. Accelerate tripping at the remote end by sending a permissive trip signal for faults detected in Zone 1.
- Suitable for shorter transmission lines, focusing on faults near the relay terminals.



Permissive Under-Reach Transfer Trip



Pilot Schemes - POTT

- POTT uses overreaching (Zone 2) elements to detect faults.
- Sends a permissive trip signal from the local to the remote relay when a fault is detected.
- Allows fast tripping for faults in the overreaching zone by communicating with the relay at the other end.
- Ideal for longer transmission lines, where overreaching protection is required to cover a larger area.



Permissive Over-Reach Transfer Trip



Line Differential Schemes

- Line differential protection is based on Kirchhoff's Current Law (KCL), which compares the current entering and leaving of a transmission line.
- Line Differential Relays (LDR) at both ends of the line communicate in realtime to detect and isolate faults.
- The system detects in-zone faults and isolates them quickly to ensure stable power transmission.



Line Differential Protection


Line Differential Schemes

Types of Line Differential Protection:

- Percent Differential Protection.
 - Uses a differential current (Idiff) and a restraining signal (Ibias) to determine if a fault exists.
 - The protection operates when Idiff exceeds a defined threshold relative to Ibias.
 - Ideal for providing security against false trips caused by CT saturation.
- Alpha Plane Differential Protection
 - Graphically represents phase current ratios on a complex plane
 - Allows for more flexible and adaptable fault detection based on the relationship between phase currents.
 - Defines operational zones with parameters like radii and sweep angles to determine stability and trip regions.



Differential Slope Characteristics



Alpha Plane Characteristics



End-To-End Testing Concepts

- Traditional testing relies heavily on GPS-based synchronization (IRIG-B signals) to ensure accurate fault simulation and timing coordination between local and remote ends.
- Two test sets are required: one at each end of the power line or transmission line, necessitating coordination between two operators. This makes the process complex and resourceintensive.
- Faults are injected at both ends of the line with pre-fault, fault, and post-fault states.



Traditional End-to-End Testing Setup



End-To-End Testing Concepts

- Traditional end-to-end testing is typically static, focusing on one point at a time, which limits the ability to test dynamic behavior or complex protection schemes.
- Requires fiber-optic communication links between protective relays and test sets for fast signal transmission.
- Fault conditions are simulated to verify relay response and ensure system reliability.



Traditional End-to-End Testing Setup



End-To-End Testing Concepts

Line Protection Relays End-End Testing: Steady State Method



Remote

Test Set

	ŝ		С	CURRENT				VOL.	VOLTAGE		
	l &		I (A)	φ (°)	f (Hz)			V (V)	φ (°)	f (Hz)	
В	പ	I1	0.800	-12.00	50.000	٧	V1	66.40	0.00	50.000	
	പ	I2	0.800	108.00	50.000	ف	V2	66.40	240.00	50.000	
	<mark>ل</mark>	I3	0.800	228.00	50.000	ý	V3	66.40	120.00	50.000	

ψ	CURRENT			VOLTAGE					
B		I (A)	φ (°)	f (Hz)			V (V)	φ (°)	f (Hz)
<mark>ل</mark>	I1	4.000	90.00	50.000	ٺ	V1	46.00	0.00	50.000
പ	I2	4.000	210.00	50.000	ٺ	V2	46.00	240.00	50.000
<mark>ပ</mark>	I3	4.000	330.00	50.000	Ú	V3	46.00	120.00	50.000

¢	CURRENT				VOLTAGE						
y		I (A)	φ (°)	f (Hz)			V (V)	φ (°)	f (Hz)		
ወ	11	1.000	5.00	50.000	٧	V1	66.40	0.00	50.00		
ወ	I2	1.000	125.00	50.000	۵	V2	66.40	240.00	50.00		
ሪ	13	1.000	245.00	50.000	ٺ	V3	66.40	120.00	50.00		



Line Protection Environment Service Condition: Steady State Testing



- Local and Remote 87L Relay trips in up normal fault conditions.
- Data handshake between Local and Remote Relays via FOC.



Line Protection Relays End-End Testing: Steady State Method Limitations



- Always need Multiple operators.
- Limited flexibility and Efficiency
- Difficulty in Simulating Complex Networking Conditions.
- Lake of Real-time Sharing and Analysis.



Line Protection Relays End-End Testing (conventional) : Steady State



 Limitations on modern Line Differential Relays Algorithms validation.





Line Protection Relays End-End Testing: Cloud-Based Approach



- Centralized Control and Flexibility.
- Reduced Operational Errors.
- Synchronization and Real-Time Data Sharing.



Line Protection Relays End-End Testing: Cloud-Based Approach



- Efficiency and Resource Optimization.
- Enhanced Testing capabilities.
- End-to-end application testing extends beyond just line differential to include Line Distance Schemes as well!



Line Protection Relays End-End Testing: Control From One End



- State-of-the-art method: Integrating two test sets through cloud-level daisy chaining.
- Synchronized Testing.
- Integrated Software and Hardware.
- Cloud-Based Data Management.
- Internet is Mandatory



Line Protection Relays End-End Testing: Control From One End





Line Protection Relays End-End Testing: Control From One End - Manual





Test Scenarios and Results – Traditional and Cloud-Based End-to-End

• Every case was tested using both a conventional setup and a cloud-based setup



Cloud-based Test Setup

Traditional Test Setup



Test Case 1: Traditional Test POTT

ወ 13 5.0000

🙈 🔗 📩 🚟

120.000



Relay B

Test Set B



60.000

2

ൾ

Max States: 3



60.000

35.371

-47.260

-72.740

120.000

60.000

60.000

60.000

3				2 2 2 3			?	X	Max State Iteratior	es: 3 ns: 1
69.000	120.000	60.000	പ	13	0.0000	0.000	60.000	٢	V3	69.00
69.000	-120.000	60.000	မ	12	10.000	126.000	60.000	۷	V2	35.37

10.000

-54.000

GGG

ሪ

Imputs Imputs Imputs Imputs											
<u>о</u>	9 (A				ait IRIG	VOLTAGE					
U		I (A)	φ (˘)	f (Hz)			V (V)	φ (˘)	f (Hz)		
ሪ	I1	5.0000	0.000	60.000	ف	V1	69.000	0.000	60.000		
ሪ	I2	5.0000	-120.000	60.000	Ú	V2	69.000	-120.000	60.000		
ധ	I3	5.0000	120.000	60.000	Ċ	V3	69.000	120.000	60.000		





Test Case 1: Traditional Test POTT

Relay A



AB fault at 10%. POTT.





STATE ASSERTED

ASSERTED

DEASSERTED DEASSERTED DEASSERTED



= >

AB fault at 90%. POTT.



Test Case 2: Cloud-Based Test POTT









Test Case 3: Traditional Test PUTT

ወ

13

5.0000

120.000







Distance Chattaney La

Inputs	2 2			3	120 TEO					
St C	ate Na	me: Trip	State 2	Nex Wait An	Next Timeout (cy) 60 Wait Any (Continue)					
				VOLTAGE V(V) φ(°) f(H:						
Gee		C I (A)	urrent φ (°)	f (Hz)			VOL ⁻ V (V)	TAGE φ (°)	f (Hz)	
<mark>କ</mark> ୧୯୧୦	I1	CI I (A) 10.000	URRENT φ (°) -54.000	f (Hz) 60.000	Ú	V1	VOL ⁻ V (V) 35.371	τAGE φ (°) -47.260	f (Hz) 60.000	
<mark>େ କ</mark> େ	I1 I2	C I (A) 10.000 10.000	URRENT φ (°) -54.000 126.000	f (Hz) 60.000 60.000	Ċ Ċ	V1 V2	VOL [*] V (V) 35.371 35.371	ΓAGE φ (°) -47.260 -72.740	f (Hz) 60.000 60.000	



60.000

69.000

120.000

60.000





Test Case 3: Traditional Test PUTT

Relay A



Deasserted

AB fault at 90%. PUTT.



Relav B

AB fault at 10%. PUTT.



Test Case 4: Cloud-Based Test PUTT









Test Scenarios and Results – Traditional End-to-End

Test Case 5: Traditional Test Line Differential Shot Test









Inputs 1	2 2 A A ate National A	3 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	State 2	?) > 1 Nex	tterations: 1 Next Timeout (cy) 60					
Ó	640		0 🐼 🗌	Wait An	Wait Any (Continue)					
ψ		С	URRENT		VOLTAGE					
B		I (A)	φ (°)	f (Hz)			V (V)	φ (°)	f (Hz)	
<mark>ل</mark>	I1	10.000	-54.000	60.000	Ú	V1	35.371	-47.260	60.000	
С С	I2	10.000	126.000	60.000	Ú	V2	35.371	-72.740	60.000	







Test Scenarios and Results – Traditional End-to-End

Test Case 5: Traditional Test Line Differential Shot Test







NOTE: Visualization of Alpha plane characteristics (or any) test is not possible with traditional testing



Test Case 6: Cloud-Based Line Differential Test - Stability





Test Case 6: Cloud-Based Line Differential Test - Stability

B RTMS Line Differential												
					Abort				Finisł	n Simulate		
Stability I 100 %												
	Inj	ected Curre	ents <mark>(Prima</mark>	ry)		Curr	ents Obser	ved From F	Relay			
Phas	Local		Rem	note	Local		Remote		11-1	1.1:66		
æ	I (A)	φ (°)	I (A)	φ (°)	I (A)	φ (°)	I (A)	φ (°)	Iblas	Ιαιττ		
А	2000.00	0	2000.00	180	1999.8	0	1999.4	180	0	0.001		
В	2000.00	-120	2000.00	60	2000.6	-120	2000.1	60	0	0.002		
с	2000.00	120	2000.00	-60	1999.6	120	2000.4	-59.8	0	0.001		



Test Case 6: Cloud-Based Line Differential Test - Search



Test Case 6: Cloud-Based Line Differential Test - Shot





Centralized Testing: This technology allows for centralized control of testing procedures, where a single operator can manage tests from one end, enhancing efficiency and reducing manpower requirements.

Synchronization and Accuracy: It leverages GPS-based synchronization for precise timing across disparate locations, ensuring high accuracy in test signal injections and fault simulations.

Real-Time Data Sharing: The cloud-based platform enables real-time data sharing and analysis, allowing for immediate troubleshooting and enhanced collaborative efforts.

Resource Optimization: By reducing the need for physical presence at both ends of a testing location, it optimizes resources and potentially lowers the costs associated with traditional testing methods.

Innovative Approach: The system represents a significant innovation in the field of teleprotection testing. Its unique method is **patent-pending**, highlighting its novel contribution to the industry.



Conclusion

- Improved Efficiency: Cloud-based testing reduces the need for on-site personnel, enabling remote testing and lowering operational costs.
- Enhanced Accuracy: Real-time data monitoring and GPS synchronization ensure more precise and faster fault detection.
- Broader Testing Capabilities: Cloud-based systems allow for testing a wider range of fault scenarios, improving protection scheme reliability.
- Reduced Human Error: Automation and centralized control minimize the likelihood of mistakes during testing and setup.
- Future of Testing: As power systems continue to advance, cloud-based testing will play a crucial role in ensuring the reliability and efficiency of grid operations. This development enables seamless retrieval of data from both end relays, enhancing the accuracy and speed of the testing process.







NERC BES Protection System Misoperation Reduction Workshop

Protection System Redundancy Criteria for NERC TPL-001.5 Footnote 13

Scott Hayes and Davis Erwin Pacific Gas and Electric





Purpose of Presentation

- Ensure Protection leaders are aware of the future costs, labor and timelines for compliance with NERC TPL-001.5 footnote 13 a-d.
- Briefly cover footnote 13 a-c including common problem areas.
- Cover footnote 13 d (control circuitry) in detail as well as discuss the SAR associated with 13 d.
- Protection groups may not be the asset owner for all components covered under footnote 13 a-d but we are the most qualified group to determine Single Point of Failure of Protection System components
- Several other entities have been contacted about their approach. The results were either:
 - Not aware of the concern.
 - Interpreted the exclusion in 13d to apply to all elements of the control circuit that are monitored and reported.
 - One Canadian Province is modifying 13d to change the requirement for local conditions to exclude <u>all</u> elements that are monitored and reported.

NERC TPL-001.5.1 Footnote 13

- NERC Standard TPL-001.5.1 is a Transmission System Planning Performance Standard
 - It requires an annual assessment of stability during specific faults with Delayed Fault Clearing due to failure of non redundant components of the Protection System
- TPL-001-5 mandates redundancy (or monitoring and reporting where allowed) of four Protection System components if stability studies reveal performance violations resulting from the failure of that Protection System component during a fault
- Identifying where redundancy exists, or monitoring and alarming exists is a very large effort and may require creating additional databases
- Exceptions/Exclusions are allowed for 13 b and c and are heavily used.

Timeline



Figure 1 Implementation Plan Timeline

Figure from NERC TPL-001-5.1 Requirement Training While there is some time until effective dates, the level of work requires action <u>now</u>.

- T+36 months: Studies must be completed by 7/1/2023 (majority of TPL-001-5.1 R2). Studies must consider these footnotes.
- T+60 months: Corrective action plans must be developed by 7/1/2025 (TPL-001-5.1 R2.7).
- T+108 months: Corrective Action Plans must be completed by 7/1/2029.

Category	Initial Condition	Event ¹	Fault Type ²	BES Level ³	Interruption of Firm Transmission Service Allowed ⁴	Non- Consequential Load Loss Allowed
P5 Multiple		Delayed Fault Clearing due to the failure of a non-redundant		EHV	No ⁹	No
Contingency (Fault plus non- redundant component of a Protection System failure to operate)	Normal System	 component of a Protection System¹⁵ protecting the Faulted element to operate as designed, for one of the following: Generator Transmission Circuit Transformer⁵ Shunt Device⁶ Bus Section 	SLG	HV	Yes	Yes
P6 Multiple Contingency (Two overlapping singles)	Loss of one of the following followed by System adjustments. ⁹ 1. Transmission Circuit 2. Transformer ⁵	Loss of one of the following: 1. Transmission Circuit 2. Transformer ⁵ 3. Shunt Device ⁶	ЗØ	EHV, HV	Yes	Yes
	 3. Shunt Device⁶ 4. Single pole of a DC line 	4. Single pole of a DC line	SLG	EHV, HV	Yes	Yes

Changes from TPL-001.4 to TPL-001.5

- TPL-001.4 footnote 13 included only one element of the NERC defined "Protection System" - Redundant protective relays.
- TPL-001.5 includes 4 of the 5 components of the "Protection System"
- Protection System redundancy must be determined from an interpretation of language in footnote 13 and supporting NERC documentation. It may be very different from how you would define redundancy.
NERC TPL-001.5 Footnote 13

- Footnote 13 requires elimination of all single points of failure. T/F
 - FALSE Footnote 13 requires identification of locations where the redundancy tests of 13 a-d are not met to scope the transmission studies that will determine if mitigation is required
- Where redundancy tests are not met, backup clearing times, breakers, fault currents and Thevenin impedances must be provided for stability studies with SLG faults
 - Providing these values is complicated for SLG faults if you use 67N elements.
 - i.e. Multistage sequential clearing Not uniform Zone 2 times.
- Planning groups need to run studies with this information and determine where instabilities may occur.

NERC TPL-001.5 Footnote 13

- Exceptions/Exclusions are allowed for 13 b-d and are heavily used outside of NPCC
- 13 d exclusion is written distinctly different than those of 13.b and 13.c.
- 13 b and 13 c lists an exception for the circuit.
 - Communication System
 - DC Supply
- 13 d only lists a subset of equipment that is excluded (trip coil only), not the circuit.

TPL-001.5 Footnote 13.

For purposes of this standard, non-redundant components of a Protection System to consider are as follows:

a. A single protective relay which responds to electrical quantities, without an alternative (which may or may not respond to electrical quantities) that provides comparable Normal Clearing times;

b. A single communications system associated with protective functions, necessary for correct operation of a communication-aided protection scheme required for Normal Clearing (an exception is a single communications system that is both monitored and reported at a Control Center);

c. A single station dc supply associated with protective functions required for Normal Clearing (an exception is a single station dc supply that is both monitored and reported at a Control Center for both low voltage and open circuit);

d. A single control circuitry (including auxiliary relays and lockout relays) associated with protective functions, from the dc supply through and including the trip coil(s) of the circuit breakers or other interrupting devices, required for Normal Clearing (the trip coil may be excluded if it is both monitored and reported at a Control Center).

13a. A single protective relay which responds to electrical quantities, without an alternative (which may or may not respond to electrical quantities) that provides comparable Normal Clearing times

- At BES voltages all utilities likely apply two levels of microprocessor protective relays
- No exclusion for protective relays for monitoring or alarming is given
- Common problem areas
 - <u>Many electromechanical relays</u> and some solid state and microprocessor relays may lack redundancy
 - Many older bus differential relay schemes are not redundant-can have significant system impacts
 - Bank differential relaying needs to be checked for delayed clearing in some cases.
- Is redundant breaker failure protection required?
 - Footnote 13 does not apply to breaker failure protection, but the main standard includes a "stuck breaker" reference. This likely requires identifying any BES breakers without breaker failure.

13b. A <u>single communications system</u> associated with protective functions, necessary for correct operation of a communication-aided protection scheme required for Normal Clearing (an <u>exception</u> is a <u>single</u> communications system that is <u>both monitored and reported at a Control</u> <u>Center</u>);

- A single communication system used to be the norm below EHV lines
- With digital communications it is now inexpensive to have redundant communication schemes.
- To rely on redundant digital communications, do we need to check for redundancy in the "cloud", components and redundant DC supplies to telecom equipment?
- An exception is given for a single scheme that is monitored and reported at a Control Center.
- Can you produce evidence that every communication system is monitored and reported to a Control Center?



13c. A <u>single station dc supply</u> associated with protective functions required for Normal Clearing (<u>an exception is a single station dc supply</u> <u>that is both monitored and reported</u> at a Control Center for <u>both low</u> <u>voltage and open circuit</u>)

- Some utilities have redundant DC batteries on some or all of their BES stations.
- Many utilities do not have redundant DC batteries at all BES stations.
- The exception for a single battery can be used but is complicated.
- Monitoring and alarming from the battery charger is generally not sufficient to meet the exception.
- See diagram on next slide.



DC Supply Monitoring

- Most companies have DC UV alarms
- New battery chargers have sophisticated monitoring/alarms but typically do not detect open battery cells or connectors
- Typical battery charger monitoring cannot detect an open cell if DC load is still connected.
- Battery Monitoring Systems are generally required to meet the monitoring exception.
- DC supply monitoring requirement of PRC-005 will meet TPL-001.5.



13d. A single control circuitry (including auxiliary relays and lockout relays) associated with protective functions, <u>from the dc supply through</u> and including the trip coil(s) of the circuit breakers or other interrupting devices, required for Normal Clearing (the trip coil may be excluded if it is both monitored and reported at a Control Center).

- Control circuitry in 13d is the most challenging part of footnote 13.
- Note the monitoring exclusion is <u>only for the trip coil</u> and no other components of the control circuit.
- The authors company has submitting a NERC Standard Authorization Request(SAR) to change 13d to allow excluding all components of the control circuit that are monitored and reported.
- See following figures

Decide Where to Draw the Line;

Drawing from the Technical Rationale for TPL-001.5



- Can you draw the line of demarcation between DC Supply (footnote 13.c) and Control Circuits (footnote 13.d) anywhere?
- No gap should exist between DC Supply and Control Circuits.
- Have you ever had a complete DC panel failure?

Figure from FERC Order No. 754 and NERC Technical Paper and Technical Rational for TPL-001.5

Control Circuitry – DC Panels



- If Primary and Backup Relays are both fed from the same DC Circuit they **fail** redundancy
- If Primary and Backup Relays are fed from separate circuits on DC Panel 1 they **fail** redundancy
- If Primary Relay is fed from DC Panel 1 and Backup Relay is fed from DC Panel 3 they **fail** redundancy
- If Primary Relay is fed from DC Panel 1 and Backup Relay is fed from DC Panel 2 they **pass** redundancy
- What if a breaker DC and Breaker Failure Relay DC are fed from the same panel?

Control Circuit – Monitored and Reported



TCM is a Trip Coil Monitor or Trip Circuit Monitor?

- Note the number of elements in the control circuit: DC panel, fuses, breakers, control wire, aux relay, trip wire, trip coil
- This Installation provides redundancy or monitoring for every portion of the control circuit but does not meet the exclusion allowed in 13d. The exclusion only applies to the trip coil
- If the relay alarm contacts are connected to a separate control circuit, a failure in the DC panel will trigger the relay alarm, a failure in the relay will trigger the relay alarm, a failure of the trip circuit Including the trip coil will trigger the trip circuit monitor alarm if programmed.

Control Circuitry –

Dual Trip Wires and Dual Trip Coils



- Best in Class / NPCC Required
- Design encouraged by Footnote 13d.

- Trip Coil A Solenoid and latch in a circuit breaker to initiate a trip
- Trip Wire Wire from any trip initiating device in the control house to the circuit breaker
- Trip Circuit Trip Coil and Trip Wire

Control Circuitry

Single Trip Wire and Single Trip Coil

The only way to meet 13 d is to add a second trip wire and trip coil Control House 100% Redundant Per Footnote 13 a-d with Trip Circuit Monitor Inside Control House



Circuit Breaker

- Many Companies have some legacy breakers with single Trip Coils.
- Breakers with one Trip Coil
 generally have one Trip Circuit
- Trip Circuit Monitor A device/ function that monitors an associated circuit breaker's trip circuit for continuity and for the presence of tripping voltage and sets an externally readable alarm when continuity or tripping voltage is lost (a surrogate for the traditional red light on relay and control panels). IEEE Std 3004.8-2016
- A Trip Circuit Monitor In the Control House monitors the entire Trip Circuit (Trip Wire + Trip Coil) but does not meet the monitoring exclusion for this configuration.

Control Circuitry –

Dual Trip Circuits and Single Trip Coil



- Many companies have some legacy (old) breakers with single trip coils.
- An exclusion is provided for a single trip coil that is monitored and reported but the exclusion does not include the trip wire.
- This design is not practical. It will require combining separate DC trip wires onto common terminals of the Trip Coil creating a single point of failure.

Future Impacts Of Current Language

Current language in 13 d could require spending millions of dollars in a large substation with minimal benefit





- When TPL-001-5 R 2.7 becomes enforceable, it will require corrective actions for studies that do not meet stability criteria.
- Control circuits in scope of TPL-001-5 Footnote 13d that are non redundant, could require corrective action such as installation of a redundant trip wire and trip coil.
- Some installations utilize underground conduit (fig A) and some use trenches (figure B).
- Underground conduit may be fully utilized, plugged with mud or collapsed in older substations.
 - Adding new conduit in energized substations frequently requires hand digging, which can be extremely expensive with no significant reliability improvement.

Track Future Changes to Your System

- Assuming your system is not perfect the following steps are required:
 - Determine all BES elements that do not meet footnote 13 Redundancies.
 - 13 d requires validating DC panel layout, DC circuit arrangement, Trip circuit redundancy, trip coil redundancy, Aux relay redundancy, etc. Detailed print review by experienced engineers is required. Estimates range from 2.5 to 5 hours per BES line.
- Creating a process or database for this information and keeping this up to date as equipment is installed or replaced will save large amounts of labor as you perform this evaluation for annual TPL -001 studies for gap analysis.
- Footnote 13 a-d cover parts of the Protection System but do Protection Engineers manage or own <u>all</u> of the assets covered?

Evidence of Monitor and Reported to a Control Center

- Evidence should be a list of Alarm Points displayed for Control Center Operators tied to every exception taken for Monitor and Reporting.
- Telling an auditor it is your standard practice may not be acceptable.
- Looking at alarms wired to an RTU at a substation may not be acceptable.
- The authors assumed that all required monitor and report elements were displayed at Control Center per company standards. This was determined to be inadequate due to SCADA mapping or naming errors on numerous points.

TPL-001.5.1 Footnote 13 d Standards Authorization Request – Submitted by PG&E

Purpose of SAR

The goal is to enhance the language of the Footnote 13d exclusion to "**any non-redundant components of the control circuitry that are both monitored and reported**" in addition to the current exclusion of the single trip coil. The proposed modification will reduce the burden on the DP, GO, and TO that would be required to install redundant control circuitry to ensure the BES will operate reliably over a broad spectrum of system conditions and following a wide range of probable contingencies that are studied under the TPL-001-5.1 Reliability Standard. This goal can be accomplished by modifying the exclusion language to include monitored and reported components of the control circuitry while reducing risk to BES performance by avoiding additional Protection System complexity.

• Changing the monitoring and reporting exclusion from "trip coil" to "trip circuit" is not equivalent to "control circuitry"

TPL-001.5.1 Footnote 13 d Standards Authorization Request – Submitted by PG&E

<u>Timeline</u>

Project 2022-02 was authorized to address multiple SAR's affecting modeling under MOD-032 and IBR issues related to TPL-001.5.

PG&E submitted SAR to NERC on December 8, 2022

SAR to modify TPL-001.5 footnote 13 accepted by NERC Board of Directors and assigned to existing SDT 2022-02.

FERC Order 901 became effective on December 18, 2023.

Project 2022-02 phase 1 to modify MOD-032 is considered high priority and may be completed by the end of 2025

Project 2022-02 phase 2 to modify TPL-001.5 currently has no projected timeline.

The NERC SPCWG has created a draft white paper to assist the SDT and a draft Implementation Guidance document related to TPL-001.5 footnote 13 d. Neither of these efforts has resulted in any change.

Shared Bus With Separate DC Supply and Control Circuitry



- 1. TPL-001.5 only applies to TP and TPC.
- 2. Bus fault with IPP battery failure.
- 3. Fault on CB 232, 242, 332, 432 or 442 with battery failure at IPP.
- 4. Fault on Switches 237, 247, or 437 with single point of failure in control circuitry.
- 5. These faults will result in delayed clearing.
- 6. Should utility require IPP and load customers to meet TPL-001.5 footnote 13 requirements?



Questions?





BAAH bus fault. Non Redundant Bus Differential scheme fails

Short Line / Longer Line

- Short Line/Long Line can be an overtrip issue.
- Zone 2 on long lines may outreach Zone 1 on short lines.

420

210

• If a fault on a short line occurs with a DC supply failure or communication failure multiple lines may trip out of section.



References

- NERC Project 2015-10 Technical Rational for TPL-001.5
- FERC Order No. 754. Single point of failure on Protection Systems
- NERC System Protection and Control Subcommittee Technical Paper of Protection System Reliability – Redundancy of Protection System Elements.
- NPCC Regional Reliability Reference Directory # 4 Bulk Power System Protection Criteria
- IEEE Std 3004.8-2016 View Definitions
 - Trip circuit monitor (TCM): A device/function that monitors an associated circuit breaker's trip circuit for continuity and for the presence of tripping voltage, and sets an externally readable alarm when continuity or tripping voltage is lost (a surrogate for the traditional red light on relay and control panels).
- IEEE Std C37.20.10-2016 View Definitions
 - Trip coil (of a mechanical switching device): A coil that is part of the electromagnet that initiates the action of a release (trip).
- IEEE PSRC, WG I 19|Redundancy Considerations for Protective Relaying Systems:
 - Another factor that contributes to the compromises of implementing a fully redundant protection scheme is the interconnection to existing equipment. An example of a limited redundant protection system results from connecting to existing circuit breakers that were originally built with single trip coils. In this case the cost of replacing the breaker to complete a fully redundant protection scheme would likely outweigh the other before mentioned benefits.

Advancements in Relay Contact Output Self-Testing and Trip Circuit Monitoring Capabilities

Austin Wade, David Schmidt, Brandon Nafsinger, and Jordan Bell Schweitzer Engineering Laboratories, Inc.





Do we have areas in our protection systems that have failed, yet we are missing the data?



Field-returned data demonstrate self-testing effectiveness

- Assessed 3,300 relays
- Recognized I/O as one of the last self-testing gaps



Trip circuit is critical to power system operation



It is time to reevaluate our trip contacts?

New output contact provides comprehensive monitoring

CM outputs

- Are built on proven highspeed, high-current output contact
- Incorporate
 - Voltage: 0-300 V
 - Current: 0–20 A





What does current tell us?



Consistent trip signature on same coil



Different breaker types and ratings



Simple algorithm for single contact

- Success when current is measured
- Fail when no current is measured



Success when current is measured



Declaring fail is not as simple


Relays know when closed output should measure current



Fail is only declared in trip window



Output closes outside of trip window



Both outputs declare success



Trip circuit monitor is built-in



What is a hidden failure?



Hidden failure (N-1)

Redundancy is ineffective if not constantly supervised

- High expense
- Hidden problems



Hidden failures in cross-tripping scheme



Which output trips the breaker?



SPT breaker wired to trip all three poles



Use manual switching to validate trip circuits



Slow breaker can indicate maintenance need



Use CM data to proactively monitor health

RTU/automation controller

- TC profiles composites
- Basic profile analysis

SCADA/central repository

- TC profile of all similar equipment
- Advanced profile analysis



Hidden failures eventually line up



Source: BenAveling

Conclusion

- Detects previously hidden failures
- Complements traditional TCM
- Provides missing data for critical trip circuits
- Opens the door to conditionbased monitoring... and more!





Questions?



Scan for corresponding technical paper