

Lesson Learned

Generation Relaying – Underfrequency Protection Coordination

Primary Interest Groups

Generation Owners (GOs)

Problem Statement

During a bulk power system (BPS) event, system frequency dipped below the auxiliary equipment relay frequency protection setting at a generating plant, causing auxiliary equipment to trip. This resulted in the loss of two generating units, which contributed to a significant load-loss event.

Details

A frequency protective relay scheme was installed on a generating plant's auxiliary equipment, which enabled under- and overfrequency element trip schemes on the equipment feeders. The associated feeders' underfrequency protection scheme was set to trip auxiliary equipment if the frequency was 59.5 Hz or less for two seconds. These underfrequency relay trip settings were installed on the system unnecessarily and weren't coordinated with the generators relay trip settings. A disturbance on the system caused the frequency to decline, and the new medium-voltage equipment relay schemes tripped out the boilers and turbines, which resulted in two generators tripping.

Corrective Actions

The frequency relay trip settings on the auxiliary equipment feeder relays were determined to be unnecessary and were removed. All existing settings associated with the auxiliary equipment at the plant were reviewed to ensure no other unintended trip settings or coordination issues existed.

Lessons Learned

Unintended generator tripping during an underfrequency event can exacerbate the condition.

To ensure reliable generator operation:

- Generator relay protection should be coordinated with all auxiliary power system relaying with specific regard to time-delay settings.
- Auxiliary equipment should be checked to ensure its protection and controls do not unnecessarily limit the generator.
- Before placing new equipment in service, a thorough review should be done of all electrical equipment, with particular attention to relay settings.

NERC's goal with publishing lessons learned is to provide industry with technical and understandable information that assists them with maintaining the reliability of the bulk power system. NERC requests that you provide input on this lesson learned by taking the short survey provided in the link below.

Click here for: [Lesson Learned Comment Form](#)

For more Information please contact:

[NERC – Lessons Learned](#) (via email)

[Jacquie Smith](#) (via email) or (303) 247-3067

Source of Lesson Learned:

ReliabilityFirst

Lesson Learned #:

20140601

Date Published:

June 19, 2014

Category:

Relaying and Protection Systems

This document is designed to convey lessons learned from NERC's various activities. It is not intended to establish new requirements under NERC's Reliability Standards or to modify the requirements in any existing Reliability Standards. Compliance will continue to be determined based on language in the NERC Reliability Standards as they may be amended from time to time. Implementation of this lesson learned is not a substitute for compliance with requirements in NERC's Reliability Standards.