# **Lesson Learned**

## Combustion Turbine Anti-Icing Control Strategy

### **Primary Interest Groups**

Generator Owner (GO) Generator Operators (GOP)

#### **Problem Statement**

Unexpected icing due to intermittent interference from outside sources may present operating challenges.

## Details

After an entity's investigation of an icing-over of a combustion turbine air inlet, it was determined that there were several situations where the original equipment manufacturer's (OEM) anti-icing logic did not detect all potential icing conditions as currently designed. This investigation was performed in consultation with the OEM's engineering department and included independent research from the entity's power plant users group. In a few instances, unexpected icing occurred where combustion turbine air inlets were subject to intermittent interference from outside sources of warm and moist air streams, such as when located near surface water bodies (rivers, lakes, oceans) or near artificial sources that emit warm, saturated air streams (such as cooling tower plumes, exhaust stack plumes, blowdown tank vents, flash tank vents, etc.). Although these outside sources are somewhat intermittent and unpredictable, they can occasionally impact the combustion turbine inlet air, depending on wind speed and direction, wind gust intensity, and plant equipment orientation. Due to the intermittent nature of these occurrences, the anti-icing instrumentation did not consistently detect these instances and icing in the inlet ductwork occurred.

## **Corrective Actions**

As a result of these occurrences, the entity instituted a more aggressive combustion turbine anti-icing strategy to prevent a reoccurrence. In addition to using the existing OEM anti-icing software package, the entity's solution proactively opens the inlet bleed heat valve to a minimum value of 10% whenever ambient temperatures drop below 45°F, ensuring a baseline level of heating is added to the combustion turbine inlet air at all times during cold weather operation. This minimum value was recommended through consultation with the OEM's engineering department along with in-service testing on the combustion turbines. To date, this approach has proven effective and has prevented a reoccurrence of the issue.

#### Lesson Learned

Ensure that manual corrective actions are proactively taken when unexpected icing may occur due to intermittent interference from outside sources of warm, moist air streams from rivers, lakes, or oceans or near artificial sources that emit warm, saturated air streams, such as cooling tower plumes, exhaust stack plumes, blowdown tank vents, or flash tank vents. Also see <u>NERC Lesson Learned LL20120903</u> "Winter <u>Storm Inlet Air Duct Icing.</u>"<sup>1</sup>

<sup>&</sup>lt;sup>1</sup> https://www.nerc.com/pa/rrm/ea/Lessons%20Learned%20Document%20Library/LL20120903\_Winter\_Storm\_Inlet\_Air\_Duct\_Icing.pdf

NERC's goal with publishing lessons learned is to provide industry with technical and understandable information that assists them with maintaining the reliability of the bulk power system. NERC is asking entities who have taken action on this lesson learned to respond to the short survey provided in the link below.

#### Click here for: Lesson Learned Survey

Lesson Learned #:	LL20230401
Date Published:	April 19, 2023
Category:	Generation Facilities

#### For more Information please contact:

#### NERC – Lessons Learned (via email)

This document is designed to convey lessons learned from NERC's various activities. It is not intended to establish new requirements under NERC's Reliability Standards or to modify the requirements in any existing Reliability Standards. Compliance will continue to be determined based on language in the NERC Reliability Standards as they may be amended from time to time. Implementation of this lesson learned is not a substitute for compliance with requirements in NERC's Reliability Standards.