

Note: an Interpretation cannot be used to change a standard.

Request for an Interpretation of a Reliability Standard
Date submitted: January 20, 2010
Date accepted: January 20, 2010
Contact information for person requesting the interpretation:
Name: Thomas E Washburn
Organization: Florida Municipal Power Pool
Telephone: 407-384-4066
E-mail: twashburn@ouc.com
Identify the standard that needs clarification:
Standard Number (include version number): TOP-002-2a
Standard Title: Normal Operations Planning
Identify specifically what requirement needs clarification:
<p>Requirement Number and Text of Requirement:</p> <p>R2. Each Balancing Authority and Transmission Operator shall ensure its operating personnel participate in the system planning and design study processes, so that these studies contain the operating personnel perspective and system operating personnel are aware of the planning purpose.</p> <p>R8. Each Balancing Authority shall plan to meet voltage and/or reactive limits, including the deliverability/capability for any single contingency.</p> <p>R19. Each Balancing Authority and Transmission Operator shall maintain accurate computer models utilized for analyzing and planning system operations.</p> <p>Clarification needed:</p> <p>For R2: What does "ensure" mean in this requirement for the Balancing Authority's operating personnel – does this mean that the Balancing Authority's operating personnel must be made available to the entity that performs the system planning and design studies for participation in those system planning and design study?</p> <p>For R8: Does "deliverability/ capability" mean to the generator terminals? Does "voltage and/or reactive limits" mean to the generator terminals?</p> <p>For R19: In the NERC Functional Model the Balancing Authority does not analyze and plan transmission operations. Does Requirement R19 mean that the Balancing Authority needs to maintain accurate computer models to analyze and plan to maintain a load-interchange-generation balance?</p>
Identify the material impact associated with this interpretation:

Identify the material impact to your organization or others caused by the lack of clarity or an incorrect interpretation of this standard.

Not having the correct interpretation of this requirement could cause a BA only (BA that is not a TOP) to be found non-compliant.