

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Implementation Plan Contents:

Prerequisite Approvals..... 2
Conforming Changes to Requirements in Already Approved Standards 2
Revisions or Retirements to Already Approved Standards..... 3
 EOP-001-0 3
 IRO-002-1 4
 IRO-003-2 6
 IRO-004-1 7
 IRO-005-2 10
 TOP-003-0 15
 TOP-005-1 16
 TOP-006-1 19
Functions that Must Comply with the Requirements in the Standards 20
Effective Dates 20

Prerequisite Approvals

Reliability Standard FAC-014-1 — Establish and Communicate System Operating Limits, needs to be approved by applicable regulatory authorities before this set of standards becomes effective:

- IRO-007 — Monitoring the Wide Area
- IRO-008 — Reliability Coordinator Operational Analyses and Real-time Assessments
- IRO-009 — Reliability Coordinator Actions to Operate Within IROLs
- IRO-010 — Reliability Coordinator Data Specification and Collection

Conforming Changes to Requirements in Already Approved Standards

Many elements contained in the set of proposed ‘Operate within IROL Standards’ address the same or similar performance objectives as requirements in already approved standards. To eliminate duplication and minimize confusion, the following requirements in Version 0 Standards should be revised or retired when the proposed standards are implemented. Justification for these revisions and retirements is provided in the tables on the following pages.

EOP-001-0 — Emergency Operations Planning

- Retire R2

IRO-002-1 — Reliability Coordination – Facilities

- Retire R2 and R6

IRO-003-2 — Reliability Coordination – Wide Area View

- Retire entire standard (R1 and R2)

IRO-004-1 — Reliability Coordination – Operations Planning

- Retire entire standard (R1 through R6)

IRO-005-2 — Reliability Coordination – Current Day Operations

- Retire R1, convert most of R1 into a reference; retire R2, R3, and R5; modify R9, R13 and R14; retire R16 and R17

TOP-003-0 — Planned Outage Coordination

- Modify R1.2

TOP-005-1 — Operational Reliability Information

- Retire R1 and R1.1
- Convert Attachment 1 into a reference

TOP-006-1 — Monitoring System Conditions Voltage and Reactive Control

- Modify R2 and R4

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Revisions or Retirements to Already Approved Standards

The following tables identify the sections of approved standards that shall be retired or revised when this standard is implemented. If the drafting team is recommending the retirement or revision of a requirement, that text is blue.

Already Approved Standard	Proposed Replacement Requirement(s)
<p>EOP-001-0</p> <p>R2. The Transmission Operator shall have an emergency load reduction plan for all identified IROLs. The plan shall include the details on how the Transmission Operator will implement load reduction in sufficient amount and time to mitigate the IROL violation before system separation or collapse would occur. The load reduction plan must be capable of being implemented within 30 minutes.</p>	<p>IRO-009-1 R1.</p> <p>R1. The Reliability Coordinator shall have one or more Operating Processes, Procedures, or Plans that identify actions it shall take or actions it shall direct others to take, for both prevention of exceeding IROLs and mitigation of instances of exceeding its IROLs within T_v up to and including load shed.</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-009-1 becomes effective, EOP-001-0 R2 should be retired. ▪ The Reliability Coordinator, not the Transmission Operator, is responsible for developing plans for mitigating IROLs. There are no measures or levels of non-compliance that need to be revised or retired when EOP-001-0 R2 is deleted. Mitigation plans need to be implemented so that the instance of exceeding the IROL is mitigated within the IROL's T_v, which can be shorter than 30 minutes. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Already Approved Standard	Proposed Replacement Requirement(s)
<p>IRO-002-1</p> <p>R2. Each Reliability Coordinator shall determine the data requirements to support its reliability coordination tasks and shall request such data from its Transmission Operators, Balancing Authorities, Transmission Owners, Generation Owners, Generation Operators, and Load-Serving Entities, or adjacent Reliability Coordinators.</p>	<p>IRO-010-1</p> <p>R1. The Reliability Coordinator shall specify and collect the data and information it needs to support Real-Time Monitoring, Operational Planning Analyses, and Real-Time Assessments. The Reliability Coordinator shall collect this data from the entities performing functions that have Facilities monitored by the Reliability Coordinator, and from entities that provide Real-Time Facility status to the Reliability Coordinator. This includes specifying and collecting data from the following:</p> <ul style="list-style-type: none"> R1.1 Balancing Authorities R1.2 Generator Owners R1.3 Generator Operators R1.4 Interchange Authority R1.5 Load-Serving Entities R1.6 Reliability Coordinators R1.7 Transmission Operators R1.8 Transmission Owners
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-010-1 becomes effective, IRO-002-1 R2 should be retired. ▪ IRO-010-1 R1 requires the Reliability Coordinator to develop and distribute a data specification to ensure that entities provide data as needed to support monitoring, analyses and assessments. The proposed requirement is more explicit than the associated requirement in IRO-002-0. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Version 0 Standards	Proposed Replacement Requirement(s)
<p>IRO-002-1</p> <p>R6. Each Reliability Coordinator shall monitor Bulk Electric System elements (generators, transmission lines, buses, transformers, breakers, etc.) that could result in SOL or IROL violations within its Reliability Coordinator Area. Each Reliability Coordinator shall monitor both real and reactive power system flows, and operating reserves, and the status of Bulk Electric System elements that are or could be critical to SOLs and IROLs and system restoration requirements within its Reliability Coordinator Area.</p>	<p>IRO-007-1</p> <p>R1. The Reliability Coordinator shall perform Real-Time Monitoring of system operating parameters within its Wide Area to determine if operating parameters are within their associated Interconnection Reliability Operating Limits (IROLs).</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-007-1 becomes effective, IRO-002-1 R6 should be retired. ▪ IRO-002-1 R6 identifies some, but not all of the parameters to be monitored by the Reliability Coordinator and can be misleading. A list of elements to be monitored (from IRO-005-2) has been converted into a Technical Reference. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Already Approved Standard	Proposed Replacement Requirement(s)
<p>IRO-003-2</p> <p>R1. Each Reliability Coordinator shall monitor all Bulk Electric System facilities, which may include sub-transmission information, within its Reliability Coordinator Area and adjacent Reliability Coordinator Areas, as necessary to ensure that, at any time, regardless of prior planned or unplanned events, the Reliability Coordinator is able to determine any potential System Operating Limit and Interconnection Reliability Operating Limit violations within its Reliability Coordinator Area.</p> <p>R2. Each Reliability Coordinator shall know the current status of all critical facilities whose failure, degradation or disconnection could result in an SOL or IROL violation. Reliability Coordinators shall also know the status of any facilities that may be required to assist area restoration objectives.</p>	<p>IRO-007-1</p> <p>R1. The Reliability Coordinator shall perform Real-Time Monitoring of system operating parameters within its Wide Area to determine if operating parameters are within their associated Interconnection Reliability Operating Limits (IROLs).</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-007-1 becomes effective, IRO-003-2 should be retired. ▪ The Transmission Operator, not the Reliability Coordinator, is responsible for operating within System Operating Limits. The Reliability Coordinator is responsible for operating within IROLs. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Already Approved Standard	Proposed Replacement Requirement(s)
<p>IRO-004-1</p> <p>R1. Each Reliability Coordinator shall conduct next-day reliability analyses for its Reliability Coordinator Area to ensure that the Bulk Electric System can be operated reliably in anticipated normal and Contingency event conditions. The Reliability Coordinator shall conduct Contingency analysis studies to identify potential interface and other SOL and IROL violations, including overloaded transmission lines and transformers, voltage and stability limits, etc.</p> <p>R2. Each Reliability Coordinator shall pay particular attention to parallel flows to ensure one Reliability Coordinator Area does not place an unacceptable or undue Burden on an adjacent Reliability Coordinator Area.</p>	<p>IRO-008-1</p> <p>R1. The Reliability Coordinator shall perform Operational Planning Analysis to assess whether the planned operations for the next day within its Wide Area, will exceed any of its Interconnection Reliability Operating Limits (IROLs) during anticipated normal and Contingency event conditions.</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-008-1 becomes effective, IRO-004-1 R1 and R2 should be retired. ▪ IRO-008 R1 requires the Reliability Coordinator to look at its 'Wide Area' rather than its 'Reliability Coordinator Area' in conducting its Operational Planning Analyses. ▪ IRO-004-1 R2 is not measurable and rather than retain it as the last remaining requirement in this standard, it should be retired when IRO-008 becomes effective. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Already Approved Standard	Proposed Replacement Requirement(s)
<p>IRO-004-1</p> <p>R3. Each Reliability Coordinator shall, in conjunction with its Transmission Operators and Balancing Authorities, develop action plans that may be required, including reconfiguration of the transmission system, re-dispatching of generation, reduction or curtailment of Interchange Transactions, or reducing load to return transmission loading to within acceptable SOLs or IROLs.</p> <p>R6. If the results of these studies indicate potential SOL or IROL violations, the Reliability Coordinator shall direct its Transmission Operators, Balancing Authorities and Transmission Service Providers to take any necessary action the Reliability Coordinator deems appropriate to address the potential SOL or IROL violation.</p>	<p>IRO-009-1</p> <p>R1. The Reliability Coordinator shall have one or more Operating Processes, Procedures, or Plans that identify actions it shall take or actions it shall direct others to take, for both prevention of exceeding IROLs and mitigation of instances of exceeding its IROLs within Tv up to and including load shed.</p> <p>R2. When an assessment of actual or expected system conditions predicts that an IROL will be exceeded, the Reliability Coordinator shall implement one or more Operating Processes, Procedures or Plans to prevent exceeding that IROL.</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-009-1 becomes effective, IRO-004-1 R3 and R6 should be retired. ▪ IRO-009-1 R1 requires the Reliability Coordinator to have plans to prevent and mitigate instances of exceeding IROLs – under some conditions, the Reliability Coordinator may not have time to ‘coordinate’ the development of these plans with all of its Transmission Operators and Balancing Authorities. ▪ IRO-009-1 R2 includes language that is more explicit than the language in IRO-004-1 R6: ‘results of these studies’ is not as specific as ‘when an assessment of actual or expected system conditions’. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Already Approved Standard	Proposed Replacement Requirement(s)
<p>IRO-004-1</p> <p>R4. Each Transmission Operator, Balancing Authority, Transmission Owner, Generator Owner, Generator Operator, and Load-Serving Entity in the Reliability Coordinator Area shall provide information required for system studies, such as critical facility status, Load, generation, operating reserve projections, and known Interchange Transactions. This information shall be available by 1200 Central Standard Time for the Eastern Interconnection and 1200 Pacific Standard Time for the Western Interconnection.</p> <p>R5. Each Reliability Coordinator shall share the results of its system studies, when conditions warrant or upon request, with other Reliability Coordinators and with Transmission Operators, Balancing Authorities, and Transmission Service Providers within its Reliability Coordinator Area. The Reliability Coordinator shall make study results available no later than 1500 Central Standard Time for the Eastern Interconnection and 1500 Pacific Standard Time for the Western Interconnection, unless circumstances warrant otherwise.</p> <p>IRO-005-2</p> <p>R2. Each Reliability Coordinator shall be aware of all Interchange Transactions that wheel through, source, or sink in its Reliability Coordinator Area, and make that Interchange Transaction information available to all Reliability Coordinators in the Interconnection.</p>	<p>IRO-010-1</p> <p>R1. The Reliability Coordinator shall have a documented data specification for data and information to build and maintain models to support Real-Time Monitoring, Operational Planning Analyses, and Real-time Assessments. The specification shall include the following: (Risk Factor: Medium) (Mitigation Time Horizons: Operations Planning)</p> <p>R1.1. List of required data and information</p> <p>R1.2. Mutually agreeable format</p> <p>R1.3. Timeframe and periodicity for providing data and information (based on its hardware and software requirements, and the time needed to do its Operational Planning Analyses)</p> <p>R1.4. Process for data provision when automated Real-Time system operating data is unavailable.</p> <p>R3. Each Balancing Authority, Generator Owner, Generator Operator, Interchange Authority, Load-serving Entity, Reliability Coordinator, Transmission Operator, and Transmission Owner shall provide data and information, as specified, to the Reliability Coordinator(s) with which it has a reliability relationship. The data and information is limited to data needed by the Reliability Coordinator to support Real-Time Monitoring, Operational Planning Analyses, and Real-Time Assessments.</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-010-1 becomes effective, IRO-004-1 R4 and R5 should be retired. ▪ IRO-010-1 is based on the philosophy that the Reliability Coordinator needs to know, in advance, what data and information it needs and what data and information it needs to share. The periodicity for collecting the data is addressed in IRO-010-1 R1.3. Only a fraction of the reliability-related data needed by the Reliability Coordinator and shared by the Reliability Coordinator is addressed in IRO-004-1 R4 and R5. ▪ When IRO-010-1 becomes effective, IRO-005-2 R2 should be retired. The e-tag system replaced the need for this requirement. In addition, if the Reliability Coordinator needs this information, the Reliability Coordinator can add this item to the list of data and information on its data specification under IRO-010 R1 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Already Approved Standard	Proposed Replacement Requirement(s)
<p>IRO-005-2 R1. Each Reliability Coordinator shall monitor its Reliability Coordinator Area parameters, including but not limited to the following:</p> <ul style="list-style-type: none"> R1.1 Current status of Bulk Electric System elements (transmission or generation including critical auxiliaries such as Automatic Voltage Regulators and Special Protection Systems) and system loading. R1.2 Current pre-contingency element conditions (voltage, thermal, or stability), including any applicable mitigation plans to alleviate SOL or IROL violations, including the plan’s viability and scope. R1.3 Current post-contingency element conditions (voltage, thermal, or stability), including any applicable mitigation plans to alleviate SOL or IROL violations, including the plan’s viability and scope. R1.4 System real and reactive reserves (actual versus required). R1.5 Capacity and energy adequacy conditions. R1.6 Current ACE for all its Balancing Authorities. R1.7 Current local or Transmission Loading Relief procedures in effect. R1.8 Planned generation dispatches. R1.9 Planned transmission or generation outages. R1.10 Contingency events. 	<p>IRO-007-1 R1. The Reliability Coordinator shall perform Real-Time Monitoring of system operating parameters within its Wide Area to determine if operating parameters are within their associated Interconnection Reliability Operating Limits (IROLs).</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-008-1 becomes effective, IRO-005-2 R1 should be retired and R1.1 through R1.10 should be converted into a Technical Reference. IRO-005-2 R1 is duplicated with IRO-007-1 R1. The list of parameters to monitor (IRO-005 -2 R1.1 through R1.10) does not identify all parameters to monitor and can be misleading. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Already Approved Standard	Proposed Replacement Requirement(s)
<p>IRO-005-2 R3. As portions of the transmission system approach or exceed SOLs or IROLs, the Reliability Coordinator shall work with its Transmission Operators and Balancing Authorities to evaluate and assess any additional Interchange Schedules that would violate those limits. If a potential or actual IROL violation cannot be avoided through proactive intervention, the Reliability Coordinator shall initiate control actions or emergency procedures to relieve the violation without delay, and no longer than 30 minutes. The Reliability Coordinator shall ensure all resources, including load shedding, are available to address a potential or actual IROL violation.</p> <p>R5. Each Reliability Coordinator shall identify the cause of any potential or actual SOL or IROL violations. The Reliability Coordinator shall initiate the control action or emergency procedure to relieve the potential or actual IROL violation without delay, and no longer than 30 minutes. The Reliability Coordinator shall be able to utilize all resources, including load shedding, to address an IROL violation.</p>	<p>IRO-009-1 R1. The Reliability Coordinator shall have one or more Operating Processes, Procedures, or Plans that identify actions it shall take or actions it shall direct others to take, for both prevention of exceeding IROLs and mitigation of instances of exceeding its IROLs within T_v up to and including load shed.</p> <p>R2. When an assessment of actual or expected system conditions predicts that an IROL will be exceeded, the Reliability Coordinator shall implement one or more Operating Processes, Procedures or Plans to prevent exceeding that IROL.</p> <p>R3. When actual system conditions show that there is an instance of exceeding an IROL, the Reliability Coordinator shall, without delay, act or direct others to act to mitigate the magnitude and duration of the instance of exceeding that IROL.</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-009-1 becomes effective, IRO-005-2 R3, and R5 should be retired. ▪ IRO-005 R3 can lead the Reliability Coordinator to believe it has up to 30 minutes to relieve an IROL violation – but some IROLs have a T_v that is much shorter than 30 minutes. ▪ IRO-005 R5 can lead the Compliance Monitor to believe that the Reliability Coordinator has information to see all SOLs, and this is not always true. Every facility in the Transmission Operator’s area has a System Operating Limit, but the Reliability Coordinator isn’t required to see all these limits and may not have information to determine the cause of instances of exceeding these limits. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Already Approved Standard	Proposed Replacement Requirement(s)
<p>IRO-005-2</p> <p>R9. The Reliability Coordinator shall coordinate with Transmission Operators, Balancing Authorities, and Generator Operators as needed to develop and implement action plans to mitigate potential or actual SOL, IROL, CPS, or DCS violations. The Reliability Coordinator shall coordinate pending generation and transmission maintenance outages with Transmission Operators, Balancing Authorities, and Generator Operators as needed in both the real time and next-day reliability analysis timeframes.</p>	<p>IRO-009-1</p> <p>R1. The Reliability Coordinator shall have one or more Operating Processes, Procedures, or Plans that identify actions it shall take or actions it shall direct others to take, for both prevention of exceeding IROLs and mitigation of instances of exceeding its IROLs within T_v up to and including load shed.</p> <p>R2. When an assessment of actual or expected system conditions predicts that an IROL will be exceeded, the Reliability Coordinator shall implement one or more Operating Processes, Procedures or Plans to prevent exceeding that IROL</p> <p>R3. When actual system conditions show that there is an instance of exceeding an IROL, the Reliability Coordinator shall, without delay, act or direct others to act to mitigate the magnitude and duration of the instance of exceeding that IROL.</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-009-1 becomes effective, IRO-005-2 R9 should be modified. ▪ IRO-005 R9 includes two requirements – one for coordinating outages, and one for coordinating the mitigation of IROLs and other limits. IRO-009-1 includes requirements to have and execute action plans to prevent and mitigate instances of exceeding IROLs. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Already Approved Standard	Proposed Replacement Requirement(s)
<p>IRO-005-2 R13. Each Reliability Coordinator shall ensure that all Transmission Operators, Balancing Authorities, Generator Operators, Transmission Service Providers, Load-Serving Entities, and Purchasing-Selling Entities operate to prevent the likelihood that a disturbance, action, or non-action in its Reliability Coordinator Area will result in a SOL or IROL violation in another area of the Interconnection. In instances where there is a difference in derived limits, the Reliability Coordinator and its Transmission Operators, Balancing Authorities, Generator Operators, Transmission Service Providers, Load-Serving Entities, and Purchasing-Selling Entities shall always operate the Bulk Electric System to the most limiting parameter.</p>	<p>IRO-009-1 R1. The Reliability Coordinator shall have one or more Operating Processes, Procedures, or Plans that identify actions it shall take or actions it shall direct others to take, for both prevention of exceeding IROLs and mitigation of instances of exceeding its IROLs within T_v up to and including load shed.</p> <p>R2. When an assessment of actual or expected system conditions predicts that an IROL will be exceeded, the Reliability Coordinator shall implement one or more Operating Processes, Procedures or Plans to prevent exceeding that IROL.</p> <p>R3. When actual system conditions show that there is an instance of exceeding an IROL, the Reliability Coordinator shall, without delay, act or direct others to act to mitigate the magnitude and duration of the instance of exceeding that IROL.</p> <p>IRO-007-1 R2. If unanimity cannot be reached on the value for an IROL or its T_v, all Reliability Coordinators who monitor that Facility (or group of Facilities) shall, without delay, use the most conservative of the values under consideration.</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-007-1 and IRO-009-1 become effective, IRO-005-2 R13 should be retired. ▪ IRO-005 R13 has two requirements – one to direct actions to ensure SOLs and IROLs are not exceeded, and one requirement to operate to the most limiting parameter in situations where there is disagreement on a limit. The first requirement in IRO-015 R13 assumes that the Reliability Coordinator can see all System Operating Limits, and this is not always true. The Reliability Coordinator is responsible for seeing IROLs and controlling operations within its Reliability Coordinator Area so as to prevent instances of exceeding IROLs. ▪ The second part of IRO-005 R13 requires entities to operate to the most limiting parameter when there is a difference in derived limits. This should be revised so that it is not applicable to the Reliability Coordinator – IRO-007-1 R2 has a similar requirement that is applicable totally to the Reliability Coordinator. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Already Approved Standard	Proposed Replacement Requirement(s)
<p>IRO-005-2 R14. Each Reliability Coordinator shall make known to Transmission Service Providers within its Reliability Coordinator Area, SOLs or IROLs within its wide-area view. The Transmission Service Providers shall respect these SOLs or and IROLs in accordance with filed tariffs and regional Total Transfer Calculation and Available Transfer Calculation processes.</p> <p>R16. Each Reliability Coordinator shall confirm reliability assessment results and determine the effects within its own and adjacent Reliability Coordinator Areas. The Reliability Coordinator shall discuss options to mitigate potential or actual SOL or IROL violations and take actions as necessary to always act in the best interests of the Interconnection at all times.</p> <p>R17. When an IROL or SOL is exceeded, the Reliability Coordinator shall evaluate the local and wide-area impacts, both real-time and post-contingency, and determine if the actions being taken are appropriate and sufficient to return the system to within IROL in thirty minutes. If the actions being taken are not appropriate or sufficient, the Reliability Coordinator shall direct the Transmission Operator, Balancing Authority, Generator Operator, or Load-Serving Entity to return the system to within IROL or SOL.</p>	<p>IRO-009-1</p> <p>R2. When an assessment of actual or expected system conditions predicts that an IROL will be exceeded, the Reliability Coordinator shall implement one or more Operating Processes, Procedures or Plans to prevent exceeding that IROL.</p> <p>R3. When actual system conditions show that there is an instance of exceeding an IROL, the Reliability Coordinator shall, without delay, act or direct others to act to mitigate the magnitude and duration of the instance of exceeding that IROL.</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-009-1 becomes effective, IRO-005-2 R14 should be modified and R16 and R17 should be retired. ▪ IRO-005-2 R14 part 1 should be retired and part 2 should be modified as it is not correct. Notifying the Transmission Service Provider of SOLs and IROLs is already addressed under FAC-014 R5.1. The Transmission Service Provider should respect both SOLs and IROLs – R14 implies that the Transmission Service Provider may respect ‘either’ SOLs or IROLs. ▪ IRO-005 R16 is a mix of requirements and the Missing Measures and Compliance Elements drafting team determined that, as written, R16 is too vague to be measured. The intent of this requirement is duplicated more clearly in IRO-008 and IRO-009. ▪ IRO-005 R17 can lead the Reliability Coordinator to believe it has up to 30 minutes to relieve an IROL violation – but some IROLs have a T_v that is much shorter than 30 minutes. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Version 0 Standards	Proposed Replacement Requirement(s)
<p>TOP-003-0</p> <p>R1. Generator Operators and Transmission Operators shall provide planned outage information.</p> <p>R1.1 Each Generator Operator shall provide outage information daily to its Transmission Operator for scheduled generator outages planned for the next day (any foreseen outage of a generator greater than 50 MW). The Transmission Operator shall establish the outage reporting requirements.</p> <p>R1.2 Each Transmission Operator shall provide outage information daily to its Reliability Coordinator, and to affected Balancing Authorities and Transmission Operators for scheduled generator and bulk transmission outages planned for the next day (any foreseen outage of a transmission line or transformer greater than 100 kV or generator greater than 50 MW) that may collectively cause or contribute to an SOL or IROL violation or a regional operating area limitation. The Reliability Coordinator shall establish the outage reporting requirements.</p>	<p>IRO-010-1</p> <p>R1. The Reliability Coordinator shall have a documented data specification for data and information to build and maintain models to support Real-Time Monitoring, Operational Planning Analyses, and Real-time Assessments. The specification shall include the following: (Risk Factor: Medium) (Mitigation Time Horizons: Operations Planning)</p> <p>R1.1. List of required data and information</p> <p>R1.2. Mutually agreeable format</p> <p>R1.3. Timeframe and periodicity for providing data and information (based on its hardware and software requirements, and the time needed to do its Operational Planning Analyses)</p> <p>R1.4. Process for data provision when automated Real-Time system operating data is unavailable.</p> <p>R3. Each Balancing Authority, Generator Owner, Generator Operator, Interchange Authority, Load-serving Entity, Reliability Coordinator, Transmission Operator, and Transmission Owner shall provide data and information, as specified, to the Reliability Coordinator(s) with which it has a reliability relationship. The data and information is limited to data needed by the Reliability Coordinator to support Real-Time Monitoring, Operational Planning Analyses, and Real-Time Assessments.</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-010-1 becomes effective, TOP-003-0 R1.2 should be modified. ▪ IRO-010-1 requires the Reliability Coordinator to provide data to other Reliability Coordinators in accordance with the data specifications it has received from those other Reliability Coordinators. Daily outage data is one of the types of data that is expected to be identified on the Reliability Coordinator’s documented data specification since this is data needed to maintain real-time models. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Version 0 Standards	Proposed Replacement Requirement(s)
<p>TOP-005-1 R1. Each Transmission Operator and Balancing Authority shall provide its Reliability Coordinator with the operating data that the Reliability Coordinator requires to perform operational reliability assessments and to coordinate reliable operations within the Reliability Coordinator Area.</p> <p>R1.1 Each Reliability Coordinator shall identify the data requirements from the list in Attachment 1-TOP-005-0 “Electric System Reliability Data” and any additional operating information requirements relating to operation of the bulk power system within the Reliability Coordinator Area.</p>	<p>IRO-010-1 R1. The Reliability Coordinator shall have a documented data specification for data and information to build and maintain models to support Real-Time Monitoring, Operational Planning Analyses, and Real-time Assessments. (Risk Factor: Medium) (Mitigation Time Horizons: Operations Planning)</p> <p>R1.1. List of required data and information R1.2. Mutually agreeable format R1.3. Timeframe and periodicity for providing data and information (based on its hardware and software requirements, and the time needed to do its Operational Planning Analyses) R1.4. Process for data provision when automated Real-Time system operating data is unavailable.</p> <p>R3. Each Balancing Authority, Generator Owner, Generator Operator, Interchange Authority, Load-serving Entity, Reliability Coordinator, Transmission Operator, and Transmission Owner shall provide data and information, as specified, to the Reliability Coordinator(s) with which it has a reliability relationship. The data and information is limited to data needed by the Reliability Coordinator to support Real-Time Monitoring, Operational Planning Analyses, and Real-Time Assessments..</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-010-1 becomes effective, TOP-005-1 R1 and R1.1 should be retired. ▪ Under IRO-010-1 each Reliability Coordinator must document what data and information it needs and entities must provide that data. The data needed by the Reliability Coordinator is needed for more than just reliability assessments – some of the data is used for real-time monitoring. Several entities, beyond the Transmission Operator and Balancing Authority (the only responsible entities identified in R1 of TOP-005-1) have data and information needed by the Reliability Coordinator. 	

Version 0 Standards	Proposed Replacement
<p>TOP-005-1 Attachment 1-TOP-005-0 - Electric System Reliability Data</p> <p>This Attachment lists the types of data that Reliability Coordinators, Balancing Authorities, and Transmission Operators are expected to provide, and are expected to share with each other.</p> <ol style="list-style-type: none"> 1. The following information shall be updated at least every ten minutes: <ol style="list-style-type: none"> 1.1. Transmission data. Transmission data for all Interconnections plus all other facilities considered key, from a reliability standpoint: <ol style="list-style-type: none"> 1.1.1 Status. 1.1.2 MW or ampere loadings. 1.1.3 MVA capability. 1.1.4 Transformer tap and phase angle settings. 1.1.5 Key voltages. 1.2. Generator data. <ol style="list-style-type: none"> 1.2.1 Status. 1.2.2 MW and MVAR capability. 1.2.3 MW and MVAR net output. 1.2.4 Status of automatic voltage control facilities. 1.3. Operating reserve. <ol style="list-style-type: none"> 1.3.1 MW reserve available within ten minutes. 1.4. Balancing Authority demand. <ol style="list-style-type: none"> 1.4.1 Instantaneous. 1.5. Interchange. <ol style="list-style-type: none"> 1.5.1 Instantaneous actual interchange with each Balancing Authority. 1.5.2 Current Interchange Schedules with each Balancing Authority by individual Interchange Transaction, including Interchange identifiers, and reserve responsibilities. 1.5.3 Interchange Schedules for the next 24 hours. 1.6. Area Control Error and frequency. <ol style="list-style-type: none"> 1.6.1 Instantaneous area control error. 1.6.2 Clock hour area control error. 1.6.3 System frequency at one or more locations in the Balancing Authority. 2. Other operating information updated as soon as available. <ol style="list-style-type: none"> 2.1. Interconnection Reliability Operating Limits and System Operating Limits in effect. 2.2. Forecast of operating reserve at peak, and time of peak for current day and next day. 2.3. Forecast peak demand for current day and next day. 2.4. Forecast changes in equipment status. 2.5. New facilities in place. 2.6. New or degraded special protection systems. 2.7. Emergency operating procedures in effect. 2.8. Severe weather, fire, or earthquake. 2.9. Multi-site sabotage. 	<p>New Technical Reference</p>

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Notes:

- When IRO-010-1 becomes effective, 'Attachment 1-TOP-005-0 Electric System Reliability Data' should be translated into a Technical Reference. This data is only a partial list of data and information that the Reliability Coordinator needs to support reliable operations.

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Version 0 Standards	Proposed Replacement Requirement(s)
<p>TOP-006-1</p> <p>R2. Each Reliability Coordinator, Transmission Operator, and Balancing Authority shall monitor applicable transmission line status, real and reactive power flows, voltage, load-tap-changer settings, and status of rotating and static reactive resources.</p> <p>R4. Each Reliability Coordinator, Transmission Operator, and Balancing Authority shall have information, including weather forecasts and past load patterns, available to predict the system’s near-term load pattern.</p>	<p>IRO-007-1</p> <p>R1. The Reliability Coordinator shall perform Real-Time Monitoring of system operating parameters within its Wide Area to determine if operating parameters are within their associated Interconnection Reliability Operating Limits (IROLs).</p> <p>IRO-010-1</p> <p>R1. The Reliability Coordinator shall have a documented data specification for data and information to build and maintain models to support Real-Time Monitoring, Operational Planning Analyses, and Real-time Assessments. The specification shall include the following: (Risk Factor: Medium) (Mitigation Time Horizons: Operations Planning)</p> <ul style="list-style-type: none"> R1.1. List of required data and information R1.2. Mutually agreeable format R1.3. Timeframe and periodicity for providing data and information (based on its hardware and software requirements, and the time needed to do its Operational Planning Analyses) R1.4. Process for data provision when automated Real-Time system operating data is unavailable. <p>R3. Each Balancing Authority, Generator Owner, Generator Operator, Interchange Authority, Load-serving Entity, Reliability Coordinator, Transmission Operator, and Transmission Owner shall provide data and information, as specified, to the Reliability Coordinator(s) with which it has a reliability relationship. The data and information is limited to data needed by the Reliability Coordinator to support Real-Time Monitoring, Operational Planning Analyses, and Real-Time Assessments.</p>
<p>Notes:</p> <ul style="list-style-type: none"> ▪ When IRO-007-1 and IRO-010-1 become effective, TOP-006-1 R2 and R4 should be modified. ▪ The Reliability Coordinator’s monitoring requirements are addressed more globally in IRO-007-1. The Reliability Coordinator may not have access to all the transmission data identified in TOP-006-1 R2. ▪ The information identified in TOP-006-1 R4 is not inclusive, and is addressed more globally in IRO-010-1 R1 and R3. 	

Implementation Plan for Operate Within Interconnection Reliability Operating Limits Standards

Functions that Must Comply with the Requirements in the Standards

Standard	Functions that Must Comply With the Requirements							
	Reliability Coordinator	Balancing Authority	Interchange Authority	Transmission Operator	Transmission Owner	Generator Owner	Generator Operator	Load Serving Entity
IRO-007-1 Monitoring the Wide Area	X							
IRO-008-1 Analyses & Assessments	X							
IRO-009-1 Actions to Operate within IROLs	X							
IRO-010-1 Data Specification & Collection	X	X	X	X	X	X	X	X

Effective Dates

The standards should all become effective the latter of the first day of the first quarter, three months after regulatory approvals **or** coincident with the effective date for FAC-014-1 — Establish and Communicate System Operating Limits.