

Consideration of Comments

Project Name:	2016-02 Modifications to CIP Standards Virtualization - Draft 5
Comment Period Start Date:	10/3/2023
Comment Period End Date:	11/29/2023
Associated Ballot(s):	2016-02 Modifications to CIP Standards Virtualization CIP-003-9 AB 5 ST 2016-02 Modifications to CIP Standards Virtualization CIP-004-7 AB 5 ST 2016-02 Modifications to CIP Standards Virtualization CIP-005-8 AB 5 ST 2016-02 Modifications to CIP Standards Virtualization CIP-007-7 AB 5 ST 2016-02 Modifications to CIP Standards Virtualization CIP-010-5 AB 5 ST

There were 71 sets of responses, including comments from approximately 185 different people from approximately 116 companies representing 10 of the Industry Segments as shown in the table on the following pages.

All comments submitted can be reviewed in their original format on the [project page](#).

If you feel that your comment has been overlooked, let us know immediately. Our goal is to give every comment serious consideration in this process. If you feel there has been an error or omission, contact Director, Standards Development [Latrice Harkness](#) (via email) or at (404) 858-8088.

Questions

1. The SDT modified the IRA definition, CIP-005 R2 and CIP-004 Applicable Systems to address IRA in routable to nonroutable (i.e., IP to serial) conversion scenarios. Do you agree with the proposed changes? If not, please provide the basis for your disagreement and an alternate proposal.
2. The SDT modified other (not related to IRA) definitions used in the CIP standards based on industry comments. Do you agree with the proposed changes? If not, please provide the basis for your disagreement and an alternate proposal.
3. The SDT revised CIP-005 R1 based on industry comments. Do you agree with the proposed changes? If not, please provide the basis for your disagreement and an alternate proposal.
4. The SDT revised CIP-007 based on industry comments. Do you agree with the proposed changes? If not, please provide the basis for your disagreement and an alternate proposal.
5. The SDT made numerous clarifying changes to CIP-010 based on industry comments. Do you agree with the proposed changes? If not, please provide the basis for your disagreement and an alternate proposal.
6. The SDT revised CIP-003. Do you agree with the proposed changes to these Reliability Standards? If not, please provide the basis for your disagreement and an alternate proposal.
7. The SDT revised the Implementation Plan to accommodate for the future enforceable date of CIP-003-9. Do you agree with the proposed Implementation Plan? If not, please provide the basis for your disagreement and an alternate proposal.
8. Please provide any additional comments for the SDT to consider, if desired.

The Industry Segments are:

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
BC Hydro and Power Authority	Adrian Andreoiu	1	WECC	BC Hydro	Hootan Jarollahi	BC Hydro and Power Authority	3	WECC
					Helen Hamilton Harding	BC Hydro and Power Authority	5	WECC
					Adrian Andreoiu	BC Hydro and Power Authority	1	WECC
MRO	Anna Martinson	1,2,3,4,5,6	MRO	MRO Group	Shonda McCain	Omaha Public Power District (OPPD)	1,3,5,6	MRO

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
					Michael Brytowski	Great River Energy	1,3,5,6	MRO
					Jamison Cawley	Nebraska Public Power District	1,3,5	MRO
					Jay Sethi	Manitoba Hydro (MH)	1,3,5,6	MRO
					Jaimin Patal	Saskatchewan Power Corporation (SPC)	1	MRO
					Kimberly Bentley	Western Area Power Administration	1,6	MRO
					Marc Gomez	Southwestern Power Administration (SWPA)	1	MRO
					Fred Meyer	Algonquin Power Co.	3	MRO
					George Brown	Pattern Operators LP	5	MRO
					Larry Heckert	Alliant Energy (ALTE)	4	MRO
					Terry Harbour	MidAmerican Energy	1,3	MRO

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
						Company (MEC)		
					Bryan Sherrow	Board Of Public Utilities (BPU)	1	MRO
					Seth Shoemaker	Muscatine Power & Water	1,3,5,6	MRO
					Bobbi Welch	Midcontinent ISO, Inc.	2	MRO
					Michael Ayotte	ITC Holdings	1	MRO
Public Utility District No. 1 of Chelan County	Anne Kronshage	6		Public Utility District No. 1 of Chelan County - Voting Group	Anne Kronshage	Public Utility District No. 1 of Chelan County	6	WECC
					Diane Landry	Public Utility District No. 1 of Chelan County	1	WECC
					Rebecca Zahler	Public Utility District No. 1 of Chelan County	5	WECC
					Joyce Gundry	Public Utility District No. 1 of Chelan County	3	WECC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
Tennessee Valley Authority	Brian Millard	1,3,5,6	SERC	TVA RBB	Ian Grant	Tennessee Valley Authority	3	SERC
					David Plumb	Tennessee Valley Authority	1	SERC
					Armando Rodriguez	Tennessee Valley Authority	6	SERC
					Nehtisha Rollis	Tennessee Valley Authority	5	SERC
Jennie Wike	Jennie Wike		WECC	Tacoma Power	Jennie Wike	Tacoma Public Utilities	1,3,4,5,6	WECC
					John Merrell	Tacoma Public Utilities (Tacoma, WA)	1	WECC
					John Nierenberg	Tacoma Public Utilities (Tacoma, WA)	3	WECC
					Hien Ho	Tacoma Public Utilities (Tacoma, WA)	4	WECC
					Terry Gifford	Tacoma Public Utilities (Tacoma, WA)	6	WECC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
					Ozan Ferrin	Tacoma Public Utilities (Tacoma, WA)	5	WECC
ACES Power Marketing	Jodirah Green	1,3,4,5,6	MRO,RF,SERC,Texas RE,WECC	ACES Collaborators	Bob Soloman	Hoosier Energy Electric Cooperative	1	RF
					Nick Fogleman	Prairie Power, Inc.	1,3	SERC
					Kevin Lyons	Central Iowa Power Cooperative	1	MRO
					Jennifer Bray	Arizona Electric Power Cooperative, Inc.	1	WECC
					Marcus Perkins	Southern Maryland Electric Cooperative	3	RF
FirstEnergy - FirstEnergy Corporation	Mark Garza	4		FE Voter	Julie Severino	FirstEnergy - FirstEnergy Corporation	1	RF
					Aaron Ghodooshim	FirstEnergy - FirstEnergy Corporation	3	RF

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
					Robert Loy	FirstEnergy - FirstEnergy Solutions	5	RF
					Mark Garza	FirstEnergy-FirstEnergy	1,3,4,5,6	RF
					Stacey Sheehan	FirstEnergy - FirstEnergy Corporation	6	RF
California ISO	Monika Montez	2	WECC	ISO/RTO Council Standards Review Committee (SRC)	Monika Montez	CAISO	2	WECC
					Bobbi Welch	Midcontinent ISO, Inc.	2	RF
					Kathleen Goodman	ISO-NE	2	NPCC
					Gregory Campoli	New York Independent System Operator	2	NPCC
					Helen Lainis	IESO	2	NPCC
					Charles Yeung	Southwest Power Pool, Inc. (RTO)	2	MRO
					Kennedy Meier	Electric Reliability Council of Texas, Inc.	2	Texas RE
					Elizabeth Davis	PJM	2	SERC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
Southern Company - Southern Company Services, Inc.	Pamela Hunter	1,3,5,6	SERC	Southern Company	Matt Carden	Southern Company - Southern Company Services, Inc.	1	SERC
					Joel Dembowski	Southern Company - Alabama Power Company	3	SERC
					Ron Carlsen	Southern Company - Southern Company Generation	6	SERC
					Leslie Burke	Southern Company - Southern Company Generation	5	SERC
Northeast Power Coordinating Council	Ruida Shu	1,2,3,4,5,6,7,8,9,10	NPCC	NPCC RSC	Gerry Dunbar	Northeast Power Coordinating Council	10	NPCC
					Alain Mukama	Hydro One Networks, Inc.	1	NPCC
					Deidre Altobell	Con Edison	1	NPCC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
					Jeffrey Streifling	NB Power Corporation	1	NPCC
					Michele Tondalo	United Illuminating Co.	1	NPCC
					Stephanie Ullah-Mazzuca	Orange and Rockland	1	NPCC
					Michael Ridolfino	Central Hudson Gas & Electric Corp.	1	NPCC
					Randy Buswell	Vermont Electric Power Company	1	NPCC
					James Grant	NYISO	2	NPCC
					John Pearson	ISO New England, Inc.	2	NPCC
					Harishkumar Subramani Vijay Kumar	Independent Electricity System Operator	2	NPCC
					Randy MacDonald	New Brunswick Power Corporation	2	NPCC
					Dermot Smyth	Con Ed - Consolidated	1	NPCC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
						Edison Co. of New York		
					David Burke	Orange and Rockland	3	NPCC
					Peter Yost	Con Ed - Consolidated Edison Co. of New York	3	NPCC
					Salvatore Spagnolo	New York Power Authority	1	NPCC
					Sean Bodkin	Dominion - Dominion Resources, Inc.	6	NPCC
					David Kwan	Ontario Power Generation	4	NPCC
					Silvia Mitchell	NextEra Energy - Florida Power and Light Co.	1	NPCC
					Glen Smith	Entergy Services	4	NPCC
					Sean Cavote	PSEG	4	NPCC
					Jason Chandler	Con Edison	5	NPCC
					Tracy MacNicoll	Utility Services	5	NPCC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
					Shivaz Chopra	New York Power Authority	6	NPCC
					Vijay Puran	New York State Department of Public Service	6	NPCC
					ALAN ADAMSON	New York State Reliability Council	10	NPCC
					David Kiguel	Independent	7	NPCC
					Joel Charlebois	AESI	7	NPCC
					Joshua London	Eversource Energy	1	NPCC
Shannon Mickens	Shannon Mickens		MRO,SPP RE,WECC	SPP RTO	Shannon Mickens	Southwest Power Pool Inc.	2	MRO
					Mia Wilson	Southwest Power Pool Inc.	2	MRO
					Josh Phillips	Southwest Power Pool Inc.	2	MRO
					Shelly Young	Southwest Power Pool Inc.	2	MRO

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
					David Minick	Southwest Power Pool Inc.	2	MRO
					Mike Wikerson	Southwest Power Pool Inc.	2	MRO
					Chris Evans	Southwest Power Pool Inc.	2	MRO
					Barry Bull	Southwest Power Pool Inc.	2	MRO
					Rebecca Sanders	Southwest Power Pool Inc.	2	MRO
					Steve Shirley	Southwest Power Pool Inc.	2	MRO
					Cheryl Kirk	Southwest Power Pool Inc.	2	MRO
Western Electricity Coordinating Council	Steven Rueckert	10		WECC CIP	Steve Rueckert	WECC	10	WECC
					Morgan King	WECC	10	WECC
					Deb McEndaffer	WECC	10	WECC
					Tom Williams	WECC	10	WECC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
Tim Kelley	Tim Kelley		WECC	SMUD and BANC	Nicole Looney	Sacramento Municipal Utility District	3	WECC
					Charles Norton	Sacramento Municipal Utility District	6	WECC
					Wei Shao	Sacramento Municipal Utility District	1	WECC
					Foung Mua	Sacramento Municipal Utility District	4	WECC
					Nicole Goi	Sacramento Municipal Utility District	5	WECC
					Kevin Smith	Balancing Authority of Northern California	1	WECC
Associated Electric Cooperative, Inc.	Todd Bennett	3		AECI	Michael Bax	Central Electric Power Cooperative (Missouri)	1	SERC
					Adam Weber	Central Electric Power Cooperative (Missouri)	3	SERC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
					Stephen Pogue	M and A Electric Power Cooperative	3	SERC
					William Price	M and A Electric Power Cooperative	1	SERC
					Peter Dawson	Sho-Me Power Electric Cooperative	1	SERC
					Mark Ramsey	N.W. Electric Power Cooperative, Inc.	1	NPCC
					John Stickley	NW Electric Power Cooperative, Inc.	3	SERC
					Tony Gott	KAMO Electric Cooperative	3	SERC
					Micah Breedlove	KAMO Electric Cooperative	1	SERC
					Kevin White	Northeast Missouri Electric Power Cooperative	1	SERC
					Skyler Wiegmann	Northeast Missouri	3	SERC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
						Electric Power Cooperative		
					Ryan Ziegler	Associated Electric Cooperative, Inc.	1	SERC
					Brian Ackermann	Associated Electric Cooperative, Inc.	6	SERC
					Brad Haralson	Associated Electric Cooperative, Inc.	5	SERC

1. The SDT modified the IRA definition, CIP-005 R2 and CIP-004 Applicable Systems to address IRA in routable to nonroutable (i.e., IP to serial) conversion scenarios. Do you agree with the proposed changes? If not, please provide the basis for your disagreement and an alternate proposal.

Sean Steffensen - IDACORP - Idaho Power Company - 1

Answer No

Document Name

Comment

Edited

Likes 0

Dislikes 0

Response

Thank you for your comment.

James Keele - Entergy - 1,3,6

Answer No

Document Name

Comment

CIP-004-7 - R6.1.2 provisioned physical access to physical BCSI (except for BCSI at a medium impact BCS without ERC). The definition which is listed in the CIP-004-8 Technical Rationales and justification states:

For BCSI in physical format, physical access is provisioned to a physical storage location designated for BCSI and for which access can be provisioned, such as a lockable file cabinet.

By the NERC definition of “Physical Access” ERC does not exist. The additional language of (except for BCSI at a medium impact BCS without ERC) should be removed since a lockable file cabinet is not able to have External Routable Connectivity (ERC) making this statement mute.

The term: Interactive Remote Access (IRA) needs to be defined before it is introduced in a NERC Requirement. It is listed in the Technical Rationale, there is no definition. List the difference between IRA and ERC. If you have ERC, you have IRA. You cannot have either with “Physical Access” as defined as stated above.

Remove R6.1.2 and refer to is as access to BCSI whether it is electronic or physical. Make it simple. You either have been granted access to BCSI or you have not. For R4.1.2 it doesn’t matter if the PSP has ERC or not. Access is access. By adding in ERC, it makes the entity to perform more work and create more policies that do not provide any more security. It makes the compliance piece harder to meet while not gaining any security.

Take guidance from the Nuclear Regulatory Commission (NRC) on Critical Group Membership. You either a critical group member or you are not. Critical group membership allows an individual to work on critical digital assets, whether it is physical or electronical. 1 access control for both types of access.

Medium impact BCS with IRA SCI supporting an Applicable System in this Part – this section needs more clarity on what it is asking the entity to look for. Measures would need to be added to better understand what the ask is.

Likes	0
Dislikes	0

Response

Thank you for your comment. The Physical BCSI reference is in relation to BCSI “at” a medium impact BCS without ERC, the ERC reference in relation to the medium impact BCS where the BCSI is stored, not the BCSI itself. The Parenthetical is a separate statement.

The same concept applies to R4 Part 4.1.2, where the relationship is between the BCS and ERC not the PSP and ERC.

Anne Kronshage - Public Utility District No. 1 of Chelan County - 6, Group Name Public Utility District No. 1 of Chelan County - Voting Group

Answer	No
---------------	----

Document Name

Comment

The SDT has created two different ways of scoping IRA with the current draft of the definition of IRA. In the first case, RE's determine if in-scope IRA exists within the definition, by deciding if the destination Cyber System is inside an ESP (as there are no cases where a Cyber System would be inside an ESP but would not be an Applicable System), while the second case requires RE's to first use the definition to determine if the a protocol conversion is taking place, then use the Applicable Systems of CIP-005 R2 to determine if the destination device is in-scope.

For example, in case 1: An EMS Server (high impact BCA) is inside an ESP. An engineer logs into the EMS server from a jump host outside the ESP. This access meets the first criteria of the definition IRA, and we don't need the Applicable Systems of CIP-005 R2 to determine it is in-scope because all such access would be in-scope.

Case 2: A comm server hosts telnet servers that translate IP to serial for a RTU at a remote site. A employee can initiate a telnet session to the comm server to remotely program the device. This device DOES meet the definition of IRA. But we cannot determine if it is in-scope IRA without knowing the RTU's classification. If the device is low impact or not BES, it is technically IRA, but has no requirements.

The SDT should make scoping of what is in-scope and what is out-of-scope consistent between all types of IRA. CHPD recommends an approach that classifies all remote access as IRA and only places requirements on IRA that originates from a device outside the ESP to a high or medium BCS or PCA.

Additionally, the definition of Intermediate System remains ambiguous as to whether it can cover such devices as Active Directory servers or even firewalls. The terminology should be changed to define the Intermediate System to be the device that IRA is restricted to, not the device that does the restriction (which is not the Intermediate System, but is the firewall and domain policy server).

CHPD's recommendation is as follows:

Definitions:

Interactive Remote Access - User-initiated, interactive electronic access by a person using a bi-directional routable protocol:

- To a routable Cyber System
- That is converted to a non-routable protocol that allows interactive access to a Cyber System

- To a Management Interface

Intermediate System - An Electronic Access Control or Monitoring System(s) that Interactive Remote Access to BES is permitted to originate from.

CIP-005 R2.1

Applicable Systems - High impact BCS and their PCA(s); Medium impact BCS and their PCA(s)

Requirement - Permit Interactive Remote Access (IRA) from outside an ESP, if any, only from an Intermediate System.

CIP-005 R2.2-R2.7 - Unchanged

Thus, all interactive remote access is "IRA", but only IRA that originates from outside an ESP to an Applicable System is in-scope of CIP-005 R2. The system-to-system exemption is no longer needed, as the access has to be "interactive" per the definition of IRA. The ESP-to-ESP exemption is also no longer needed, as that type of communication naturally falls out-of-scope of the updated R2.1 language. And the non-routable concern is brought into the fold by the second bullet point of the definition of IRA.

Likes	0
Dislikes	0

Response

Thank you for your comments. While it is true that there is some scoping found within NERC Glossary definitions, is only through careful review of the definitions and Standards that a determination of scope of impact can be identified. The SDT chose to modify definitions within our SAR to remove as much scoping language from the definitions as is possible and beneficial, to enable the definition to cover as many scenarios as possible. The intent is to have scope identified through the combination of definition, applicability, and requirement language. Therefore, the scoping is developed through the same process for each bullet in the IRA definition.

Mark Garza - FirstEnergy - FirstEnergy Corporation - 4, Group Name FE Voter

Answer	No
Document Name	
Comment	

FirstEnergy suggests including the following in the proposed IRA Definition:

- User-initiated electronic access by a person using a bi-directional routable protocol:
- That is converted by the responsible entity to a non-routable protocol that allows access to a Cyber System **when conversion is performed by a device located outside of the ESP of the Cyber System**

Likes 0

Dislikes 0

Response

Thank you for your comment. The SDT considered the suggestion and believes that the suggestion would not address the issue in the SAR. The SDT is trying to clarify situations where there is no ESP.

Tim Kelley - Tim Kelley On Behalf of: Charles Norton, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Fong Mua, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Kevin Smith, Balancing Authority of Northern California, 1; Nicole Goi, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Nicole Looney, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Wei Shao, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; - Tim Kelley, Group Name SMUD and BANC

Answer

No

Document Name

Comment

SMUD and BANC appreciate the Standard Drafting Team’s work to modify the IRA definition. In the second bullet of the proposed definition, we recommend changing the words “To a Cyber System...” to “To a BES Cyber System...” so that the scope is not expanded to non-BES, EACMS and PACS.

Likes 0

Dislikes 0

Response

Thank you for your comments. While it is true that there is some scoping found within NERC Glossary definitions, is only through careful review of the definitions and Standards that a determination of scope of impact can be identified. The SDT chose to modify definitions within our SAR to remove as much scoping language from the definitions as is possible and beneficial, to enable the definition to cover as many scenarios as possible. The intent is to have scope identified through the combination of definition, applicability, and requirement language. Therefore, the scoping is developed through the same process for each bullet in the IRA definition.

Lindsey Mannion - ReliabilityFirst - 10

Answer	No
Document Name	
Comment	

The gap between what is system-to-system communications and what is Interactive Remote Access (IRA) with the new IRA definition should be addressed. Entities often rely on IRA ports for system-to-system communication but have not adequately enforced protections or deployed additional internal controls to ensure that malicious actors do not use the ports, or the ports are used later to establish user-initiated remote access. Additional technical measures or controls should be added to a new definition to ensure validity of declared system-to-system communications to Applicable Systems are not used for IRA. In addition, approval of CIP-005-8, with the modified IRA definition, is still conditional, based upon approval of the entire suite of proposed CIP definitions associated with virtualization and SCI terminology. With no formal definition of system-to-system, there is still lingering issues regarding where this fine line between system-to-system and IRA exists. By stipulating system-to-system communications excludes the ability for direct user-initiated electronic access at any time, better delineates IRA from system-to-system communications.

Suggested Interactive Remote Access definition:

User-initiated electronic access by a person using a bi-directional routable protocol:

To a Cyber System protected by an Electronic Security Perimeter(s) (ESP);

That is converted by the responsible entity to a non-routable protocol that allows access to a Cyber System; or

To a Management Interface.

Interactive Remote Access does not include:

Communication that originates from a Cyber System protected by any of the Responsible Entity’s ESPs; or
 System-to-system process communications that cannot be used to establish user-initiated electronic access.

Likes 0

Dislikes 0

Response

Thank you for your comments. The SDT feels that the language added to the end of the definition is unnecessary because it describes communication that is out of scope of the definition.

Brian Millard - Tennessee Valley Authority - 1,3,5,6 - SERC, Group Name TVA RBB

Answer

No

Document Name

Comment

Although IP to Serial Converters are devices within a ESP and PSP environment in which they could be manipulated if the network is compromised, they can not be directly interacted with through interactive remote access. The serial based systems down stream of the converter would only operate on non-routable serial communications protocol. The language as proposed inappropriately brings these non-IRA devices into scope of this requirement.

Likes 0

Dislikes 0

Response

Thank you for your comments. The v5TAG included this specific issue within the SAR to clarify how to control remote access via what was termed the “500 mile serial cable.” The SDT concurred that this was an important clarifying step to take. The systems that are being protected through these updates are the BCS themselves, not the IP to Serial Converters and the security controls are to be applied to the routable protocol side of the conversion. As such the SDT feels the changes are appropriate and necessary.

Karen Artola - CPS Energy - 1,3,5 - Texas RE

Answer	No
Document Name	
Comment	
Do not agree with the statement, "That is converted by the responsible entity to a non-routable protocol that allows access to a Cyber System;" When read, the wording implies that the connection must always be converted to a non-routable protocol. A more correct statement would be, "To include connections, which are converted by the responsible entity to a non-routable protocol that allows access to a Cyber System".	
Likes 0	
Dislikes 0	
Response	
Thank you for your comments.	
Ben Hammer - Western Area Power Administration - 1	
Answer	No
Document Name	
Comment	
The use of a non routable protocol ip to serial does not cover scenarios where an intermediate system is used first to get to the protocol converter. For example, a utility using a centralized EACMS (intermediate server) placed in front of the protocol converter that mitigates the security risks.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comment. The identified control of an Intermediate System between the initiating Cyber Asset and the protocol converter could itself fulfill the requirement language clarified in CIP 005 R2.	

Sheila Suurmeier - Black Hills Corporation - 5	
Answer	No
Document Name	
Comment	
<p>Black Hills Corporation requests the standards drafting team consider defining the term “system-to-system process communications” as it is referenced in the current and proposed definition of Interactive Remote Access (IRA). Clearly identifying “system-to-system process communications” versus IRA would allow entities to know which controls need to be applied.</p> <p>The SDT should make scoping of what is in-scope and what is out-of-scope consistent between all types of IRA. We recommend an approach that classifies all remote access as IRA and only places requirements on IRA that originates from a device outside the ESP to a high or medium BCS or PCA.</p> <p>Additionally, the definition of Intermediate System remains ambiguous as to whether it can cover such devices as Active Directory servers or even firewalls. The terminology should be changed to define the Intermediate System to be the device that IRA is restricted to, not the device that does the restriction (which is not the Intermediate System, but is the firewall and domain policy server).</p> <p>Our recommendation is as follows:</p> <p>Definitions:</p> <p>Interactive Remote Access -</p> <p>User-initiated electronic access by a person using a bi-directional routable protocol:</p> <ul style="list-style-type: none"> • To a Cyber System protected by an Electronic Security Perimeter(s) (ESP); • That is converted by the responsible entity to a non-routable protocol that allows access to a Cyber System; or • To a Management Interface. <p>Interactive Remote Access does not include: Communication that originates from a Cyber System protected by any of the Responsible Entity’s ESPs; or System-to-system process communications that cannot be used to establish user-initiated electronic access.</p>	

Likes	0
Dislikes	0
Response	
<p>Thank you for your comments. While it is true that there is some scoping found within NERC Glossary definitions, is only through careful review of the definitions and Standards that a determination of scope of impact can be identified. The SDT chose to modify definitions within our SAR to remove as much scoping language from the definitions as is possible and beneficial, to enable the definition to cover as many scenarios as possible. The intent is to have scope identified through the combination of definition, applicability and requirement language. Therefore, the scoping is developed through the same process for each bullet in the IRA definition. The SDT feels that the language added to the end of the definition is unnecessary because it describes communication that is out of scope of the definition.</p>	
Rachel Schuldt - Rachel Schuldt On Behalf of: Claudine Bates, Black Hills Corporation, 5, 6, 1, 3; - Rachel Schuldt	
Answer	No
Document Name	
Comment	
<p>Black Hills Corporation requests the standards drafting team consider defining the term “system-to-system process communications” as it is referenced in the current and proposed definition of Interactive Remote Access (IRA). Clearly identifying “system-to-system process communications” versus IRA would allow entities to know which controls need to be applied.</p> <p>The SDT should make scoping of what is in-scope and what is out-of-scope consistent between all types of IRA. We recommend an approach that classifies all remote access as IRA and only places requirements on IRA that originates from a device outside the ESP to a high or medium BCS or PCA.</p> <p>Additionally, the definition of Intermediate System remains ambiguous as to whether it can cover such devices as Active Directory servers or even firewalls. The terminology should be changed to define the Intermediate System to be the device that IRA is restricted to, not the device that does the restriction (which is not the Intermediate System, but is the firewall and domain policy server).</p> <p>Our recommendation is as follows:</p> <p>Definitions:</p>	

Interactive Remote Access -

User-initiated electronic access by a person using a bi-directional routable protocol:

- To a Cyber System protected by an Electronic Security Perimeter(s) (ESP);
- That is converted by the responsible entity to a non-routable protocol that allows access to a Cyber System; or
- To a Management Interface.

Interactive Remote Access does not include:

Communication that originates from a Cyber System protected by any of the Responsible Entity’s ESPs; or

System-to-system process communications that cannot be used to establish user-initiated electronic access.

Likes	0
Dislikes	0

Response

Thank you for your comments. While it is true that there is some scoping found within NERC Glossary definitions, is only through careful review of the definitions and Standards that a determination of scope of impact can be identified. The SDT chose to modify definitions within our SAR to remove as much scoping language from the definitions as is possible and beneficial, to enable the definition to cover as many scenarios as possible. The intent is to have scope identified through the combination of definition, applicability, and requirement language. Therefore, the scoping is developed through the same process for each bullet in the IRA definition. The SDT feels that the language added to the end of the definition is unnecessary because it describes communication that is out of scope of the definition.

Josh Combs - Black Hills Corporation - 3

Answer	No
Document Name	

Comment

Black Hills Corporation requests the standards drafting team consider defining the term “system-to-system process communications” as it is referenced in the current and proposed definition of Interactive Remote Access (IRA). Clearly identifying “system-to-system process communications” versus IRA would allow entities to know which controls need to be applied.

The SDT should make scoping of what is in-scope and what is out-of-scope consistent between all types of IRA. We recommend an approach that classifies all remote access as IRA and only places requirements on IRA that originates from a device outside the ESP to a high or medium BCS or PCA.

Additionally, the definition of Intermediate System remains ambiguous as to whether it can cover such devices as Active Directory servers or even firewalls. The terminology should be changed to define the Intermediate System to be the device that IRA is restricted to, not the device that does the restriction (which is not the Intermediate System, but is the firewall and domain policy server).

Our recommendation is as follows:

Definitions:

Interactive Remote Access -

User-initiated electronic access by a person using a bi-directional routable protocol:

- To a Cyber System protected by an Electronic Security Perimeter(s) (ESP);
- That is converted by the responsible entity to a non-routable protocol that allows access to a Cyber System; or
- To a Management Interface.

Interactive Remote Access does not include:

Communication that originates from a Cyber System protected by any of the Responsible Entity’s ESPs; or System-to-system process communications that cannot be used to establish user-initiated electronic access.

Likes	0
Dislikes	0
Response	

Thank you for your comments. While it is true that there is some scoping found within NERC Glossary definitions, is only through careful review of the definitions and Standards that a determination of scope of impact can be identified. The SDT chose to modify definitions within our SAR to remove as much scoping language from the definitions as is possible and beneficial, to enable the definition to cover as many scenarios as possible. The intent is to have scope identified through the combination of definition, applicability, and requirement language. Therefore, the scoping is developed through the same process for each bullet in the IRA definition. The SDT feels that the language added to the end of the definition is unnecessary because it describes communication that is out of scope of the definition.

Micah Runner - Black Hills Corporation - 1

Answer	No
Document Name	

Comment

Black Hills Corporation requests the standards drafting team consider defining the term “system-to-system process communications” as it is referenced in the current and proposed definition of Interactive Remote Access (IRA). Clearly identifying “system-to-system process communications” versus IRA would allow entities to know which controls need to be applied.

The SDT should make scoping of what is in-scope and what is out-of-scope consistent between all types of IRA. We recommend an approach that classifies all remote access as IRA and only places requirements on IRA that originates from a device outside the ESP to a high or medium BCS or PCA.

Additionally, the definition of Intermediate System remains ambiguous as to whether it can cover such devices as Active Directory servers or even firewalls. The terminology should be changed to define the Intermediate System to be the device that IRA is restricted to, not the device that does the restriction (which is not the Intermediate System, but is the firewall and domain policy server).

Our recommendation is as follows:

Definitions:

Interactive Remote Access -

User-initiated electronic access by a person using a bi-directional routable protocol:

- To a Cyber System protected by an Electronic Security Perimeter(s) (ESP);

- That is converted by the responsible entity to a non-routable protocol that allows access to a Cyber System;
 or
- To a Management Interface.

Interactive Remote Access does not include:

Communication that originates from a Cyber System protected by any of the Responsible Entity’s ESPs; or

System-to-system process communications that cannot be used to establish user-initiated electronic access.

Likes	0
Dislikes	0

Response

Thank you for your comments. While it is true that there is some scoping found within NERC Glossary definitions, is only through careful review of the definitions and Standards that a determination of scope of impact can be identified. The SDT chose to modify definitions within our SAR to remove as much scoping language from the definitions as is possible and beneficial, to enable the definition to cover as many scenarios as possible. The intent is to have scope identified through the combination of definition, applicability, and requirement language. Therefore, the scoping is developed through the same process for each bullet in the IRA definition. The SDT feels that the language added to the end of the definition is unnecessary because it describes communication that is out of scope of the definition.

Adrian Andreoiu - BC Hydro and Power Authority - 1, Group Name BC Hydro

Answer	No
Document Name	

Comment

BC Hydro appreciates the opportunity to review and comment and offers the following.

BC Hydro requests clarity on the definition of Interactive Remote Access (IRA) for the following reason: IRA definition (second bullet) uses the words "To a Cyber System..." which could lead to the understanding that the scope is expanded to non-BES, EACMS and PACS.

BC Hydro proposes that the wording is changed to "To a BES Cyber System..." to make it clear.

Likes 0

Dislikes 0

Response

Thank you for your comments. While it is true that there is some scoping found within NERC Glossary definitions, is only through careful review of the definitions and Standards that a determination of scope of impact can be identified. The SDT chose to modify definitions within our SAR to remove as much scoping language from the definitions as is possible and beneficial, to enable the definition to cover as many scenarios as possible. The intent is to have scope identified through the combination of definition, applicability, and requirement language. Therefore, the scoping is developed through the same process for each bullet in the IRA definition.

Andy Fuhrman - Andy Fuhrman On Behalf of: Theresa Allard, Minnkota Power Cooperative Inc., 1; - Andy Fuhrman

Answer

No

Document Name

Comment

MPC supports comments submitted by ACES.

Likes 0

Dislikes 0

Response

Thank you for your comment, please see response to ACES.

Steve Toosevich - NiSource - Northern Indiana Public Service Co. - 1

Answer

No

Document Name

Comment

NIPSCO does not agree with the proposed definition. The new definition of IRA seems to be virtually the same as ERC. It is a distinction without much of a difference.	
Likes	0
Dislikes	0
Response	
Thank you for your comments. The SDT notes that IRA and ERC definitions are similar, however the IRA definition includes user initiated access, IP to Serial Conversion and management interfaces. The difference is in the applicability of requirements based on the type of access.	
Shannon Mickens - Shannon Mickens On Behalf of: Joshua Phillips, Southwest Power Pool, Inc. (RTO), 2; - Shannon Mickens, Group Name SPP RTO	
Answer	No
Document Name	
Comment	
Due to the non-routable protocol's inability to cross an EAP, the definition of Interactive Remote Access (IRA) should not apply. Given this limitation, the ability to cross an EAP to access a Cyber Asset within the ESP should have its definition limited to only routable protocols.	
Likes	0
Dislikes	0
Response	
Thank you for your comments.	
Chris Carnesi - Chris Carnesi On Behalf of: Dennis Sismaet, Northern California Power Agency, 4, 6, 3, 5; Jeremy Lawson, Northern California Power Agency, 4, 6, 3, 5; Michael Whitney, Northern California Power Agency, 4, 6, 3, 5; - Chris Carnesi	
Answer	No
Document Name	

Comment

NCPA suggests editing the new IRA definition to say "To a BCS..." in the first bullet point in lieu of just "Cyber Systems" to avoid including other system types such as EACMS, PACS and PCAs.

Likes 0

Dislikes 0

Response

Thank you for your comments. While it is true that there is some scoping found within NERC Glossary definitions, is only through careful review of the definitions and Standards that a determination of scope of impact can be identified. The SDT chose to modify definitions within our SAR to remove as much scoping language from the definitions as is possible and beneficial, to enable the definition to cover as many scenarios as possible. The intent is to have scope identified through the combination of definition, applicability, and requirement language. Therefore, the scoping is developed through the same process for each bullet in the IRA definition.

Nicolas Turcotte - Hydro-Quebec (HQ) - 1

Answer

No

Document Name

Comment

HQ supports NPCC RSC comments and provides the following additional comments:

If the goal is to ensure that user interactive actions, is done remotely(i.e., not in the PSP), on a BCA and PCA, then those actions must go through an intermediate system, and the users must have training, ie CIP-004.

The IRA definition should be simple and not technologically limited (routable vs nonroutable).

The security risks associated to IRA are not dependent on the routable scenarios or routable to nonroutable (i.e., IP to serial) conversion scenarios. They are associated to the remote access.

Furthermore, if the intention of the IRA definition is to say “Communication that originates from a BCA or a PCA protected by any of the Responsible Entity’s ESPs”, Why is this part of the definition when CIP-005 R1.1 Requires that BCA or a PCA are to be protected by an ESP ?

Also, since CIP-005 R2.4 and R2.5, include System-to-system process communication, I would remove “or System-to-system process communication.” to the definition of IRA as the concept is in the requirements.

SDT should simplify the definition. Suggested improvements include:

IRA: User-initiated electronic access by a person to a BCA or a PCA .

Interactive Remote Access does not include: Out going communication that originates from a BCA or PCA;

The modifications to CIP-004 are adequate.

The modification to CIP-005 R2, more precisely R2.7 is not required, since R1.2 is there to manage all the routable communication. Also R2.7 implies that the converter (IP to Serial) is outside of the ESP. [BCA] – IP – [F/W] – [IPtoSerial] - Serial

Likes	0
Dislikes	0

Response

Thank you for your comments. The proposed IRA definition oversimplifies the challenge and does not address all appropriate instances of IRA. R2.7 is required in order to authenticate remote users before access into the ESP is allowed.

Rachel Coyne - Texas Reliability Entity, Inc. - 10

Answer	No
Document Name	
Comment	

Texas RE agrees that IRA definitions and requirements should be modified to address IRA in routable to nonroutable conversion scenarios. Texas RE noticed however, a gap between the glossary definition and the proposed requirements as written, specifically with regards to IRA to SCI.

The SDT has defined IRA as meeting one of the three following criteria:

- User-initiated electronic access by a person using a bi-directional routable protocol to a cyber system protected by an ESP.
- User-initiated electronic access by a person using a bi-directional routable protocol that is converted by the responsible entity to a non-routable protocol that allows access to a cyber system.
- User-initiated electronic access by a person using a bi-directional routable protocol to a management interface.

In CIP-005 R2 Part 2.1 the SDT requires that IRA only be permitted through an Intermediate System. One of the applicable systems is “SCI supporting an Applicable System in this Part.” In CIP-005 R1 Part 1.1 applicable systems are required to be protected by an ESP. SCI is not an applicable system. Since SCI are not an applicable system in CIP-005 R1 Part 1.1 they are not required to be protected by an ESP. An SCI not protected by an ESP will not match the “User-initiated electronic access by a person using a bi-directional routable protocol to a cyber system protected by an ESP” criteria. As such, these communications would not meet the definition of IRA and would therefore be out of scope for CIP-005 R2 Part 2.1.

Texas RE therefore recommends modifying the proposed glossary definition of IRA to include a “User-initiated electronic access by a person using a bi-directional routable protocol to SCI supporting a BCS.”

Likes 0

Dislikes 0

Response

Thank you for your comments. The SDT feels that the security issue that SCI introduces is not through the production interfaces (since they are covered by their inclusion in the BCA, PCA etc.) but through the Management Interface to the SCI. This is the reason for the inclusion of the third bullet in the IRA definition.

Jennifer Bray - Arizona Electric Power Cooperative, Inc. - 1

Answer

No

Document Name	
Comment	
<p>AEPC has signed on to ACES comments:</p> <p>ACES feels the first sub bullet to the IRA definition is overly wordy and is confusing. ACES suggests:</p> <p>“To a BCS or a defined Electronic Access Point (EAP).”</p> <p>The CIP standards are not concerned with IRA to any other systems besides Applicable Systems/BCS, so scoping the definition to just what NERC/CIP’s definition is, does not allow any scope creep.</p>	
Likes	0
Dislikes	0
Response	
<p>Thank you for your comments. The proposed IRA definition oversimplifies the challenge and does not address all appropriate instances of IRA. While it is true that there is some scoping found within NERC Glossary definitions, is only through careful review of the definitions and Standards that a determination of scope of impact can be identified. The SDT chose to modify definitions within our SAR to remove as much scoping language from the definitions as is possible and beneficial, to enable the definition to cover as many scenarios as possible. The intent is to have scope identified through the combination of definition, applicability, and requirement language. Therefore, the scoping is developed through the same process for each bullet in the IRA definition.</p>	
Junji Yamaguchi - Hydro-Quebec (HQ) - 5	
Answer	No
Document Name	
Comment	
<p>HQ supports NPCC RSC comments and provides the following additional comments:</p> <p>If the goal is to ensure that user interactive actions, is done remotely(i.e., not in the PSP), on a BCA and PCA, then those actions must go through an intermediate system, and the users must have training, ie CIP-004.</p>	

The IRA definition should be simple and not technologically limited (routable vs nonroutable).
 The security risks associated to IRA are not dependent on the routable scenarios or routable to nonroutable (i.e., IP to serial) conversion scenarios. They are associated to the remote access.
 Furthermore, if the intention of the IRA definition is to say “Communication that originates from a BCA or a PCA protected by any of the Responsible Entity’s ESPs”, Why is this part of the definition when CIP-005 R1.1 Requires that BCA or a PCA are to be protected by an ESP ?

Also, since CIP-005 R2.4 and R2.5, include System-to-system process communication, I would remove “or System-to-system process communication.” to the definition of IRA as the concept is in the requirements.

SDT should simplify the definition. Suggested improvements include:

- IRA: User-initiated electronic access by a person to a BCA or a PCA .
- Interactive Remote Access does not include: Out going communication that originates from a BCA or PCA;

The modifications to CIP-004 are adequate.

The modification to CIP-005 R2, more precisely R2.7 is not required, since R1.2 is there to manage all the routable communication. Also R2.7 implies that the converter (IP to Serial) is outside of the ESP. [BCA] – IP – [F/W] – [IPtoSerial] - Serial

Likes 0

Dislikes 0

Response

Thank you for your comments. The proposed IRA definition oversimplifies the challenge and does not address all appropriate instances of IRA. R2.7 is required in order to authenticate remote users before access into the ESP is allowed.

Teresa Krabe - Lower Colorado River Authority - 5

Answer

No

Document Name

Comment

By adding the new applicable system of medium impact with IRA in CIP-004 it causes confusion. LCRA believes the intent is to require training and background checks only for individuals with provisioned electronic access to medium impact BCS with IRA; however, it could be construed that any access to these devices requires R2 and R3 to be complied with.

Likes 0

Dislikes 0

Response

Thank you for your comments. The intent of the inclusion of Medium impact BCS with IRA within the bulk of CIP-004 is to ensure those requirements are met just as others are where the security risk includes remote access. The exclusion of medium impact BCS without ERC is a nod to backwards compatibility and the concern that many of the CIP-004 Requirements have a time restriction that may not be able to be served if the disabling of access requires a drive to the location.

James Baldwin - James Baldwin On Behalf of: Matt Lewis, Lower Colorado River Authority, 5, 1; - James Baldwin

Answer

No

Document Name

Comment

By adding the new applicable system of medium impact with IRA in CIP-004 it causes confusion. LCRA believes the intent is to require training and background checks only for individuals with provisioned electronic access to medium impact BCS with IRA; however, it could be construed that any access to these devices requires R2 and R3 to be complied with.

Likes 0

Dislikes 0

Response

Thank you for your comments. The intent of the inclusion of Medium impact BCS with IRA within the bulk of CIP-004 is to ensure those requirements are met just as others are where the security risk includes remote access. The exclusion of medium impact BCS without ERC is a nod to backwards compatibility and the concern that many of the CIP-004 Requirements have a time restriction that may not be able to be served if the disabling of access requires a drive to the location.

Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name NPCC RSC	
Answer	No
Document Name	
Comment	
<p>There seems to be an inconsistency between EACMS definition and the CIP-005 R2 requirements:</p> <ol style="list-style-type: none"> 1) {C}EACMS definition includes a protocol converter for BCS where no ESP exists. 2) New R2 Applicable Systems requires an Intermediate System 3) New R2.7 requires an ESP between the Intermediate System and the BCS <p>Is the intent of the SDT to require the protocol converter to be an Intermediate System? In the case where no ESP exists, then R2.7 cannot be met.</p> <p>Suggest change the Applicable Systems in R2.1 to exclude situations without ERC or change R2.7 requirements to exclude situations where protocol converter is used and there is no ESP</p>	
Likes	0
Dislikes	0
Response	
<p>Thank you for your comments. The SDT believes that the definitions and requirement language is consistent as intended.</p> <ol style="list-style-type: none"> 1. EACMS definition includes a protocol converter for BCS where no ESP exists. True, and only for “those” that perform electronic access control or electronic access monitoring for the BCS (OR ESP). 2. Applicable Systems columns only define where a requirement is applicable. They do not establish a requirement in themselves. If no Intermediate Systems are in use, then there is no applicability. However, if there is IRA, then there may be an issue with compliance to R2 Part 2.1. 	

3. R2 Part 2.7 requires the IS to be placed such that “routable protocol communications” to the BCS must go through an ESP. This does not require an ESP unless there is routable protocol communications between the IS and BCA. Due to the “routable protocol communications” CIP-005 R1 would be applicable, and there should already be an ESP.

Constantin Chitescu - Ontario Power Generation Inc. - 5

Answer No

Document Name

Comment

OPG supports NPCC Regional Standards Committee’s comments.

There seems to be an inconsistency between EACMS definition and the CIP-005 R2 requirements:

- 1) EACMS definition includes a protocol converter for BCS where no ESP exists.
- 2) New R2 Applicable Systems requires an Intermediate System
- 3) New R2.7 requires an ESP between the Intermediate System and the BCS

Is the intent of the SDT to require the protocol converter to be an Intermediate System? In the case where no ESP exists, then R2.7 cannot be met.

Suggest change the Applicable Systems in R2.1 to exclude situations without ERC or change R2.7 requirements to exclude situations where protocol converter is used and there is no ESP

Likes 0

Dislikes 0

Response

Thank you for your comments. The SDT believes that the definitions and requirement language is consistent as intended.

- 1. EACMS definition includes a protocol converter for BCS where no ESP exists. True, and only for “those” that perform electronic access control or electronic access monitoring for the BCS (OR ESP).
- 2. Applicable Systems columns only define where a requirement is applicable. They do not establish a requirement in themselves. If no Intermediate Systems are in use, then there is no applicability. However, if there is IRA, then there may be an issue with compliance to R2 Part 2.1.

3. R2 Part 2.7 requires the IS to be placed such that “routable protocol communications” to the BCS must go through an ESP. This does not require an ESP unless there is routable protocol communications between the IS and BCA. Due to the “routable protocol communications” CIP-005 R1 would be applicable, and there should already be an ESP.

Alain Mukama - Hydro One Networks, Inc. - 1,3

Answer No

Document Name

Comment

There is a conflict between the newly proposed EACMS which includes "those not protected by an Electronic Security Perimeter used by the responsible entity to convert routable protocol communications to non-routable communications to a BCS" and CIP-005-8 R2.7 that mandates ESP between Intermediate System and High/Medium Impact BCS. Please clarify how to identify ESP when protocol converter is used to connect High/Medium Impact Cyber System serially for IRA from Intermediate System. {C}{C}

Likes 0

Dislikes 0

Response

Thank you for your comments. R2 Part 2.7 requires the IS to be placed such that “routable protocol communications” to the BCS must go through an ESP. This does not require an ESP unless there are routable protocol communications between the IS and BCA. Due to the “routable protocol communications” CIP-005 R1 would be applicable, and there should already be an ESP.

Roger Fradenburgh - Roger Fradenburgh On Behalf of: Nick Lauriat, Network and Security Technologies, 1; - Roger Fradenburgh

Answer No

Document Name

Comment

NST sees no reason to change the existing approved definition's use of "remote access client or other remote access technology." The second part of the proposed definition would, as written, apply to any remote connection using a communications path that included routable to serial conversion, regardless of where that conversion took place (e.g., remote location vs. "local," or "inside the BES asset"

location). If this is what the SDT intends, NST recommends updating the CIP-005 Technical Rationale document to make this clear. NST is also concerned that as proposed, the revised definition could be interpreted to apply to any Cyber System, not just BES Cyber Systems and associated in-scope devices.

Likes 1	Central Hudson Gas & Electric Corp., 1, Ridolfino Michael
Dislikes 0	

Response

Thank you for your comments. While it is true that there is some scoping found within NERC Glossary definitions, is only through careful review of the definitions and Standards that a determination of scope of impact can be identified. The SDT chose to modify definitions within our SAR to remove as much scoping language from the definitions as is possible and beneficial, to enable the definition to cover as many scenarios as possible. The intent is to have scope identified through the combination of definition, applicability, and requirement language. Therefore, the scoping is developed through the same process for each bullet in the IRA definition. The language “remote access client or other remote access technology” used in the current version of the IRA definition was removed for clarity based on industry comments in previous drafts.

Michael Russell – Massachusetts Municipal Wholesale Electric Company – 5 – NPCC

Answer	No
Document Name	

Comment

There seems to be an inconsistency between EACMS definition and the CIP-005 R2 requirements:

- 1) EACMS definition includes a protocol converter for BCS where no ESP exists.
- 2) New R2 Applicable Systems requires an Intermediate System
- 3) New R2.7 requires an ESP between the Intermediate System and the BCS

Is the intent of the SDT to require the protocol converter to be an Intermediate System? In the case where no ESP exists, then R2.7 cannot be met.

Suggest change the Applicable Systems in R2.1 to exclude situations without ERC or change R2.7 requirements to exclude situations where protocol converter is used and there is no ESP

Likes	0
Dislikes	0
Response	
<p>Thank you for your comments. The SDT believes that the definitions and requirement language is consistent as intended.</p> <ol style="list-style-type: none"> 1. EACMS definition includes a protocol converter for BCS where no ESP exists. True, and only for “those” that perform electronic access control or electronic access monitoring for the BCS (OR ESP). 2. Applicable Systems columns only define where a requirement is applicable. They do not establish a requirement in themselves. If no Intermediate Systems are in use, then there is no applicability. However, if there is IRA, then there may be an issue with compliance to R2 Part 2.1. 3. R2 Part 2.7 requires the IS to be placed such that “routable protocol communications” to the BCS must go through an ESP. This does not require an ESP unless there are routable protocol communications between the IS and BCA. Due to the “routable protocol communications” CIP-005 R1 would be applicable, and there should already be an ESP. 	
<p>Jennie Wike – Jennie Wike On Behalf of: Hien Ho, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; John Merrell, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Ozan Ferrin, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Terry Gifford, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; - Jennie Wike, Group Name Tacoma Power</p>	
Answer	No
Document Name	
Comment	
<p>Tacoma Power is concerned that the exception language in CIP-004 R2 Part 2.3 invalidates the inclusion of the applicable system of “medium impact BCS with IRA”. Tacoma Power recommends deleting the “(except for medium impact BCS without ERC)” from the R2 Part 2.3 requirement language.</p> <p>Additional editorial comment: “Medium” should not be capitalized in CIP-004 R5 Part 5.1 and R5.2, and R6 Part 6.3.</p>	
Likes	0
Dislikes	0
Response	

Thank you for your comments. The SDT has made the clarifying changes to align with the intent.	
Tracy MacNicoll – Utility Services, Inc. – 4	
Answer	No
Document Name	
Comment	
It is unclear if a protocol converter meets the proposed definitions for EACMS and EAP. The lack of clarity makes it difficult to apply the new IRA definition when protocol converters are used. The identification of a EAP on a protocol converter could establish an ESP around a BES Cyber System that does not use a routable protocol. The establishment of an ESP would also cause the non-routable BES Cyber System to meet the definition of ERC, which causes a significant increase in the number of applicable CIP requirements.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comments. The SDT does not see that identification of an EAP on a protocol converter would automatically create an ESP around a BCS that is NOT connected to a network via a routable protocol. The requirement for an ESP is only established by CIP-005 R1 Part 1.1 requirement language, which does not apply to BCS not connected to a network via a routable protocol.	
Israel Perez – Israel Perez On Behalf of: Mathew Weber, Salt River Project, 3, 1, 6, 5; Sarah Blankenship, Salt River Project, 3, 1, 6, 5; Thomas Johnson, Salt River Project, 3, 1, 6, 5; Timothy Singh, Salt River Project, 3, 1, 6, 5; - Israel Perez	
Answer	No
Document Name	
Comment	
This should specifically exclude direct access from a TCA. More detail is needed to understand the scope, for ex: are all serial addresses needed.	
Likes 0	

Dislikes	0
Response	
Thank you for your comments.	
Jodirah Green – ACES Power Marketing – 1,3,4,5,6 – MRO,WECC,Texas RE,SERC,RF, Group Name ACES Collaborators	
Answer	No
Document Name	
Comment	
<p>ACES feels the first sub bullet to the IRA definition is overly wordy and is confusing. ACES suggests:</p> <p>“To a BCS or a defined Electronic Access Point (EAP).”</p> <p>The CIP standards are not concerned with IRA to any other systems besides Applicable Systems/BCS, so scoping the definition to just what NERC/CIP’s definition is, does not allow any scope creep.</p>	
Likes	0
Dislikes	0
Response	
<p>Thank you for your comments. While it is true that there is some scoping found within NERC Glossary definitions, is only through careful review of the definitions and Standards that a determination of scope of impact can be identified. The SDT chose to modify definitions within our SAR to remove as much scoping language from the definitions as is possible and beneficial, to enable the definition to cover as many scenarios as possible. The intent is to have scope identified through the combination of definition, applicability, and requirement language. Therefore, the scoping is developed through the same process for each bullet in the IRA definition.</p>	
John Galloway - John Galloway On Behalf of: Michael Puscas, ISO New England, Inc., 2; - John Galloway	
Answer	Yes
Document Name	
Comment	

ISO-NE supports the ISO/RTO Council comments in this area.	
Likes	0
Dislikes	0
Response	
Thank you for your comments, please see response to the ISO/RTO council.	
Jay Sethi - Manitoba Hydro - 1,3,5,6 - MRO	
Answer	Yes
Document Name	
Comment	
The standard drafting team has done a good job in clearly defining the scope of IRA.	
Likes	0
Dislikes	0
Response	
Thank you for your comment.	
Richard Vendetti - NextEra Energy - 5	
Answer	Yes
Document Name	
Comment	
NEE supports EEI comments	
Likes	0

Dislikes	0
Response	
Thank you for your comment, please see response to EEI.	
Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company	
Answer	Yes
Document Name	
Comment	
Southern supports the proposed changes for the IRA definition to address IRA in routable to nonroutable (i.e., IP to serial) conversion.	
Likes	0
Dislikes	0
Response	
Thank you for your comment.	
Wayne Sipperly - North American Generator Forum - 5 - MRO,WECC,Texas RE,NPCC,SERC,RF	
Answer	Yes
Document Name	
Comment	
The NAGF agrees with the proposed changes to the IRA definition.	
Likes	0
Dislikes	0
Response	
Thank you for your comment.	

Steven Rueckert - Western Electricity Coordinating Council - 10, Group Name WECC CIP	
Answer	Yes
Document Name	
Comment	
It appears there may be a discrepancy in the use of BES and BPS. The revised definition of BES Cyber Asset (BCA) includes the following: "Reliable Operatin of the Buld Electric System (BES) while the term Reliable Operation in the Glossary includes: "Operating the element of the Bulk-Power System ..."	
Likes 0	
Dislikes 0	
Response	
Thank you for your comments. The SDT asserts that the use of Reliable Operation covers the essence of how a BCA should be defined and the further wording of "Reliable Operation of the Bulk Electric System (BES)" scopes the definition down to only the elements of the BES. This same wording is also used in the Reliability Co-Ordinator definition	
Gail Elliott - Gail Elliott On Behalf of: Michael Moltane, International Transmission Company Holdings Corporation, 1; - Gail Elliott	
Answer	Yes
Document Name	
Comment	
ITC supports the response submitted by EEI	
Likes 0	
Dislikes 0	
Response	
Thank you for your comment, please see response to EEI.	

Mark Gray - Edison Electric Institute - NA - Not Applicable - NA - Not Applicable	
Answer	Yes
Document Name	
Comment	
EEI supports the modifications to the IRA definition, CIP-005 (Requirement R2) and CIP-004 (Applicable Systems) that address IRA in routable to nonrouteable (i.e., IP to serial) conversion scenarios.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comment.	
Daniel Gacek - Exelon - 1	
Answer	Yes
Document Name	
Comment	
Exelon supports the comments submitted by the EEI.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comment, please see response to EEI.	
Kinte Whitehead - Exelon - 3	
Answer	Yes

Document Name	
Comment	
Exelon is supporting EEI comments in response to this question.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comment, please see response to EEI.	
Marcus Bortman - APS - Arizona Public Service Co. - 6	
Answer	Yes
Document Name	
Comment	
AZPS supports the proposed changes	
Likes 0	
Dislikes 0	
Response	
Thank you for your comment.	
Joanne Anderson - Public Utility District No. 2 of Grant County, Washington - 1,4,5,6 - WECC	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Thank you for your support.	
Patricia Lynch - NRG - NRG Energy, Inc. - 5	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Clay Walker - Clay Walker On Behalf of: John Lindsey, Cleco Corporation, 6, 5, 1, 3; Maurice Paulk, Cleco Corporation, 6, 5, 1, 3; Robert Hirschak, Cleco Corporation, 6, 5, 1, 3; Stephanie Huffman, Cleco Corporation, 6, 5, 1, 3; Wayne Messina, LaGen, 4; - Clay Walker	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	

LaTroy Brumfield - American Transmission Company, LLC - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Jennifer Buckman - Southern Indiana Gas and Electric Co. - 3,5,6 - RF	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Robert Follini - Avista - Avista Corporation - 3	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Thank you for your support.	
Tristan Miller - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Donna Wood - Tri-State G and T Association, Inc. - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Richard Jackson - U.S. Bureau of Reclamation - 1	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Andrea Jessup - Bonneville Power Administration - 1,3,5,6 - WECC	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Todd Bennett - Associated Electric Cooperative, Inc. - 3, Group Name AECl	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Thank you for your support.	
Rebika Yitna - MEAG Power - 1,3 - SERC	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Mike Magruder - Avista - Avista Corporation - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Casey Jones - Berkshire Hathaway - NV Energy - 5 - WECC	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Erik Gustafson - PNM Resources - Public Service Company of New Mexico - 1,3 - WECC,Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Mark Flanary - Midwest Reliability Organization - 10	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	

Response	
Thank you for your support.	
C. A. Campbell - LS Power Development, LLC - 5	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Ellese Murphy - Ellese Murphy On Behalf of: Marcelo Pesantez, Duke Energy - Florida Power Corporation, 3; - Ellese Murphy	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Monika Montez - California ISO - 2 - WECC, Group Name ISO/RTO Council Standards Review Committee (SRC)	
Answer	Yes
Document Name	

Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
John Daho - John Daho On Behalf of: David Weekley, MEAG Power, 3, 1; Roger Brand, MEAG Power, 3, 1; - John Daho	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Anna Martinson - MRO - 1,2,3,4,5,6 - MRO, Group Name MRO Group	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	

Thank you for your support.	
Martin Sidor - NRG - NRG Energy, Inc. - 6	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
David Jendras Sr - Ameren - Ameren Services - 3	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Dwanique Spiller - Berkshire Hathaway - NV Energy - 5	
Answer	Yes
Document Name	
Comment	

Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Kennedy Meier - Electric Reliability Council of Texas, Inc. - 2	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	

2. The SDT modified other (not related to IRA) definitions used in the CIP standards based on industry comments. Do you agree with the proposed changes? If not, please provide the basis for your disagreement and an alternate proposal.

Jodirah Green - ACES Power Marketing - 1,3,4,5,6 - MRO,WECC,Texas RE,SERC,RF, Group Name ACES Collaborators

Answer	No
---------------	----

Document Name	
----------------------	--

Comment

ACES feels the way the definition of Electronic Access Point (EAP) is written in this draft is overly wordy. ACES suggests:
 "An electronic policy enforcement point or a Cyber Asset interface on Electronic Access Control or Monitoring Systems that controls routable communication to and from BES Cyber Systems."

ACES feels the way the definition of Intermediate System is written in this draft is overly wordy. ACES suggests:
 "Electronic Access Control or Monitoring Systems (EACMS) used to restrict Interactive Remote Access to only authorized users"

ACES also noted that the definition of an Intermediate System no longer states that it must not be located inside an ESP, combined with the removal of the language from R2.1: "such that the Cyber Asset initiating Interactive Remote Access does not directly access an applicable Cyber Asset." Without those two statements IRA could be initiated through an ESP to an Intermediate System located in an ESP. ACES feels the removal of the language from the definition and requirement is not what was intended and needs to be added back to ensure the security of IRA. Furthermore

with the removal of the language, it allows a Cyber Asset IRA client to connect directly to Applicable Systems, if the Intermediate System is also an EACMS with an EAP. In this scenario the Cyber Asset client connects to the EACMS using a VPN client and Multi Factor Authentication. Once connected to the Intermediate System, the IRA Client could connect directly to applicable systems. There are other scenarios, but this is the most obvious.

EACMS is already plural. so adding "one or more" to the definition of Intermediate System is redundant.

ACES feels the second bullet point on the new Management Interface should be scoped down. There are a variety of vulnerabilities in “autonomous subsystems” in which one could gain access to a system’s console. Changing the scope of the definition to be ONLY those devices specifically designed and or used to allow access to a console would reduce scope creep. ACES suggests:

“Is an autonomous subsystem, specifically designed and or used to provide access to the console independently of the Cyber Asset’s CPU, firmware, and operating system;”

ACES feels the first word in bullet point one, section 4, of the TCA definition should be “to” rather than “on”

Likes 0

Dislikes 0

Response

Thank you for your comments.

The SDT asserts that an EAP may also be controlling routable communication to PCAs and EACMS within the ESP, so limiting the definition to BCS may not be appropriate.

The SDT asserts that the Intermediate System may be made of one EACMS, thus one or more is appropriate.

The SDT asserts that the change to the Intermediate System definition removes requirements out of the definition. Please see CIP-005-8 Requirement R2.7 and the Technical Rationale for changes to definitions.

The SDT asserts that VPN Gateway and IRA tunnel connection from the client to the Applicable System would be logically a direct connection and does not meet CIP-005-8 Requirement R2.7

The SDT asserts that limiting the second bullet of the Management Interface definition to lights out console type access only would not cover interfaces that allow for remote power control

The SDT asserts that one or more EACMS is needed to cover the case of a single system

The SDT asserts that in the TCA definition, "on" a network better describes the intent of the definition	
Israel Perez - Israel Perez On Behalf of: Mathew Weber, Salt River Project, 3, 1, 6, 5; Sarah Blankenship, Salt River Project, 3, 1, 6, 5; Thomas Johnson, Salt River Project, 3, 1, 6, 5; Timothy Singh, Salt River Project, 3, 1, 6, 5; - Israel Perez	
Answer	No
Document Name	
Comment	
Glossary, changes cause us to read many glossary terms to understand the term, then go to read standard and see how changes to glossary term has impact to the standard.	
EX: Management Interface. Definition should include physical interface or process, not both within the same definition.	
EX: term 'unauthorized' used, focus on the risk of unauthorized change. How is unauthorized defined?	
Likes	0
Dislikes	0
Response	
Thank you for your comments	
The SDT asserts that it was tasked to clean up definitions by removing requirements and make them broader. Scoping has been moved to either the Applicable Systems column or within the requirement language itself.	
The SDT asserts that the Management Interface definition should describe it in a broad sense and that the scoping is done within the Applicable Systems column (SCI supporting an Applicable System ...) and the requirement language (Protect ESP and SCI configuration...)	
The SDT asserts that definitions/meanings of terms like "authorized"/"unauthorized", "vendor", etc. should be explicitly defined by the entity within their own compliance programs	
Michael Russell - Massachusetts Municipal Wholesale Electric Company - 5 - NPCC	

Answer	No
Document Name	
Comment	
<p>PCA Definition – routable protocol missing. Please clarify ESP criteria / demarcation considerations if a Responsible Entity takes a “policy” or ruleset based approach to an ESP; in relation to PCAs. Examples involving firewall / VLans / Switch controls... Can a Responsible Entity Choose what devices are PCAs based on the policy? The first bullet is missing the concept of being explicitly connected by a routable protocol Are protected by an Electronic Security Perimeter (ESP) but are not part of the highest impact BES Cyber System (BCS) protected by the same ESP; or.... Suggest Are connected to a network using a routable protocol and are protected by an Electronic Security Perimeter (ESP) but are not part of the highest impact BES Cyber System (BCS) protected by the same ESP; or.</p>	
Likes 0	
Dislikes 0	
Response	
<p>Thank you for your comments</p> <p>The SDT asserts that within the PCA definition of “being protected by an ESP” already implies that routable protocol is being used</p> <p>The SDT understands that there are complex issues around documenting ESP policy, especially in a hybrid networking situation. The SDT will be proposing that Implementation Guidance on ESP policy be created by one of the prequalified organizations.</p>	
Roger Fradenburgh - Roger Fradenburgh On Behalf of: Nick Lauriat, Network and Security Technologies, 1; - Roger Fradenburgh	
Answer	No
Document Name	

Comment

NST respectfully offers the following comments on proposed new and revised definitions:

Intermediate System: NST recommends maintaining the "not within an ESP" language from the current definition rather than having that component be implied by a requirement part.

Management Interface: NST recommends changing, "An administrative interface,..." to, "A dedicated physical or logical administrative interface,..."

Electronic Security Perimeter: NST believes the proposed new part of the current ESP definition, "or a logical boundary defined by one or more EAPs" is redundant and unnecessary. We therefore recommend maintaining the currently approved ESP definition.

Virtual Cyber Asset: NST suggests including some of the wording found in the definition of "Cyber Asset," such as, "including software and data." NST notes that the proposed definition, as written, would make it possible for a VCA to be hosted on a BES Cyber Asset that is itself a VCA. If this is what the SDT intends, NST recommends modifying the definition to make this clear.

Electronic Access Control and Monitoring System: NST sees no need for modifying the existing definition. We also note that not all protocol converters perform access control and/or monitoring, which makes it inappropriate to include them in a revised definition of EACMS.

External Routable Connectivity: As we did in 2022, NST believes the use of the word, "through (an ESP)" has the potential to cause confusion over the kind(s) of routable communications that may qualify as ERC. ERC to or from a Cyber Asset should be clearly defined as "through" an ESP boundary or access point, not "through" an ESP. The online Merriam Webster dictionary defines "through" as "a function word to indicate movement into at one side or point and out at another and especially the opposite side of // 'drove a nail through the board'". NST believes the existing definition of ERC can and should be retained as-is.

Shared Cyber Infrastructure: NST recommends adding "hardware" to "One or more programmable electronic devices, including the software,..." NST also recommends adding language to either or both of the "Cyber Asset" and "SCI" definitions that clarifies a device that hosts and/or provides storage resources for BES Cyber Systems and associated virtual devices at a single impact level (e.g., high) should be identified as a Cyber Asset, not as SCI.

Electronic Access Point: As we did in 2022, NST believes the proposed definition of EAP is problematic in two respects. First, we believe it could be interpreted to mean an EAP should control all routable communication between a BCS and any other Cyber Asset regardless of whether that "other" device is within or outside of the same ESP protecting the BCS. Second, we believe the SDT should better define "policy enforcement point" lest Responsible Entities, Regional Entities, and NERC develop their own conflicting definitions.

Transient Cyber Asset: As we did in 2022, NST notes the proposed definition includes a statement ("Virtual machines hosted on a physical Transient Cyber Asset (TCA) are treated as software on that physical TCA.") that directly conflicts with a statement included in the proposed definition of Cyber Asset ("VCAs are not considered software or data of Cyber Assets.").

Likes	1	Central Hudson Gas & Electric Corp., 1, Ridolfino Michael
Dislikes	0	

Response

Thank you for your comments

The SDT asserts that it was tasked with removing requirements from its definitions, therefore it is appropriate that the Intermediate System definition does not contain its location relative to an ESP. This has been moved to CIP-005 Requirement 2.7

The SDT asserts that the Management Interface definition also needs to cover both non-dedicated physical and non-dedicated logical interfaces which may be used to manage ESP or SCI configuration such as those running on SCI management systems

The SDT asserts that the ESP definition requires "boundary" for forward compatibility in zero trust model and "border" for backwards compatibility.

The SDT asserts that for the definition of VCA, where "SCI and Cyber Assets that host VCAs" are excluded is appropriate as is. Adding an additional description to the Cyber Assets wording such as "SCI and Cyber Assets including software or data, that host VCAs" may cause additional confusion as to which asset is these are associated with. The SDT asserts that the situation of VCAs running on a VCA is already addressed as intended.

The SDT asserts that the ERC definition required changes to cover zero trust models which do not have the concept of inside or outside of an ESP

The SDT asserts that the SCI definition reference to “devices” already covers hardware. The SDT will be proposing that Implementation Guidance on all-in vs SCI be created by one of the prequalified organizations.

The SDT recognizes that ESP policy and how this relates to EAP and ESP policy enforcement can be a complex area, especially in hybrid situations. The SDT will be proposing that Implementation Guidance on ESP policy be created by one of the prequalified organizations.

The SDT asserts that the EACMS definition requires changes to address protocol converter that are used to provide IP connectivity to BCS

The SDT asserts that the TCA definition is as intended and that it is appropriate that virtual machines, running on a TCA , as not being VCAs

Constantin Chitescu - Ontario Power Generation Inc. - 5

Answer	No
Document Name	
Comment	
<p>OPG supports NPCC Regional Standards Committee’s comments.</p> <p>PCA Definition – routable protocol missing. Please clarify ESP criteria / demarcation considerations if a Responsible Entity takes a “policy” or ruleset based approach to an ESP; in relation to PCAs. Examples involving firewall / VLans / Switch controls... Can a Responsible Entity Choose what devices are PCAs based on the policy? The first bullet is missing the concept of being explicitly connected by a routable protocol Are protected by an Electronic Security Perimeter (ESP) but are not part of the highest impact BES Cyber System (BCS) protected by the same ESP; or.... Suggest.... Are connected to a network using a routable protocol and are protected by an Electronic Security Perimeter (ESP) but are not part of the highest impact BES Cyber System (BCS) protected by the same ESP; or.</p>	
Likes	0

Dislikes	0
Response	
Thank you for your comments. Please refer to the response for NPCC	
Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name NPCC RSC	
Answer	No
Document Name	
Comment	
<p>PCA Definition – routable protocol missing.</p> <p>Please clarify ESP criteria / demarcation considerations if a Responsible Entity takes a “policy” or ruleset based approach to an ESP; in relation to PCAs. Examples involving firewall / VLans / Switch controls... Can a Responsible Entity Choose what devices are PCAs based on the policy?</p> <p>The first bullet is missing the concept of being explicitly connected by a routable protocol</p> <p><i>Are protected by an Electronic Security Perimeter (ESP) but are not part of the highest impact BES Cyber System (BCS) protected by the same ESP; or....</i></p> <p>Suggest</p> <p><i>.... Are connected to a network using a routable protocol and are protected by an Electronic Security Perimeter (ESP) but are not part of the highest impact BES Cyber System (BCS) protected by the same ESP; or.</i></p>	
Likes	0
Dislikes	0
Response	
The SDT asserts that within the PCA definition of “being protected by an ESP” already implies that routable protocol is being used	

The SDT understands that there are complex issues around documenting ESP policy, especially in a hybrid networking situation. The SDT will be proposing that Implementation Guidance on ESP policy be created by one of the prequalified organizations.

James Baldwin - James Baldwin On Behalf of: Matt Lewis, Lower Colorado River Authority, 5, 1; - James Baldwin

Answer No

Document Name

Comment

LCRA believes the current CIP-002 SAR regarding serial-IP converters should be resolved prior to defining them as an EACMS.

Likes 0

Dislikes 0

Response

Thank you for your comments.
 The SDT asserts that this is part of the SAR for Project 2021-03 CIP-002

Teresa Krabe - Lower Colorado River Authority - 5

Answer No

Document Name

Comment

LCRA believes the current CIP-002 SAR regarding serial-IP converters should be resolved prior to defining them as an EACMS.

Likes 0

Dislikes 0

Response

Thank you for your comments.

The SDT asserts that this is part of the SAR for Project 2021-03 CIP-002

Junji Yamaguchi - Hydro-Quebec (HQ) - 5

Answer	No
---------------	----

Document Name	
----------------------	--

Comment

HQ supports NPCC RSC comments and provides the following additional comments:

The suggested definitions are mixing the concepts and they are making the overall understanding complicated. For example, the identification of PCA’s is done through CIP-005. CIP-002 defines the BES that defines the BCS, and at the end the BCA. It’s not written in CIP-002 that BCA need to be defined.

No where in the standard is the PCA is directly defined. The first time you see it is in part 1.1 of the R1 table in CIP-005.

For example, we have a BCA and we have a Cyber Asset they are communicating using a routable protocol, they are in the same network. Both Cyber Assets have an IP address. Theses Cyber Assets are connected via a routable protocol, thus they are in a ESP and the non qualified Cyber Asset is the PCA. In this case, the PCA is protected by an ESP.

Going with a different example, we have a BCA and we have a Cyber Asset they are communicating using a non routable protocol, there’s no network and both Cyber Asset don’t have an IP address. Those Cyber Asset are not connected via a routable protocol; thus they are not in an ESP and the non qualified Cyber Asset is nothing.

The second bullet of the PCA definition is a bit complicated, there’s the mention of “isolates routable connectivity”. We are no longer into PERMIT or DENY we are isolating, but we are still linked by the routable connectivity, ie routable protocol.

The part that is getting more confusing is the definition of the ESP. The definition of ESP has two concepts, one is based on routable protocol which works with 1.1 of CIP-005, the other is based on a logical boundary defined by one or more Electronic Access Points (EAP). What is a logical boundary ? Is a logical boundary based on routable protocol? To add to the confusion the EAP is a policy enforcement interface and it’s related to an EACMS. Is a policy a ruled based on routable protocol? Which requirement is asking to document this policy? Is it CIP-005R1.2? How to we evaluate the policy ?

Regarding the EACMS definition, which is again build with two concepts. One of the concept is “, including those not protected by an Electronic Security Perimeter used by the responsible entity to convert routable protocol communications to non routable communications to a BCS”. Considering how the current proposed standard is written, a converter (routable protocol communications to non routable communications) is associated to IRA. And IRA is associated to the concept of Intermediate System, and Intermediate System is tag as an EACMS. This logic is establish with the current proposed standard. What is the added value to add this concept to the definition of EACMS ?

Overall it seems that the SDT tried to answer multiple objectives (concepts) with the same term/definition. The end result is that we have variations in the definition and the terms are cascading. The SDT should make the definition simpler and limit the number of cascades (ESP->EAP->EACMS) . Definitions are there to ease the understanding or support the requirements, they shouldn't add additional controls.

Likes 0

Dislikes 0

Response

Thank you for your comments. Please see the response for NPCC

The SDT asserts that additional CIP-002 criteria and requirements for the identification of PCAs, EACMS and SCI is part of the SAR for Project 2021-03 CIP-002

The SDT understands that there are complex issues around ESP policy, EAP and EACMS, especially in a hybrid networking situation. The SDT will be proposing that Implementation Guidance on ESP policy be created by one of the prequalified organizations.

The SDT asserts that a protocol converter allowing IP connectivity to a BCS is performing the EACMS function, therefore it is appropriate to add this to the EACMS definition.

Jennifer Bray - Arizona Electric Power Cooperative, Inc. - 1

Answer

No

Document Name

Comment

AEPC has signed on to ACES comments:

ACES feels the way the definition of Electronic Access Point (EAP) is written in this draft is overly wordy. ACES suggests:

“An electronic policy enforcement point or a Cyber Asset interface on Electronic Access Control or Monitoring Systems that controls routable communication to and from BES Cyber Systems.”

ACES feels the way the definition of Intermediate System is written in this draft is overly wordy. ACES suggests:

“Electronic Access Control or Monitoring Systems (EACMS) used to restrict Interactive Remote Access to only authorized users”

ACES also noted that the definition of an Intermediate System no longer states that it must not be located inside an ESP, combined with the removal of the language from R2.1: “such that the Cyber Asset initiating Interactive Remote Access does not directly access an applicable Cyber Asset.” Without those two statements IRA could be initiated through an ESP to an Intermediate System located in an ESP. ACES feels the removal of the language from the definition and requirement is not what was intended and needs to be added back to ensure the security of IRA. Furthermore

with the removal of the language, it allows a Cyber Asset IRA client to connect directly to Applicable Systems, if the Intermediate System is also an EACMS with an EAP. In this scenario the Cyber Asset client connects to the EACMS using a VPN client and Multi Factor Authentication. Once connected to the Intermediate System, the IRA Client could connect directly to applicable systems. There are other scenarios, but this is the most obvious.

EACMS is already plural. so adding “one or more” to the definition of Intermediate System is redundant.

ACES feels the second bullet point on the new Management Interface should be scoped down. There are a variety of vulnerabilities in “autonomous subsystems” in which one could gain access to a system’s console. Changing the scope of the definition to be ONLY those devices specifically designed and or used to allow access to a console would reduce scope creep. ACES suggests:

“Is an autonomous subsystem, specifically designed and or used to provide access to the console independently of the Cyber Asset’s CPU, firmware, and operating system;”

Likes 0

Dislikes	0
Response	
Thank you for your comments. Please refer to the ACES response	
Nicolas Turcotte - Hydro-Quebec (HQ) - 1	
Answer	No
Document Name	
Comment	
<p>HQ supports NPCC RSC comments and provides the following additional comments:</p> <p>The suggested definitions are mixing the concepts and they are making the overall understanding complicated. For example, the identification of PCA's is done through CIP-005. CIP-002 defines the BES that defines the BCS, and at the end the BCA. It's not written in CIP-002 that BCA need to be defined.</p> <p>No where in the standard is the PCA is directly defined. The first time you see it is in part 1.1 of the R1 table in CIP-005.</p> <p>For example, we have a BCA and we have a Cyber Asset they are communicating using a routable protocol, they are in the same network. Both Cyber Assets have an IP address. Theses Cyber Assets are connected via a routable protocol, thus they are in a ESP and the non qualified Cyber Asset is the PCA. In this case, the PCA is protected by an ESP.</p> <p>Going with a different example, we have a BCA and we have a Cyber Asset they are communicating using a non routable protocol, there's no network and both Cyber Asset don't have an IP address. Those Cyber Asset are not connected via a routable protocol; thus they are not in an ESP and the non qualified Cyber Asset is nothing.</p> <p>The second bullet of the PCA definition is a bit complicated, there's the mention of "isolates routable connectivity". We are no longer into PERMIT or DENY we are isolating, but we are still linked by the routable connectivity, ie routable protocol.</p> <p>The part that is getting more confusing is the definition of the ESP. The definition of ESP has two concepts, one is based on routable protocol which works with 1.1 of CIP-005, the other is based on a logical boundary defined by one or more Electronic Access Points (EAP). What is a logical boundary ? Is a logical boundary based on routable protocol? To add to the confusion the EAP is a policy enforcement</p>	

interface and it's related to an EACMS. Is a policy a ruled based on routable protocol? Which requirement is asking to document this policy? Is it CIP-005R1.2? How to we evaluate the policy ?

Regarding the EACMS definition, which is again build with two concepts. One of the concept is “, including those not protected by an Electronic Security Perimeter used by the responsible entity to convert routable protocol communications to non routable communications to a BCS”. Considering how the current proposed standard is written, a converter (routable protocol communications to non routable communications) is associated to IRA. And IRA is associated to the concept of Intermediate System, and Intermediate System is tag as an EACMS. This logic is establish with the current proposed standard. What is the added value to add this concept to the definition of EACMS ?

Overall it seems that the SDT tried to answer multiple objectives (concepts) with the same term/definition. The end result is that we have variations in the definition and the terms are cascading. The SDT should make the definition simpler and limit the number of cascades (ESP->EAP->EACMS) . Definitions are there to ease the understanding or support the requirements, they shouldn't add additional controls.

Likes 0

Dislikes 0

Response

Thank you for your comments. Please refer to the HQ5 response

Chris Carnesi - Chris Carnesi On Behalf of: Dennis Sismaet, Northern California Power Agency, 4, 6, 3, 5; Jeremy Lawson, Northern California Power Agency, 4, 6, 3, 5; Michael Whitney, Northern California Power Agency, 4, 6, 3, 5; - Chris Carnesi

Answer

No

Document Name

Comment

NCPA recommends the following edits:

Cyber System should say "Two or more Cyber Assets...." as the word system implies multiples devices working together.

The proposed Intermediate System definition removed the requirement of not being inside the ESP, however in the proposed language for CIP-005-8 R2.7 it states "...communications from an Intermediate System to a high or medium impact BCS or associated PCAs must be through an ESP", which implies that it must reside outside of the ESP. NCPA suggests keeping the original language in the Intermediate System to include not being located within an ESP.

Likes 0

Dislikes 0

Response

Thank you for your comments.

The SDT asserts that a Cyber System can consist of 1 Cyber Asset , therefore this is appropriate

The SDT asserts that it was tasked with removing requirements out of the Intermediate System definition. The requirement language was moved from the definition to CIP-005 R2.7

Steve Toosevich - NiSource - Northern Indiana Public Service Co. - 1

Answer

No

Document Name

Comment

SCI is superfluous considering that existing classification definitions can be applied. SCI does not clearly state what devices would be included and which are not included. Cyber Systems definition seems to rope in non-CIP assets. BES Cyber Systems definition is sufficient for grouping together Cyber Assets.

Likes 0

Dislikes 0

Response

Thank you for your comments.

The SDT asserts that SCI definition is as intended and that the Applicable Systems column in the requirements performs the scoping required to narrow down the applicability. The SDT will be proposing that Implementation Guidance on the aspects of All-in vs SCI be created by one of the prequalified organizations.

Andy Fuhrman - Andy Fuhrman On Behalf of: Theresa Allard, Minnkota Power Cooperative Inc., 1; - Andy Fuhrman

Answer	No
---------------	----

Document Name	
----------------------	--

Comment

MPC supports comments submitted by ACES.

Likes	0
-------	---

Dislikes	0
----------	---

Response

Thank you for your comments. Please refer to the ACES response

Adrian Andreoiu - BC Hydro and Power Authority - 1, Group Name BC Hydro

Answer	No
---------------	----

Document Name	
----------------------	--

Comment

The definition of Intermediate System remains ambiguous as to whether it can cover such devices as Active Directory servers or firewalls. The terminology should be changed to define the Intermediate System to be the device that IRA is restricted to, not the device that does the restriction (which is not the Intermediate System, but is the firewall and/or domain policy server).

Also, the definition of BES Cyber Asset (BCA) uses the Glossary Term "Reliable Operations". This definition of BCA could increase the scope of the Cyber Assets being used for the operation of the BES since Reliable Operations defines Bulk-Power System's method of operation (which is a broader less precise term than BES).

Lastly the use of the term "Management Interface" needs clarification with use case and pertinent examples.

Likes 0

Dislikes 0

Response

Thank you for your comments.

The SDT asserts that the Intermediate System definition is as intended. The entity must evaluate all systems needed for the function of the Intermediate System and classify them appropriately.

The SDT asserts that the use of Reliable Operation covers the essence of how a BCA should be defined and the further wording of "Reliable Operation of the Bulk Electric System (BES)" scopes the definition down to only the elements of the BES. This same wording is also used in the Reliability Co-Ordinator definition

The SDT will be proposing that Implementation Guidance on Management Interfaces be created by one of the prequalified organizations.

Micah Runner - Black Hills Corporation - 1

Answer

No

Document Name

Comment

Black Hills Corporation has the following comments regarding the CIP definition changes:

Cyber Assets: The last two sentences of the definition should be included as a note to the definition so that the term Cyber Asset is not in the definition of a Cyber Asset. Here is an example of what that could look like:

“Programmable electronic devices, excluding Shared Cyber Infrastructure, including the hardware, software, and data in those devices.

(Note – Application containers are considered software of Virtual Cyber Assets (VCAs) or Cyber Assets. VCAs are not considered software or data of Cyber Assets.)”

EAP: The definition should be revised to include the following commas to ensure clarity of the definition: “An electronic policy enforcement point, or a Cyber Asset interface on an Electronic Access Control or Monitoring Systems, that controls routable communication to and from one or more BES Cyber Systems or their associated Protected Cyber Assets.”

Likes 0

Dislikes 0

Response

Thank you for your response

The SDT discussed your proposed changes to the Cyber Asset definition. The current positioning and phrasing are needed for the definition to work as intended.

The SDT discussed your proposed changes to the EAP definition. The current positioning and phrasing are needed for backwards compatibility

Rachel Schuldt - Rachel Schuldt On Behalf of: Claudine Bates, Black Hills Corporation, 5, 6, 1, 3; - Rachel Schuldt

Answer

No

Document Name

Comment

Black Hills Corporation has the following comments regarding the CIP definition changes:

Cyber Assets: The last two sentences of the definition should be included as a note to the definition so that the term Cyber Asset is not in the definition of a Cyber Asset. Here is an example of what that could look like:

“Programmable electronic devices, excluding Shared Cyber Infrastructure, including the hardware, software, and data in those devices.

(Note – Application containers are considered software of Virtual Cyber Assets (VCAs) or Cyber Assets. VCAs are not considered software or data of Cyber Assets.)”

EAP: The definition should be revised to include the following commas to ensure clarity of the definition: “An electronic policy enforcement point, or a Cyber Asset interface on an Electronic Access Control or Monitoring Systems, that controls routable communication to and from one or more BES Cyber Systems or their associated Protected Cyber Assets.”

Likes 0

Dislikes 0

Response

Thank you for your response

The SDT discussed your proposed changes to the Cyber Asset definition. The current positioning and phrasing are needed for the definition to work as intended.

The SDT discussed your proposed changes to the EAP definition. The current positioning and phrasing are needed for backwards compatibility

Josh Combs - Black Hills Corporation - 3

Answer

No

Document Name

Comment

Black Hills Corporation has the following comments regarding the CIP definition changes:

Cyber Assets: The last two sentences of the definition should be included as a note to the definition so that the term Cyber Asset is not in the definition of a Cyber Asset. Here is an example of what that could look like:

“Programmable electronic devices, excluding Shared Cyber Infrastructure, including the hardware, software, and data in those devices.

(Note – Application containers are considered software of Virtual Cyber Assets (VCAs) or Cyber Assets. VCAs are not considered software or data of Cyber Assets.)”

EAP: The definition should be revised to include the following commas to ensure clarity of the definition: “An electronic policy enforcement point, or a Cyber Asset interface on an Electronic Access Control or Monitoring Systems, that controls routable communication to and from one or more BES Cyber Systems or their associated Protected Cyber Assets.”

Likes 0

Dislikes 0

Response

Thank you for your response

The SDT discussed your proposed changes to the Cyber Asset definition. The current positioning and phrasing are needed for the definition to work as intended.

The SDT discussed your proposed changes to the EAP definition. The current positioning and phrasing are needed for backwards compatibility

Sheila Suurmeier - Black Hills Corporation - 5

Answer

No

Document Name

Comment

Black Hills Corporation has the following comments regarding the CIP definition changes:

Cyber Assets: The last two sentences of the definition should be included as a note to the definition so that the term Cyber Asset is not in the definition of a Cyber Asset. Here is an example of what that could look like:

“Programmable electronic devices, excluding Shared Cyber Infrastructure, including the hardware, software, and data in those devices.

(Note – Application containers are considered software of Virtual Cyber Assets (VCAs) or Cyber Assets. VCAs are not considered software or data of Cyber Assets.)”

EAP: The definition should be revised to include the following commas to ensure clarity of the definition: “An electronic policy enforcement point, or a Cyber Asset interface on an Electronic Access Control or Monitoring Systems, that controls routable communication to and from one or more BES Cyber Systems or their associated Protected Cyber Assets.”

Likes 0

Dislikes 0

Response

Thank you for your response

The SDT discussed your proposed changes to the Cyber Asset definition. The current positioning and phrasing are needed for the definition to work as intended.

The SDT discussed your proposed changes to the EAP definition. The current positioning and phrasing are needed for backwards compatibility

Todd Bennett - Associated Electric Cooperative, Inc. - 3, Group Name AECl

Answer

No

Document Name

Comment

The BCA definition changes include the defined term "Reliable Operation" which applies to the BPS by definition rather than just the BES. AECI supports the use of the previous "reliable operation" undefined term as it would eliminate the risk of scope expansion to non-BES assets.

Likes 0

Dislikes 0

Response

Thank you for your response . The SDT asserts that the use of Reliable Operation covers the essence of how a BCA should be defined and the further wording of "Reliable Operation of the Bulk Electric System (BES)" scopes the definition down to only the elements of the BES. This same wording is also used in the Reliability Co-Ordinator definition

Lindsey Mannion - ReliabilityFirst - 10

Answer

No

Document Name

Comment

The new Electronic Security Perimeter (ESP) definition still complicates the situation with respect to mixed-trust environments where a Responsible entity may choose to create ESPs and corresponding EAP's per individual Cyber System (zero trust paradigm). While this may be easier with standalone physical Cyber Assets – introducing SCI, VCA, virtual clusters, and virtual networking creates complexity that could allow unauthorized access if not carefully configured for applicable VM guests and virtual networks – especially if affinity controls are not strictly created and enforced. Marrying both ESP and zero-trust within an overall ESP would better serve our Responsible Entities and create a more secure environment as zero-trust Cyber Assets would not be directly internet-facing. Maintaining the ESP, and fully incorporating virtualization and zero trust paradigms within an identified ESP allows Responsible Entities to leverage another layer of defense (defense-in-depth) for Applicable Systems by limiting ingress/egress points and access to these BCS.

For the Shared Cyber Infrastructure definition, where is this to be identified and categorized? CIP-002 only requires the identification of BCS while the associated Technical Rationale warns of Assets with Multiple Classifications regarding high water marking. Is the entity to assume SCI must be included in CIP-002 even though it is not specifically included in the BCS definition?

Likes	0
Dislikes	0
Response	
Thank you for your comments	
The SDT will be proposing that Implementation Guidance on ESP policy / Zero Trust be created by one of the prequalified organizations	
The SDT asserts identification of SCI (as well as EACMS and PCAs) is now within the scope of Project 2021-03 CIP-002	
Tim Kelley - Tim Kelley On Behalf of: Charles Norton, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Fong Mua, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Kevin Smith, Balancing Authority of Northern California, 1; Nicole Goi, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Nicole Looney, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Wei Shao, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; - Tim Kelley, Group Name SMUD and BANC	
Answer	No
Document Name	
Comment	
SMUD and BANC have the following comments regarding the CIP definition changes:	
Cyber Assets: The last two sentence of the definition should be included as a note to the definition so that the term Cyber Asset is not in the definition of a Cyber Asset. Here is an example of what that could look like:	
“Programmable electronic devices, excluding Shared Cyber Infrastructure, including the hardware, software, and data in those devices.	
(Note – Application containers are considered software of Virtual Cyber Assets (VCAs) or Cyber Assets. VCAs are not considered software or data of Cyber Assets.)”	
Cyber System: The definition should be changed to the following: “Two or more Cyber Assets, Virtual Cyber Assets, or Shared Cyber Infrastructure working together to provide or perform a specific function.”	

EAP: The definition should be revised to include the following commas to ensure clarity of the definition: “An electronic policy enforcement point, or a Cyber Asset interface on an Electronic Access Control or Monitoring Systems, that controls routable communication to and from one or more BES Cyber Systems or their associated Protected Cyber Assets.”

BCA: The proposed BES Cyber Asset (BCA) definition now capitalizes “Reliable Operation”, which describes/ defines how to operate the **Bulk Electric System (BES)**. However, Reliable Operations specifically refers to the **Bulk-Power System** in its definition:

*“Operating the elements of the **[Bulk-Power System]** within equipment and electric system thermal, voltage, and stability limits so that instability, uncontrolled separation, or cascading failures of such system will not occur as a result of a sudden disturbance, including a cybersecurity incident, or unanticipated failure of system elements.”*

The Bulk-Power System is defined as:

“(A) facilities and control systems necessary for operating an interconnected electric energy transmission network (or any portion thereof); and

(B) electric energy from generation facilities needed to maintain transmission system reliability. The term does not include facilities used in the local distribution of electric energy. (Note that the terms “Bulk-Power System” or “Bulk Power System” shall have the same meaning.)”

The Bulk-Power System term is broader in scope and less precise than the Bulk Electric System term. The Bulk Electric System is defined as:

“...all Transmission Elements operated at 100 kV or higher and Real Power and Reactive Power resources connected at 100 kV or higher. This does not include facilities used in the local distribution of electric energy...”

With the capitalization of “Reliable Operations”, it could be interpreted that the proposed definition of BCA could increase the scope of the Cyber Assets used for operating the BES since Reliable Operations describes/defines how to operate the Bulk-Power System, which is a broader less precise term than BES.

SMUD and BANC would like to understand why the defined term, Reliable Operation, was used and if the intent of the revision is to broaden the scope of Cyber Assets.

Likes 0

Dislikes	0
Response	
<p>Thank you for your comments Cyber System, Cyber Asset, EAP</p> <p>The SDT asserts that the Cyber Asset definition was carefully crafted to work as intended and that the proposed change may have unintended consequences.</p> <p>The SDT asserts that the Cyber System definition is as intended and meant to be inclusive / shorthand so as to be used in situations where separately specifying Cyber Assets, VCAs and SCI repeatedly would have been excessively wordy and caused confusion</p> <p>The SDT asserts that the EAP definition was crafted as-is for backward compatibility purposes .</p> <p>The SDT asserts that the use of Reliable Operation covers the essence of how a BCA should be defined and the further wording of “Reliable Operation of the Bulk Electric System (BES)” scopes the definition down to only the elements of the BES. This same wording is also used in the Reliability Co-Ordinator definition</p>	
Tracy MacNicoll - Utility Services, Inc. - 4	
Answer	Yes
Document Name	
Comment	
<p>USV support the comments made by NPCC RSC.</p> <p>The proposed ESP definition uses the terms “border” and “boundary”. It is unclear what difference is between these two terms and how this difference impacts the proposed definition.</p>	
Likes	0
Dislikes	0

Response	
Thank you for your comments . Please refer to the NPCC response	
The SDT asserts that “boundary” is forward compatible with zero trust networking and “border” is required for backwards compatibility. Please refer to the CIP-005-8 Technical Rationale	
David Jendras Sr - Ameren - Ameren Services - 3	
Answer	Yes
Document Name	
Comment	
In the CIP Senior Manager definition, the words "cyber security" should be deleted. As proposed it implies that the CSM is no longer responsible for physical security Standards CIP-006 & CIP-014.	
Likes	0
Dislikes	0
Response	
Thank you for your comments	
The SDT asserts that the title of the CIP-006 Standard includes the words “Cyber Security”	
The SDT asserts that CIP Senior Manager is not associated with CIP-014 and also that “Cyber Security” is not in the title for CIP-014	
Marcus Bortman - APS - Arizona Public Service Co. - 6	
Answer	Yes
Document Name	
Comment	

AZPS supports the changes to definitions within draft 5.	
Likes	0
Dislikes	0
Response	
Thank you for your comments	
Kinte Whitehead - Exelon - 3	
Answer	Yes
Document Name	
Comment	
Exelon is supporting EEI comments in response to this question.	
Likes	0
Dislikes	0
Response	
Thank you for your comments	
Daniel Gacek - Exelon - 1	
Answer	Yes
Document Name	
Comment	
Exelon supports the comments submitted by the EEI.	

Likes	0
Dislikes	0
Response	
Thank you for your comments	
Mark Gray - Edison Electric Institute - NA - Not Applicable - NA - Not Applicable	
Answer	Yes
Document Name	
Comment	
EEI supports the changes made to the definitions as posted in this Draft 5 posting.	
Likes	0
Dislikes	0
Response	
Thank you for your comments	
Gail Elliott - Gail Elliott On Behalf of: Michael Moltane, International Transmission Company Holdings Corporation, 1; - Gail Elliott	
Answer	Yes
Document Name	
Comment	
ITC supports the response submitted by EEI	
Likes	0
Dislikes	0

Response	
Thank you for your comments.	
Wayne Sipperly - North American Generator Forum - 5 - MRO,WECC,Texas RE,NPCC,SERC,RF	
Answer	Yes
Document Name	
Comment	
The NAGF agrees with the definition changes.	
Likes	0
Dislikes	0
Response	
Thank you for your comments.	
Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company	
Answer	Yes
Document Name	
Comment	
Southern agrees and supports the changes to the definitions in Draft 5.	
Likes	0
Dislikes	0
Response	
Thank you for your comments.	

Richard Vendetti - NextEra Energy - 5	
Answer	Yes
Document Name	
Comment	
NEE supports EEI comments	
Likes	0
Dislikes	0
Response	
Thank you for your comments.	
Jay Sethi - Manitoba Hydro - 1,3,5,6 - MRO	
Answer	Yes
Document Name	
Comment	
The work the standard drafting team has done to move requirements out of the definitions and in to the standards improves the reliability standards overall.	
Likes	0
Dislikes	0
Response	
Thank you for your comments.	
John Galloway - John Galloway On Behalf of: Michael Puscas, ISO New England, Inc., 2; - John Galloway	

Answer	Yes
Document Name	
Comment	
ISO-NE supports the ISO/RTO Council comments in this area.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comments.	
Andrea Jessup - Bonneville Power Administration - 1,3,5,6 - WECC	
Answer	Yes
Document Name	
Comment	
BPA has two recommendations:	
Cyber Asset definition: recommend improving the grammar by rewriting so there is not an “excluding” phrase separated from an “including” phrase by nothing but a comma. As written it will cause confusion.	
ERC definition: Given that the EAP definition would be modified to refer to EACMS as the ‘location’ of the EAP, the definition of ERC might read better if it stated “through an EAP” or “through its EACMS” rather than “through its ESP.”	
Likes 0	
Dislikes 0	
Response	

Thank you for your comments.

The SDT asserts that the Cyber Asset definition was carefully crafted as-is and that changes may have unintended consequences
 The SDT asserts that the ERC definition was crafted to be both forward compatible with zero trust networking as well as backwards compatible

Mark Garza - FirstEnergy - FirstEnergy Corporation - 4, Group Name FE Voter

Answer Yes

Document Name

Comment

FirstEnergy does not opposed the other definitions.

Likes 0

Dislikes 0

Response

Thank you for your comments.

Kennedy Meier - Electric Reliability Council of Texas, Inc. - 2

Answer Yes

Document Name

Comment

Likes 0

Dislikes 0

Response

Thank you for your support.	
Dwanique Spiller - Berkshire Hathaway - NV Energy - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Jennie Wike - Jennie Wike On Behalf of: Hien Ho, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; John Merrell, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Ozan Ferrin, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Terry Gifford, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; - Jennie Wike, Group Name Tacoma Power	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Alain Mukama - Hydro One Networks, Inc. - 1,3	
Answer	Yes
Document Name	

Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Martin Sidor - NRG - NRG Energy, Inc. - 6	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Steven Rueckert - Western Electricity Coordinating Council - 10, Group Name WECC CIP	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	

Thank you for your support.	
Anna Martinson - MRO - 1,2,3,4,5,6 - MRO, Group Name MRO Group	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
John Daho - John Daho On Behalf of: David Weekley, MEAG Power, 3, 1; Roger Brand, MEAG Power, 3, 1; - John Daho	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Rachel Coyne - Texas Reliability Entity, Inc. - 10	
Answer	Yes
Document Name	
Comment	

Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Shannon Mickens - Shannon Mickens On Behalf of: Joshua Phillips, Southwest Power Pool, Inc. (RTO), 2; - Shannon Mickens, Group Name SPP RTO	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Monika Montez - California ISO - 2 - WECC, Group Name ISO/RTO Council Standards Review Committee (SRC)	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	

Thank you for your support.	
Ellese Murphy - Ellese Murphy On Behalf of: Marcelo Pesantez, Duke Energy - Florida Power Corporation, 3; - Ellese Murphy	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
C. A. Campbell - LS Power Development, LLC - 5	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support. Thank you for your support.	
Mark Flanary - Midwest Reliability Organization - 10	
Answer	Yes
Document Name	
Comment	

Likes 0	
Dislikes 0	
Response	
Erik Gustafson - PNM Resources - Public Service Company of New Mexico - 1,3 - WECC,Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Casey Jones - Berkshire Hathaway - NV Energy - 5 - WECC	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	

Ben Hammer - Western Area Power Administration - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Mike Magruder - Avista - Avista Corporation - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support. Thank you for your support.	
Karen Artola - CPS Energy - 1,3,5 - Texas RE	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Brian Millard - Tennessee Valley Authority - 1,3,5,6 - SERC, Group Name TVA RBB	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Rebika Yitna - MEAG Power - 1,3 - SERC	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Richard Jackson - U.S. Bureau of Reclamation - 1	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Donna Wood - Tri-State G and T Association, Inc. - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Tristan Miller - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Thank you for your support.	
Robert Follini - Avista - Avista Corporation - 3	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Jennifer Buckman - Southern Indiana Gas and Electric Co. - 3,5,6 - RF	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
LaTroy Brumfield - American Transmission Company, LLC - 1	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Anne Kronshage - Public Utility District No. 1 of Chelan County - 6, Group Name Public Utility District No. 1 of Chelan County - Voting Group	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Clay Walker - Clay Walker On Behalf of: John Lindsey, Cleco Corporation, 6, 5, 1, 3; Maurice Paulk, Cleco Corporation, 6, 5, 1, 3; Robert Hirschak, Cleco Corporation, 6, 5, 1, 3; Stephanie Huffman, Cleco Corporation, 6, 5, 1, 3; Wayne Messina, LaGen, 4; - Clay Walker	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Thank you for your support.	
James Keele - Entergy - 1,3,6	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Patricia Lynch - NRG - NRG Energy, Inc. - 5	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Joanne Anderson - Public Utility District No. 2 of Grant County, Washington - 1,4,5,6 - WECC	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	

3. The SDT revised CIP-005 R1 based on industry comments. Do you agree with the proposed changes? If not, please provide the basis for your disagreement and an alternate proposal.

Tim Kelley - Tim Kelley On Behalf of: Charles Norton, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Fong Mua, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Kevin Smith, Balancing Authority of Northern California, 1; Nicole Goi, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Nicole Looney, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Wei Shao, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; - Tim Kelley, Group Name SMUD and BANC

Answer No

Document Name

Comment

SMUD and BANC disagree with the new definitions for IRA and Cyber System as the proposed definition changes may expand the scope of CIP-005, Requirement R1 to non-BES Cyber Systems.

Likes 1 Central Hudson Gas & Electric Corp., 1, Ridolfino Michael

Dislikes 0

Response

The SDT asserts that the purpose of the IRA glossary term is to describe a certain type of access, without scoping the security requirements on such access within the term’s definition. The actual scope of and required controls on IRA are contained within CIP-005 R2. It is in R2 where the generic “Cyber System” in the definition of IRA is appropriately scoped. The SDT asserts the NERC glossary should function solely as a dictionary and all mandatory requirements and scoping of such requirements should be in the standards themselves. Positively, this avoids situations where an entity is essentially “non-compliant” with a requirement or scope included in a glossary definition, therefore they are potentially non-compliant with all requirements in the standard that rely on that definition.

The SDT notes that CIP-005 R1 does not refer to IRA and does not agree, nor is it the intent, that the IRA definition expands the ESP scope to non-BCS, with the exception of the PCAs within the ESP.

Andrea Jessup - Bonneville Power Administration - 1,3,5,6 - WECC	
Answer	No
Document Name	
Comment	
<p>As with Draft 4, BPA does not support the expansion of R1, Part 1.6 to include the protection of data traversing communications links. Expansion to communications links does not consider devices that cannot meet this criterion. Putting communication links in scope would increase costs and maintenance activities and would require re-architecture of links.</p> <p>BPA does support the replacement of “protect” with “permit” in R 1 Part 1.3; this adds clarity to the intent of the requirement.</p>	
Likes	0
Dislikes	0
Response	
<p>Thank you for the support of the changes to R1.3.</p> <p>As to Requirement Part 1.6, the SDT notes this new Requirement Part is a combination of scenarios where a single ESP is extended between different PSPs and thus access to this network is not physically protected while between PSPs. To date, this has been the purview of CIP-006 R1.10, however that was designed for “across the hall” LAN scenarios and it was limited to cabling and non-programmable components (i.e., unmanaged hubs/switches, patch panels, etc.). For virtualization purposes, the SDT needed to incorporate true WAN scenarios with flat networks (thus a single ESP) so that VCAs could seamlessly move from hypervisors in one physical data center to another physical data center over large distances, increasing reliability and resiliency of those VCAs’ functions. The SDT chose to simplify this by incorporating CIP-006 R1.10 scenarios (“across the hall”) with this larger “Super-ESP” scenario (“across the state”) so that there is one single requirement in one standard that addresses all scenarios where a single ESP must exit one PSP and extend to another.</p> <p>Along with this multi-site WAN scenario, the existing exemption 4.2.3.2 in the CIP standards would not exclude any Cyber Assets between the sites, such as the carrier’s equipment because it is not “between discrete ESPs”; it is all within the same ESP and thus all that equipment would be, at minimum, PCAs within the ESP. That is an unintended consequence of the desire to extend a flat ESP across sites</p>	

to increase resiliency of VCAs moving seamlessly between sites. The SDT therefore added a new exemption 4.2.3.3 that will exclude Cyber Assets to address this while working hand-in-hand with this new Requirement Part 1.6. The end result is the responsible entity is required to protect the data while it is between PSPs and can do so either in the previous CIP-006 R1.10 way for short distances or in the new R1.6 way for long distances and then may exempt the Cyber Assets between the encryption points where the data is protected. The SDT asserts this consolidates all the scenarios, removing the local one from CIP-006 R1.10 and combining it all into this new R1.6 in CIP-005 whose scope is protecting the ESP.

Adrian Andreoiu - BC Hydro and Power Authority - 1, Group Name BC Hydro

Answer No

Document Name

Comment

The STD proposed a change to specify EAP as applicable systems. BC Hydro recommends providing additional clarity on evidence expectations where network-like evidence is expected at the BCS level.

Likes 0

Dislikes 0

Response

The SDT notes that EAP is not used in the Applicable Systems column for R1 and its Parts. It is used in the example measures for R1.2 as “EAP configuration”. Previous drafts did include EAP as an applicable system but that is no longer the case.

Andy Fuhrman - Andy Fuhrman On Behalf of: Theresa Allard, Minnkota Power Cooperative Inc., 1; - Andy Fuhrman

Answer No

Document Name

Comment

MPC supports comments submitted by the MRO NERC Standards Review Forum (NSRF) and ACES.

Likes	0
Dislikes	0
Response	
Thank you. Please see response to MRO NSRF and ACES.	
Chris Carnesi - Chris Carnesi On Behalf of: Dennis Sismaet, Northern California Power Agency, 4, 6, 3, 5; Jeremy Lawson, Northern California Power Agency, 4, 6, 3, 5; Michael Whitney, Northern California Power Agency, 4, 6, 3, 5; - Chris Carnesi	
Answer	No
Document Name	
Comment	
NCPA does not agree based on comments made in question 1 related to the proposed IRA definition change.	
Likes	0
Dislikes	0
Response	
Thank you, please see response to Q1 in regards to IRA definition change.	
Nicolas Turcotte - Hydro-Quebec (HQ) - 1	
Answer	No
Document Name	
Comment	
HQ supports NPCC RSC comments and provides the following additional comments:	
R1.2 We support the following modification “excluding time sensitive communications of Protection Systems” (replacing “communications using protocol IEC TR 61850-90-5 R-GOOSE”) assuming that the intent of the SDT was to link with the definition of Protection System (Glossary of terms)	

In the column Measures, the SDT mentions VLAN and VXLAN, they are not routable protocols. Please refer to the OSI model.

R1.3 The objective of Requirement R1.2 is to protect the BCA and the PCA through the management of the routable protocol communications (Permit/Deny). The EACMS and SCI assist in the delivery of the BCA/PCA functionalities. The EACMS and SCI Management interface are just as important, we suggest wording the requirement R1.2 and R1.3 the same way. R1.2 could be worded as: “Protect Applicable System by implementing policy enforcement to permit only needed network accessibility documenting the reason, and deny all other communications, through the ESP.” Doing so would removed the need of R1.3 or would be more “inline”.

Please note the usage of the word policy, this usage is to ensure a logical link between the requirements and the definitions.

The definition of ESP brings the concept of routable protocol and the concept of logical boundary.

R1.4 This requirement should consider including the introduction of Management interface concept. Management interface is another mean to interact with the Cyber Asset and should be address.

Likes	0
Dislikes	0

Response

Thank you for your support of R1.2 and the SDT agrees the intent is to link to the “Protection System” in the NERC Glossary of Terms.

In the Measures for R1.2, the SDT does use examples of VLAN and VXLAN *configuration* and agrees that while those are not OSI layer routable protocols in and of themselves, their configuration could be used as methods to “Permit only needed routable protocol *communications*”.

For R1.3, the SDT thanks you for the suggestion but asserts that two separate Requirement Parts are necessary. R1.2 is scoped to the Applicable Systems protected by (inside) the ESP while R1.3 is to protect the Management Interface of the Cyber Assets creating and controlling the ESP (thus not protected by the ESP itself). Should R1.2 and R1.3 be combined, the SDT foresees a “hall of mirrors” possibility. Also, the SDT believes R1.2 should NOT include a “per system capability” option but R1.3 should due to varying capability of Management Interfaces, thus necessitating separate Requirement Parts. The SDT also notes that while these are separate Parts, it is one single Requirement R1.

For R1.4, the SDT did not consider Dial-Up Connectivity changes as part of our SAR.

Around the ESP definition, the SDT retained the existing language and added new language for zero trust

Jennifer Bray - Arizona Electric Power Cooperative, Inc. - 1

Answer No

Document Name

Comment

AEPC has signed on to ACES comments:

ACES feels R1.3 should be reworded:

“EACMS, and their supporting SCI, that control access to and from an ESP for an Applicable System in Part 1.1”

ACES feels in R1.4: “if any” is not necessary.

Likes 0

Dislikes 0

Response

Thank you. Please see response to ACES.

Junji Yamaguchi - Hydro-Quebec (HQ) - 5

Answer No

Document Name

Comment

HQ supports NPCC RSC comments and provides the following additional comments:

R1.2 We support the following modification “excluding time sensitive communications of Protection Systems” (replacing “communications using protocol IEC TR 61850-90-5 R-GOOSE”) assuming that the intent of the SDT was to link with the definition of Protection System (Glossary of terms)

In the column Measures, the SDT mentions VLAN and VXLAN, they are not routable protocols. Please refer to the OSI model.

R1.3 The objective of Requirement R1.2 is to protect the BCA and the PCA through the management of the routable protocol communications (Permit/Deny). The EACMS and SCI assist in the delivery of the BCA/PCA functionalities. The EACMS and SCI Management interface are just as important, we suggest wording the requirement R1.2 and R1.3 the same way. R1.2 could be worded as: “Protect Applicable System by implementing policy enforcement to permit only needed network accessibility documenting the reason, and deny all other communications, through the ESP.” Doing so would removed the need of R1.3 or would be more “inline”.

Please note the usage of the word policy, this usage is to ensure a logical link between the requirements and the definitions.

The definition of ESP brings the concept of routable protocol and the concept of logical boundary.

R1.4 This requirement should consider including the introduction of Management interface concept. Management interface is another mean to interact with the Cyber Asset and should be address.

Likes	0
Dislikes	0
Response	
Thank you. Please see response to Hydro-Quebec comments (Nicolas Turcotte) above.	
Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name NPCC RSC	
Answer	No
Document Name	
Comment	

1.3 broaden from *network accessibility* to be more objective = “*protect configuration*” in order to allow other methods to protect the configuration

Protect ESP and SCI configurations by implementing methods to permit only needed network accessibility to Management Interfaces of Applicable Systems, per system capability.

Suggest

Implement methods to protect ESP and SCI configurations at Management Interfaces of Applicable Systems, per system capability, per system capability.

Likes 0

Dislikes 0

Response

Thank you for the suggestion. The intent of adding “Protect the ESP and SCI configurations” was to add the objective, the “why”, behind the required action of permitting only needed network accessibility to the Management Interface. In the proposed language, the SDT considers implementing these methods “at” the Management Interface may be too prescriptive and could remove some needed flexibility. For example, the intent may be met by implementing a dedicated management zone in the infrastructure to which the Management Interface is connected. In this instance, the method is not implemented “at” the Management Interface in question, however the objective can be met from methods implemented elsewhere.

Constantin Chitescu - Ontario Power Generation Inc. - 5

Answer

No

Document Name

Comment

OPG supports NPCC Regional Standards Committee’s comments.

1.3 broaden from network accessibility to be more objective = “protect configuration” in order to allow other methods to protect the configuration

Protect ESP and SCI configurations by implementing methods to permit only needed network accessibility to Management Interfaces of Applicable Systems, per system capability.

Suggest

Implement methods to protect ESP and SCI configurations at Management Interfaces of Applicable Systems, per system capability, per system capability.

Likes 0

Dislikes 0

Response

Thank you. Please see response to NPCC RSC comments above.

Alain Mukama - Hydro One Networks, Inc. - 1,3

Answer

No

Document Name

Comment

Part 1.5 -> Suggestion to consider IPS/IDS on the edge of a facility instead of between discrete ESPs (E.g. if a facility has a number of ESP and non-ESP network segments, but has IPS/IDS controls at the routing edge of the facility)

Part 2.6 -> Use wording from CIP-007 that explicitly excludes storage resources (consistency in language)

Part 2.7 -> It could be clearer if this requirement just explicitly states that the intermediate system is required to be outside of the ESP that it is providing access to. The requirement to route through an EAP is then covered by R1.2 and not needed to re-stated in this requirement.

Likes 0

Dislikes 0

Response

In regards to Part 1.5, the SDT is not changing the intent, only making necessary conforming changes to allow for perimeter-less technology such as some Zero Trust installations. The SDT notes that in the currently approved CIP-005-7, Part 1.5 does imply the detection must be at the EAP as that is the Applicable System. To the point raised, the Applicable System is now the BCS and it no longer prescribes nor implies where on the network the method must be implemented, only that the method can be shown to detect the communications entering or leaving the ESP and thus may be upstream. The SDT believes the currently proposed R1.5 better incorporates the suggested scenario and allows the entity to take the encouraged step of detecting malicious communications in an even broader scope than what is strictly required by the CIP standard.

Roger Fradenburgh - Roger Fradenburgh On Behalf of: Nick Lauriat, Network and Security Technologies, 1; - Roger Fradenburgh

Answer No

Document Name

Comment

As we did in 2022, NST objects to the use of the phrase "through the ESP," as in, "Permit only needed routable protocol communications, documenting the reason, and deny all other routable protocol communications, through the ESP;..." (R1.2). Data packets don't go "through" an ESP, they go into or out of an ESP through an access point.

NST also notes that while R1.3 requires a Responsible Entity to control network access to the Management Interfaces of SCI, there is no comparable requirement for devices (e.g., Hypervisors) that are not SCI according to the SDT's proposed definition but that still host virtual machines that are in scope for R1. This inconsistency should be addressed.

Likes 1 Central Hudson Gas & Electric Corp., 1, Ridolfino Michael

Dislikes 0

Response

Thank you for the comment. The intent of "through the ESP" is to better incorporate future Zero Trust implementations where there is no "logical border surrounding a network" but instead Policy Enforcement Points at the accessed resource itself or as close to it as possible. In these instances that are designed to be perimeter-less, the concepts of "inside" and "outside" begin to fail and the SDT is removing those now to be better prepared for future technologies. The SDT asserts that even in traditional Layer 3 firewalls that define an ESP, the communications between systems that are encapsulated in packets go "through" the perimeter (ESP) in order to reach their destination.

As to the scoping of R1.3 to SCI, the SDT notes that for hypervisors that are not SCI because they are considered BCS or PCA, the hypervisors will be categorized the same as the VCAs they host and thus R1 will apply as well as CIP-007 R1 to the hypervisor itself. The SDT asserts the concern is addressed by these other requirements. R1.3 is bringing in two scenarios that would not otherwise be addressed.

Michael Russell - Massachusetts Municipal Wholesale Electric Company - 5 - NPCC

Answer No

Document Name

Comment

1.3 broaden from network accessibility to be more objective = “protect configuration” in order to allow other methods to protect the configuration
 Protect ESP and SCI configurations by implementing methods to permit only needed network accessibility to Management Interfaces of Applicable Systems, per system capability.
 Suggest
 Implement methods to protect ESP and SCI configurations at Management Interfaces of Applicable Systems, per system capability, per system capability.

Likes 0

Dislikes 0

Response

Thank you. Please see the response to NPCC RSC above.

Israel Perez - Israel Perez On Behalf of: Mathew Weber, Salt River Project, 3, 1, 6, 5; Sarah Blankenship, Salt River Project, 3, 1, 6, 5; Thomas Johnson, Salt River Project, 3, 1, 6, 5; Timothy Singh, Salt River Project, 3, 1, 6, 5; - Israel Perez

Answer No

Document Name

Comment

Thank you for your comment. No, due to lack of understanding of scope of impact to our systems. Better understanding of ‘applicable systems’ is needed. Provide examples. Implementation plan guidance needed to better understand how to be in compliance.

Likes 0

Dislikes 0

Response

Thank you for your comment. The SDT would be glad to respond to specific examples of unclear scope. Section 4.3 of the standards (above the requirement section) is where the term “Applicable Systems” is defined within the standards. While the SDT has not produced Implementation Guidance (which usually documents a single way to implement), it has produced much material in the Technical Rationale documents related to these changes that the SDT hopes will be helpful.

Jodirah Green - ACES Power Marketing - 1,3,4,5,6 - MRO,WECC,Texas RE,SERC,RF, Group Name ACES Collaborators

Answer

No

Document Name

Comment

ACES feels R1.3 should be reworded:

“EACMS, and their supporting SCI, that control access to and from an ESP for an Applicable System in Part 1.1”

ACES feels in R1.4: “if any” is not necessary.

Likes 0

Dislikes 0

Response

Thank you for your proposed change. The SDT has carefully crafted the current applicability based on comments from previous drafts and asserts the suggested language would broaden it beyond the intended scope. An example will help regarding this one specific piece of the Applicable Systems column. The SDT is focused on Management Interfaces that define/create or are “on” the ESP and thus control it. It is

not the intent to include all EACMS that are outside the ESP (but could be included in the proposed phrasing of “control access to and from an ESP”). For example, the intent is to include the Management Interface of a network switch that is configured with a VLAN that is part of the ESP and another VLAN that is not. Thus, the switch “controls” the ESP by defining what is and is not the ESP. The management port on a firewall is similar, controlling what is and is not the ESP. Then consider a domain controller outside the ESP that is an EACMS and part of an Intermediate System – it has no “Management Interface” of the sort where you can control its network accessibility such as putting an ACL on a port as one example. It does help enforce access authentication and authorization for access to the ESP, but it doesn’t control the ESP itself. This distinction is why the SDT has used the language it has chosen.

Regarding Part 1.4 and the “if any”. The SDT agrees it is not strictly necessary, but as the SDT was making conforming changes to handle the “per system capability” language, the intent was to help lessen the burden on entities as dial-up becomes obsolete. Since the overall Requirement includes “shall implement one or more documented processes that...”, adding “if any” may help those entities that no longer have any dial-ups and thus do not need to implement a documented process for a non-existent technology in their environment.

Shannon Mickens - Shannon Mickens On Behalf of: Joshua Phillips, Southwest Power Pool, Inc. (RTO), 2; - Shannon Mickens, Group Name SPP RTO

Answer	No
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Mark Garza - FirstEnergy - FirstEnergy Corporation - 4, Group Name FE Voter	
Answer	Yes
Document Name	

Comment

FirstEnergy does not opposed these changes.

Likes 0

Dislikes 0

Response

Thank you.

John Galloway - John Galloway On Behalf of: Michael Puscas, ISO New England, Inc., 2; - John Galloway

Answer

Yes

Document Name

Comment

ISO-NE supports the ISO/RTO Council comments in this area.

Likes 0

Dislikes 0

Response

Thank you. Please see responses to the ISO/RTO Council comments.

Jay Sethi - Manitoba Hydro - 1,3,5,6 - MRO

Answer

Yes

Document Name

Comment

The standard drafting team has done an excellent job in addressing comments in CIP-005 and compliance to the new wording is backwards compatible. Manitoba Hydro notes that the definition of Intermediate System was updated to remove the phrase “The

Intermediate System must not be located inside the Electronic Security Perimeter” and requirement R2.7 was added requiring “Routable protocol communications from an Intermediate System to a high or medium impact BCS or associated PCAs must be through an ESP.”. The new requirement does not make it clear that an EACMS that contains an EAP cannot also be the intermediate system. The following wording is suggested to clarify that a separate system such as a "jump host" must be used as an Intermediate System:

“Routable protocol communications from an Intermediate System to a high or medium impact BCS or associated PCAs must be through an EAP in a separate Cyber Asset or Virtual Cyber Asset.”

Likes 0

Dislikes 0

Response

Thank you for your encouraging words regarding our work on CIP-005.

On the issue raised regarding R2.7, the SDT does not intend to prescribe architecture to the point of what CA or VCA a function may reside. For example, some “security appliances” that have firewall/EAP capability also have separate functionality within them that can perform part of the Intermediate System function. Historically this definition has stated “must not be located inside” which allowed for “outside or ON” the ESP. The SDT does not want to preclude architectures where at least some portion of the Intermediate System functionality may execute on the EAP.

Mark Flanary - Midwest Reliability Organization - 10

Answer Yes

Document Name

Comment

While we can agree with the changes as they stand, should circumstances arise where additional changes to CIP-005 are necessary, we offer the following recommendations:

Part 1.3 - We recommend against the changing of "to and from" to simply "to". Controlling outbound communication is vital protection to prevent connectivity of a compromised system out to a comand-and-control server.

Part 2.3 - Consider the scenario of low impact SCI as the initiating system. The requirement phrase "Cyber Asset or Virtual Cyber Asset" excludes SCI from the set of possible initiating systems. We recommend updating the language to encapsulate all forms by using the defined term "Cyber Systems" or adding SCI.

Likes 0

Dislikes 0

Response

Thank you for the recommendations.

For Part 1.3, the SDT concluded that when speaking specifically of Management Interfaces on SCI and EACMS, while there are several ways to control the traffic to such interfaces, many such interfaces may not have the capability for outbound filtering. The intent is to block access to the 'front door' of the ability to configure/reconfigure these particular types of systems. In some situations, such as the SCI hosting a BCS within an ESP, the Management Interface will also inherit numerous CIP required controls, in addition to this Requirement Part which would be in addition.

Richard Vendetti - NextEra Energy - 5

Answer

Yes

Document Name

Comment

NEE supports EEI comments

Likes 0

Dislikes 0

Response

Thank you. See response to EEI comments.

Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company

Answer	Yes
Document Name	
Comment	
Southern agrees and supports the changes to the Applicable Systems, Requirements, and Measures in CIP-005 R1.	
Likes 0	
Dislikes 0	
Response	
Thank you.	
Wayne Sipperly - North American Generator Forum - 5 - MRO,WECC,Texas RE,NPCC,SERC,RF	
Answer	Yes
Document Name	
Comment	
The NAGF agrees with the proposed changes to CIP-005 Requirement R1.	
Likes 0	
Dislikes 0	
Response	
Thank you.	
Anna Martinson - MRO - 1,2,3,4,5,6 - MRO, Group Name MRO Group	
Answer	Yes
Document Name	
Comment	

The standard drafting team has done an excellent job in addressing comments in CIP-005. The NSRF notes that the definition of Intermediate System was updated to remove the phrase “The Intermediate System must not be located inside the Electronic Security Perimeter” and requirement R2.7 was added requiring “Routable protocol communications from an Intermediate System to a high or medium impact BCS or associated PCAs must be through an ESP.”. The new requirement does not make it clear that an EACMS that contains an EAP cannot also be the intermediate system. The following wording is suggested:

“Routable protocol communications from an Intermediate System to a high or medium impact BCS or associated PCAs must be through an EAP in a separate Cyber Asset or Virtual Cyber Asset.”

Likes 0

Dislikes 0

Response

Thank you. Please see the response to the similar comment from Manitoba Hydro above.

Gail Elliott - Gail Elliott On Behalf of: Michael Moltane, International Transmission Company Holdings Corporation, 1; - Gail Elliott

Answer Yes

Document Name

Comment

ITC supports the response submitted by EEI

Likes 0

Dislikes 0

Response

Thank you. See response to EEI comments.

Mark Gray - Edison Electric Institute - NA - Not Applicable - NA - Not Applicable

Answer Yes

Document Name	
Comment	
EEI supports the changes made to CIP-005, Requirement R1.	
Likes 0	
Dislikes 0	
Response	
Thank you.	
Daniel Gacek - Exelon - 1	
Answer	Yes
Document Name	
Comment	
Exelon supports the comments submitted by the EEI.	
Likes 0	
Dislikes 0	
Response	
Thank you. See response to EEI comments.	
Kinte Whitehead - Exelon - 3	
Answer	Yes
Document Name	
Comment	

Exelon is supporting EEI comments in response to this question.

Likes 0

Dislikes 0

Response

Thank you. See response to EEI comments.

Marcus Bortman - APS - Arizona Public Service Co. - 6

Answer

Yes

Document Name

Comment

AZPS supports the proposed changes

Likes 0

Dislikes 0

Response

Thank you.

Tracy MacNicoll - Utility Services, Inc. - 4

Answer

Yes

Document Name

Comment

USV supports the comments made by NPCC RSC

The R1.5 requirement language limits the scope of this requirement to “routable communication entering or leaving an ESP”. Suggest moving this scoping language to the applicability column by adding “with ERC” to both high and medium impact BCS listed.

Likes 0

Dislikes 0

Response

Thank you for your comment. The SDT notes that for R1.5 if the scoping phrasing was removed and moved into a “with ERC” phrase in the Applicable Systems column, which would scope to systems with a certain kind of connectivity, but would leave it unclear exactly what traffic requires the malicious communication detection. It could inadvertently broaden the scope from the traffic entering or leaving the ESP (north/south) to all east/west traffic on all networks within the ESP which is not the intended scope.

Joanne Anderson - Public Utility District No. 2 of Grant County, Washington - 1,4,5,6 - WECC

Answer

Yes

Document Name

Comment

Likes 0

Dislikes 0

Response

Thank you for your support.

Patricia Lynch - NRG - NRG Energy, Inc. - 5

Answer

Yes

Document Name

Comment

Likes 0

Dislikes	0
Response	
James Keele - Entergy - 1,3,6	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Clay Walker - Clay Walker On Behalf of: John Lindsey, Cleco Corporation, 6, 5, 1, 3; Maurice Paulk, Cleco Corporation, 6, 5, 1, 3; Robert Hirschak, Cleco Corporation, 6, 5, 1, 3; Stephanie Huffman, Cleco Corporation, 6, 5, 1, 3; Wayne Messina, LaGen, 4; - Clay Walker	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Anne Kronshage - Public Utility District No. 1 of Chelan County - 6, Group Name Public Utility District No. 1 of Chelan County - Voting Group	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
LaTroy Brumfield - American Transmission Company, LLC - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Jennifer Buckman - Southern Indiana Gas and Electric Co. - 3,5,6 - RF	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Thank you for your support.	
Robert Follini - Avista - Avista Corporation - 3	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Tristan Miller - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Lindsey Mannion - ReliabilityFirst - 10	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Donna Wood - Tri-State G and T Association, Inc. - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Richard Jackson - U.S. Bureau of Reclamation - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	

Response	
Thank you for your support.	
Todd Bennett - Associated Electric Cooperative, Inc. - 3, Group Name AECI	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Rebika Yitna - MEAG Power - 1,3 - SERC	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Brian Millard - Tennessee Valley Authority - 1,3,5,6 - SERC, Group Name TVA RBB	
Answer	Yes
Document Name	

Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Karen Artola - CPS Energy - 1,3,5 - Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Mike Magruder - Avista - Avista Corporation - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	

Thank you for your support.	
Ben Hammer - Western Area Power Administration - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Sheila Suurmeier - Black Hills Corporation - 5	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Rachel Schuldts - Rachel Schuldts On Behalf of: Claudine Bates, Black Hills Corporation, 5, 6, 1, 3; - Rachel Schuldts	
Answer	Yes
Document Name	
Comment	

Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Josh Combs - Black Hills Corporation - 3	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Micah Runner - Black Hills Corporation - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	

Casey Jones - Berkshire Hathaway - NV Energy - 5 - WECC	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Erik Gustafson - PNM Resources - Public Service Company of New Mexico - 1,3 - WECC,Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
C. A. Campbell - LS Power Development, LLC - 5	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Thank you for your support.	
Ellese Murphy - Ellese Murphy On Behalf of: Marcelo Pesantez, Duke Energy - Florida Power Corporation, 3; - Ellese Murphy	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Monika Montez - California ISO - 2 - WECC, Group Name ISO/RTO Council Standards Review Committee (SRC)	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Steve Toosevich - NiSource - Northern Indiana Public Service Co. - 1	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Rachel Coyne - Texas Reliability Entity, Inc. - 10	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
John Daho - John Daho On Behalf of: David Weekley, MEAG Power, 3, 1; Roger Brand, MEAG Power, 3, 1; - John Daho	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Thank you for your support.	
Steven Rueckert - Western Electricity Coordinating Council - 10, Group Name WECC CIP	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Teresa Krabe - Lower Colorado River Authority - 5	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
James Baldwin - James Baldwin On Behalf of: Matt Lewis, Lower Colorado River Authority, 5, 1; - James Baldwin	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Martin Sidor - NRG - NRG Energy, Inc. - 6	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
David Jendras Sr - Ameren - Ameren Services - 3	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	

Response	
Thank you for your support.	
Jennie Wike - Jennie Wike On Behalf of: Hien Ho, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; John Merrell, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Ozan Ferrin, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Terry Gifford, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; - Jennie Wike, Group Name Tacoma Power	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Dwanique Spiller - Berkshire Hathaway - NV Energy - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Kennedy Meier - Electric Reliability Council of Texas, Inc. - 2	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
	Thank you for your support.

4. The SDT revised CIP-007 based on industry comments. Do you agree with the proposed changes? If not, please provide the basis for your disagreement and an alternate proposal.	
Kennedy Meier - Electric Reliability Council of Texas, Inc. - 2	
Answer	No
Document Name	
Comment	
ERCOT joins the comments submitted by the ISO/RTO Council (IRC) Standards Review Committee (SRC) and adopts them as its own.	
Likes	0
Dislikes	0
Response	
Thank you for your comments. Please refer to the IRC response	
Roger Fradenburgh - Roger Fradenburgh On Behalf of: Nick Lauriat, Network and Security Technologies, 1; - Roger Fradenburgh	
Answer	No
Document Name	
Comment	
NST believes R1.3 needs to be re-worded to make it clear it applies to SCI hosting both high and medium impact BES Cyber Systems if a Responsible Entity doesn't want "high water marking" to compel treating the medium impact BCS as PCAs associated with the high impact BCS.	
Likes	0
Dislikes	0

Response	
Thank you for your comments.	
The SDT will be proposing that Implementation Guidance on affinity be created by one of the prequalified organizations	
Alain Mukama - Hydro One Networks, Inc. - 1,3	
Answer	No
Document Name	
Comment	
Part R1.3 -> The requirement outlines controls/evidence recommended for non-BCS VCAs sharing SCI, but does not provide options potential options of classifying/securing non-BCS VCAs where physical/logical isolation cannot be achieved or is financially restrictive.	
Likes	0
Dislikes	0
Response	
Thank You for your response	
The SDT will be proposing that Implementation Guidance on affinity be created by one of the prequalified organizations	
Junji Yamaguchi - Hydro-Quebec (HQ) - 5	
Answer	No
Document Name	
Comment	
HQ supports NPCC RSC comments and provides the following additional comments:	

R1.1 The requirement “Disable or prevent unneeded routable protocol network accessibility on each Applicable System, per system capability. “ This requirement is ambiguous and the column measure is still referencing logical ports. Furthermore, how will this requirement will be evaluated ? The previous version of this requirement was less ambiguous.

R1.3 the definition of SCI includes the storage resource but this requirement exclude the storage resources. How is the shared storage resources managed ? What about the shared network resource ?

For some requirements the TFE was removed for “per system capability.”We do understand that TFE process isn’t optimal but it permitted more nuance than per system capability. For example, the TFE basis for approval of a technical feasibility exception are, at least the two following points;

{C}(i) is not technically possible or is precluded by technical limitations; or

{C}(ii) is operationally infeasible or could adversely affect reliability of the Bulk Electric System to an extent that outweighs the reliability benefits of Strict Compliance with the Applicable Requirement;

Per system capability is only equal to the first point but doesn’t equal to the second or to the other three. The SDT should define per system capability.

Likes	0
Dislikes	0

Response

Thank you for your response

The SDT asserts that multiple controls are available (overlay, underlay, zero trust) to meet the network accessibility requirement and the entity needs to demonstrate which controls are used. The SDT will be proposing that Implementation Guidance on network accessibility be created by one of the prequalified organizations

The SDT asserts that the Management Interface definition and SCI definition make it clear that management systems associated with storage resources are in scope and that the storage resource itself is excluded (i.e., virtual disk/LUN). The SDT will be proposing that Implementation Guidance on affinity be created by one of the prequalified organizations

The SDT suggests contacting NERC Compliance as to how to document “system capability” for those requirements were “per Cyber Asset capability” was previously used

Nicolas Turcotte - Hydro-Quebec (HQ) - 1

Answer No

Document Name

Comment

HQ supports NPCC RSC comments and provides the following additional comments:

R1.1 The requirement “Disable or prevent unneeded routable protocol network accessibility on each Applicable System, per system capability. “ This requirement is ambiguous and the column measure is still referencing logical ports. Furthermore, how will this requirement will be evaluated ? The previous version of this requirement was less ambiguous.

R1.3 the definition of SCI includes the storage resource but this requirement exclude the storage resources. How is the shared storage resources managed ? What about the shared network resource ?

For some requirements the TFE was removed for “per system capability.”We do understand that TFE process isn’t optimal but it permitted more nuance than per system capability. For example, the TFE basis for approval of a technical feasibility exception are, at least the two following points;

- (i) is not technically possible or is precluded by technical limitations; or
- (ii) is operationally infeasible or could adversely affect reliability of the Bulk Electric System to an extent that outweighs the reliability benefits of Strict Compliance with the Applicable Requirement;

Per system capability is only equal to the first point but doesn’t equal to the second or to the other three. The SDT should define per system capability.

Likes 0

Dislikes 0

Response	
Thank you for your response. Please refer to the HQ5 response above	
Steve Toosevich - NiSource - Northern Indiana Public Service Co. - 1	
Answer	No
Document Name	
Comment	
SCI is superfluous considering that existing classification definitions can be applied. SCI does not clearly state what devices would be included and which are not included. Cyber Systems definition seems to rope in non-CIP assets. BES Cyber Systems definition is sufficient for grouping together Cyber Assets.	
Likes	0
Dislikes	0
Response	
Thank You for your response The SDT will be proposing that Implementation Guidance on All-in vs SCI be created by one of the prequalified organizations	
Monika Montez - California ISO - 2 - WECC, Group Name ISO/RTO Council Standards Review Committee (SRC)	
Answer	No
Document Name	
Comment	
The ISO/RTO Council (IRC) Standards Review Committee (SRC) requests clarification of the term “network accessibility” used within requirement R1 Part1.1, which reads as follows: “Disable or prevent unneeded routable protocol network accessibility on each Applicable System, per system capability.” One of the measures also references this term: “Identity or process based access policy or workload configuration demonstrating needed network accessibility .” Specifically, the SRC requests that the drafting team clarify whether entities will need to define the term “network accessibility” in their documented processes or whether a standardized definition	

will apply. If there is a specific definition that entities are intended to use, the SRC requests that the SDT provide the definition that will apply.

Likes 0

Dislikes 0

Response

Thank you for your response. The SDT asserts that multiple controls are available (overlay, underlay, zero trust) to meet the network accessibility requirement and the entity needs to demonstrate which controls are used.

The SDT will be proposing that Implementation Guidance on network accessibility be created by one of the prequalified organizations

Tim Kelley - Tim Kelley On Behalf of: Charles Norton, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Fong Mua, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Kevin Smith, Balancing Authority of Northern California, 1; Nicole Goi, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Nicole Looney, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Wei Shao, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; - Tim Kelley, Group Name SMUD and BANC

Answer

No

Document Name

Comment

SMUD and BANC appreciate the Standard Drafting Team’s work to modify CIP-007. However, we note that the word “system” is used inconsistently, especially with regards to “per system capability”, and this makes the High and Medium impact requirements less stringent than the requirements for Low impact. We recommend changing the language to “per Cyber Asset capability.”

Likes 0

Dislikes 0

Response

Thank you for your response

The SDT suggests contacting NERC Compliance as to how to document “per system capability” for those requirements were “per Cyber Asset capability” was previously used.

James Keele - Entergy - 1,3,6

Answer No

Document Name

Comment

Likes 0

Dislikes 0

Response

David Jendras Sr - Ameren - Ameren Services - 3

Answer Yes

Document Name

Comment

Ameren would like clarity on the change from where technically feasible to per system capability. Does this mean that the TFE process is going away or are they changing it to a different name?

Likes 0

Dislikes 0

Response

Thank you for your response. The SDT suggests contacting NERC Compliance as to how to document “per system capability”

Marcus Bortman - APS - Arizona Public Service Co. - 6	
Answer	Yes
Document Name	
Comment	
AZPS supports the proposed changes	
Likes 0	
Dislikes 0	
Response	
Thank you for your response	
Kinte Whitehead - Exelon - 3	
Answer	Yes
Document Name	
Comment	
Exelon is supporting EEL comments in response to this question.	
Likes 0	
Dislikes 0	
Response	
Thank you for your response	
Daniel Gacek - Exelon - 1	
Answer	Yes

Document Name	
Comment	
Exelon supports the comments submitted by the EEI.	
Likes 0	
Dislikes 0	
Response	
Thank you for your response	
Mark Gray - Edison Electric Institute - NA - Not Applicable - NA - Not Applicable	
Answer	Yes
Document Name	
Comment	
EEI supports the changes made to CIP-007.	
Likes 0	
Dislikes 0	
Response	
Thank you for your response	
Gail Elliott - Gail Elliott On Behalf of: Michael Moltane, International Transmission Company Holdings Corporation, 1; - Gail Elliott	
Answer	Yes
Document Name	
Comment	

ITC supports the response submitted by EEI	
Likes	0
Dislikes	0
Response	
Thank you for your response	
Wayne Sipperly - North American Generator Forum - 5 - MRO,WECC,Texas RE,NPCC,SERC,RF	
Answer	Yes
Document Name	
Comment	
The NAGF agrees with the proposed changes to CIP-007.	
Likes	0
Dislikes	0
Response	
Thank you for your response	
Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company	
Answer	Yes
Document Name	
Comment	
Southern agrees and supports the changes made to CIP-007.	

Likes	0
Dislikes	0
Response	
Thank you for your response	
Richard Vendetti - NextEra Energy - 5	
Answer	Yes
Document Name	
Comment	
NEE supports EEI comments	
Likes	0
Dislikes	0
Response	
Thank you for your response	
Adrian Andreoiu - BC Hydro and Power Authority - 1, Group Name BC Hydro	
Answer	Yes
Document Name	
Comment	
BC Hydro agrees with the changes however seeks further clarification as follows.	
BC Hydro seeks clarification with use cases or examples on proposed changes to CIP-007 R1.1, whether, “per system capability” means entities are compelled to install software (if possible) that can be used to block network accessibility? Specifically, if a Cyber Asset uses a	

method (e.g.: host firewall) that can block the unneeded network accessibility, but that method has been determined to be detrimental to reliable operations, does this mean entities are compelled to continue to use that method although it affects the operation?

BC Hydro also seeks clarification on Routable protocol network accessibility particularly, as Technical Feasibility Exception (TFE) is replaced by "per system capability", are the entities expected to make decisions on whether to document or not to document exceptions on per system capability? Please provide some use case examples and further guidance.

Likes 0

Dislikes 0

Response

Thank you for your response. The SDT asserts that multiple controls are available (overlay, underlay, zero trust) to meet the network accessibility requirement and the entity needs to demonstrate which controls are used.

The SDT will be proposing that Implementation Guidance on network accessibility be created by one of the prequalified organizations

The SDT suggests contacting NERC Compliance as to how to document "per system capability" for those requirements were "per Cyber Asset capability" was previously used

Micah Runner - Black Hills Corporation - 1

Answer

Yes

Document Name

Comment

Black Hills Corporation agrees with the comments from Public Utility District No. 1 of Chelan County: in our review of the proposed changes, we identified an opportunity to enhance the clarity of the requirement section of R1.3. Our proposed wording for R1.3 is as follows: Mitigate the risk of CPU or memory vulnerabilities by preventing the sharing of CPU resources and memory resources, excluding storage resources, between VCAs that are within an ESP, and VCAs that are not within an ESP.

Likes 0

Dislikes	0
Response	
Thank you for your response The SDT discussed your proposed change. The SDT asserts that the wording was intentional as “within” does not support zero trust networking.	
The SDT will be proposing that Implementation Guidance on affinity be created by one of the prequalified organizations	
Rachel Schuldt - Rachel Schuldt On Behalf of: Claudine Bates, Black Hills Corporation, 5, 6, 1, 3; - Rachel Schuldt	
Answer	Yes
Document Name	
Comment	
Black Hills Corporation agrees with the comments from Public Utility District No. 1 of Chelan County: in our review of the proposed changes, we identified an opportunity to enhance the clarity of the requirement section of R1.3. Our proposed wording for R1.3 is as follows: Mitigate the risk of CPU or memory vulnerabilities by preventing the sharing of CPU resources and memory resources, excluding storage resources, between VCAs that are within an ESP, and VCAs that are not within an ESP.	
Likes	0
Dislikes	0
Response	
Thank you for your comment. Please see the response for Black Hills Corp	
Josh Combs - Black Hills Corporation - 3	
Answer	Yes
Document Name	
Comment	

Black Hills Corporation agrees with the comments from Public Utility District No. 1 of Chelan County: in our review of the proposed changes, we identified an opportunity to enhance the clarity of the requirement section of R1.3. Our proposed wording for R1.3 is as follows: Mitigate the risk of CPU or memory vulnerabilities by preventing the sharing of CPU resources and memory resources, excluding storage resources, between VCAs that are within an ESP, and VCAs that are not within an ESP.

Likes 0

Dislikes 0

Response

Thank you for your comment. Please see the response for Black Hills Corp

Sheila Suurmeier - Black Hills Corporation - 5

Answer Yes

Document Name

Comment

Black Hills Corporation agrees with the comments from Public Utility District No. 1 of Chelan County: in our review of the proposed changes, we identified an opportunity to enhance the clarity of the requirement section of R1.3. Our proposed wording for R1.3 is as follows: Mitigate the risk of CPU or memory vulnerabilities by preventing the sharing of CPU resources and memory resources, excluding storage resources, between VCAs that are within an ESP, and VCAs that are not within an ESP.

Likes 0

Dislikes 0

Response

Thank you for your comment. Please see the response for Black Hills Corp

Andrea Jessup - Bonneville Power Administration - 1,3,5,6 - WECC

Answer Yes

Document Name

Comment

BPA notes that implementation of and documenting compliance with Part 1.1 may pose technical challenges depending on an entity's architecture or processes.

Likes 0

Dislikes 0

Response

The SDT asserts that multiple controls are available (overlay, underlay, zero trust) to meet the network accessibility requirement and the entity needs to demonstrate which controls are used.

The SDT will be proposing that Implementation Guidance on network accessibility be created by one of the prequalified organizations

Lindsey Mannion - ReliabilityFirst - 10

Answer

Yes

Document Name

Comment

Consider rewording R1.3 for clarity.

Likes 0

Dislikes 0

Response

Thank you for your response

The SDT reviewed the wording for R1.3 . The SDT concluded that it was intentional . The SDT will be proposing that Implementation Guidance on affinity be created by one of the prequalified organizations

Mark Garza - FirstEnergy - FirstEnergy Corporation - 4, Group Name FE Voter

Answer	Yes
Document Name	
Comment	
FirstEnergy does not opposed these changes.	
Likes 0	
Dislikes 0	
Response	
Thank you for your response	
Anne Kronshage - Public Utility District No. 1 of Chelan County - 6, Group Name Public Utility District No. 1 of Chelan County - Voting Group	
Answer	Yes
Document Name	
Comment	
<p>CHPD agrees with the proposed changed to CIP-007 R1.3.</p> <p>We would also like to express our support for the decision to remove the Electronic Access Control and Monitoring Systems (EACMS) and Physical Access Control Systems (PACS) from the list of applicable systems in CIP-007 R1.3. This change is a positive step forward, as it helps support backward compatibility with the standard.</p> <p>However, in our review of the proposed changes, we identified an opportunity to enhance the clarity of the requirement section of R1.3. Our proposed wording for R1.3 is as follows: Mitigate the risk of CPU or memory vulnerabilities by preventing the sharing of CPU resources and memory resources, excluding storage resources, between VCAs that are within an ESP, and VCAs that are not within an ESP.</p>	

We believe this reworded requirement maintains the original intent of the section while making it more straightforward and easier to understand. By replacing "VCAs that are, or are associated with, a medium or high impact BCS" with "VCAs that are within an ESP," we simplify the language while preserving the core security objectives of the requirement.

Likes 0

Dislikes 0

Response

Thank you for your response.

The SDT discussed your proposed change. The SDT asserts that the wording was intentional as “within” does not support zero trust networking. The SDT will be proposing that Implementation Guidance on affinity be created by one of the prequalified organizations

Jodirah Green - ACES Power Marketing - 1,3,4,5,6 - MRO,WECC,Texas RE,SERC,RF, Group Name ACES Collaborators

Answer

Yes

Document Name

Comment

Likes 0

Dislikes 0

Response

Israel Perez - Israel Perez On Behalf of: Mathew Weber, Salt River Project, 3, 1, 6, 5; Sarah Blankenship, Salt River Project, 3, 1, 6, 5; Thomas Johnson, Salt River Project, 3, 1, 6, 5; Timothy Singh, Salt River Project, 3, 1, 6, 5; - Israel Perez

Answer

Yes

Document Name

Comment

Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Dwanique Spiller - Berkshire Hathaway - NV Energy - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Tracy MacNicoll - Utility Services, Inc. - 4	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	

Jennie Wike - Jennie Wike On Behalf of: Hien Ho, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; John Merrell, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Ozan Ferrin, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Terry Gifford, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; - Jennie Wike, Group Name Tacoma Power

Answer Yes

Document Name

Comment

Likes 0

Dislikes 0

Response

Thank you for your support.

Michael Russell - Massachusetts Municipal Wholesale Electric Company - 5 - NPCC

Answer Yes

Document Name

Comment

Likes 0

Dislikes 0

Response

Thank you for your support.

Constantin Chitescu - Ontario Power Generation Inc. - 5

Answer Yes

Document Name

Comment

Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Martin Sidor - NRG - NRG Energy, Inc. - 6	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name NPCC RSC	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	

James Baldwin - James Baldwin On Behalf of: Matt Lewis, Lower Colorado River Authority, 5, 1; - James Baldwin	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Teresa Krabe - Lower Colorado River Authority - 5	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Steven Rueckert - Western Electricity Coordinating Council - 10, Group Name WECC CIP	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Thank you for your support.	
Anna Martinson - MRO - 1,2,3,4,5,6 - MRO, Group Name MRO Group	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
John Daho - John Daho On Behalf of: David Weekley, MEAG Power, 3, 1; Roger Brand, MEAG Power, 3, 1; - John Daho	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Jennifer Bray - Arizona Electric Power Cooperative, Inc. - 1	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Rachel Coyne - Texas Reliability Entity, Inc. - 10	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Chris Carnesi - Chris Carnesi On Behalf of: Dennis Sismaet, Northern California Power Agency, 4, 6, 3, 5; Jeremy Lawson, Northern California Power Agency, 4, 6, 3, 5; Michael Whitney, Northern California Power Agency, 4, 6, 3, 5; - Chris Carnesi	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Thank you for your support.	
Shannon Mickens - Shannon Mickens On Behalf of: Joshua Phillips, Southwest Power Pool, Inc. (RTO), 2; - Shannon Mickens, Group Name SPP RTO	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Andy Fuhrman - Andy Fuhrman On Behalf of: Theresa Allard, Minnkota Power Cooperative Inc., 1; - Andy Fuhrman	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	

Ellese Murphy - Ellese Murphy On Behalf of: Marcelo Pesantez, Duke Energy - Florida Power Corporation, 3; - Ellese Murphy	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
C. A. Campbell - LS Power Development, LLC - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Mark Flanary - Midwest Reliability Organization - 10	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Thank you for your support.	
Erik Gustafson - PNM Resources - Public Service Company of New Mexico - 1,3 - WECC,Texas RE	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Casey Jones - Berkshire Hathaway - NV Energy - 5 - WECC	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Ben Hammer - Western Area Power Administration - 1	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Jay Sethi - Manitoba Hydro - 1,3,5,6 - MRO	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Mike Magruder - Avista - Avista Corporation - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Thank you for your support.	
Karen Artola - CPS Energy - 1,3,5 - Texas RE	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Brian Millard - Tennessee Valley Authority - 1,3,5,6 - SERC, Group Name TVA RBB	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Rebika Yitna - MEAG Power - 1,3 - SERC	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
John Galloway - John Galloway On Behalf of: Michael Puscas, ISO New England, Inc., 2; - John Galloway	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Todd Bennett - Associated Electric Cooperative, Inc. - 3, Group Name AECl	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	

Response	
Thank you for your support.	
Richard Jackson - U.S. Bureau of Reclamation - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Donna Wood - Tri-State G and T Association, Inc. - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Tristan Miller - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE	
Answer	Yes
Document Name	

Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Robert Follini - Avista - Avista Corporation - 3	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Jennifer Buckman - Southern Indiana Gas and Electric Co. - 3,5,6 - RF	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	

Thank you for your support.	
LaTroy Brumfield - American Transmission Company, LLC - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Clay Walker - Clay Walker On Behalf of: John Lindsey, Cleco Corporation, 6, 5, 1, 3; Maurice Paulk, Cleco Corporation, 6, 5, 1, 3; Robert Hirschak, Cleco Corporation, 6, 5, 1, 3; Stephanie Huffman, Cleco Corporation, 6, 5, 1, 3; Wayne Messina, LaGen, 4; - Clay Walker	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Patricia Lynch - NRG - NRG Energy, Inc. - 5	
Answer	Yes
Document Name	

Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Joanne Anderson - Public Utility District No. 2 of Grant County, Washington - 1,4,5,6 - WECC	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	

5. The SDT made numerous clarifying changes to CIP-010 based on industry comments. Do you agree with the proposed changes? If not, please provide the basis for your disagreement and an alternate proposal.	
James Keele - Entergy - 1,3,6	
Answer	No
Document Name	
Comment	
<p>Entergy disagrees with CIP-010 R1.1 as written for two reasons.</p> <p>First, the requirements as written is difficult to follow as a single sentence with many oxford commas and could benefit from a rewrite to reduce confusion. Entergy proposes the requirement be rewritten similar to the following: “Authorize changes that affect Applicable Systems and alter the behavior of one or more cyber security controls (as defined by the Responsible Entity) that serve one or more requirement parts in CIP-005 or CIP-007. This excludes procedural and physical controls.”</p> <p>Secondly, Entergy is concerned regarding the removal of the previous CIP-010 R1.4 language that allowed an assessment of potentially impacted security controls, the ambiguity of the “as defined by the Responsible Entity” language, and how this could expand the scope of testing and change authorization.</p> <p>As written the standard implies that any potential change to a control “defined by the Responsible Entity” would require authorization and subsequent testing, which would result in Responsible Entity security controls testing expanding from a list of potentially impacted security controls to a verification of all security controls regardless on the actual nature of the change to prove a control wasn’t impacted. As written the “defined by the Responsible Entity” could be interpreted as being related to the defining of the controls, not the defining by the Responsible Entity of a change to a control.</p> <p>Entergy believes the intent of this requirement is still to perform authorizations and testing of potential and identified impacts to CIP-005 and CIP-007 controls prior to deployment. This is supported by the proposed CIP-010 R1.4 language to “verify the behavior(s) of the altered cyber security controls” which implies a verification of a pre-determined set of impacts, not a verification of all controls.</p> <p>If Entergy is interpreting this correctly, then Entergy proposes that CIP-010 R1.1 be rewritten to something similar to the following, which replaces “defined” with “determined”:</p>	

“Authorize changes that the Reponsible Entity determines will affect Applicable Systems and alter the behavior of one or more cyber security controls that serve one or more requirement parts in CIP-005 or CIP-007. This excludes procedural and physical controls.”

Likes 0

Dislikes 0

Response

Thank you for your comments. The SDT recognizes the complexities of the requirement language, and appreciates the concern. The SDT was mindful of comma placement and conforms with the NERC style guide. The SDT intent is consistent with the security objectives as articulated in your comments, as a primary goal was to maintain backwards compatibility while adding the appropriate level of flexibility to enable for virtualization. The SDT considered the suggestion to replace “defined” with “determined” in Requirement Part 1.1 and determined “defined” was the appropriate term because it is referring to the controls in scope for the change authorization process. Using the word “determined” could be interpreted as more subjective and could create the need for potentially exhaustive evidence to justify to an auditor for each change how the entity determined the authorization was required in each instance, whereas “defined” becomes a documented finite set of cyber security controls the entity expects change authorization for because of the way the cyber security control(s) serve one or more requirement parts in CIP-005 or CIP-007 for that entity . As a result, the SDT has not made this modification.

Anne Kronshage - Public Utility District No. 1 of Chelan County - 6, Group Name Public Utility District No. 1 of Chelan County - Voting Group

Answer No

Document Name

Comment

The problem with the current standard verbiage is that there is no requirement for a baseline, but there is no way to accomplish what the standard requires without creating baselines to monitor. Knowing you are going to be making a change that affects the baseline is a much more straightforward measure than trying to predict which/if any changes will affect CIP-005 or CIP-007 security controls tests and to what extent these should be re-tested after a change that may or may not affect the test results. For example in R1.2 the measure to include evidence such as "...a list of differences between the production and test environments with descriptions of how any differences were accounted for" cannot be accomplished without a baseline to compare against.

R2.1's requirement is unclear whether we should be monitoring for different test results, or if we should be monitoring for changes to a baseline (again, there is no mention of baselines so I'm not convinced this is a valid interpretation). If it is the case that we need to test all CIP-005 and CIP-007 controls (except physical and procedural), these are the bulk of bookending tasks for any new system. Performing this for hundreds of devices monthly is not feasible. We are a smaller entity, and we can't imagine how a larger entity could perform hundreds or thousands of bookends every month.

In Attachment 2 Section 2.1 there are two instances of the same typo for "..Responsible Entity **that that** document.."

Likes 0

Dislikes 0

Response

Thank you for your comments. The SDT considered your comments and suggestions that Requirement R2 monitoring cannot be accomplished without Requirement R1 'baselines'. The SDT maintains the prescriptive 'baseline' concept defeats the key objective to enable the standards for virtualization through greater flexibility in the requirement with 'baselines' as one means to achieve the objective. The SDT determined the focus of the requirements should remain at an objective level of 'what' is required, instead of getting into 'how'. The terminology, "as defined by the Responsible Entity." within Requirement R1 Part 1.1. maintains backwards compatibility and clarity that an entity may choose to continue to use baselines as the method to determine which changes "...alter the behavior of one or more cyber security controls... ..serving one or more requirement parts in CIP-005 or CIP-007...", for which those changes then require authorization per Requirement R1 Part 1.1.

Requirement R2 Part 2.1 monitoring applies to a subset of the changes authorization per Requirement R1 Part 1.1.as a function of its applicability to high impact BES Cyber Systems and their associated: 1. EACMS; and 2. PCA, and SCI supporting an Applicable System in Requirement R2 Part 2.1. SDT's scoping of methods to monitor for "...unauthorized changes that alter the behavior of one or more cyber security controls, excluding procedural and physical controls, serving one or more requirement part CIP-007, as defined by the Responsible Entity." further assures this requirement is not misinterpreted as a mini audit of CIP-005 and CIP-007, but is that subset of CIP-007-related changes authorized per Requirement R1 Part 1.1. The mapping of Measures by mapping to the former 'baseline' attributes further demonstrates 'baselines' remain one way how an entity may choose to demonstrate compliance. The SDT determined the scoping and applicability was clear and appropriate and did not make modifications to Requirement R2 Part 2.1.

Thank you for calling out the typos, the SDT has addressed them.

Tim Kelley - Tim Kelley On Behalf of: Charles Norton, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Fong Mua, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Kevin Smith, Balancing Authority of Northern California, 1; Nicole Goi, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Nicole Looney, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Wei Shao, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; - Tim Kelley, Group Name SMUD and BANC

Answer	No
Document Name	
Comment	
<p>SMUD and BANC do not agree with the changes to CIP-010 for the following reasons:</p> <ul style="list-style-type: none"> - CIP-010 should be reverted to its current state with the simple addition to the “Applicable Systems column” with the newly added SCI, like how it is being done for the CIP-007 revisions, to accommodate for the addition of SCI. - The Technical Feasibility Exception was removed and not replaced with “per system capability?” If an entity has an approved TFE for CIP-010-4 R1.5, the changes proposed in CIP-010-5 R1.2 would now be applicable to that entity with no relief. Therefore, with CIP-010-5 R1.2 the entity would now be noncompliant. - The Technical Rational for Requirement R2 is “to keep the scope of R2 to those things for which there are an automated solution that can monitor these areas and alert entities to changes.” Additionally, “The SDT also added “per system capability” in recognition that not all changes in scope can be monitored on every potential in-scope Cyber System. This addition makes the requirement conditional if a system is incapable of monitoring a particular unauthorized change category.” However, there is no mention that CIP-010-5 R2 Part 2.1 is only applicable for automated solutions and no automated solutions are excluded. Is that assumed/implied/allowed with the “per system capability” statement? Furthermore, in the Measures it states, “Examples of evidence may include, but are not limited to, reports generated from automated tools or manual reviews along with records of investigation for any unauthorized changes that were detected.” This statement causes further confusion for which the Standard Drafting Team (SDT) should address. - The SDT should clarify if the term “per system capability” applies to Parts 2.1.1 through 2.1.7. The language that precedes the Parts reads, “...that include at least one cyber security control for each of the following:” which refutes the “per system capability” statement. Is there a way for the SDT to incorporate the “per system capability” for each sub-requirement? 	
Likes	0

Dislikes 0

Response

Thank you for your comments. The SDT appreciates the perspective shared about reverting to former approved, but maintains the shift from prescriptive requirements to objective level requirements is necessary to enable the standards for virtualization, as well as to permit new and emerging technologies, features and tools moving into the future. For this reason, the SDT did not revert nor modify the proposed requirement language.

The SDT contends the proposed changes to Requirement R1 negate the need for both the “technically feasible” and “per system capability” because the focus is on testing the implemented CIP-005 and/or CIP-007 cybersecurity controls the responsible entity determines as serving the requirements in CIP-005 and CIP-007 and require authorization. If a particular CIP-005 or CIP-007 cyber security control cannot be implemented due to technical infeasibility or per system capability, then that unimplemented cyber security control would not be in scope for CIP-010-5 Requirement R1, nor former Requirement Part 1.5 (which is Part 1.2 in the final draft). Please see the Technical Rationale (TR) for more information.

The SDT reviewed the requirement language and measures for CIP-010-5 Requirement R2 Part 2.1 and does not intend for the ‘per system capability’ language to exclude manual monitoring methods from the scope of Part 2.1. The SDT’s intent when using the ‘per system capability’ language is to keep the scope of R2 to those things for which automated solutions are available and likely to monitor these areas and alert entities to changes. It should be noted that the ‘system’ in ‘per system capability’ refers to the Applicable Systems for the requirement, and not the capability of the automated tool used to monitor. As a result, the ‘per system capability’ language does not absolve entities of the obligation to implement monitoring methods where automated solutions have not been implemented, and while potentially less ideal, manual methods to accomplish the same results where automated monitoring cannot be done remains a requirement where the Applicable System is capable of producing data related to the list of seven cyber security-related categories to monitor. TR has been updated to include this clarification.

The TR has been updated to recognize that the automated monitoring output (alarms, alerts, reports, logs etc.) may require manual review by the recipients to determine if the detected change was unauthorized and what subsequent actions, if any, may need to be taken, and to provide clarity on the intention of the reference to manual reviews as records in the measures.

The SDT intends for the ‘per system capability’ language in Requirement Part 2.1 to be transitive and applicable to all of the listed subparts 2.1.1 – 2.1.7 and maintains that where one of those seven security controls is not relevant to the implementation of the entity’s

Applicable Systems, it renders the obligation moot. If an entity has not implemented VCA on SCI within their Applicable Systems, the entity would not be subject to Part 2.1.2 because there is nothing to monitor. The TR was reviewed, and includes statements reflecting the SDT also added “per system capability” in recognition that not all changes in scope can be monitored on every potential in-scope Cyber System. This addition makes the requirement conditional if a system is incapable of monitoring a particular unauthorized change category.

Lindsey Mannion - ReliabilityFirst - 10

Answer No

Document Name

Comment

R1-Removing baseline configuration does not change what needs to be done in practice. Entities will still need to retain a baseline configuration as evidence from which to establish the changes that were authorized.

For Part 1.1 an entity will still need to show the baseline configuration prior to the change to show required cyber security controls in CIP-005 and CIP-007 are not adversely affected.

For Part 2.1 an entity will still need to provide baseline configurations for evidence that they monitor at least once every 35 calendar days for unauthorized changes to the items listed Parts 1.1 and 1.2.

Likes 0

Dislikes 0

Response

Thank you for your comments. The SDT maintains that establishing and maintaining a baseline is one way an entity may comply with CIP-010-5, and for entities that choose that method, the SDT agrees the revised Standard is backwards compatible and the Measure and accompanying evidence would be consistent with that which an entity might use today to demonstrate compliance.

Where an entity chooses other methods, the evidence for Part 2.1 would not require baselines configurations themselves. The Measures provide options for how an entity could demonstrate the automates monitoring methods used for the cyber security controls the entity

defined in Requirement R1 as serving the requirements in CIP-007, in combination with the output of those monitoring methods, and supporting investigation documentation of detected unauthorized changes.

John Galloway - John Galloway On Behalf of: Michael Puscas, ISO New England, Inc., 2; - John Galloway

Answer No

Document Name

Comment

ISO-NE supports the ISO/RTO Council comments in this area, which are replicated here:

ISO/RTO Council is looking for clarification regarding the R2 requirement language that is mandating specific and prescriptive security controls to be monitored for change relevant to CIP-007 standard. In particular, the proposed requirement language of “... that include at least one cyber security control for each of the following...” is the area of confusion. See underlined section within the proposed requirement language below:

“Methods to monitor, per system capability, at least once every 35 calendar days, for unauthorized changes that affect Applicable Systems, where those changes alter the behavior of one or more cyber security controls, excluding procedural and physical controls, serving one or more requirement parts in CIP-007, as defined by the Responsible Entity; that include at least one cyber security control for each of the following:

- 2.1.1. Configuration on each Applicable System that affects its routable protocol network accessibility;
- 2.1.2. Configuration of CPU or memory sharing of VCAs on SCI;
- 2.1.3. Installation, removal, and update of operating system, firmware, software, and cyber security patches.
- 2.1.4. Configuration of malicious code protection methods;
- 2.1.5. Configuration of security event logging or alerting;
- 2.1.6. Configuration of authentication methods; and

2.1.7. Changes to the enabled or disabled status of accounts.”

ISO/RTO Council would like for the SDT to clarify if the intent of this requirement is to monitor for changes to all of the CIP-007 controls? If this is meant to be defined by the entity, ISO-NE recommends moving the sub-bullets language to the measures section similar to R1.

ISO-NE adds the following comment:

With respect to the proposed 2.1.7 sub-requirement, changes to account access should be considered part of CIP-004 Access Management as a subject and not be administered from the CIP-007 requirements. ISO-NE recommends striking the 2.1.7 sub-requirement if the sub-requirements are retained in the proposed version of CIP-010 R2.

Likes 0

Dislikes 0

Response

Thank you for your comments. Please also refer to the SDT response for ISO/RTO Council.

Adrian Andreoiu - BC Hydro and Power Authority - 1, Group Name BC Hydro

Answer

No

Document Name

Comment

With respect to R1.4, BC Hydro seeks clarity, if evidence from a representative test system is sufficient OR if evidence from a production system(s) is also required in all cases.

Requirement R1.4 uses "behavior" which is a very open term and can be used in many ways. BC Hydro seeks clarity on this with examples or use cases to explain the scope of the word behavior.

Likes 0

Dislikes 0

Response

Thank you for your comments. The Applicable Systems is the subject of the requirement and examples of evidence can be found in the Measures. The SDT has developed Technical Rationale, which describes the reasoning behind the terminology used in CIP-010. The SDT will be deferring to the pre-qualified organizations for the industry development of Implementation Guidance to help assure there is an owning group that can maintain it over time.

Monika Montez - California ISO - 2 - WECC, Group Name ISO/RTO Council Standards Review Committee (SRC)

Answer No

Document Name

Comment

The SRC requests clarification regarding the language in requirement R2 that mandates the use of specific and prescriptive security controls to be monitored for changes relevant to the CIP-007 standard. In particular, the SRC requests clarification of the proposed requirement language of “... that include at least one cyber security control for each of the following...” See the underlined section within the proposed requirement language below:

“Methods to monitor, per system capability, at least once every 35 calendar days, for unauthorized changes that affect Applicable Systems, where those changes alter the behavior of one or more cyber security controls, excluding procedural and physical controls, serving one or more requirement parts in CIP-007, as defined by the Responsible Entity; **that include at least one cyber security control for each of the following:**

- 2.1.1. Configuration on each Applicable System that affects its routable protocol network accessibility;
- 2.1.2. Configuration of CPU or memory sharing of VCAs on SCI;
- 2.1.3. Installation, removal, and update of operating system, firmware, software, and cyber security patches.
- 2.1.4. Configuration of malicious code protection methods;
- 2.1.5. Configuration of security event logging or alerting;
- 2.1.6. Configuration of authentication methods; and

2.1.7. Changes to the enabled or disabled status of accounts.”

The requirements contained in the draft of CIP-007-7 have a combined total of 21 Parts, but the draft CIP-010-5 R2 language only lists seven controls (Parts 2.1.1 – 2.1.7). It is therefore unclear whether R2 is intended to require entities to monitor for changes that impact all CIP-007 controls or only for changes that impact the items listed in R2. The SRC requests that the SDT clarify this ambiguity. If the intent is for entities to determine which controls to include in their monitoring to detect changes that would impact CIP-007 protections, the SRC recommends moving the language in Parts 2.1.1 – 2.1.7 to the measures section, similar to the way the measures section associated with requirement R1 Part 1.1 is structured.

Likes 0

Dislikes 0

Response

Thank you for your comments. The SDT has used the phrasing “that include at least one cyber security control for each of the following” in order to allow entities to monitor a primary security control if they have multiple overlapping controls. The SDT’s intent is that having multiple security controls over these categories is a good and beneficial practice where possible, and entities should not be discouraged from having more than one. This phrasing’s intent is to allow the entity to choose the primary control they monitor for unauthorized change. The entity may of course do more than one, but one is required. Additionally, the SDT also added “per system capability” in recognition that not all changes in scope can be monitored on every potential in-scope Cyber System. This addition makes the requirement conditional if a system is incapable of monitoring a particular unauthorized change category. The SDT performed an extensive analysis of the CIP-007 requirement parts, as compared to the former baseline attribute model and concluded the seven parts are a minimum set of cyber security controls (technical controls) that must be implemented and monitored for unauthorized changes to the Applicable Systems in Part 2.1. The language does not preclude entities from choosing to go above and beyond the minimums of the standard based on their risk tolerance. Please see the TR for additional information on the intent of each of the seven components.

Steve Toosevich - NiSource - Northern Indiana Public Service Co. - 1

Answer No

Document Name

Comment

NIPSCO disagrees with the changes as “security controls” needs to be better scoped and defined.	
Likes	0
Dislikes	0
Response	
<p>Thank you for your comments. CIP-010-5 scopes “security controls” by assuring the consistent use of the phrase ‘cyber security controls’, and through reference to those which serve the requirement parts of CIP-005 and CIP-007. The focus of CIP-005 and CIP-007 and their requirement parts is to implement technical controls that protect the cyber security posture of the logical environment and the systems that comprise or support it. The focus of CIP-010-5 is authorizing changes that affect the security posture of those Applicable Systems, and monitoring for unauthorized changes to the technical controls that have been implemented to maintain that cyber security posture. The Measures provide examples of potential evidence, and the TR provides details on the SDT’s intent as it relates to the scope of the applicable ‘cyber security controls’ that serve CIP-005 and CIP-007.</p>	
<p>Shannon Mickens - Shannon Mickens On Behalf of: Joshua Phillips, Southwest Power Pool, Inc. (RTO), 2; - Shannon Mickens, Group Name SPP RTO</p>	
Answer	No
Document Name	
Comment	
<p>There appears to be inconsistency in the CIP-010-5 proposed draft language for Requirements R1 (authorization) and R2 (monitoring). The draft R2 language is more prescriptive for a set of CIP-007 controls while the draft R1 language is now non-prescriptive and related to the “behavior” of CIP-005 and CIP-007 controls, which is subjective and does not align with the list of CIP-007 controls listed in the draft R2 language. In addition, the CIP-010-5 proposed draft language is unclear whether R2 is intended to require entities to monitor for changes that impact all CIP-007 controls or only for changes that impact the items listed in R2. SPP recommends keeping the currently approved requirement language of CIP-010-4, Requirements R1 and R2, as entities have already established virtualized environments that comply with CIP-010-4 today.</p>	
Likes	0

Dislikes	0
Response	
<p>Thank you for your comments. The scoping of Requirement R2 is an intentional subset of the scope for Requirement R1. The focus of CIP-010-5 Requirement R1 is authorizing changes that affect the security posture of those Applicable Systems as well as the logical environments that protect them. This is why R1 includes the obligation to authorize changes that alter the behavior of one or more cyber security controls that are implemented to protect the system or environment. The Applicable Systems for the R2 monitoring requirement for unauthorized changes is an intentional a subset of cyber security controls (CIP-007) to align with the Appliable Systems scope and those technical controls that have been implemented at the System or Cyber Asset level to maintain that cyber security posture.</p> <p>In Requirement R2 Part 2.1 the SDT’s intention is to scope the monitoring to the seven listed items, per system capability. Additionally, the SDT also added “per system capability” in recognition that not all changes in scope can be monitored on every potential in-scope Cyber System. This addition makes the requirement conditional if a system is incapable of monitoring a particular unauthorized change category. The SDT has used the phrasing “that include at least one cyber security control for each of the following” in order to allow entities to monitor a primary security control if they have multiple overlapping controls. The SDT’s intent is that having multiple security controls over these categories is a good and beneficial practice where possible, and entities should not be discouraged from having more than one. This phrasing’s intent is to allow the entity to choose the primary control they monitor for unauthorized change. The entity may of course do more than one, but one is required. The SDT performed and extensive analysis of the CIP-007 requirement parts, as compared to the former baseline attribute model and concluded the seven parts are a minimum set of cyber security controls (technical controls) that must be implemented and monitored for unauthorized changes to the Applicable Systems in Part 2.1. The language does not preclude entities from choosing to go above and beyond the minimums of the standard based on their risk tolerance. Please see the TR for additional information on the intent of each of the seven components. The SDT appreciates the perspective shared about reverting to former approved, but maintains the shift from prescriptive requirements to objective level requirements is necessary to enable the standards for virtualization, as well as to permit new and emerging technologies, features and tools moving into the future. For this reason, the SDT did not revert nor modify the proposed requirement language.</p>	
<p>Chris Carnesi - Chris Carnesi On Behalf of: Dennis Sismaet, Northern California Power Agency, 4, 6, 3, 5; Jeremy Lawson, Northern California Power Agency, 4, 6, 3, 5; Michael Whitney, Northern California Power Agency, 4, 6, 3, 5; - Chris Carnesi</p>	
Answer	No
Document Name	
Comment	

The proposed language removes the baseline requirements that had previously outlined specifically what needed authorization change requests and has been replaced with referencing all of CIP-005 and CIP-007 controls. As the standards evolve over time this makes is unclear and left open for interpretation of what changes an Entity must consider for authorization requests for compliance purposes vs. “best practices”. NCPA recommends including language in 1.1 to include the specific criteria that an Entity will be held accountable to in the requirement.

Likes 0

Dislikes 0

Response

Thank you for your comments. The SDT considered your comments about the removal of 'baselines' from Requirement R1 and maintains the prescriptive 'baseline' concept defeats the key objective to enable the standards for virtualization through greater flexibility in the requirement with 'baselines' as one means to achieve the objective. The SDT determined the focus of the requirements should remain at an objective level of 'what' is required, instead of getting into 'how'. The terminology, "as defined by the Responsible Entity." within Requirement R1 Part 1.1. maintains backwards compatibility and clarity that an entity may choose to continue to use baselines as the method to determine which changes "...alter the behavior of one or more cyber security controls... ...serving one or more requirement parts in CIP-005 or CIP-007...", for which those changes then require authorization per Requirement R1 Part 1.1. Ultimately it is up to each Registered Entity to define their process in a manner that ensures those changes serving one or more requirement parts in CIP-005 or CIP-007 are authorization per Requirement R1 Part 1.1, and that evidence exists to demonstrate those authorizations.

Nicolas Turcotte - Hydro-Quebec (HQ) - 1

Answer

No

Document Name

Comment

HQ supports NPCC RSC comments and provides the following additional comments:

Considering the ambiguity of the controls defined in CIP-005 5 and CIP-007 the updated version of Table R1, part 1.1 deteriorates the cyber security of the cyber assets,. The Measures column contains more explicit examples than the requirement themselves. As an

example, for CIP-007 the requirement is “Disable or prevent unneeded routable protocol network accessibility on each Applicable System, per system capability.”. The column Measures of CIP-007 R1.1 contains the following :

- • Installation, removal, or update of operating system, firmware, software, or cyber security patches, including changes to VCA parent images from which Applicable Systems will be instantiated (CIP-007 R1.1, R2)
- • Configuration changes that affect routable protocol network accessibility (CIP-007 R1.1)

The SDT should ensure that controls are clearly defined in CIP-005 and CIP-007 .The SDT should also ensure that the requirements are easy measurable, and limit interpretations.

The suggested version of requirement 1.3 is defining the applicability by listing the following components; the operating systems, firmware, software, or software patches In the previous version of this requirement, the applicability was 1.1.1. Operating system(s) (including version) or firmware where no independent operating system exists; 1.1.2. Any commercially available or open-source application software (including version) intentionally installed; and 1.1.5. Any security patches applied. The SDT should evaluate if the intent, of the new version, was it to increase the scope of the requirement.

Likes	0
Dislikes	0

Response

Thank you for your comments. Please see the response to NPCC RSC comments. The SDT maintains the shift from prescriptive requirements to objective level requirements is necessary to enable the standards for virtualization, as well as to permit new and emerging technologies, features and tools moving into the future. Because this approach was built with backwards compatibility in mind, entities may continue to implement a baseline as their process for changes that must be authorized. The SDT maintains the adjustments to Requirement R1 Part 1.3 do not increase scope, but rather reframe the existing obligation without the use of the term baseline. This supports enabling the standard for virtualization. For this reason, the SDT did not revert nor modify the proposed requirement language.

Rachel Coyne - Texas Reliability Entity, Inc. - 10

Answer	No
--------	----

Document Name	
---------------	--

Comment

Regarding CIP-010 R1, Texas RE continues to be concerned security obligations will be reduced by removing the reference to baseline configurations. Establishing and maintaining baseline configurations represent best practices for system hardening. Texas RE recommends adhering to NIST Special Publication 800-53 (Rev. 5), CM-2 Baseline Configuration, which states, “Maintaining baseline configurations requires creating new baselines as organizational information systems change over time. Baseline configurations of information systems reflect the current enterprise architecture.” See also CM-7 Least Functionality, which states: Review and update the list of authorized software programs.

Regarding CIP-010 R2, Texas RE is concerned the proposed changes to CIP-010 R1 do not include a control to verify that unintended changes have not been made. For medium impact BCS this is currently captured in requirements to authorize changes and update baseline configuration documentation within 30 calendar days. Texas RE recommends adding medium impact BCS and their associated EACMS and PCA to the Applicable Systems column of CIP-010 R2 and its subpart(s). In FERC Order 706, paragraph 398 FERC states 'We agree with ISO/RTO Council that the phrase “verification that unintended changes have not been made” captures the core issue. Our concern is that some form of verification is performed to detect when unauthorized changes have been made and to identify those changes, as well as ensuring that the proper alerts are issued.'

Further, Texas RE recommends dividing CIP-010 R2 Part 2.1 into two parts for clarity:

CIP-010 R2 Part 2.1:

The Responsible Entity shall define its cyber security controls, excluding procedural and physical controls, serving one or more requirement parts in CIP-007, to include at least one cyber security control from each of the following:

- 2.1.1. Configuration on each Applicable System that affects its routable protocol network accessibility;
- 2.1.2. Configuration of CPU or memory sharing of VCAs on SCI;
- 2.1.3. Installation, removal, and update of operating system, firmware, software, and cyber security patches.
- 2.1.4. Configuration of malicious code protection methods;
- 2.1.5. Configuration of security event logging or alerting;

- 2.1.6. Configuration of authentication methods; and
- 2.1.7. Changes to the enabled or disabled status of accounts.

CIP-010 R2 Part 2.2:

The Responsible Entity shall implement methods to monitor, per system capability, at least once every 35 calendar days, for unauthorized changes that affect Applicable Systems, where those changes alter the behavior of one or more cyber security controls defined in Part 2.1.

Likes	0
Dislikes	0

Response

Thank you for your comments.

The SDT maintains the shift from prescriptive requirements to objective level requirements is necessary to enable the standards for virtualization, as well as to permit new and emerging technologies, features and tools moving into the future. Because this approach was built with backwards compatibility in mind, entities may continue to implement a baseline as their process for changes that must be authorized

It is outside the scope of the 2016-02 SAR and the virtualization objectives of the SAR to expand the scope of Requirement R2 to include medium impact BCS and their associated EACMS and PCA. For this reason, the SDT maintained the scope proposed in draft 5.

The SDT considered the proposed language to split Part 2.1 into two subparts and appreciates the thought TRE has given to this approach. The SDT agrees it has potential to add clarity and the split would not substantially modify the intent of the proposed language in draft 5. The SDT discussed the unintended consequences of making this potentially clarifying change in the final balloting phase at the risk of it being perceived as substantive, and elected not to make the modification. Again, thank you for this idea.

Junji Yamaguchi - Hydro-Quebec (HQ) - 5

Answer	No
Document Name	

Comment

HQ supports NPCC RSC comments and provides the following additional comments:

Considering the ambiguity of the controls defined in CIP-005 5 and CIP-007 the updated version of Table R1, part 1.1 deteriorates the cyber security of the cyber assets,. The Measures column contains more explicit examples than the requirement themselves. As an example, for CIP-007 the requirement is “Disable or prevent unneeded routable protocol network accessibility on each Applicable System, per system capability.”. The column Measures of CIP-007 R1.1 contains the following :

- • Installation, removal, or update of operating system, firmware, software, or cyber security patches, including changes to VCA parent images from which Applicable Systems will be instantiated (CIP-007 R1.1, R2)
- • Configuration changes that affect routable protocol network accessibility (CIP-007 R1.1)

The SDT should ensure that controls are clearly defined in CIP-005 and CIP-007 .The SDT should also ensure that the requirements are easy measurable, and limit interpretations.

The suggested version of requirement 1.3 is defining the applicability by listing the following components; the operating systems, firmware, software, or software patches In the previous version of this requirement, the applicability was 1.1.1. Operating system(s) (including version) or firmware where no independent operating system exists; 1.1.2. Any commercially available or open-source application software (including version) intentionally installed; and 1.1.5. Any security patches applied. The SDT should evaluate if the intent, of the new version, was it to increase the scope of the requirement.

Likes	0
Dislikes	0

Response

Thank you for your comments. Please see the response to NPCC RSC comments. The SDT maintains the shift from prescriptive requirements to objective level requirements is necessary to enable the standards for virtualization, as well as to permit new and emerging technologies, features and tools moving into the future. Because this approach was built with backwards compatibility in mind, entities may continue to implement a baseline as their process for changes that must be authorized. The SDT maintains the adjustments

to Requirement R1 Part 1.3 do not increase scope, but rather reframe the existing obligation without the use of the term baseline. This supports enabling the standard for virtualization. For this reason, the SDT did not revert nor modify the proposed requirement language.

Teresa Krabe - Lower Colorado River Authority - 5

Answer No

Document Name

Comment

The new language in CIP-010 has become more complex adding to compliance risk. Additionally, CIP-010 R2 may become harder to monitor and some of the configurations required to be monitored may require new tools than the current baseline monitoring tools.

Likes 0

Dislikes 0

Response

Thank you for your comments. The SDT maintains the shift from prescriptive requirements to objective level requirements is necessary to enable the standards for virtualization, as well as to permit new and emerging technologies, features and tools moving into the future. Because this approach was built with backwards compatibility in mind, entities may continue to implement a baseline as their process for changes that must be authorized.

The SDT's intent when using the 'per system capability' language is to keep the scope of R2 to those things for which automated solutions are available and likely monitoring these areas and alerting entities to changes. It should be noted that the 'system' in 'per system capability' refers to the Applicable Systems for the requirement, and not the capability of the automated tool used to monitor. As a result, the 'per system capability' language does not absolve entities of the obligation to implement monitoring methods where automated solutions have not been implemented, and while potentially less ideal, manual methods to accomplish the same results where automated monitoring cannot be done remains a requirement where the Applicable System is capable of producing data related to the list of seven cyber security-related categories to monitor.

James Baldwin - James Baldwin On Behalf of: Matt Lewis, Lower Colorado River Authority, 5, 1; - James Baldwin

Answer No

Document Name	
Comment	
The new language in CIP-010 has become more complex adding to compliance risk. Additionally, CIP-010 R2 may become harder to monitor and some of the configurations required to be monitored may require new tools than the current baseline monitoring tools.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comments. The SDT appreciates the perspective shared and maintains the shift from prescriptive requirements to objective level requirements is necessary to enable the standards for virtualization, as well as to permit new and emerging technologies, features and tools moving into the future. For this reason, the SDT did not modify the requirement language.	
Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name NPCC RSC	
Answer	No
Document Name	
Comment	
Please clarify if the change management approach or objective is shifting from change managing a device configuration to change managing a “policy” or process approach. The confusion is if the shift of focus is from managing assets determined by CIP 2 criteria towards Responsible Entity methods / processes / “policy” based documented plan.	
Example would be dealing with planned patch management (based on schedule or plan). If the patch does not impact CIP 5 or CIP 7 security controls, does change management only apply from a deviation of the patch management plan / policy?	
Suggest adding the concept of intent or “intended changes” into R1.1 and R1.4, otherwise R1.4 becomes a defacto full vulnerability assessment for any change	
Suggest	

R1.1

Authorize intended changes that affect Applicable Systems where those intended changes alter the behavior of one or more cyber security controls, excluding procedural and physical controls, serving one or more requirement parts in CIP-005 or CIP-007, as defined by the Responsible Entity.

R1.4

As a part of the intended changes authorized per Part 1.1, verify that the behavior(s) any cyber security controls that were intentionally altered, or previously assessed as potentially being altered, were not adversely affected.

Likes 0

Dislikes 0

Response

Thank you for your comments. The change management approach is not shifting from a Cyber Asset approach to a policy-based approach. The SDT performed a comprehensive analysis of CIP-005 and CIP-007 and determined the administrative documentation (policy, plan, process, procedure etc.) requirements exist at the parent requirement level, and the implemented cyber security controls at the Cyber System or Cyber Asset level exist in the Requirement Parts. To ensure clarity that the objective is to manage configuration changes to the Applicable Systems themselves, the SDT intentionally used the language, "...serving one or more requirement parts in CIP-005 or CIP-007..."

Regarding the concept of intended changes for requirement parts 1.1 and 1.4, it is the responsible entity that defines the process under R1, and that process would include those altered cyber security controls identified through execution of requirement part 1.1. The SDT determined the act of establishing the documented process defined by the Responsible Entity assures the process scope is related to intended changes, and therefore obviating the need to modify the requirement language to include 'intent'. Similarly, requirement part 1.4 is scoped to that applicable to requirement part 1.1, also addressing the concern of 'intent'.

Constantin Chitescu - Ontario Power Generation Inc. - 5

Answer

No

Document Name

Comment

OPG supports NPCC Regional Standards Committee’s comments.

Please clarify if the change management approach or objective is shifting from change managing a device configuration to change managing a “policy” or process approach. The confusion is if the shift of focus is from managing assets determined by CIP 2 criteria towards Responsible Entity methods / processes / “policy” based documented plan.

Example would be dealing with planned patch management (based on schedule or plan). If the patch does not impact CIP 5 or CIP 7 security controls, does change management only apply from a deviation of the patch management plan / policy?

Suggest adding the concept of intent or “intended changes” into R1.1 and R1.4, otherwise R1.4 becomes a defacto full vulnerability assessment for any change

Suggest

R1.1
 Authorize intended changes that affect Applicable Systems where those intended changes alter the behavior of one or more cyber security controls, excluding procedural and physical controls, serving one or more requirement parts in CIP-005 or CIP-007, as defined by the Responsible Entity.

R1.4
 As a part of the intended changes authorized per Part 1.1, verify that the behavior(s) any cyber security controls that were intentionally altered, or previously assessed as potentially being altered, were not adversely affected.

Likes 0

Dislikes 0

Response

Thank you for your comments. Please also refer to the SDT response for NPCC RSC.

Roger Fradenburgh - Roger Fradenburgh On Behalf of: Nick Lauriat, Network and Security Technologies, 1; - Roger Fradenburgh

Answer No

Document Name

Comment

NST is unpersuaded by the SDT's argument that in modern computing environments, configuration baselines are of sufficiently limited value, while also being burdensome to maintain, that they can quite reasonably be downgraded from being included in CIP-010 requirements, and instead offered as merely one possible approach to compliance. Establishing and maintaining configuration baselines are identified as key elements of any good cyber security program in several NIST publications, including recently released SP 800-82 Release 3 ("Guide to Operational Technology (OT) Security") and the one cited by the SDT in its most recent Technical Justification document. Given the long-standing enthusiasm among both FERC and NERC personnel for examining and enhancing the mapping between CIP and NIST Standards, dropping a requirement to maintain documented configuration baselines seems oddly out of step with that and other related initiatives.

Regarding R1.1, it is NST's opinion that if the proposed language was adopted, there would be no end to arguments between Responsible Entities and Regional Entity audit teams about whether compliance had been adequately demonstrated. There are many possible changes to a Cyber Asset's installed software, such as security patches for data packet handlers, that would have no impact on the behavior of CIP-005 or CIP-007 controls. Should changes of this nature be exempt from a requirement to formally authorize them? NST is also concerned that allowing Responsible Entities to define the specific CIP-005 and CIP-007 controls within the scope of R1.1 could result in significant disparities among Responsible Entities and/or Regions in how these controls are identified. NST agrees CIP requirements should be written in a manner that avoids making them overly prescriptive, but at a time when NERC is seeking to impose greater consistency on Entities' CIP-008 programs (universal "attempts to compromise" criteria), it seems counterintuitive for a drafting team to be proposing changes to CIP-010 that would, in our opinion, reduce consistency.

Regarding R2.1:

NST notes that CIP-005 controls are omitted. We presume this to have been an oversight.

NST considers the proposed list of monitored items to be reasonable, but as with R1.1, we believe that it's a mistake to limit the scope to only those changes that could impact CIP-005 or CIP-007 controls, and that allowing Entities to decide on their own what they'll monitor could lead to many and varied interpretations of what R2.1 is intended to require. For example, 2.1.3 specifies monitoring for unauthorized "Installation, removal, and update of operating system, firmware, software, and cyber security patches." As noted previously, many such changes wouldn't alter CIP-005 and/or CIP-007 controls. Would it be permissible for an Entity to not consider 2.1.3 at all unless changes to a Cyber Asset's CIP-005 and/or CIP-007 behavior is detected?

Likes 0

Dislikes 0

Response

Thank you for your comments. The SDT maintains the shift from prescriptive requirements to objective level requirements is necessary to enable the standards for virtualization, as well as to permit new and emerging technologies, features and tools moving into the future. Because this approach was built with backwards compatibility in mind, entities may continue to implement a baseline as their process for changes that must be authorized.

The scoping of Requirement R2 is an intentional subset of the scope for Requirement R1. The focus of CIP-010-5 Requirement R1 is authorizing changes that affect the security posture of those Applicable Systems as well as the logical environments that protect them. This is why R1 includes the obligation to authorize changes that alter the behavior of one or more cyber security controls that are implemented to protect the system or environment. The Applicable Systems for the R2 monitoring requirement for unauthorized changes is an intentional a subset of cyber security controls (CIP-007) to align with the Applicable Systems scope and those technical controls that have been implemented at the System or Cyber Asset level to maintain that cyber security posture.

In Requirement R2 Part 2.1 the SDT's intention is to scope the monitoring to the seven listed items, per system capability. Additionally, the SDT also added "per system capability" in recognition that not all changes in scope can be monitored on every potential in-scope Cyber System. This addition makes the requirement conditional if a system is incapable of monitoring a particular unauthorized change category. The SDT has used the phrasing "that include at least one cyber security control for each of the following" in order to allow entities to monitor a primary security control if they have multiple overlapping controls. The SDT's intent is that having multiple security controls over these categories is a good and beneficial practice where possible, and entities should not be discouraged from having more than one. This phrasing's intent is to allow the entity to choose the primary control they monitor for unauthorized change. The entity may of course do more than one, but one is required. The SDT performed an extensive analysis of the CIP-007 requirement parts, as compared to the former baseline attribute model and concluded the seven parts are a minimum set of cyber security controls (technical controls) that must be implemented and monitored for unauthorized changes to the Applicable Systems in Part 2.1.

The SDT contends it would be difficult to defend the unauthorized "Installation, removal, and update of operating system, firmware, software, and cyber security patches." would not alter the behavior of the technical controls serving CIP-007, and maintains entities would be obligated to consider and monitor for those types of changes as written. As an example, the implementation of CIP-007 Requirement R1 technically controls the disablement or prevention of unneeded routable protocol network accessibility on each Applicable System. When installing, removing, or updating operating system, firmware, software, or security patches it is reasonable to

expect those cyber security controls that were implemented to serve CIP-007 Requirement R1 cannot behave as originally implemented because the change is one in nature that would alter the previously implemented security configuration to intentionally disable or block unneeded ports, services, or accessibility via a routable protocol. Similarly, the implementation of CIP-007 Requirement R3 technically controls an Applicable System’s ability to deter, detect, or prevent malicious code. Malware prevention solutions are typically software. The installation, removal, or updating of that software is likely to alter the behavior of the originally configured cyber security control implemented to serve Requirement R3, hence the approval for those changes is required and the monitoring of at least one cyber security control that could alter the behavior of the malware prevention solution is required, and so on.

The language does not preclude entities from choosing to go above and beyond the minimums of the standard based on their risk tolerance. Please see the TR for additional information on the intent of each of the seven components.

Michael Russell - Massachusetts Municipal Wholesale Electric Company - 5 - NPCC

Answer	No
---------------	----

Document Name	
----------------------	--

Comment

Please clarify if the change management approach or objective is shifting from change managing a device configuration to change managing a “policy” or process approach. The confusion is if the shift of focus is from managing assets determined by CIP 2 criteria towards Responsible Entity methods / processes / “policy” based documented plan.

Example would be dealing with planned patch management (based on schedule or plan). If the patch does not impact CIP 5 or CIP 7 security controls, does change management only apply from a deviation of the patch management plan / policy?

Suggest adding the concept of intent or “intended changes” into R1.1 and R1.4, otherwise R1.4 becomes a defacto full vulnerability assessment for any change

Suggest

R1.1

Authorize intended changes that affect Applicable Systems where those intended changes alter the behavior of one or more cyber security controls, excluding procedural and physical controls, serving one or more requirement parts in CIP-005 or CIP-007, as defined by the Responsible Entity.

R1.4

As a part of the intended changes authorized per Part 1.1, verify that the behavior(s) any cyber security controls that were intentionally altered, or previously assessed as potentially being altered, were not adversely affected.

Likes 0

Dislikes 0

Response

Thank you for your comments. The change management approach is not shifting from a Cyber Asset approach to a policy-based approach. The SDT performed a comprehensive analysis of CIP-005 and CIP-007 and determined the administrative documentation (policy, plan, process, procedure etc.) requirements exist at the parent requirement level, and the implemented cyber security controls at the Cyber System or Cyber Asset level exist in the Requirement Parts. To ensure clarity that the objective is to manage configuration changes to the Applicable Systems themselves, the SDT intentionally used the language, "...serving one or more requirement parts in CIP-005 or CIP-007..."

Regarding the concept of intended changes for requirement parts 1.1 and 1.4, it is the responsible entity that defines the process under R1, and that process would include those altered cyber security controls identified through execution of requirement part 1.1. The SDT determined the act of establishing the documented process defined by the Responsible Entity assures the process scope is related to intended changes, and therefore obviating the need to modify the requirement language to include 'intent'. Similarly, requirement part 1.4 is scoped to that applicable to requirement part 1.1, also addressing the concern of 'intent'.

Israel Perez - Israel Perez On Behalf of: Mathew Weber, Salt River Project, 3, 1, 6, 5; Sarah Blankenship, Salt River Project, 3, 1, 6, 5; Thomas Johnson, Salt River Project, 3, 1, 6, 5; Timothy Singh, Salt River Project, 3, 1, 6, 5; - Israel Perez

Answer

No

Document Name

Comment

1) With the Guidelines and Technical Basis section removed from the CIP-010-5 standard and currently nothing in the Technical Rationale or Implementation documents outlining what a CIP-010-5 R3 paper based or active vulnerability assessment should contain, does the SDT plan to add any guidance for vulnerability assessments as it relates to SCI in these aforementioned documents?

2) We need to better understand the timeline, since the 30 day timeframe is no longer listed. Also need to better understand what evidence to provide for a “baseline”, since the R1 has been changed. Remove the phrase "the behavior of".

Justification:

1) adding "the behavior of" might make the requirement not backwards compatible

2) adding "the behavior of" could give an impression to an auditor that we need to have additional detailed testing such as penetration testing of each altered control

3) this word will cause security teams to spend a lot of time needlessly testing low-value controls rather than looking for adversaries in their networks

Likes 0

Dislikes 0

Response

Thank you for your comments. 1) The SDT will be deferring to the pre-qualified organizations for the industry development of Implementation Guidance to help assure there is an owning group that can maintain it over time, and will not be adding vulnerability assessment guidance. The Guidelines and Technical Basis section was never enforceable, and remains available in former versions of the standards if an entity chooses to refer to it as guidance. 2) the construct requires the entity to perform the obligations in R1 'as a part of the change authorized in Part 1.1. This means the Registered Entity's process must account for the order of operations associated with authorized changes and the timing needed to accomplish each requirement part such that the cyber security controls remain intact as changes occur and the Applicable System(s) is(are) secure. The SDT continues to maintain the prescriptive 'baseline' concept defeats the key objective to enable the standards for virtualization through greater flexibility in the requirement (with 'baselines' as one means to achieve the objective) and the focus at an objective level of 'what' is required, instead of getting into 'how' is supported by the terminology, "as defined by the Responsible Entity." for the methods to determine which changes "...alter the behavior of one or more cyber security controls... ...serving one or more requirement parts in CIP-005 or CIP-007...", for which those changes then require authorization per Requirement R1 Part 1.1. For these reasons, the SDT chose not to modify the requirement language. The SDT brought the security objective to the forefront in Requirement R1 Part 1.1 by starting it with “Authorize changes...”. Next it narrows the scope to those “that affect Applicable Systems” and the SDT made conforming changes to Applicable Systems to add SCI. The SDT considered that many entities scope their own internal change management processes this way; if a change is to or affects something in their NERC CIP

program for medium/highs, it goes through change management. However, the requirement needs a bit more precise scoping that is accomplished with the objective language of “...altered behaviors...” to the underlying technical controls, so it doesn’t include changes such as a user changing their password or desktop background, or a system log being written to hundreds of times an hour. The requirement needs a lower bound, a floor, without attempting to incorporate a prescriptive list of change types or categories. The SDT used the objective language “...where those changes alter the behavior of one or more cyber security controls, excluding procedural and physical controls, serving one or more requirement parts in CIP-005 and CIP-007, as defined by the Responsible Entity.” The intent is to bind the scope to those changes that affect the system’s CIP security posture. More precisely, the intent is to set the floor of the scope to changes that alter the behavior of a cyber security control the entity uses to keep the system secure per CIP-005 and CIP-007 requirements. Please see the Technical Rationale for additional information.

Kennedy Meier - Electric Reliability Council of Texas, Inc. - 2

Answer	No
Document Name	
Comment	
ERCOT joins the comments submitted by the IRC SRC and adopts them as its own.	
Likes 0	
Dislikes 0	

Response

Thank you for your comments. Please also refer to the SDT response for IRC SRC.

Mark Garza - FirstEnergy - FirstEnergy Corporation - 4, Group Name FE Voter

Answer	Yes
Document Name	
Comment	
FirstEnergy does not opposed these changes.	

Likes	0
Dislikes	0
Response	
Thank you for your comments and support.	
Richard Vendetti - NextEra Energy - 5	
Answer	Yes
Document Name	
Comment	
NEE supports EEI comments	
Likes	0
Dislikes	0
Response	
Thank you for your comments and support. Please also refer to the SDT response for EEI.	
Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company	
Answer	Yes
Document Name	
Comment	
Southern agrees with the changes in CIP-010 regarding the updates to change management controls. They include the change behaviors as well as the excluded physical and procedural controls, serving one or more requirement parts in CIP-005 or CIP-007.	
Likes	0
Dislikes	0

Response	
Thank you for your comments and support.	
Wayne Sipperly - North American Generator Forum - 5 - MRO,WECC,Texas RE,NPCC,SERC,RF	
Answer	Yes
Document Name	
Comment	
The NAGF agrees with the proposed changes to CIP-010.	
Likes	0
Dislikes	0
Response	
Thank you for your comments and support.	
Gail Elliott - Gail Elliott On Behalf of: Michael Moltane, International Transmission Company Holdings Corporation, 1; - Gail Elliott	
Answer	Yes
Document Name	
Comment	
ITC supports the response submitted by EEI	
Likes	0
Dislikes	0
Response	
Thank you for your comments and support. Please also refer to the SDT response for EEI.	
Mark Gray - Edison Electric Institute - NA - Not Applicable - NA - Not Applicable	

Answer	Yes
Document Name	
Comment	
EEI supports the proposed changes to CIP-010.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comments and support.	
Daniel Gacek - Exelon - 1	
Answer	Yes
Document Name	
Comment	
Exelon supports the comments submitted by the EEI.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comments and support. Please also refer to the SDT response for EEI.	
Kinte Whitehead - Exelon - 3	
Answer	Yes
Document Name	
Comment	

Exelon is supporting EEI comments in response to this question.

Likes 0

Dislikes 0

Response

Thank you for your comments and support. Please also refer to the SDT response for EEI.

Marcus Bortman - APS - Arizona Public Service Co. - 6

Answer

Yes

Document Name

Comment

AZPS supports the proposed changes

Likes 0

Dislikes 0

Response

Thank you for your comments and support.

David Jendras Sr - Ameren - Ameren Services - 3

Answer

Yes

Document Name

Comment

Ameren supports the proposed changes to CIP-010.

Likes 0

Dislikes	0
Response	
Thank you for your comments and support.	
Tracy MacNicoll - Utility Services, Inc. - 4	
Answer	Yes
Document Name	
Comment	
USV supports the comments made by NPCC RSC	
Likes	0
Dislikes	0
Response	
Thank you for your comments. Please also refer to the SDT response for NPCC RSC.	
Joanne Anderson - Public Utility District No. 2 of Grant County, Washington - 1,4,5,6 - WECC	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Patricia Lynch - NRG - NRG Energy, Inc. - 5	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Clay Walker - Clay Walker On Behalf of: John Lindsey, Cleco Corporation, 6, 5, 1, 3; Maurice Paulk, Cleco Corporation, 6, 5, 1, 3; Robert Hirschak, Cleco Corporation, 6, 5, 1, 3; Stephanie Huffman, Cleco Corporation, 6, 5, 1, 3; Wayne Messina, LaGen, 4; - Clay Walker	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
LaTroy Brumfield - American Transmission Company, LLC - 1	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Thank you for your support.	
Jennifer Buckman - Southern Indiana Gas and Electric Co. - 3,5,6 - RF	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Robert Follini - Avista - Avista Corporation - 3	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Tristan Miller - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Donna Wood - Tri-State G and T Association, Inc. - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Richard Jackson - U.S. Bureau of Reclamation - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Thank you for your support.	
Andrea Jessup - Bonneville Power Administration - 1,3,5,6 - WECC	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Todd Bennett - Associated Electric Cooperative, Inc. - 3, Group Name AECl	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Rebika Yitna - MEAG Power - 1,3 - SERC	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Brian Millard - Tennessee Valley Authority - 1,3,5,6 - SERC, Group Name TVA RBB	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Karen Artola - CPS Energy - 1,3,5 - Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	

Response	
Thank you for your support.	
Mike Magruder - Avista - Avista Corporation - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Jay Sethi - Manitoba Hydro - 1,3,5,6 - MRO	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Ben Hammer - Western Area Power Administration - 1	
Answer	Yes
Document Name	

Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Sheila Suurmeier - Black Hills Corporation - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Rachel Schuldt - Rachel Schuldt On Behalf of: Claudine Bates, Black Hills Corporation, 5, 6, 1, 3; - Rachel Schuldt	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	

Thank you for your support.	
Josh Combs - Black Hills Corporation - 3	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Micah Runner - Black Hills Corporation - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Casey Jones - Berkshire Hathaway - NV Energy - 5 - WECC	
Answer	Yes
Document Name	
Comment	

Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Erik Gustafson - PNM Resources - Public Service Company of New Mexico - 1,3 - WECC,Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Mark Flanary - Midwest Reliability Organization - 10	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	

C. A. Campbell - LS Power Development, LLC - 5	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Ellese Murphy - Ellese Murphy On Behalf of: Marcelo Pesantez, Duke Energy - Florida Power Corporation, 3; - Ellese Murphy	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Andy Fuhrman - Andy Fuhrman On Behalf of: Theresa Allard, Minnkota Power Cooperative Inc., 1; - Andy Fuhrman	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Thank you for your support.	
Jennifer Bray - Arizona Electric Power Cooperative, Inc. - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
John Daho - John Daho On Behalf of: David Weekley, MEAG Power, 3, 1; Roger Brand, MEAG Power, 3, 1; - John Daho	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Anna Martinson - MRO - 1,2,3,4,5,6 - MRO, Group Name MRO Group	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Steven Rueckert - Western Electricity Coordinating Council - 10, Group Name WECC CIP	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Martin Sidor - NRG - NRG Energy, Inc. - 6	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Thank you for your support.	
Alain Mukama - Hydro One Networks, Inc. - 1,3	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Jennie Wike - Jennie Wike On Behalf of: Hien Ho, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; John Merrell, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Ozan Ferrin, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Terry Gifford, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; - Jennie Wike, Group Name Tacoma Power	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Dwanique Spiller - Berkshire Hathaway - NV Energy - 5	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Jodirah Green - ACES Power Marketing - 1,3,4,5,6 - MRO,WECC,Texas RE,SERC,RF, Group Name ACES Collaborators	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	

6. The SDT revised CIP-003. Do you agree with the proposed changes to these Reliability Standards? If not, please provide the basis for your disagreement and an alternate proposal.

Kristine Martz - Amazon Web Services - 7

Answer No

Document Name

Comment

The inclusion of “Shared Cyber Infrastructure (SCI) that supports a low impact BCS” in the applicable systems identified in CIP-003 R2, may be confusing to Responsible Entities who only have low impact BCS because the proposed SCI definition only identifies as SCI those programmable electronic devices that host or are associated with applicable systems of different impact ratings.

First, it appears that if a Responsible Entity is using infrastructure to host only low impact VCAs, the proposed SCI definition would make CIP-003-10 R2 inapplicable to such shared infrastructure.

Second, if the Responsible Entity is using SCI to host VCAs with a low impact and another different impact rating, the proposed standard suggests that the SCI (and all of its VCAs) would need to be protected at the level applicable to the impact rating of the highest impact system(s) hosted, which would apparently subject the SCI hosting a low impact BCS to the requirements for SCI hosting medium or high impact BCS, making the requirements in CIP-003-10 R2 unnecessary or redundant.

AWS encourages the Standard Drafting Team for Project 2016-02 to develop implementation guidance, include statements in the CIP-003 Technical Rationale, or other appropriate industry supporting documents, to clarify how Responsible Entities should implement the new requirements for SCI supporting low impact BCS under CIP-003 R2 given the two issues identified above.

Likes 0

Dislikes 0

Response

Thank you for your comments.

CIP-003-10 R2 states in the parent requirement that it is applicable to "...low impact BES Cyber Systems BCS, and Shared Cyber Infrastructure (SCI) that supports a low impact BCS...", and the SDT agrees that where shared infrastructure is serving only low impact BCS it would not meet the 2nd component of the first bullet in the SCI definition and therefore would not qualify as SCI. Having said that, in that scenario the shared infrastructure becomes a component of the low impact BCS and would remain subject to the Requirements within R2.

The SDT wanted to assure entities could use SCI to host low impact BCS, and that it is permissible to host low with medium and high on the same SCI, but then the SCI itself inherits the highest requirement set based on highest impact rated host. Where SCI is supporting BES Cyber Systems of multiple impact levels, the SDT contends it is appropriate based on risk and impact to expect that SCI be protected to the highest impacted rated BCS and associated Applicable System. While CIP-003-10 R2 may be rendered moot in this particular use case, this is one of myriad use cases thereby making CIP-003-10 R2 useful and necessary to protect the remainder.

The SDT will be deferring to the pre-qualified organizations for the industry development of Implementation Guidance to help assure there is an owning group that can maintain it over time.

Roger Fradenburgh - Roger Fradenburgh On Behalf of: Nick Lauriat, Network and Security Technologies, 1; - Roger Fradenburgh

Answer	No
Document Name	
Comment	
NST believes Appendix 1 Section 2 (Physical Security Controls) should include supporting SCI, if any, for consistency with other revised CIP-003 requirements.	
Likes	0
Dislikes	0
Response	
Thank you for your comments. Appendix A for CIP-003-10 R2 inherits the applicability for parent requirement CIP-003-10 R2, which is applicable to "...low impact BCS, and Shared Cyber Infrastructure (SCI) that supports a low impact BCS..."	

Ben Hammer - Western Area Power Administration - 1

Answer No

Document Name

Comment

The changes to CIP-003 Specifically R2 attachment 1. should be incorporated into the CIP-004, CIP-005, CIP-006, CIP-007, and CIP-010 standards, add requirements to those standards as they pertain to low impact BES Cyber systems, either to existing requirements or to new requirements. Leave CIP-003 specifically to establishing responsibility and accountability. For Section 3 part 3.1 add an and after the 1st bullet, as shown below:

3.1 Permit only necessary inbound and outbound electronic access as determined by the Responsible Entity for any communications that are:

i. Between:

- a low impact BCS; or
- An SCI that supports a low impact BCS and a Cyber System(s) outside the asset containing:
 - the low impact BCS(s); or
 - the SCI that supports a low impact BCS; **and**

ii. using a routable protocol when entering or leaving the asset containing the low impact BCS or SCI that supports a low impact BCS; and

iii. not used for time-sensitive communications of Protection Systems.

Likes 0

Dislikes 0

Response

Thank you for your comments. The SDT considered your suggested edits and determined consolidation of low impact requirements with medium and high requirements is out of the scope of the SAR.

Tim Kelley - Tim Kelley On Behalf of: Charles Norton, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Fong Mua, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Kevin Smith, Balancing Authority of Northern California, 1; Nicole Goi, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Nicole Looney, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Wei Shao, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; - Tim Kelley, Group Name SMUD and BANC	
Answer	No
Document Name	
Comment	
SMUD and BANC feel that inconsistent use of the word “system”, especially with regards to “per system capability” is making the High and Medium impact requirements less stringent than the Low impact requirements. We recommend changing the language to “per Cyber Asset capability”.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comments. The SDT considered your suggestion and, because of the Note in CIP-003-10 Requirement R2 that specifically excludes the obligation to have and maintain an inventory of Cyber Assets in the low impact BES Cyber System, the SDT determined “per system capability” is the appropriate option.	
Israel Perez - Israel Perez On Behalf of: Mathew Weber, Salt River Project, 3, 1, 6, 5; Sarah Blankenship, Salt River Project, 3, 1, 6, 5; Thomas Johnson, Salt River Project, 3, 1, 6, 5; Timothy Singh, Salt River Project, 3, 1, 6, 5; - Israel Perez	
Answer	Yes
Document Name	
Comment	
CIP Virtualization Standard proposed is CIP-003-10 is not clear. Choppy jump from section 3 to section 6, need to combine.	
Recommend skip this version, go to or wait for CIP-003-a	

Likes	0
Dislikes	0
Response	
Thank you for your comments and support. Another drafting team is working to combine Attachment 1 Sections 3 and 6. At the point wherein that proposal is approved, the change will be merged with the CIP-003-10 changes to enable for virtualization.	
Marcus Bortman - APS - Arizona Public Service Co. - 6	
Answer	Yes
Document Name	
Comment	
AZPS supports the proposed changes	
Likes	0
Dislikes	0
Response	
Thank you for your comments and support. Please also refer to the SDT response for EEI.	
Kinte Whitehead - Exelon - 3	
Answer	Yes
Document Name	
Comment	
Exelon is supporting EEI comments in response to this question.	
Likes	0
Dislikes	0

Response	
Thank you for your comments and support. Please also refer to the SDT response for EEI.	
Daniel Gacek - Exelon - 1	
Answer	Yes
Document Name	
Comment	
Exelon supports the comments submitted by the EEI.	
Likes	0
Dislikes	0
Response	
Thank you for your comments and support. Please also refer to the SDT response for EEI.	
Mark Gray - Edison Electric Institute - NA - Not Applicable - NA - Not Applicable	
Answer	Yes
Document Name	
Comment	
EEI supports the proposed changes made to CIP-003.	
Likes	0
Dislikes	0
Response	
Thank you for your comments and support.	
Gail Elliott - Gail Elliott On Behalf of: Michael Moltane, International Transmission Company Holdings Corporation, 1; - Gail Elliott	

Answer	Yes
Document Name	
Comment	
ITC supports the response submitted by EEI	
Likes 0	
Dislikes 0	
Response	
Thank you for your comments and support. Please also refer to the SDT response for EEI.	
Wayne Sipperly - North American Generator Forum - 5 - MRO,WECC,Texas RE,NPCC,SERC,RF	
Answer	Yes
Document Name	
Comment	
The NAGF agrees with the proposed changes to CIP-003.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comments and support. Please also refer to the SDT response for EEI.	
Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company	
Answer	Yes
Document Name	
Comment	

Southern agrees with and supports the proposed changes to CIP-003.	
Likes	0
Dislikes	0
Response	
Thank you for your comments and support.	
Richard Vendetti - NextEra Energy - 5	
Answer	Yes
Document Name	
Comment	
NEE supports EEI comments	
Likes	0
Dislikes	0
Response	
Thank you for your comments and support. Please also refer to the SDT response for EEI.	
Mark Garza - FirstEnergy - FirstEnergy Corporation - 4, Group Name FE Voter	
Answer	Yes
Document Name	
Comment	
FirstEnergy does not opposed these changes.	
Likes	0

Dislikes	0
Response	
Thank you for your comments and support.	
Kennedy Meier - Electric Reliability Council of Texas, Inc. - 2	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Jodirah Green - ACES Power Marketing - 1,3,4,5,6 - MRO,WECC,Texas RE,SERC,RF, Group Name ACES Collaborators	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Dwanique Spiller - Berkshire Hathaway - NV Energy - 5	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Tracy MacNicoll - Utility Services, Inc. - 4	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Jennie Wike - Jennie Wike On Behalf of: Hien Ho, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; John Merrell, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Ozan Ferrin, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Terry Gifford, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; - Jennie Wike, Group Name Tacoma Power	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Thank you for your support.	
Michael Russell - Massachusetts Municipal Wholesale Electric Company - 5 - NPCC	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
David Jendras Sr - Ameren - Ameren Services - 3	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Alain Mukama - Hydro One Networks, Inc. - 1,3	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Constantin Chitescu - Ontario Power Generation Inc. - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Martin Sidor - NRG - NRG Energy, Inc. - 6	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	

Response	
Thank you for your support.	
Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name NPCC RSC	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
James Baldwin - James Baldwin On Behalf of: Matt Lewis, Lower Colorado River Authority, 5, 1; - James Baldwin	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Teresa Krabe - Lower Colorado River Authority - 5	
Answer	Yes
Document Name	

Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Junji Yamaguchi - Hydro-Quebec (HQ) - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Steven Rueckert - Western Electricity Coordinating Council - 10, Group Name WECC CIP	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	

Thank you for your support.	
Anna Martinson - MRO - 1,2,3,4,5,6 - MRO, Group Name MRO Group	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
John Daho - John Daho On Behalf of: David Weekley, MEAG Power, 3, 1; Roger Brand, MEAG Power, 3, 1; - John Daho	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Rachel Coyne - Texas Reliability Entity, Inc. - 10	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Thank you for your support.	
Nicolas Turcotte - Hydro-Quebec (HQ) - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Chris Carnesi - Chris Carnesi On Behalf of: Dennis Sismaet, Northern California Power Agency, 4, 6, 3, 5; Jeremy Lawson, Northern California Power Agency, 4, 6, 3, 5; Michael Whitney, Northern California Power Agency, 4, 6, 3, 5; - Chris Carnesi	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	

Thank you for your support.	
Shannon Mickens - Shannon Mickens On Behalf of: Joshua Phillips, Southwest Power Pool, Inc. (RTO), 2; - Shannon Mickens, Group Name SPP RTO	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Steve Toosevich - NiSource - Northern Indiana Public Service Co. - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Monika Montez - California ISO - 2 - WECC, Group Name ISO/RTO Council Standards Review Committee (SRC)	
Answer	Yes
Document Name	

Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Andy Fuhrman - Andy Fuhrman On Behalf of: Theresa Allard, Minnkota Power Cooperative Inc., 1; - Andy Fuhrman	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Ellese Murphy - Ellese Murphy On Behalf of: Marcelo Pesantez, Duke Energy - Florida Power Corporation, 3; - Ellese Murphy	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	

Thank you for your support.	
C. A. Campbell - LS Power Development, LLC - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Adrian Andreoiu - BC Hydro and Power Authority - 1, Group Name BC Hydro	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Mark Flanary - Midwest Reliability Organization - 10	
Answer	Yes
Document Name	
Comment	

Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Erik Gustafson - PNM Resources - Public Service Company of New Mexico - 1,3 - WECC,Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Casey Jones - Berkshire Hathaway - NV Energy - 5 - WECC	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	

Micah Runner - Black Hills Corporation - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Rachel Schuldt - Rachel Schuldt On Behalf of: Claudine Bates, Black Hills Corporation, 5, 6, 1, 3; - Rachel Schuldt	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Josh Combs - Black Hills Corporation - 3	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Thank you for your support.	
Sheila Suurmeier - Black Hills Corporation - 5	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Jay Sethi - Manitoba Hydro - 1,3,5,6 - MRO	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Mike Magruder - Avista - Avista Corporation - 1	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Karen Artola - CPS Energy - 1,3,5 - Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Brian Millard - Tennessee Valley Authority - 1,3,5,6 - SERC, Group Name TVA RBB	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Thank you for your support.	
Rebika Yitna - MEAG Power - 1,3 - SERC	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Todd Bennett - Associated Electric Cooperative, Inc. - 3, Group Name AECl	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Andrea Jessup - Bonneville Power Administration - 1,3,5,6 - WECC	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Richard Jackson - U.S. Bureau of Reclamation - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Donna Wood - Tri-State G and T Association, Inc. - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	

Response	
Thank you for your support.	
Lindsey Mannion - ReliabilityFirst - 10	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Tristan Miller - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Robert Follini - Avista - Avista Corporation - 3	
Answer	Yes
Document Name	

Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Jennifer Buckman - Southern Indiana Gas and Electric Co. - 3,5,6 - RF	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
LaTroy Brumfield - American Transmission Company, LLC - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	

Thank you for your support.	
Anne Kronshage - Public Utility District No. 1 of Chelan County - 6, Group Name Public Utility District No. 1 of Chelan County - Voting Group	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
Clay Walker - Clay Walker On Behalf of: John Lindsey, Cleco Corporation, 6, 5, 1, 3; Maurice Paulk, Cleco Corporation, 6, 5, 1, 3; Robert Hirschak, Cleco Corporation, 6, 5, 1, 3; Stephanie Huffman, Cleco Corporation, 6, 5, 1, 3; Wayne Messina, LaGen, 4; - Clay Walker	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Thank you for your support.	
James Keele - Entergy - 1,3,6	
Answer	Yes
Document Name	

Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Patricia Lynch - NRG - NRG Energy, Inc. - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	
Joanne Anderson - Public Utility District No. 2 of Grant County, Washington - 1,4,5,6 - WECC	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	

Thank you for your support.	
Jennifer Bray - Arizona Electric Power Cooperative, Inc. - 1	
Answer	
Document Name	
Comment	
Answer is yes.	
Likes 0	
Dislikes 0	
Response	
Thank you for your support.	

7. The SDT revised the Implementation Plan to accommodate for the future enforceable date of CIP-003-9. Do you agree with the proposed Implementation Plan? If not, please provide the basis for your disagreement and an alternate proposal.	
Wayne Sipperly - North American Generator Forum - 5 - MRO,WECC,Texas RE,NPCC,SERC,RF	
Answer	No
Document Name	
Comment	
The NAGF believes that NERC needs to clarify the process and time lines for reconciliation of the multiple CIP-003 Standards Under Development and CIP-003-09 before being able to answer Question 7 accurately.	
Likes	0
Dislikes	0
Response	
Teresa Krabe - Lower Colorado River Authority - 5	
Answer	No
Document Name	
Comment	
Unintended consequences of IRA definition could increase cost of physical access controls for medium impact with IRA.	
Likes	0
Dislikes	0
Response	

James Baldwin - James Baldwin On Behalf of: Matt Lewis, Lower Colorado River Authority, 5, 1; - James Baldwin	
Answer	No
Document Name	
Comment	
Unintended consequences of IRA definition could increase cost of physical access controls for medium impact with IRA.	
Likes 0	
Dislikes 0	
Response	
Roger Fradenburgh - Roger Fradenburgh On Behalf of: Nick Lauriat, Network and Security Technologies, 1; - Roger Fradenburgh	
Answer	No
Document Name	
Comment	
NST's "No" on this question reflects our concerns about several proposed or revised definitions and about proposed changes to CIP-003, CIP-004, CIP-005, CIP-007, and CIP-010.	
Likes 0	
Dislikes 0	
Response	
Mark Garza - FirstEnergy - FirstEnergy Corporation - 4, Group Name FE Voter	

Answer	Yes
Document Name	
Comment	
FirstEnergy does not opposed these changes.	
Likes 0	
Dislikes 0	
Response	
Richard Vendetti - NextEra Energy - 5	
Answer	Yes
Document Name	
Comment	
NEE supports EEI comments	
Likes 0	
Dislikes 0	
Response	
Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company	
Answer	Yes
Document Name	
Comment	

Southern agrees with the revised Implementation Plan to become effective on or about April 1, 2026 or the first day of the first calendar quarter that is twenty-four (24) months after the effective date of the applicable governmental authority’s order approving the Revised CIP Standards and Definitions.	
Likes	0
Dislikes	0
Response	
Gail Elliott - Gail Elliott On Behalf of: Michael Moltane, International Transmission Company Holdings Corporation, 1; - Gail Elliott	
Answer	Yes
Document Name	
Comment	
ITC supports the response submitted by EEI	
Likes	0
Dislikes	0
Response	
Mark Gray - Edison Electric Institute - NA - Not Applicable - NA - Not Applicable	
Answer	Yes
Document Name	
Comment	
EEI supports the revised Implementation plan as proposed.	

Likes	0
Dislikes	0
Response	
Daniel Gacek - Exelon - 1	
Answer	Yes
Document Name	
Comment	
Exelon supports the comments submitted by the EEI.	
Likes	0
Dislikes	0
Response	
Kinte Whitehead - Exelon - 3	
Answer	Yes
Document Name	
Comment	
Exelon is supporting EEI comments in response to this question.	
Likes	0
Dislikes	0
Response	

Marcus Bortman - APS - Arizona Public Service Co. - 6	
Answer	Yes
Document Name	
Comment	
AZPS supports the revised implementation plan.	
Likes 0	
Dislikes 0	
Response	
Joanne Anderson - Public Utility District No. 2 of Grant County, Washington - 1,4,5,6 - WECC	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Patricia Lynch - NRG - NRG Energy, Inc. - 5	
Answer	Yes
Document Name	

Comment	
Likes 0	
Dislikes 0	
Response	
James Keele - Entergy - 1,3,6	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Clay Walker - Clay Walker On Behalf of: John Lindsey, Cleco Corporation, 6, 5, 1, 3; Maurice Paulk, Cleco Corporation, 6, 5, 1, 3; Robert Hirschak, Cleco Corporation, 6, 5, 1, 3; Stephanie Huffman, Cleco Corporation, 6, 5, 1, 3; Wayne Messina, LaGen, 4; - Clay Walker	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	

Response	
Anne Kronshage - Public Utility District No. 1 of Chelan County - 6, Group Name Public Utility District No. 1 of Chelan County - Voting Group	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
LaTroy Brumfield - American Transmission Company, LLC - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Jennifer Buckman - Southern Indiana Gas and Electric Co. - 3,5,6 - RF	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Robert Follini - Avista - Avista Corporation - 3	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Tristan Miller - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	

Response	
<p>Tim Kelley - Tim Kelley On Behalf of: Charles Norton, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Fong Mua, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Kevin Smith, Balancing Authority of Northern California, 1; Nicole Goi, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Nicole Looney, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; Wei Shao, Sacramento Municipal Utility District, 3, 6, 4, 1, 5; - Tim Kelley, Group Name SMUD and BANC</p>	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
<p>Lindsey Mannion - ReliabilityFirst - 10</p>	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
<p>Donna Wood - Tri-State G and T Association, Inc. - 1</p>	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Richard Jackson - U.S. Bureau of Reclamation - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Andrea Jessup - Bonneville Power Administration - 1,3,5,6 - WECC	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Todd Bennett - Associated Electric Cooperative, Inc. - 3, Group Name AECI	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
John Galloway - John Galloway On Behalf of: Michael Puscas, ISO New England, Inc., 2; - John Galloway	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Rebika Yitna - MEAG Power - 1,3 - SERC	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Brian Millard - Tennessee Valley Authority - 1,3,5,6 - SERC, Group Name TVA RBB	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Karen Artola - CPS Energy - 1,3,5 - Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	

Response	
Mike Magruder - Avista - Avista Corporation - 1	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Jay Sethi - Manitoba Hydro - 1,3,5,6 - MRO	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Ben Hammer - Western Area Power Administration - 1	
Answer	Yes
Document Name	

Comment	
Likes 0	
Dislikes 0	
Response	
Sheila Suurmeier - Black Hills Corporation - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Rachel Schuldt - Rachel Schuldt On Behalf of: Claudine Bates, Black Hills Corporation, 5, 6, 1, 3; - Rachel Schuldt	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	

Josh Combs - Black Hills Corporation - 3	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Micah Runner - Black Hills Corporation - 1	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Casey Jones - Berkshire Hathaway - NV Energy - 5 - WECC	
Answer	Yes
Document Name	
Comment	

Likes 0	
Dislikes 0	
Response	
Erik Gustafson - PNM Resources - Public Service Company of New Mexico - 1,3 - WECC,Texas RE	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Mark Flanary - Midwest Reliability Organization - 10	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	

Adrian Andreoiu - BC Hydro and Power Authority - 1, Group Name BC Hydro	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
C. A. Campbell - LS Power Development, LLC - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Ellese Murphy - Ellese Murphy On Behalf of: Marcelo Pesantez, Duke Energy - Florida Power Corporation, 3; - Ellese Murphy	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
Andy Fuhrman - Andy Fuhrman On Behalf of: Theresa Allard, Minnkota Power Cooperative Inc., 1; - Andy Fuhrman	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Monika Montez - California ISO - 2 - WECC, Group Name ISO/RTO Council Standards Review Committee (SRC)	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Steve Toosevich - NiSource - Northern Indiana Public Service Co. - 1	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Shannon Mickens - Shannon Mickens On Behalf of: Joshua Phillips, Southwest Power Pool, Inc. (RTO), 2; - Shannon Mickens, Group Name SPP RTO	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Chris Carnesi - Chris Carnesi On Behalf of: Dennis Sismaet, Northern California Power Agency, 4, 6, 3, 5; Jeremy Lawson, Northern California Power Agency, 4, 6, 3, 5; Michael Whitney, Northern California Power Agency, 4, 6, 3, 5; - Chris Carnesi	
Answer	Yes
Document Name	
Comment	

Likes	0
Dislikes	0
Response	
John Daho - John Daho On Behalf of: David Weekley, MEAG Power, 3, 1; Roger Brand, MEAG Power, 3, 1; - John Daho	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Anna Martinson - MRO - 1,2,3,4,5,6 - MRO, Group Name MRO Group	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name NPCC RSC	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Martin Sidor - NRG - NRG Energy, Inc. - 6	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Constantin Chitescu - Ontario Power Generation Inc. - 5	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Alain Mukama - Hydro One Networks, Inc. - 1,3	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
David Jendras Sr - Ameren - Ameren Services - 3	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Michael Russell - Massachusetts Municipal Wholesale Electric Company - 5 - NPCC	
Answer	Yes

Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
<p>Jennie Wike - Jennie Wike On Behalf of: Hien Ho, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; John Merrell, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Ozan Ferrin, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; Terry Gifford, Tacoma Public Utilities (Tacoma, WA), 1, 4, 5, 6, 3; - Jennie Wike, Group Name Tacoma Power</p>	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
<p>Tracy MacNicoll - Utility Services, Inc. - 4</p>	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes	0
Response	
Dwanique Spiller - Berkshire Hathaway - NV Energy - 5	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Israel Perez - Israel Perez On Behalf of: Mathew Weber, Salt River Project, 3, 1, 6, 5; Sarah Blankenship, Salt River Project, 3, 1, 6, 5; Thomas Johnson, Salt River Project, 3, 1, 6, 5; Timothy Singh, Salt River Project, 3, 1, 6, 5; - Israel Perez	
Answer	Yes
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
Jodirah Green - ACES Power Marketing - 1,3,4,5,6 - MRO,WECC,Texas RE,SERC,RF, Group Name ACES Collaborators	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Kennedy Meier - Electric Reliability Council of Texas, Inc. - 2	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
Jennifer Bray - Arizona Electric Power Cooperative, Inc. - 1	
Answer	
Document Name	
Comment	
Answer is yes.	

Likes 0	
Dislikes 0	
Response	
Steven Rueckert - Western Electricity Coordinating Council - 10, Group Name WECC CIP	
Answer	
Document Name	
Comment	
No Comment	
Likes 0	
Dislikes 0	
Response	

8. Please provide any additional comments for the SDT to consider, if desired.	
Kristine Martz - Amazon Web Services - 7	
Answer	
Document Name	
Comment	
<p>AWS supports the efforts of the Project 2016-02 SDT in addressing industry comments and feedback. We understand that the proposed revisions address on-premises virtualization, though we appreciate that these changes, such as the removal of Cyber Asset references directly in requirement language, could enable further consideration of cloud technology in future standards development projects.</p> <p>Should these revisions not achieve industry consensus to move forward, we encourage the SDT to consider alternatives to the standards development process to achieve the outcomes set forth in the SAR including the development of ERO endorsed implementation guidance based on the many educational resources the SDT has already created to educate industry on cyber security for virtualized environments. Additionally, we encourage NERC to develop Risk-Based Compliance Monitoring and Enforcement Program (CMEP) Practice Guides to provide direction to ERO Enterprise CMEP staff on approaches to carry out compliance monitoring and enforcement activities related to virtualization, which is already widely employed across the industry and provides a number of operational and cost efficiencies as well as other benefits. Clear guidance on CIP compliance for virtual assets would greatly benefit the industry and its stakeholders by allowing for compliance certainty when moving towards greater virtualization.</p>	
Likes 0	
Dislikes 0	
Response	
Thank you for your comment.	
Jodirah Green - ACES Power Marketing - 1,3,4,5,6 - MRO,WECC,Texas RE,SERC,RF, Group Name ACES Collaborators	
Answer	
Document Name	

Comment	
ACES and it's members would like to thank the SDT for their continued hard work.	
Likes	0
Dislikes	0
Response	
Thank you for your comment.	
Israel Perez - Israel Perez On Behalf of: Mathew Weber, Salt River Project, 3, 1, 6, 5; Sarah Blankenship, Salt River Project, 3, 1, 6, 5; Thomas Johnson, Salt River Project, 3, 1, 6, 5; Timothy Singh, Salt River Project, 3, 1, 6, 5; - Israel Perez	
Answer	
Document Name	
Comment	
With the Guidelines and Technical Basis section removed from the CIP-010-5 standard and currently nothing in the Technical Rationale or Implementation documents outlining what a CIP-010-5 R3 paper based or active vulnerability assessment should contain, does the SDT plan to add any guidance for vulnerability assessments as it relates to SCI in these aforementioned documents?	
Likes	0
Dislikes	0
Response	
Unfortunately, CIP-010 was already modified outside of the 2016-02 project prior to opening the standard. Since this language was already removed, the SDT will not be able to reintroduce this language at this time due to the limitations in the scope of our SAR.	
Marcus Bortman – APS – Arizona Public Service Co. – 6	
Answer	

Document Name	
Comment	
No additional comments at this time.	
Likes 0	
Dislikes 0	
Response	
Thank you for your response.	
Romel Aquino – Edison International – Southern California Edison Company – 3	
Answer	
Document Name	
Comment	
See comments submitted by the Edison Electric Institute	
Likes 0	
Dislikes 0	
Response	
Thank you for your comment.	
Daniel Gacek – Exelon – 1	
Answer	
Document Name	
Comment	

Exelon supports the comments submitted by the EEI.	
Likes	0
Dislikes	0
Response	
Thank you for your comment.	
Teresa Krabe – Lower Colorado River Authority – 5	
Answer	
Document Name	
Comment	
None at this time.	
Likes	0
Dislikes	0
Response	
Thank you for your comment.	
Junji Yamaguchi – Hydro-Quebec (HQ) – 5	
Answer	
Document Name	
Comment	
The SDT added this exemption 4.2.3.3. Cyber Systems, associated with communication networks and data communication links, between the Cyber Systems providing confidentiality and integrity of an ESP that extends to one or more geographic locations. Our understanding	

is that “communication networks” is associated with routable protocol (layer 3 of the OSI model) and that “data communication links” is associated with non- routable protocol (layer 2 of the OSI model). SDT should clarify the intent if this is not the case.

The SDT should ensure the security posture of the Cyber Assets and not only facilitating the adoption of new technology by introducing ambiguous requirements.

The SDT should evaluate the requirements against the ERT tool approach. In other words, can the requirement be evaluated with the ERT tool?

The SDT should ensure that the requirements are clear and precise and stand by themselves and that no additional reading is required (i.e., technical rationale). The technical rationale should be viewed as a rationale and not provide explanation on how to understand the requirement.

The SDT should review the requirements with the concept of applying Protection Systems definition.

Likes 0

Dislikes 0

Response

Thank you for your comment. Regarding the exemption language in 4.2.3.3, the SDT intended to ensure that transport devices that were not owned by the Responsible Entity would not be in scope. This is enabled by the new language in CIP-005 1.6 which allows the entity to extend and ESP beyond a single geographic location. When the Responsible Entity enables a security control, such as encryption, across networks it doesn’t own the equipment that is carrying that traffic but has no access to the data should not be considered in scope.

In terms of the ERT tools, the SDT is unable to address enforcement issues such as how the ERT tool will accommodate the new standards. The SDT assumes that the tool will be updated accordingly by NERC’s enforcement processes.

Steven Rueckert - Western Electricity Coordinating Council - 10, Group Name WECC CIP

Answer

Document Name

Comment

<p>The CIP-004-8 R2.3, R4.1.2, R5.1, R5.2, R6.1.2, R6.3, exclusion '(except for medium impact without ERC)' appears to be unnecessary considering medium impact without ERC is not an applicable system of the requirement.</p>	
Likes	0
Dislikes	0
<p>Response</p>	
<p>Thank you for your comment. The SDT removed the language in CIP-004-8 R2.3. Please see the CIP-004 Technical Rationale for an explanation for why this exception language is necessary.</p>	
<p>Anna Martinson - MRO - 1,2,3,4,5,6 - MRO, Group Name MRO Group</p>	
<p>Answer</p>	
<p>Document Name</p>	
<p>Comment</p>	
<p>In the draft standards there is inconsistency in the wording of section "C. Compliance 1. Compliance Monitoring Process 1.1. Compliance Enforcement Authority:". The following wording is used in CIP-003-10, and is suggested for the other standards as it matches the definition in the NERC Rules of Procedures:</p>	
<p>1.1. Compliance Enforcement Authority: As defined in the NERC Rules of Procedure, "Compliance Enforcement Authority" (CEA) means NERC or the Regional Entity in their respective roles of monitoring and enforcing compliance with mandatory and enforceable Reliability Standards.</p>	
<p>The following is used in CIP-004-8, CIP-005-8, CIP-007-7 and CIP-010-5</p>	
<p>1.1. Compliance Enforcement Authority: "Compliance Enforcement Authority" (CEA)</p>	
<p>means NERC or the Regional Entity, or any entity as otherwise designated by an</p>	
<p>Applicable Governmental Authority, in their respective roles of monitoring and/or</p>	

enforcing compliance with mandatory and enforceable Reliability Standards in their respective jurisdictions.

Likes 0

Dislikes 0

Response

Thank you for your comment. The SDT has checked all standards and made sure the compliance section complies with the current NERC Reliability Standard template.

Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company

Answer

Document Name

Comment

No additional comments.

Likes 0

Dislikes 0

Response

Thank you for your comment.

Jennifer Bray - Arizona Electric Power Cooperative, Inc. - 1

Answer

Document Name

Comment

Thank you for the ability to comment.

Likes	0
Dislikes	0
Response	
Thank you for your comment.	
Nicolas Turcotte - Hydro-Quebec (HQ) - 1	
Answer	
Document Name	
Comment	
<p>The SDT added this exemption 4.2.3.3. Cyber Systems, associated with communication networks and data communication links, between the Cyber Systems providing confidentiality and integrity of an ESP that extends to one or more geographic locations. Our understanding is that “communication networks” is associated with routable protocol (layer 3 of the OSI model) and that “data communication links” is associated with non-routable protocol (layer 2 of the OSI model). SDT should clarify the intent if this is not the case.</p> <p>The SDT should ensure the security posture of the Cyber Assets and not only facilitating the adoption of new technology by introducing ambiguous requirements.</p> <p>The SDT should evaluate the requirements against the ERT tool approach. In other words, can the requirement be evaluated with the ERT tool?</p> <p>The SDT should ensure that the requirements are clear and precise and stand by themselves and that no additional reading is required, i.e., technical rationale. The technical rationale should be viewed as a rationale and not provide explanation on how to understand the requirement.</p> <p>The SDT should review the requirements with the concept of applying Protection Systems definition.</p>	
Likes	0
Dislikes	0
Response	

Thank you for your comment. Regarding the exemption language in 4.2.3.3, the SDT intended to ensure that transport devices that were not owned by the Responsible Entity would not be in scope. This is enabled by the new language in CIP-005 1.6 which allows the entity to extend and ESP beyond a single geographic location. When the Responsible Entity enables a security control, such as encryption, across networks it doesn't own the equipment that is carrying that traffic but has no access to the data should not be considered in scope.

In terms of the ERT tools, the SDT is unable to address enforcement issues such as how the ERT tool will accommodate the new standards. The SDT assumes that the tool will be updated accordingly by NERC's enforcement processes.

Richard Vendetti - NextEra Energy - 5

Answer

Document Name

Comment

NEE supports EEI comments

Likes 0

Dislikes 0

Response

Thank you for your comment. Please see response to EEI.

Andy Fuhrman - Andy Fuhrman On Behalf of: Theresa Allard, Minnkota Power Cooperative Inc., 1; - Andy Fuhrman

Answer

Document Name

Comment

MPC supports comments submitted by the MRO NERC Standards Review Forum (NSRF).

Likes 0

Dislikes 0

Response	
Thank you for your comment. Please see response to MRO NSRF.	
Ellese Murphy - Ellese Murphy On Behalf of: Marcelo Pesantez, Duke Energy - Florida Power Corporation, 3; - Ellese Murphy	
Answer	
Document Name	
Comment	
Duke Energy thanks the Virtualization Standard Drafting Team for their hard work to get to Draft 5, and for their careful consideration of industry comments from Draft 4.	
Likes 0	
Dislikes 0	
Response	
Thank you for your comment.	
Jay Sethi - Manitoba Hydro - 1,3,5,6 - MRO	
Answer	
Document Name	
Comment	
<p>In the draft standards there is inconsistency in the wording of section “C. Compliance 1. Compliance Monitoring Process 1.1. Compliance Enforcement Authority:”. The following wording is used in CIP-003-10, and is suggested for the other standards as it matches the definition in the NERC Rules of Procedures:</p> <p>1.1. Compliance Enforcement Authority: As defined in the NERC Rules of Procedure, “Compliance Enforcement Authority” (CEA) means NERC or the Regional Entity in their respective roles of monitoring and enforcing compliance with mandatory and enforceable Reliability Standards.</p>	

The following is used in CIP-004-8, CIP-005-8, CIP-007-7 and CIP-010-5

1.1. Compliance Enforcement Authority: “Compliance Enforcement Authority” (CEA)

means NERC or the Regional Entity, or any entity as otherwise designated by an Applicable Governmental Authority, in their respective roles of monitoring and/or enforcing compliance with mandatory and enforceable Reliability Standards in their respective jurisdictions.

Likes 0

Dislikes 0

Response

Thank you for your comment. The SDT has checked all standards and made sure the compliance section complies with the current NERC Reliability Standard template.

Andrea Jessup - Bonneville Power Administration - 1,3,5,6 - WECC

Answer

Document Name

Comment

CIP-005 R2.6: BPA reiterates disagreement with the requirement to prevent sharing of memory resources in R2.6. The theoretical risk represented by CPU-sharing is not high enough to mandate the significant re-architecture required to adequately separate CPU usage as specified in Part 2.6. BPA recommends allowing the continued use of shared resources to allow entities the flexibility to balance risk mitigation with resources, maintenance and cost of maintaining the grid.

Likes 0

Dislikes 0

Response

Thank you for your comment. Based on industry feedback the SDT was trying to strike a balance between the flexibility of virtualization and known CPU/memory vulnerabilities. The intent is to allow clusters of devices such as servers to be leveraged with rules to prevent the sharing of CPU/memory. The SDT thought this was an acceptable balance to allow entities to take advantage of pooling resources while still avoiding the security risks associated with sharing CPU/memory on the same individual device.

Richard Jackson - U.S. Bureau of Reclamation - 1

Answer

Document Name

Comment

No additional comments

Likes 0

Dislikes 0

Response

Thank you for your comment.

Donna Wood - Tri-State G and T Association, Inc. - 1

Answer

Document Name

Comment

NA

Likes 0

Dislikes 0

Response

Thank you for your comment.	
Mark Garza - FirstEnergy - FirstEnergy Corporation - 4, Group Name FE Voter	
Answer	
Document Name	
Comment	
<p>FirstEnergy asks the DT for clarification training requirements for CIP-004.</p> <p>Training requirement 2.2 and 2.3 appear to be inconsistent in the description with the use of “includes Mediums with ERC” as well as Access Authorization/verification in requirement 4.1 and 4.2.</p>	
Likes 0	
Dislikes 0	
Response	
<p>Thank you for your comment. The SDT removed the language in CIP-004-8 R2.3. Please see the CIP-004 Technical Rationale for an explanation for why this exception language is necessary.</p>	

End of Report