

#### **Mapping Document for COM-001-2**

#### **Revisions or Retirements to Already Approved Standards**

The following tables identify the sections of approved standards that shall be retired or revised when this standard is implemented. If the drafting team is recommending the retirement or revision of a requirement, that text is blue.

### **Proposed Replacement Requirement(s)**

## • COM-001-1.1

- R1. Each Reliability Coordinator, Transmission
  Operator and Balancing Authority shall
  provide adequate and reliable
  telecommunications facilities for the exchange
  of Interconnection and operating information:
  [Violation Risk Factor: High]
  - **R1.1.** Internally. [Violation Risk Factor: High]
  - **R1.2.** Between the Reliability Coordinator and its Transmission Operators and Balancing Authorities. [Violation Risk Factor: High]
  - R1.3. With other Reliability Coordinators, Transmission Operators, and Balancing Authorities as necessary to maintain reliability. [Violation Risk Factor: High]
  - **R1.4.** Where applicable, these facilities shall be redundant and diversely routed. [Violation Risk Factor: High]

#### COM-001-2

- R1. Each Reliability Coordinator shall have Interpersonal Communications capability with the following entities: [Violation Risk Factor: High][Time Horizon: Real-time Operations]
  - **R1.1.** All Transmission Operators and Balancing Authorities within its Reliability Coordinator Area.
  - **R1.2.** Adjacent Reliability Coordinators within the same Interconnection.
- **R2.** Each Reliability Coordinator shall designate an Alternative Interpersonal Communications capability with the following entities: [Violation Risk Factor: High][Time Horizon: Realtime Operations]
  - **R2.1.** All Transmission Operators and Balancing Authorities within its Reliability Coordinator Area.
  - **R2.2.** Adjacent Reliability Coordinators within the same Interconnection.
- **R3.** Each Transmission Operator shall have Interpersonal Communications capability with the following entities:



		Violat )perat	ion Risk Factor: High][Time Horizon: Real-time ions]
	R	23.1.	Its Reliability Coordinator.
	R	23.2.	Each Balancing Authority within its Transmission Operator Area.
	R	23.3.	Each Distribution Provider within its Transmission Operator Area.
	R	23.4.	Each Generator Operator within its Transmission Operator Area.
	R	23.5.	Adjacent Transmission Operators synchronously connected within the same Interconnection.
R	Ir ei	nterpe ntities	ransmission Operator shall designate an Alternative rsonal Communications capability with the following: [Violation Risk Factor: High][Time Horizon: Real-perations]
	R	24.1.	Its Reliability Coordinator.
	R	24.2.	Each Balancing Authority within its Transmission Operator Area.
	R	24.3.	Adjacent Balancing Authorities.

• **Notes:** The requirements we<u>re</u> made clearer as to which capabilities specific entities were required to have to <u>reliability reliable communications</u>.

Already Approved Standard	Proposed Replacement Requirement(s)

• COM-001-1<u>.1</u>



- **R1.** Each Reliability Coordinator, Transmission Operator and Balancing Authority shall provide adequate and reliable telecommunications facilities for the exchange of Interconnection and operating information: [Violation Risk Factor: High]
  - **R1.1.** Internally. [Violation Risk Factor: High]
  - R1.2. Between the Reliability
    Coordinator and its Transmission
    Operators and Balancing Authorities.
    [Violation Risk Factor: High]
  - R1.3. With other Reliability
    Coordinators, Transmission Operators,
    and Balancing Authorities as
    necessary to maintain reliability.
    [Violation Risk Factor: High]
  - R1.4. Where applicable, these facilities shall be redundant and diversely routed. [Violation Risk Factor: High]

#### **COM-001-2**

- **R5.** Each Balancing Authority shall have Interpersonal Communications capability with the following entities: [Violation Risk Factor: High][Time Horizon: Real-time Operations]
  - **R5.1.** Its Reliability Coordinator.
  - **R5.2.** Each Transmission Operator that operates Facilities within its Balancing Authority Area
  - **R5.3.** Each Distribution Provider within its Balancing Authority Area
  - **R5.4.** Each Generator Operator that operates Facilities within its Balancing Authority Area
  - **R5.5.** Adjacent Balancing Authorities.
- **R6.** Each Balancing Authority shall designate an Alternative Interpersonal Communications capability with the following entities: [Violation Risk Factor: High][Time Horizon: Realtime Operations]
  - **R6.1.** Its Reliability Coordinator.
  - **R6.2.** Each Transmission Operator that operates Facilities within its Balancing Authority Area).
  - **R6.3.** Adjacent Balancing Authorities.
- **R7.** Each Distribution Provider shall have Interpersonal Communications capability with the following entities: [Violation Risk Factor: High][Time Horizon: Real-time Operations]
  - **R7.1.** Its Transmission Operator.



R8.	R7.2. Its Balancing Authority.  Each Generator Operator shall have Interpersonal Communications capability with the following entities: [Violation Risk Factor: High][Time Horizon: Real-time Operations]
	R8.1. Its Balancing Authority. R8.2. Its Transmission Operator.

**Notes:** The requirements we made clearer as to which capabilities specific entities were required to have <u>for to reliability reliable</u> <u>interpersonal communications</u>. R<u>7 and R8 were <u>8 is</u> created to address the FERC directive to "expands the applicability to include generator operators and distribution providers and includes Requirements for their telecommunications facilities"</u>

Already Approved Standard	Proposed Replacement Requirement(s)			
COM-001-1 <u>.1</u>	COM-001-2			
R2. Each Reliability Coordinator, Transmission Operator, and Balancing Authority shall manage, alarm, test and/or actively monitor vital telecommunications facilities. Special attention shall be given to emergency telecommunications facilities and equipment not used for routine communications. [Violation Risk Factor: Medium]	R9. Each Reliability Coordinator, Transmission Operator, and Balancing Authority shall, on at least a monthly basis, test its Alternative Interpersonal Communications capability. If the test is unsuccessful, the entity shall initiate action to repair or designate a replacement Alternative Interpersonal Communications capability within 2 hours. [Violation Risk Factor: Medium][Time Horizon: Real-time Operations]			

#### **Notes:**

Already Approved Standard		Proposed Replacement Requirement(s)		
COM-001-1 <u>.1</u>		COM-001-2		



R3.	Each Reliability Coordinator, Transmission
	Operator and Balancing Authority shall provide a
	means to coordinate telecommunications among
	their respective areas. This coordination shall
	include the ability to investigate and recommend
	solutions to telecommunications problems within
	the area and with other areas. [Violation Risk
	Factor: Lower]

R1. Each Reliability Coordinator, Transmission Operator, Balancing Authority, Distribution Provider, and Generator Operator shall notify impacted entities within 60 minutes of the detection of a failure of its Interpersonal Communications capabilities that lasts 30 minutes or longer. [Violation Risk Factor: Medium][Time Horizon: Real-time Operations]

#### **Notes:**

	Already Approved Standard	Proposed Replacement Requirement(s)			
R4. Unless agreed to otherwise, each Reliability Coordinator, Transmission Operator, and Balancing Authority shall use English as the language for all communications between and among operating personnel responsible for the real- time generation control and operation of the interconnected Bulk Electric System. Transmission Operators and Balancing Authorities may use an alternate language for internal operations. [Violation Risk Factor: Medium]		None - retire  This requirement is being vetted by the OPCPSDT in COM- 003. This requirement and measure will be removed from COM 001-11 upon the effective date of COM-003-1			
Note	es:				
	Already Approved Standard	Proposed Replacement Requirement(s)			



### COM-001-1.1

**R5.** Each Reliability Coordinator, Transmission Operator, and Balancing Authority shall have written operating instructions and procedures to enable continued operation of the system during the loss of telecommunications facilities. [Violation Risk Factor: Lower]

#### EOP-008-0

- **R1.** Each Reliability Coordinator, Transmission Operator and Balancing Authority shall have a plan to continue reliability operations in the event its control center becomes inoperable. The contingency plan must meet the following requirements:
  - **R1.1.** The contingency plan shall not rely on data or voice communication from the primary control facility to be viable.
  - **R1.2.** The plan shall include procedures and responsibilities for providing basic tie line control and procedures and for maintaining the status of all inter-area schedules, such that there is an hourly accounting of all schedules.
  - **R1.3.** The contingency plan must address monitoring and control of critical transmission facilities, generation control, voltage control, time and frequency control, control of critical substation devices, and logging of significant power system events. The plan shall list the critical facilities.
  - **R1.4.** The plan shall include procedures and responsibilities for maintaining basic voice communication capabilities with other areas.
  - **R1.5.** The plan shall include procedures and responsibilities for conducting periodic tests, at least annually, to ensure viability of the plan.
  - **R1.6.** The plan shall include procedures and responsibilities for providing annual training to ensure that operating personnel are able to implement the contingency plans.
  - **R1.7.** The plan shall be reviewed and updated annually.
  - **R1.8.** Interim provisions must be included if it is expected to take



more than one hour to implement the contingency plan for loss of primary control facility.

#### EOP-008-1

- R1. Each Reliability Coordinator, Balancing Authority, and Transmission Operator shall have a current Operating Plan describing the manner in which it continues to meet its functional obligations with regard to the reliable operations of the BES in the event that its primary control center functionality is lost. This Operating Plan for backup functionality shall include the following, at a minimum:

  [Violation Risk Factor = Medium] [Time Horizon = Operations Planning]
  - 1.1. The location and method of implementation for providing backup functionality for the time it takes to restore the primary control center functionality.
  - 1.2. A summary description of the elements required to support the backup functionality. These elements shall include, at a minimum:
    - 1.2.1. Tools and applications to ensure that System Operators have situational awareness of the BES.
    - 1.2.2. Data communications.
    - 1.2.3. Voice communications.
    - 1.2.4. Power source(s).
    - 1.2.5. Physical and cyber security.
  - 1.3. An Operating Process for keeping the backup functionality consistent with the primary control center.
  - 1.4. Operating Procedures, including decision authority, for use in determining when to implement the Operating Plan for backup



<u>functionality.</u>
1.5. A transition period between the loss of primary control center functionality and the time to fully implement the backup functionality that is less than or equal to two hours.
1.6. An Operating Process describing the actions to be taken during the transition period between the loss of primary control center functionality and the time to fully implement backup functionality elements identified in Requirement R1, Part 1.2. The Operating Process shall include at a minimum:
1.6.1. A list of all entities to notify when there is a change in operating locations.
1.6.2. Actions to manage the risk to the BES during the transition from primary to backup functionality as well as during outages of the primary or backup functionality.
1.6.3. Identification of the roles for personnel involved during the initiation and implementation of the Operating Plan for backup functionality.

Notes: The RC SDT proposes retiring COM-001-1 R5 as it is redundant with EOP-008-0 Requirement R1 as well as EOP-008-1 R1 which replaces it.

Already Approved Standard	Proposed Replacement Requirement(s)			
COM-001-1  R6. Each NERCNet User Organization shall adhere to the requirements in Attachment 1-COM-001,	None - retire			
"NERCNet Security Policy." [Violation Risk Factor: Lower]				



**Notes:** The RC SDT is recommending that R6 be retired. This is an ERO procedural issue and should not be in a reliability standard. It should be included in the ERO Rules of Procedure.

Already Approved Standard	Proposed Replacement Requirement(s)		
None	New Requirement		
	<b>R11.</b> Each Distribution Provider and Generator Operator that experiences a failure of any of its Interpersonal Communication capabilities shall consult with their Transmission Operator or Balancing Authority as applicable to determine a mutually agreeable time to restore the Interpersonal Communication capability. [Violation Risk Factor: Medium] [Time Horizon: Real-time Operations]		
Notes:			



# **Functions that Must Comply with the Requirements in the Standards**

Standard	Functions that Must Comply With the Requirements							
Standard	Reliability Coordinator	Balancing Authority	Purchasing Selling Entity	Transmission Operator	Transmission Service Provider	Load Serving Entity	Generator Operator	Distribution Provider
COM-001-2	Х	Х		Х	Х		Х	Х
Communi- cations								