

Meeting Notes

Project 2020-06 Verifications of Models and Data for Generators

Standard Drafting Team Meeting

October 20, 2021 | 1:00 - 4:00 p.m. Eastern

Introduction and Chair's Remarks

[NERC Antitrust Compliance Guidelines](#) and [Public Announcement*](#)
[NERC Participant Conduct Policy](#)

Administrative

1. Review NERC Antitrust Compliance Guidelines and Public Announcement
2. Safety Instructions – N/A
3. Determination of Quorum
 - a. The rule for NERC standard drafting team (SDT) states that a quorum requires two-thirds of the voting members. Quorum was met.
4. Introductions and Chair's Remarks – Brad Marszalkowski, chair
 - a. The SDT chair shared some of the [Odessa Disturbance Report](#) findings in relation to Project 2020-06. He recognized the engagement of the SDT members, and highlighted the need for outreach to industry groups to share project updates.
5. Review Meeting Agenda and Objectives

Agenda Items

1. Administrative (5 minutes) (Chris)
2. Discuss Applicability revision options (30 minutes) (Jason)
 - a. The SDT resolved unanimously that Option C will be used for Applicability revisions, which references the BES Inclusions without MVA values unless needed. Share this approach with NAGF partners to get their perspective on change in MVA threshold for individual units.
3. Consensus points (90 minutes) (Brad)
 - a. **EMT models:** The SDT resolved with a majority vote that EMT models would be required of the GO for Legacy IBR (when request by the TP) and all new IBR plants installed after a specified date (TBD by SDT). Group A can determine an initial cutoff date for EMT models.

- b. **Large signal disturbance response:** The SDT resolved with a majority vote that large signal disturbance responses need to be validated when feasible.
- 4. **Discuss merge of MOD-026/027 (15 minutes) (Chris, Brad)** - The group discussed pros and cons of merging MOD-026/027 together. Members stated that merging the two standards is possible, but there would be considerations if voltage and frequency staged testing happens on different dates and how to demonstrate compliance. The SDT decided to wait on making a final decision and to continue standard revisions to MOD-026.
- 5. **Revisions to MOD-026 (60 minutes) (SDT)** - The SDT reviewed initial revisions to Applicability, and Requirement R1 and R6.
- 6. **Project timeline (10 minutes)**
 - a. Goal for initial posting March 2022
- 7. **Next meeting**
 - a. Wednesday, November 10, 2021
- 8. **Adjourn**